

Environmental Protection Agency

§ 265.190

§ 265.174 Inspections.

At least weekly, the owner or operator must inspect areas where containers are stored, except for Performance Track member facilities, that must conduct inspections at least once each month, upon approval by the Director. To apply for reduced inspection frequency, the Performance Track member facility must follow the procedures described in §265.15(b)(5) of this part. The owner or operator must look for leaking containers and for deterioration of containers caused by corrosion or other factors.

[Comment: See §265.171 for remedial action required if deterioration or leaks are detected.]

[71 FR 16910, Apr. 4, 2006, as amended at 71 FR 40275, July 14, 2006]

§ 265.175 [Reserved]

§ 265.176 Special requirements for ignitable or reactive waste.

Containers holding ignitable or reactive waste must be located at least 15 meters (50 feet) from the facility's property line.

[Comment: See §265.17(a) for additional requirements.]

§ 265.177 Special requirements for incompatible wastes.

(a) Incompatible wastes, or incompatible wastes and materials, (see appendix V for examples) must not be placed in the same container, unless §265.17(b) is complied with.

(b) Hazardous waste must not be placed in an unwashed container that previously held an incompatible waste or material (see appendix V for examples), unless §265.17(b) is complied with.

(c) A storage container holding a hazardous waste that is incompatible with any waste or other materials stored nearby in other containers, piles, open tanks, or surface impoundments must be separated from the other materials or protected from them by means of a dike, berm, wall, or other device.

[Comment: The purpose of this is to prevent fires, explosions, gaseous emissions, leaching, or other discharge of hazardous waste or hazardous waste constituents which could result from the mixing of incompatible

wastes or materials if containers break or leak.]

§ 265.178 Air emission standards.

The owner or operator shall manage all hazardous waste placed in a container in accordance with the applicable requirements of subparts AA, BB, and CC of this part.

[61 FR 59968, Nov. 25, 1996]

Subpart J—Tank Systems

SOURCE: 51 FR 25479, July 14, 1986, unless otherwise noted.

§ 265.190 Applicability.

The requirements of this subpart apply to owners and operators of facilities that use tank systems for storing or treating hazardous waste except as otherwise provided in paragraphs (a), (b), and (c) of this section or in §265.1 of this part.

(a) Tank systems that are used to store or treat hazardous waste which contains no free liquids and are situated inside a building with an impermeable floor are exempted from the requirements in §265.193. To demonstrate the absence or presence of free liquids in the stored/treated waste, the following test must be used: Method 9095B (Paint Filter Liquids Test) as described in "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods," EPA Publication SW-846, as incorporated by reference in §260.11 of this chapter.

(b) Tank systems, including sumps, as defined in §260.10, that serve as part of a secondary containment system to collect or contain releases of hazardous wastes are exempted from the requirements in §265.193(a).

(c) Tanks, sumps, and other collection devices used in conjunction with drip pads, as defined in §260.10 of this chapter and regulated under 40 CFR part 265 subpart W, must meet the requirements of this subpart.

[51 FR 25479, July 14, 1986, as amended at 53 FR 34087, Sept. 2, 1988; 55 FR 50486, Dec. 6, 1990; 58 FR 46050, Aug. 31, 1993; 70 FR 34585, June 14, 2005]