

**Environmental Protection Agency**

**§ 408.30**

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kg/kkg of seafood)	
TSS .....	2.2	0.74
Oil and grease .....	0.60	0.20
pH .....	( <sup>1</sup> )	( <sup>1</sup> )
English units (lb/1,000 lb of seafood)		
TSS .....	2.2	0.74
Oil and grease .....	0.60	0.20
pH .....	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 60 FR 33940, June 29, 1995]

**§ 408.23 [Reserved]**

**§ 408.24 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH .....	No limitation.
Oil and grease .....	Do.
TSS .....	Do.

[40 FR 6438, Feb. 11, 1975, as amended at 60 FR 33940, June 29, 1995]

**§ 408.25 Standards of performance for new sources.**

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kg/kkg of seafood)	
BOD5 .....	0.30	0.15
TSS .....	0.90	0.45
Oil and grease .....	0.13	0.065
pH .....	( <sup>1</sup> )	( <sup>1</sup> )
English units (lb/1,000 lb of seafood)		
BOD5 .....	0.30	0.15
TSS .....	0.90	0.45
Oil and grease .....	0.13	0.065
pH .....	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

**§ 408.26 Pretreatment standards for new sources.**

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33940, June 29, 1995]

**§ 408.27 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.22 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

**Subpart C—Mechanized Blue Crab Processing Subcategory**

**§ 408.30 Applicability; description of the mechanized blue crab processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing of blue crab in which