

(NFPA) Standard 805 (NFPA 805), "Performance-Based Standard for Fire Protection for Light Water Reactor Electric Generating Plants," 2001 Edition. Copies of NFPA 805 may be purchased from the NFPA Customer Service Department, 1 Batterymarch Park, P.O. Box 9101, Quincy, Massachusetts 02269-9101 and in PDF format through the NFPA Online Catalog (<http://www.nfpa.org>) or by calling 1-800-344-3555 or 617-770-3000. Copies are also available for inspection at the NRC Library, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland 20852-2738, and at the NRC PDR, One White Flint North, Room O1-F15, 11555 Rockville Pike, Rockville, Maryland 20852-2738.

Date of issuance: March 31, 2016.

Effective date: As of the date of issuance and shall be implemented as described in the transition license conditions.

Amendment Nos.: 231 and 181. A publicly-available version is in ADAMS under Accession No. ML15344A346; documents related to these amendments are listed in the Safety Evaluation enclosed with the amendments.

Renewed Facility Operating License Nos. DPR-67 and NPF-16: Amendments revised the Renewed Facility Operating Licenses and Technical Specifications.

Date of initial notice in Federal Register: December 26, 2013 (78 FR 78407). The supplemental letters dated February 24, March 25, April 25, July 14, August 27, September 10, and October 10, 2014; and March 10, April 1, April 20, May 12, August 21, and October 22, 2015, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register**.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 31, 2016.

No significant hazards consideration comments received: No.

Omaha Public Power District, Docket No. 50-285, Fort Calhoun Station, Unit No. 1, Washington County, Nebraska

Date of amendment request: July 24, 2015.

Brief description of amendment: The amendment revised the Technical Specification (TS) Surveillance Requirements (SRs), which currently require operation of ventilation systems with charcoal filters for a 10-hour period at a monthly frequency. The SRs are revised to require operation of the

systems for 15 continuous minutes at a monthly frequency.

Date of issuance: April 5, 2016.

Effective date: As of the date of issuance and shall be implemented within 90 days from the date of issuance.

Amendment No.: 287. A publicly-available version is in ADAMS under Accession No. ML16084A755; documents related to this amendment are listed in the Safety Evaluation enclosed with the amendment.

Renewed Facility Operating License No. DPR-40: The amendment revised the License and Technical Specifications.

Date of initial notice in Federal Register: October 13, 2015 (80 FR 61485).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 5, 2016.

No significant hazards consideration comments received: No.

PSEG Nuclear LLC and Exelon Generation Company, LLC, Docket Nos. 50-272 and 50-311, Salem Nuclear Generating Station (Salem), Unit Nos. 1 and 2, Salem County, New Jersey

Date of amendment request: March 27, 2015, as supplemented by letter dated February 3, 2016.

Brief description of amendments: The amendments revised certain Technical Specification (TS) 3/4.3.1, "Reactor Trip System Instrumentation," actions. Specifically, TS Table 3.3-1, Action 2, is revised to allow one power range (PR) channel to be bypassed for up to 4 hours for surveillance testing, and two new action notes are established for the PR nuclear instrumentation in TS Table 4.3-1. The changes support the installation and use of bypass test capability for the PR nuclear instrumentation.

Date of issuance: March 28, 2016.

Effective date: As of the date of issuance and shall be implemented at Salem, Unit No. 1, prior to returning to the MODE of applicability following refueling outage 1R24, and at Salem, Unit No. 2, prior to returning to the MODE of applicability following refueling outage 2R22.

Amendment Nos.: 312 (Unit No. 1) and 293 (Unit No. 2). A publicly-available version is in ADAMS under Accession No. ML16054A068; documents related to these amendments are listed in the Safety Evaluation enclosed with the amendments.

Renewed Facility Operating License Nos. DPR-70 and DPR-75: Amendments revised the Renewed Facility Operating Licenses and TSs.

Date of initial notice in Federal Register: July 7, 2015 (80 FR 38776).

The supplemental letter dated February 3, 2016, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register**.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated March 28, 2016.

No significant hazards consideration comments received: No.

Dated at Rockville, Maryland, this 15th day of April 2016.

For the Nuclear Regulatory Commission.

Anne T. Boland,

Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. 2016-09543 Filed 4-25-16; 8:45 am]

BILLING CODE 7590-01-P

POSTAL SERVICE

Product Change—Priority Mail Negotiated Service Agreement

AGENCY: Postal Service™.

ACTION: Notice.

SUMMARY: The Postal Service gives notice of filing a request with the Postal Regulatory Commission to add a domestic shipping services contract to the list of Negotiated Service Agreements in the Mail Classification Schedule's Competitive Products List.

DATES: *Effective date:* April 26, 2016.

FOR FURTHER INFORMATION CONTACT: Elizabeth A. Reed, 202-268-3179.

SUPPLEMENTARY INFORMATION: The United States Postal Service® hereby gives notice that, pursuant to 39 U.S.C. 3642 and 3632(b)(3), on April 20, 2016, it filed with the Postal Regulatory Commission a *Request of the United States Postal Service to Add Priority Mail Contract 208 to Competitive Product List*. Documents are available at www.prc.gov, Docket Nos. MC2016-123, CP2016-156.

Stanley F. Mires,

Attorney, Federal Compliance.

[FR Doc. 2016-09621 Filed 4-25-16; 8:45 am]

BILLING CODE 7710-12-P