

which is based upon, and perpetuates, a regulation that is unconstitutional, irrational, and inconsistent with the HSR Act.

Very truly yours,

/s/

Phillip Goldstein

[FR Doc. 2016-25525 Filed 10-20-16; 8:45 am]

BILLING CODE 4410-11-P

DEPARTMENT OF JUSTICE

Notice of Lodging of Proposed National Resources Restoration Consent Decree Under the Comprehensive Environmental Response, Compensation and Liability Act

On October 13, 2016, the Department of Justice lodged a proposed Consent Decree with the United States District Court for the District of New Jersey in the lawsuit entitled *United States v. Wyeth Holdings LLC*, Civil Action No. 3:16-cv-07219-AET-LHG.

The United States filed this lawsuit under the Comprehensive Environmental Response, Compensation and Liability Act on behalf of the United States Fish and Wildlife Service and the National Oceanic and Atmospheric Administration. In its complaint the United States alleges that Defendant Wyeth Holdings LLC is liable for damages for, injury to, destruction of, or loss of natural resources in connection with the American Cyanamid Superfund Site in the Township of Bridgewater and Borough of Bound Brook, New Jersey. The proposed Consent Decree resolves claims brought by the United States and related claims brought by the New Jersey Department of Environmental Protection in a related action. In exchange for a covenant not to sue for injury to the Raritan River, Wyeth Holdings LLC agrees to remove the Weston Causeway Dam on the Millstone River; design a fish passage at the Island Farm Weir on the Raritan River; pay federal and state future oversight costs; reimburse federal and state assessment costs totaling \$184,363; pay fish and habitat survey costs totaling \$50,000; and fund the evaluation and monitoring of trust resources prior to and after removal of the Weston Causeway Dam.

The publication of this notice opens a period for public comment on the Consent Decree. Comments should be addressed to the Assistant Attorney General, Environment and Natural Resources Division, and should refer to *United States v. Wyeth Holdings LLC*, Civil Action No. 3:16-cv-07219-AET-

LHG, D.J. Ref. No. 90-11-3-07250/2. All comments must be submitted no later than sixty (60) days after the publication date of this notice. Comments may be submitted either by email or by mail:

<i>To submit comments:</i>	<i>Send them to:</i>
By email	<i>pubcomment-ees.enrd@usdoj.gov.</i>
By mail	Assistant Attorney General, U.S. DOJ-ENRD, P.O. Box 7611, Washington, DC 20044-7611.

During the public comment period, the Consent Decree may be examined and downloaded at this Justice Department Web site: <https://www.justice.gov/enrd/consent-decrees>. We will provide a paper copy of the Consent Decree upon written request and payment of reproduction costs. Please mail your request and payment to: Consent Decree Library, U.S. DOJ-ENRD, P.O. Box 7611, Washington, DC 20044-7611.

Please enclose a check or money order for \$21.50 (25 cents per page reproduction cost) payable to the United States Treasury.

Robert E. Maher Jr.,

Assistant Section Chief, Environmental Enforcement Section, Environment and Natural Resources Division.

[FR Doc. 2016-25451 Filed 10-20-16; 8:45 am]

BILLING CODE 4410-15-P

DEPARTMENT OF JUSTICE

Parole Commission

Sunshine Act Meeting

TIME AND DATE: 12:00 p.m., Wednesday, October 26, 2016.

PLACE: U.S. Parole Commission, 90 K Street NE., 3rd Floor, Washington, DC.

STATUS: Closed.

MATTERS TO BE CONSIDERED: Determination on three original jurisdiction cases.

CONTACT PERSON FOR MORE INFORMATION: Jacqueline Graham, Staff Assistant to the Chairman, U.S. Parole Commission, 90 K Street NE., 3rd Floor, Washington, DC 20530, (202) 346-7010.

Dated: October 18, 2016.

J. Patricia W. Smoot,

Chairman, U.S. Parole Commission.

[FR Doc. 2016-25582 Filed 10-19-16; 11:15 am]

BILLING CODE 4410-31-P

DEPARTMENT OF JUSTICE

Parole Commission

Sunshine Act Meeting

TIME AND DATE: 11:00 a.m., October 26, 2016.

PLACE: U.S. Parole Commission, 90 K Street NE., 3rd Floor, Washington, DC.

STATUS: Open.

MATTERS TO BE CONSIDERED: Approval of July 27, 2016 minutes.

CONTACT PERSON FOR MORE INFORMATION: Jacqueline Graham, Staff Assistant to the Chairman, U.S. Parole Commission, 90 K Street NE., 3rd Floor, Washington, DC 20530, (202) 346-7010.

Dated: October 18, 2016.

J. Patricia W. Smoot,

Chairman, U.S. Parole Commission.

[FR Doc. 2016-25583 Filed 10-19-16; 11:15 am]

BILLING CODE 4410-31-P

NATIONAL SCIENCE FOUNDATION

Sunshine Act Meeting; National Science Board

The National Science Board, pursuant to NSF regulations (45 CFR part 614), the National Science Foundation Act, as amended (42 U.S.C. 1862n-5), and the Government in the Sunshine Act (5 U.S.C. 552b), hereby gives short notice of the scheduling of an Executive Committee teleconference for the transaction of National Science Board business. The Executive Committee determined that the interests of the National Science Foundation require the short notice.

DATE & TIME: Thursday, October 20, 2016 from 5:00 p.m. to 5:30 p.m. EDT.

SUBJECT MATTER: (1) Committee Chair's Opening Remarks; (2) Approval of Executive Committee Minutes of July 2016; (3) IPA Program Review.

STATUS: Open.

This meeting will be held by teleconference at the National Science Foundation, 4201 Wilson Blvd., Arlington, VA 22230. A public audio stream will be available for this meeting. Request the link by contacting nationalsciencebrd@nsf.gov prior to the teleconference. Please refer to the National Science Board Web site for additional information and schedule updates (time, place, subject matter or status of meeting) which may be found at <http://www.nsf.gov/nsb/notices/>. The point of contact for this meeting is Kathy Jacquart, 4201 Wilson Blvd.,

Arlington, VA 22230. Telephone: (703) 292-7000.

Chris Blair,

Executive Assistant to the NSB Office.

[FR Doc. 2016-25635 Filed 10-19-16; 4:15 pm]

BILLING CODE 7555-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-457; NRC-2016-0215]

Exelon Generation Company, LLC; Braidwood Station, Unit 2

AGENCY: Nuclear Regulatory Commission.

ACTION: License amendment application; opportunity to comment, request a hearing, and petition for leave to intervene.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of an amendment to Renewed Facility Operating License No. NPF-77, issued to Exelon Generation Company, LLC, for operation of Braidwood Station, Unit 2, located in Will County, Illinois. The proposed amendment would allow a one-time extension from 72 hours to 200 hours of the technical specification (TS) completion time associated with the 2A service water (SX) pump in support of maintenance activities.

DATES: Submit comments by November 21, 2016. Requests for a hearing or petition for leave to intervene must be filed by December 20, 2016.

ADDRESSES: You may submit comments by any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2016-0215. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: Carol.Gallagher@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *Mail comments to:* Cindy Bladey, Office of Administration, Mail Stop: OWFN-12-H08, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

For additional direction on obtaining information and submitting comments, see "Obtaining Information and Submitting Comments" in the **SUPPLEMENTARY INFORMATION** section of this document.

FOR FURTHER INFORMATION CONTACT: Joel S. Wiebe, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington DC 20555-

0001; telephone: 301-415-6606, email: Joel.Wiebe@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID NRC-2016-0215 when contacting the NRC about the availability of information for this action. You may obtain publicly-available information related to this action by any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2016-0215.
- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. The application for license amendment dated September 30, 2016 is available in ADAMS under Accession No. ML16274A474.

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

B. Submitting Comments

Please include Docket ID NRC-2016-0215 in your comment submission.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission. The NRC will post all comment submissions at <http://www.regulations.gov> as well as enter the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment submissions into ADAMS.

II. Introduction

The NRC is considering issuance of an amendment to Renewed Facility Operating License No. NPF-77, issued to Exelon Generation Company, LLC, for operation of Braidwood Station, Unit 2, located in Will County, Illinois.

The proposed amendment would allow a one-time extension from 72 hours to 200 hours of the TS completion time associated with the 2A SX pump in support of maintenance activities.

Before any issuance of the proposed license amendment, the NRC will need to make the findings required by the Atomic Energy Act of 1954, as amended (the Act), and NRC's regulations.

The NRC has made a proposed determination that the license amendment request involves no significant hazards consideration. Under the NRC's regulations in section 50.92 of title 10 of the *Code of Federal Regulations* (10 CFR), this means that operation of the facility in accordance with the proposed amendment would not: (1) Involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed changes have been evaluated using the risk informed processes described in RG [Regulatory Guide] 1.174, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis," Revision 2 dated May 2011, RG 1.177, "An Approach for Plant-Specific, Risk-Informed Decisionmaking: Technical Specifications," Revision 1 dated May 2011 and NRC Regulatory Guide 1.200, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities," Revision 2 dated March 2009. The risk associated with the proposed change was found to be acceptable.

The previously analyzed accidents are initiated by the failure of plant structures, systems, or components. The SX System is not considered an initiator for any of these previously analyzed events. The proposed change does not have a detrimental impact on the integrity of any plant structure, system, or component that initiates an analyzed event. No active or passive failure mechanisms that could lead to an accident are affected. The proposed change will not