

§ 54.1

review of the relative merits of the submitted site and alternative sites under subpart A of part 51 of this chapter is requested, there is a reasonable likelihood that further staff review would identify one or more preferable alternative sites and the staff review of one or more site suitability issues would lead to an irreversible and irretrievable commitment of resources prior to the submittal of the analysis of alternative sites in the Environmental Report that would prejudice the later review and decision on alternative sites under subpart F and/or G of part 2 and subpart A of part 51 of this chapter; or (b) in cases where, in the judgment of the staff, early review of any site suitability issue or issues would not be in the public interest, considering (1) the degree of likelihood that any early findings on those issues would retain their validity in later reviews, (2) the objections, if any, of cognizant state or local government agencies to the conduct of an early review on those issues, and (3) the possible effect on the public interest of having an early, if not necessarily conclusive, resolution of those issues.

PART 53 [RESERVED]

PART 54—REQUIREMENTS FOR RENEWAL OF OPERATING LICENSES FOR NUCLEAR POWER PLANTS

GENERAL PROVISIONS

- Sec.
- 54.1 Purpose.
 - 54.3 Definitions.
 - 54.4 Scope.
 - 54.5 Interpretations.
 - 54.7 Written communications.
 - 54.9 Information collection requirements: OMB approval.
 - 54.11 Public inspection of applications.
 - 54.13 Completeness and accuracy of information.
 - 54.15 Specific exemptions.
 - 54.17 Filing of application.
 - 54.19 Contents of application—general information.
 - 54.21 Contents of application—technical information.
 - 54.22 Contents of application—technical specifications.
 - 54.23 Contents of application—environmental information.
 - 54.25 Report of the Advisory Committee on Reactor Safeguards.
 - 54.27 Hearings.
 - 54.29 Standards for issuance of a renewed license.
 - 54.30 Matters not subject to a renewal review.
 - 54.31 Issuance of a renewed license.
 - 54.33 Continuation of CLB and conditions of renewed license.

10 CFR Ch. I (1–1–97 Edition)

- 54.35 Requirements during term of renewed license.
- 54.37 Additional records and recordkeeping requirements.
- 54.41 Violations.
- 54.43 Criminal penalties.

AUTHORITY: Secs. 102, 103, 104, 161, 181, 182, 183, 186, 189, 68 Stat. 936, 937, 938, 948, 953, 954, 955, as amended, sec. 234, 83 Stat. 1244, as amended (42 U.S.C. 2132, 2133, 2134, 2135, 2201, 2232, 2233, 2236, 2239, 2282); secs. 201, 202, 206, 88 Stat. 1242, 1244, as amended (42 U.S.C. 5841, 5842).

SOURCE: 60 FR 22491, May 8, 1995, unless otherwise noted.

GENERAL PROVISIONS

§ 54.1 Purpose.

This part governs the issuance of renewed operating licenses for nuclear power plants licensed pursuant to Sections 103 or 104b of the Atomic Energy Act of 1954, as amended (68 Stat. 919), and Title II of the Energy Reorganization Act of 1974 (88 Stat. 1242).

§ 54.3 Definitions.

- (a) As used in this part,
Current licensing basis (CLB) is the set of NRC requirements applicable to a specific plant and a licensee's written commitments for ensuring compliance with and operation within applicable NRC requirements and the plant-specific design basis (including all modifications and additions to such commitments over the life of the license) that are docketed and in effect. The CLB includes the NRC regulations contained in 10 CFR Parts 2, 19, 20, 21, 26, 30, 40, 50, 51, 54, 55, 70, 72, 73, 100 and appendices thereto; orders; license conditions; exemptions; and technical specifications. It also includes the plant-specific design-basis information defined in 10 CFR 50.2 as documented in the most recent final safety analysis report (FSAR) as required by 10 CFR 50.71 and the licensee's commitments remaining in effect that were made in docketed licensing correspondence such as licensee responses to NRC bulletins, generic letters, and enforcement actions, as well as licensee commitments documented in NRC safety evaluations or licensee event reports.
Integrated plant assessment (IPA) is a licensee assessment that demonstrates that a nuclear power plant facility's

structures and components requiring aging management review in accordance with § 54.21(a) for license renewal have been identified and that the effects of aging on the functionality of such structures and components will be managed to maintain the CLB such that there is an acceptable level of safety during the period of extended operation.

Nuclear power plant means a nuclear power facility of a type described in 10 CFR 50.21(b) or 50.22.

Time-limited aging analyses, for the purposes of this part, are those licensee calculations and analyses that:

- (1) Involve systems, structures, and components within the scope of license renewal, as delineated in § 54.4(a);
 - (2) Consider the effects of aging;
 - (3) Involve time-limited assumptions defined by the current operating term, for example, 40 years;
 - (4) Were determined to be relevant by the licensee in making a safety determination;
 - (5) Involve conclusions or provide the basis for conclusions related to the capability of the system, structure, and component to perform its intended functions, as delineated in § 54.4(b); and
 - (6) Are contained or incorporated by reference in the CLB.
- (b) All other terms in this part have the same meanings as set out in 10 CFR 50.2 or Section 11 of the Atomic Energy Act, as applicable.

§ 54.4 Scope.

- (a) Plant systems, structures, and components within the scope of this part are—
 - (1) Safety-related systems, structures, and components which are those relied upon to remain functional during and following design-basis events (as defined in 10 CFR 50.49 (b)(1)) to ensure the following functions—
 - (i) The integrity of the reactor coolant pressure boundary;
 - (ii) The capability to shut down the reactor and maintain it in a safe shutdown condition; or
 - (iii) The capability to prevent or mitigate the consequences of accidents that could result in potential offsite exposure comparable to the guidelines in § 50.34(a)(1) or § 100.11 of this chapter, as applicable.

(2) All nonsafety-related systems, structures, and components whose failure could prevent satisfactory accomplishment of any of the functions identified in paragraphs (a)(1)(i), (ii), or (iii) of this section.

(3) All systems, structures, and components relied on in safety analyses or plant evaluations to perform a function that demonstrates compliance with the Commission’s regulations for fire protection (10 CFR 50.48), environmental qualification (10 CFR 50.49), pressurized thermal shock (10 CFR 50.61), anticipated transients without scram (10 CFR 50.62), and station blackout (10 CFR 50.63).

(b) The intended functions that these systems, structures, and components must be shown to fulfill in § 54.21 are those functions that are the bases for including them within the scope of license renewal as specified in paragraphs (a)(1)–(3) of this section.

[60 FR 22491, May 8, 1995, as amended at 61 FR 65175, Dec. 11, 1996]

EFFECTIVE DATE NOTE: At 61 FR 65175, Dec. 11, 1996, § 54.4 was amended by revising paragraph (a)(1)(iii), effective Jan. 10, 1997. For the convenience of the user, the superseded text is set forth as follows:

§ 54.4 Scope.

- (a) * * *
- (1) * * *
- (iii) The capability to prevent or mitigate the consequences of accidents that could result in potential offsite exposure comparable to the 10 CFR Part 100 guidelines.

* * * * *

§ 54.5 Interpretations.

Except as specifically authorized by the Commission in writing, no interpretation of the meaning of the regulations in this part by any officer or employee of the Commission other than a written interpretation by the General Counsel will be recognized to be binding upon the Commission.

§ 54.7 Written communications.

All applications, correspondence, reports, and other written communications shall be filed in accordance with applicable portions of 10 CFR 50.4.

§ 54.9 Information collection requirements: OMB approval.

(a) The Nuclear Regulatory Commission has submitted the information collection requirements contained in this part to the Office of Management and Budget (OMB) for approval as required by the Paperwork Reduction Act of 1980 (44 U.S.C. 3501 et seq.). OMB has approved the information collection requirements contained in this part under control numbers 150–0155.

(b) The approved information collection requirements contained in this part appear in §§ 54.13, 54.17, 54.19, 54.21, 54.22, 54.23, 54.33, and 54.37.

§ 54.11 Public inspection of applications.

Applications and documents submitted to the Commission in connection with renewed applications may be made available for public inspection in accordance with the provisions of the regulations contained in 10 CFR Part 2.

§ 54.13 Completeness and accuracy of information.

(a) Information provided to the Commission by an applicant for a renewed license or information required by statute or by the Commission's regulations, orders, or license conditions to be maintained by the applicant must be complete and accurate in all material respects.

(b) Each applicant shall notify the Commission of information identified by the applicant as having, for the regulated activity, a significant implication for public health and safety or common defense and security. An applicant violates this paragraph only if the applicant fails to notify the Commission of information that the applicant has identified as having a significant implication for public health and safety or common defense and security. Notification must be provided to the Administrator of the appropriate regional office within 2 working days of identifying the information. This requirement is not applicable to information that is already required to be provided to the Commission by other reporting or updating requirements.

§ 54.15 Specific exemptions.

Exemptions from the requirements of this part may be granted by the Commission in accordance with 10 CFR 50.12.

§ 54.17 Filing of application.

(a) The filing of an application for a renewed license must be in accordance with Subpart A of 10 CFR Part 2 and 10 CFR 50.4 and 50.30.

(b) Any person who is a citizen, national, or agent of a foreign country, or any corporation, or other entity which the Commission knows or has reason to know is owned, controlled, or dominated by an alien, a foreign corporation, or a foreign government, is ineligible to apply for and obtain a renewed license.

(c) An application for a renewed license may not be submitted to the Commission earlier than 20 years before the expiration of the operating license currently in effect.

(d) An applicant may combine an application for a renewed license with applications for other kinds of licenses.

(e) An application may incorporate by reference information contained in previous applications for licenses or license amendments, statements, correspondence, or reports filed with the Commission, provided that the references are clear and specific.

(f) If the application contains Restricted Data or other defense information, it must be prepared in such a manner that all Restricted Data and other defense information are separated from unclassified information in accordance with 10 CFR 50.33(j).

(g) As part of its application and in any event prior to the receipt of Restricted Data or the issuance of a renewed license, the applicant shall agree in writing that it will not permit any individual to have access to Restricted Data until an investigation is made and reported to the Commission on the character, association, and loyalty of the individual and the Commission shall have determined that permitting such persons to have access to Restricted Data will not endanger the common defense and security. The agreement of the applicant in this regard is part of the renewed license, whether so stated or not.

§ 54.19 Contents of application—general information.

(a) Each application must provide the information specified in 10 CFR 50.33(a) through (e), (h), and (i). Alternatively, the application may incorporate by reference other documents that provide the information required by this section.

(b) Each application must include conforming changes to the standard indemnity agreement, 10 CFR 140.92, Appendix B, to account for the expiration term of the proposed renewed license.

§ 54.21 Contents of application—technical information.

Each application must contain the following information:

(a) An integrated plant assessment (IPA). The IPA must—

(1) For those systems, structures, and components within the scope of this part, as delineated in § 54.4, identify and list those structures and components subject to an aging management review. Structures and components subject to an aging management review shall encompass those structures and components—

(i) That perform an intended function, as described in § 54.4, without moving parts or without a change in configuration or properties. These structures and components include, but are not limited to, the reactor vessel, the reactor coolant system pressure boundary, steam generators, the pressurizer, piping, pump casings, valve bodies, the core shroud, component supports, pressure retaining boundaries, heat exchangers, ventilation ducts, the containment, the containment liner, electrical and mechanical penetrations, equipment hatches, seismic Category I structures, electrical cables and connections, cable trays, and electrical cabinets, excluding, but not limited to, pumps (except casing), valves (except body), motors, diesel generators, air compressors, snubbers, the control rod drive, ventilation dampers, pressure transmitters, pressure indicators, water level indicators, switchgears, cooling fans, transistors, batteries, breakers, relays, switches, power inverters, circuit boards, battery chargers, and power supplies; and

(ii) That are not subject to replacement based on a qualified life or specified time period.

(2) Describe and justify the methods used in paragraph (a)(1) of this section.

(3) For each structure and component identified in paragraph (a)(1) of this section, demonstrate that the effects of aging will be adequately managed so that the intended function(s) will be maintained consistent with the CLB for the period of extended operation.

(b) CLB changes during NRC review of the application. Each year following submittal of the license renewal application and at least 3 months before scheduled completion of the NRC review, an amendment to the renewal application must be submitted that identifies any change to the CLB of the facility that materially affects the contents of the license renewal application, including the FSAR supplement.

(c) An evaluation of time-limited aging analyses.

(1) A list of time-limited aging analyses, as defined in § 54.3, must be provided. The applicant shall demonstrate that—

(i) The analyses remain valid for the period of extended operation;

(ii) The analyses have been projected to the end of the period of extended operation; or

(iii) The effects of aging on the intended function(s) will be adequately managed for the period of extended operation.

(2) A list must be provided of plant-specific exemptions granted pursuant to 10 CFR 50.12 and in effect that are based on time-limited aging analyses as defined in § 54.3. The applicant shall provide an evaluation that justifies the continuation of these exemptions for the period of extended operation.

(d) An FSAR supplement. The FSAR supplement for the facility must contain a summary description of the programs and activities for managing the effects of aging and the evaluation of time-limited aging analyses for the period of extended operation determined by paragraphs (a) and (c) of this section, respectively.

§ 54.22 Contents of application—technical specifications.

Each application must include any technical specification changes or additions necessary to manage the effects of aging during the period of extended operation as part of the renewal application. The justification for changes or additions to the technical specifications must be contained in the license renewal application.

§ 54.23 Contents of application—environmental information.

Each application must include a supplement to the environmental report that complies with the requirements of Subpart A of 10 CFR Part 51.

§ 54.25 Report of the Advisory Committee on Reactor Safeguards.

Each renewal application will be referred to the Advisory Committee on Reactor Safeguards for a review and report. Any report will be made part of the record of the application and made available to the public, except to the extent that security classification prevents disclosure.

§ 54.27 Hearings.

A notice of an opportunity for a hearing will be published in the FEDERAL REGISTER in accordance with 10 CFR 2.105. In the absence of a request for a hearing filed within 30 days by a person whose interest may be affected, the Commission may issue a renewed operating license without a hearing upon 30-day notice and publication once in the FEDERAL REGISTER of its intent to do so.

§ 54.29 Standards for issuance of a renewed license.

A renewed license may be issued by the Commission up to the full term authorized by § 54.31 if the Commission finds that:

(a) Actions have been identified and have been or will be taken with respect to the matters identified in Paragraphs (a)(1) and (a)(2) of this section, such that there is reasonable assurance that the activities authorized by the renewed license will continue to be conducted in accordance with the CLB, and that any changes made to the plant's CLB in order to comply with

this paragraph are in accord with the Act and the Commission's regulations. These matters are:

(1) managing the effects of aging during the period of extended operation on the functionality of structures and components that have been identified to require review under § 54.21(a)(1); and

(2) time-limited aging analyses that have been identified to require review under § 54.21(c).

(b) Any applicable requirements of Subpart A of 10 CFR Part 51 have been satisfied.

(c) Any matters raised under § 2.758 have been addressed.

§ 54.30 Matters not subject to a renewal review.

(a) If the reviews required by § 54.21 (a) or (c) show that there is not reasonable assurance during the current license term that licensed activities will be conducted in accordance with the CLB, then the licensee shall take measures under its current license, as appropriate, to ensure that the intended function of those systems, structures or components will be maintained in accordance with the CLB throughout the term of its current license.

(b) The licensee's compliance with the obligation under Paragraph (a) of this section to take measures under its current license is not within the scope of the license renewal review.

§ 54.31 Issuance of a renewed license.

(a) A renewed license will be of the class for which the operating license currently in effect was issued.

(b) A renewed license will be issued for a fixed period of time, which is the sum of the additional amount of time beyond the expiration of the operating license (not to exceed 20 years) that is requested in a renewal application plus the remaining number of years on the operating license currently in effect. The term of any renewed license may not exceed 40 years.

(c) A renewed license will become effective immediately upon its issuance, thereby superseding the operating license previously in effect. If a renewed license is subsequently set aside upon further administrative or judicial appeal, the operating license previously in effect will be reinstated unless its

term has expired and the renewal application was not filed in a timely manner.

(d) A renewed license may be subsequently renewed in accordance with all applicable requirements.

§ 54.33 Continuation of CLB and conditions of renewed license.

(a) Whether stated therein or not, each renewed license will contain and otherwise be subject to the conditions set forth in 10 CFR 50.54.

(b) Each renewed license will be issued in such form and contain such conditions and limitations, including technical specifications, as the Commission deems appropriate and necessary to help ensure that systems, structures, and components subject to review in accordance with § 54.21 will continue to perform their intended functions for the period of extended operation. In addition, the renewed license will be issued in such form and contain such conditions and limitations as the Commission deems appropriate and necessary to help ensure that systems, structures, and components associated with any time-limited aging analyses will continue to perform their intended functions for the period of extended operation.

(c) Each renewed license will include those conditions to protect the environment that were imposed pursuant to 10 CFR 50.36b and that are part of the CLB for the facility at the time of issuance of the renewed license. These conditions may be supplemented or amended as necessary to protect the environment during the term of the renewed license and will be derived from information contained in the supplement to the environmental report submitted pursuant to 10 CFR Part 51, as analyzed and evaluated in the NRC record of decision. The conditions will identify the obligations of the licensee in the environmental area, including, as appropriate, requirements for reporting and recordkeeping of environmental data and any conditions and monitoring requirements for the protection of the nonaquatic environment.

(d) The licensing basis for the renewed license includes the CLB, as defined in § 54.3(a); the inclusion in the licensing basis of matters such as li-

icensee commitments does not change the legal status of those matters unless specifically so ordered pursuant to paragraphs (b) or (c) of this section.

§ 54.35 Requirements during term of renewed license.

During the term of a renewed license, licensees shall be subject to and shall continue to comply with all Commission regulations contained in 10 CFR Parts 2, 19, 20, 21, 26, 30, 40, 50, 51, 54, 55, 70, 72, 73, and 100, and the appendices to these parts that are applicable to holders of operating licenses.

§ 54.37 Additional records and record-keeping requirements.

(a) The licensee shall retain in an auditable and retrievable form for the term of the renewed operating license all information and documentation required by, or otherwise necessary to document compliance with, the provisions of this part.

(b) After the renewed license is issued, the FSAR update required by 10 CFR 50.71(e) must include any systems, structures, and components newly identified that would have been subject to an aging management review or evaluation of time-limited aging analyses in accordance with § 54.21. This FSAR update must describe how the effects of aging will be managed such that the intended function(s) in § 54.4(b) will be effectively maintained during the period of extended operation.

§ 54.41 Violations.

(a) The Commission may obtain an injunction or other court order to prevent a violation of the provisions of the following acts—

(1) The Atomic Energy Act of 1954, as amended.

(2) Title II of the Energy Reorganization Act of 1974, as amended or

(3) A regulation or order issued pursuant to those acts.

(b) The Commission may obtain a court order for the payment of a civil penalty imposed under Section 234 of the Atomic Energy Act—

(1) For violations of the following—

(i) Sections 53, 57, 62, 63, 81, 82, 101, 103, 104, 107, or 109 of the Atomic Energy Act of 1954, as amended;

§ 54.43

(ii) Section 206 of the Energy Reorganization Act;

(iii) Any rule, regulation, or order issued pursuant to the sections specified in paragraph (b)(1)(i) of this section;

(iv) Any term, condition, or limitation of any license issued under the sections specified in paragraph (b)(1)(i) of this section.

(2) For any violation for which a license may be revoked under Section 186 of the Atomic Energy Act of 1954, as amended.

§ 54.43 Criminal penalties.

(a) Section 223 of the Atomic Energy Act of 1954, as amended, provides for criminal sanctions for willful violations of, attempted violation of, or conspiracy to violate, any regulation issued under sections 161b, 161i, or 161o of the Act. For purposes of section 223, all the regulations in Part 54 are issued under one or more of sections 161b, 161i, or 161o, except for the sections listed in paragraph (b) of this section.

(b) The regulations in Part 54 that are not issued under Sections 161b, 161i, or 161o for the purposes of Section 223 are as follows: §§ 54.1, 54.3, 54.4, 54.5, 54.7, 54.9, 54.11, 54.15, 54.17, 54.19, 54.21, 54.22, 54.23, 54.25, 54.27, 54.29, 54.31, 54.41, and 54.43.

PART 55—OPERATORS' LICENSES

Subpart A—General Provisions

- Sec.
- 55.1 Purpose.
 - 55.2 Scope.
 - 55.3 License requirements.
 - 55.4 Definitions.
 - 55.5 Communications.
 - 55.6 Interpretations.
 - 55.7 Additional requirements.
 - 55.8 Information collection requirements: OMB approval.
 - 55.9 Completeness and accuracy of information.

Subpart B—Exemptions

- 55.11 Specific exemptions.
- 55.13 General exemptions.

Subpart C—Medical Requirements

- 55.21 Medical examination.
- 55.23 Certification.
- 55.25 Incapacitation because of disability or illness.
- 55.27 Documentation.

10 CFR Ch. I (1–1–97 Edition)

Subpart D—Applications

- 55.31 How to apply.
- 55.33 Disposition of an initial application.
- 55.35 Re-applications.

Subpart E—Written Examinations and Operating Tests

- 55.41 Written examination: Operators.
- 55.43 Written examination: Senior operators.
- 55.45 Operating tests.
- 55.47 Waiver of examination and test requirements.
- 55.49 Integrity of examinations and tests.

Subpart F—Licenses

- 55.51 Issuance of licenses.
- 55.53 Conditions of licenses.
- 55.55 Expiration.
- 55.57 Renewal of licenses.
- 55.59 Qualification.

Subpart G—Modification and Revocation of Licenses

- 55.61 Modification and revocation of licenses.

Subpart H—Enforcement

- 55.71 Violations.
- 55.73 Criminal penalties.

AUTHORITY: Secs. 107, 161, 182, 68 Stat. 939, 948, 953, as amended, sec. 234, 83 Stat. 444, as amended (42 U.S.C. 2137, 2201, 2232, 2282); secs. 201, as amended, 202, 88 Stat. 1242, as amended, 1244 (42 U.S.C. 5841, 5842).

Sections 55.41, 55.43, 55.45, and 55.59 also issued under sec. 306, Pub. L. 97–425, 96 Stat. 2262 (42 U.S.C. 10226). Section 55.61 also issued under secs. 186, 187, 68 Stat. 955 (42 U.S.C. 2236, 2237).

SOURCE: 52 FR 9460, Mar. 25, 1987, unless otherwise noted.

Subpart A—General Provisions

§ 55.1 Purpose.

The regulations in this part:

(a) Establish procedures and criteria for the issuance of licenses to operators and senior operators of utilization facilities licensed pursuant to the Atomic Energy Act of 1954, as amended, or section 202 of the Energy Reorganization Act of 1974, as amended, and part 50 of this chapter,

(b) Provide for the terms and conditions upon which the Commission will issue or modify these licenses, and