AUTHENTICATED
U.S. GOVERNMENT
INFORMATION
GPO

(1) The maximum capacity of all oil storage tanks and flow lines on the facility. Flow line volume may be estimated; and

(2) The volume of oil calculated to leak from a break in any pipelines connected to the facility considering shutdown time, the effect of hydrostatic pressure, gravity, frictional wall forces and other factors; and

(3) The daily production volume from an uncontrolled blowout of the highest capacity well associated with the facility. In determining the daily discharge rate, you must consider reservoir characteristics, casing/production tubing sizes, and historical production and reservoir pressure data. Your scenario must discuss how to respond to this well flowing for 30 days as required by §254.26(d)(1).

(b) For exploratory or development drilling operations, the size of your worst case discharge scenario is the daily volume possible from an uncontrolled blowout. In determining the daily discharge rate, you must consider any known reservoir characteristics. If reservoir characteristics are unknown, you must consider the characteristics of any analog reservoirs from the area and give an explanation for the selection of the reservoir(s) used. Your scenario must discuss how to respond to this well flowing for 30 days as required by §254.26(d)(1).

(c) For a pipeline facility, the size of your worst case discharge scenario is the volume possible from a pipeline break. You must calculate this volume as follows:

(1) Add the pipeline system leak detection time to the shutdown response time.

(2) Multiply the time calculated in paragraph (c)(1) of this section by the highest measured oil flow rate over the preceding 12-month period. For new pipelines, you should use the predicted oil flow rate in the calculation.

(3) Add to the volume calculated in paragraph (c)(2) of this section the total volume of oil that would leak from the pipeline after it is shut in. Calculate this volume by taking into account the effects of hydrostatic pressure, gravity, frictional wall forces, length of pipeline segment, tie-ins with other pipelines, and other factors.

(d) If your facility which stores, handles, transfers, processes, or transports oil does not fall into the categories listed in paragraph (a), (b), or (c) of this section, contact the Regional Supervisor for instructions on the calculation of the volume of your worst case discharge scenario.

Subpart D—Oil-Spill Response Requirements for Facilities Located in State Waters Seaward of the Coast Line.

§254.50 Spill response plans for facilities located in State waters seaward of the coast line.

Owners or operators of facilities located in State waters seaward of the coast line must submit a spill-response plan to MMS for approval. You may choose one of three methods to comply with this requirement. The three methods are described in §§254.51, 254.52, and 254.53.

§254.51 Modifying an existing OCS response plan.

You may modify an existing response plan covering a lease or facility on the OCS to include a lease or facility in State waters located seaward of the coast line. Since this plan would cover more than one lease or facility, it would be considered a Regional Response Plan. You should refer to §254.3 and contact the appropriate regional MMS office if you have any questions on how to prepare this Regional Response Plan.

§254.52 Following the format for an OCS response plan.

You may develop a response plan following the requirements for plans for OCS facilities found in subpart B of this part.

§254.53 Submitting a response plan developed under State requirements.

(a) You may submit a response plan to MMS for approval that you developed in accordance with the laws or regulations of the appropriate State. The plan must contain all the elements the State and OPA require and must:

(1) Be consistent with the requirements of the National Contingency