AUTHENTICATED
U.S. GOVERNMENT
INFORMATION
GPO

Title 40—Protection of Environment

(This book contains part 63)

Part

CHAPTER I—Environmental Protection Agency (Continued) 63

CHAPTER I—ENVIRONMENTAL PROTECTION AGENCY (CONTINUED)

EDITORIAL NOTE: Nomenclature changes to chapter I appear at 65 FR 47324, 47325, Aug. 2, 2000.

SUBCHAPTER C—AIR PROGRAMS (CONTINUED)

Part		*Page*
63	National emission standards for hazardous air pollutants for source categories	5

SUBCHAPTER C—AIR PROGRAMS (CONTINUED)

PART 63—NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES

Subpart ZZZZ—National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

WHAT THIS SUBPART COVERS

Sec.
63.6580 What is the purpose of subpart ZZZZ?
63.6585 Am I subject to this subpart?
63.6590 What parts of my plant does this subpart cover?
63.6595 When do I have to comply with this subpart?

EMISSION LIMITATIONS

63.6600 What emission limitations and operating limitations must I meet?

GENERAL COMPLIANCE REQUIREMENTS

63.6605 What are my general requirements for complying with this subpart?

TESTING AND INITIAL COMPLIANCE REQUIREMENTS

63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations?
63.6615 When must I conduct subsequent performance tests?
63.6620 What performance tests and other procedures must I use?
63.6625 What are my monitoring, installation, operation, and maintenance requirements?
63.6630 How do I demonstrate initial compliance with the emission limitations and operating limitations?

CONTINUOUS COMPLIANCE REQUIREMENTS

63.6635 How do I monitor and collect data to demonstrate continuous compliance?
63.6640 How do I demonstrate continuous compliance with the emission limitations and operating limitations?

NOTIFICATION, REPORTS, AND RECORDS

63.6645 What notifications must I submit and when?
63.6650 What reports must I submit and when?
63.6655 What records must I keep?
63.6660 In what form and how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.6665 What parts of the General Provisions apply to me?
63.6670 Who implements and enforces this subpart?
63.6675 What definitions apply to this subpart?

TABLE 1A TO SUBPART ZZZZ OF PART 63—EMISSION LIMITATIONS FOR EXISTING, NEW, AND RECONSTRUCTED SPARK IGNITION, 4SRB STATIONARY RICE
TABLE 1B TO SUBPART ZZZZ OF PART 63—OPERATING LIMITATIONS FOR EXISTING, NEW, AND RECONSTRUCTED SPARK IGNITION, 4SRB STATIONARY RICE
TABLE 2A TO SUBPART ZZZZ OF PART 63—EMISSION LIMITATIONS FOR NEW AND RECONSTRUCTED LEAN BURN AND COMPRESSION IGNITION STATIONARY RICE
TABLE 2B TO SUBPART ZZZZ OF PART 63—OPERATING LIMITATIONS FOR NEW AND RECONSTRUCTED LEAN BURN AND COMPRESSION IGNITION STATIONARY RICE
TABLE 3 TO SUBPART ZZZZ OF PART 63—SUBSEQUENT PERFORMANCE TESTS
TABLE 4 TO SUBPART ZZZZ OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS
TABLE 5 TO SUBPART ZZZZ OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS AND OPERATING LIMITATIONS
TABLE 6 TO SUBPART ZZZZ OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITATIONS AND OPERATING LIMITATIONS
TABLE 7 TO SUBPART ZZZZ OF PART 63—REQUIREMENTS FOR REPORTS
TABLE 8 TO SUBPART ZZZZ OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART ZZZZ

Subpart AAAAA—National Emission Standards for Hazardous Air Pollutants for Lime Manufacturing Plants

WHAT THIS SUBPART COVERS

63.7080 What is the purpose of this subpart?
63.7081 Am I subject to this subpart?
63.7082 What parts of my plant does this subpart cover?
63.7083 When do I have to comply with this subpart?

EMISSION LIMITATIONS

63.7090 What emission limitations must I meet?

GENERAL COMPLIANCE REQUIREMENTS

63.7100 What are my general requirements for complying with this subpart?

TESTING AND INITIAL COMPLIANCE REQUIREMENTS

63.7110 By what date must I conduct performance tests and other initial compliance demonstrations?
63.7111 When must I conduct subsequent performance tests?
63.7112 What performance tests, design evaluations, and other procedures must I use?
63.7113 What are my monitoring installation, operation, and maintenance requirements?
63.7114 How do I demonstrate initial compliance with the emission limitations standard?

CONTINUOUS COMPLIANCE REQUIREMENTS

63.7120 How do I monitor and collect data to demonstrate continuous compliance?
63.7121 How do I demonstrate continuous compliance with the emission limitations standard?

NOTIFICATIONS, REPORTS, AND RECORDS

63.7130 What notifications must I submit and when?
63.7131 What reports must I submit and when?
63.7132 What records must I keep?
63.7133 In what form and for how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.7140 What parts of the General Provisions apply to me?
63.7141 Who implements and enforces this subpart?
63.7142 What are the requirements for claiming area source status?
63.7143 What definitions apply to this subpart?

TABLE 1 TO SUBPART AAAAA OF PART 63—EMISSION LIMITS
TABLE 2 TO SUBPART AAAAA OF PART 63—OPERATING LIMITS
TABLE 3 TO SUBPART AAAAA OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITS
TABLE 4 TO SUBPART AAAAA OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS
TABLE 5 TO SUBPART AAAAA OF PART 63—CONTINUOUS COMPLIANCE WITH OPERATING LIMITS
TABLE 6 TO SUBPART AAAAA OF PART 63—PERIODIC MONITORING FOR COMPLIANCE WITH OPACITY AND VISIBLE EMISSIONS LIMITS
TABLE 7 TO SUBPART AAAAA OF PART 63—REQUIREMENTS FOR REPORTS
TABLE 8 TO SUBPART AAAAA OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART AAAAA

Subpart BBBBB—National Emission Standards for Hazardous Air Pollutants for Semiconductor Manufacturing

WHAT THIS SUBPART COVERS

63.7180 What is the purpose of this subpart?
63.7181 Am I subject to this subpart?
63.7182 What parts of my facility does this subpart cover?
63.7183 When do I have to comply with this subpart?

EMISSION STANDARDS

63.7184 What emission limitations, operating limits, and work practice standards must I meet?

COMPLIANCE REQUIREMENTS

63.7185 What are my general requirements for complying with this subpart?
63.7186 By what date must I conduct performance tests or other initial compliance demonstrations?
63.7187 What performance tests and other compliance procedures must I use?
63.7188 What are my monitoring installation, operation, and maintenance requirements?

APPLICATIONS, NOTIFICATIONS, REPORTS, AND RECORDS

63.7189 What applications and notifications must I submit and when?
63.7190 What reports must I submit and when?
63.7191 What records must I keep?
63.7192 In what form and how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.7193 What parts of the General Provisions apply to me?
63.7194 Who implements and enforces this subpart?
63.7195 What definitions apply to this subpart?

TABLE 1 TO SUBPART BBBBB OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS
TABLE 2 TO SUBPART BBBBB OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART BBBBB

Subpart CCCCC—National Emission Standards for Hazardous Air Pollutants for Coke Ovens: Pushing, Quenching, and Battery Stacks

WHAT THIS SUBPART COVERS

63.7280 What is the purpose of this subpart?
63.7281 Am I subject to this subpart?

63.7282 What parts of my plant does this subpart cover?
63.7283 When do I have to comply with this subpart?

EMISSION LIMITATIONS AND WORK PRACTICE STANDARDS

63.7290 What emission limitations must I meet for capture systems and control devices applied to pushing emissions?
63.7291 What work practice standards must I meet for fugitive pushing emissions if I have a by-product coke oven battery with vertical flues?
63.7292 What work practice standards must I meet for fugitive pushing emissions if I have a by-product coke oven battery with horizontal flues?
63.7293 What work practice standards must I meet for fugitive pushing emissions if I have a non-recovery coke oven battery?
63.7294 What work practice standard must I meet for soaking?
63.7295 What requirements must I meet for quenching?
63.7296 What emission limitations must I meet for battery stacks?

OPERATION AND MAINTENANCE REQUIREMENTS

63.7300 What are my operation and maintenance requirements?

GENERAL COMPLIANCE REQUIREMENTS

63.7310 What are my general requirements for complying with this subpart?

INITIAL COMPLIANCE REQUIREMENTS

63.7320 By what date must I conduct performance tests or other initial compliance demonstrations?
63.7321 When must I conduct subsequent performance tests?
63.7322 What test methods and other procedures must I use to demonstrate initial compliance with the emission limits for particulate matter?
63.7323 What procedures must I use to establish operating limits?
63.7324 What procedures must I use to demonstrate initial compliance with the opacity limits?
63.7325 What test methods and other procedures must I use to demonstrate initial compliance with the TDS or constituent limits for quench water?
63.7326 How do I demonstrate initial compliance with the emission limitations that apply to me?
63.7327 How do I demonstrate initial compliance with the work practice standards that apply to me?
63.7328 How do I demonstrate initial compliance with the operation and maintenance requirements that apply to me?

CONTINUOUS COMPLIANCE REQUIREMENTS

63.7330 What are my monitoring requirements?
63.7331 What are the installation, operation, and maintenance requirements for my monitors?
63.7332 How do I monitor and collect data to demonstrate continuous compliance?
63.7333 How do I demonstrate continuous compliance with the emission limitations that apply to me?
63.7334 How do I demonstrate continuous compliance with the work practice standards that apply to me?
63.7335 How do I demonstrate continuous compliance with the operation and maintenance requirements that apply to me?
63.7336 What other requirements must I meet to demonstrate continuous compliance?

NOTIFICATIONS, REPORTS, AND RECORDS

63.7340 What notifications must I submit and when?
63.7341 What reports must I submit and when?
63.7342 What records must I keep?
63.7343 In what form and how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.7350 What parts of the General Provisions apply to me?
63.7351 Who implements and enforces this subpart?
63.7352 What definitions apply to this subpart?

TABLE 1 TO SUBPART CCCCC OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART CCCCC

Subpart DDDDD—National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters

WHAT THIS SUBPART COVERS

63.7480 What is the purpose of this subpart?
63.7485 Am I subject to this subpart?
63.7490 What is the affected source of this subpart?
63.7491 Are any boilers or process heaters not subject to this subpart?
63.7495 When do I have to comply with this subpart?

EMISSION LIMITS AND WORK PRACTICE STANDARDS

63.7499 What are the subcategories of boilers and process heaters?
63.7500 What emission limits, work practice standards, and operating limits must I meet?

GENERAL COMPLIANCE REQUIREMENTS

63.7505 What are my general requirements for complying with this subpart?
63.7506 Do any boilers or process heaters have limited requirements?
63.7507 What are the health-based compliance alternatives for the hydrogen chloride (HCl) and total selected metals (TSM) standards?

TESTING, FUEL ANALYSES, AND INITIAL COMPLIANCE REQUIREMENTS

63.7510 What are my initial compliance requirements and by what date must I conduct them?
63.7515 When must I conduct subsequent performance tests or fuel analyses?
63.7520 What performance tests and procedures must I use?
63.7521 What fuel analyses and procedures must I use?
63.7522 Can I use emission averaging to comply with this subpart?
63.7525 What are my monitoring, installation, operation, and maintenance requirements?
63.7530 How do I demonstrate initial compliance with the emission limits and work practice standards?

CONTINUOUS COMPLIANCE REQUIREMENTS

63.7535 How do I monitor and collect data to demonstrate continuous compliance?
63.7540 How do I demonstrate continuous compliance with the emission limits and work practice standards?
63.7541 How do I demonstrate continuous compliance under the emission averaging provision?

NOTIFICATIONS, REPORTS, AND RECORDS

63.7545 What notifications must I submit and when?
63.7550 What reports must I submit and when?
63.7555 What records must I keep?
63.7560 In what form and how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.7565 What parts of the General Provisions apply to me?
63.7570 Who implements and enforces this subpart?
63.7575 What definitions apply to this subpart?

TABLE 1 TO SUBPART DDDDD OF PART 63—EMISSION LIMITS AND WORK PRACTICE STANDARDS
TABLE 2 TO SUBPART DDDDD OF PART 63—OPERATING LIMITS FOR BOILERS AND PROCESS HEATERS WITH PARTICULATE MATTER EMISSION LIMITS
TABLE 3 TO SUBPART DDDDD OF PART 63—OPERATING LIMITS FOR BOILERS AND PROCESS HEATERS WITH MERCURY EMISSION LIMITS AND BOILERS AND PROCESS HEATERS THAT CHOOSE TO COMPLY WITH THE ALTERNATIVE TOTAL SELECTED METALS EMISSION LIMITS
TABLE 4 TO SUBPART DDDDD OF PART 63—OPERATING LIMITS FOR BOILERS AND PROCESS HEATERS WITH HYDROGEN CHLORIDE EMISSION LIMITS
TABLE 5 TO SUBPART DDDDD OF PART 63—PERFORMANCE TESTING REQUIREMENTS
TABLE 6 TO SUBPART DDDDD OF PART 63—FUEL ANALYSIS REQUIREMENTS
TABLE 7 TO SUBPART DDDDD OF PART 63—ESTABLISHING OPERATING LIMITS
TABLE 8 TO SUBPART DDDDD OF PART 63—DEMONSTRATING CONTINUOUS COMPLIANCE
TABLE 9 TO SUBPART DDDDD OF PART 63—REPORTING REQUIREMENTS
TABLE 10 TO SUBPART DDDDD OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART DDDDD
APPENDIX A TO SUBPART DDDDD—METHODOLOGY AND CRITERIA FOR DEMONSTRATING ELIGIBILITY FOR THE HEALTH-BASED COMPLIANCE ALTERNATIVES

Subpart EEEEE—National Emission Standards for Hazardous Air Pollutants for Iron and Steel Foundries

WHAT THIS SUBPART COVERS

63.7680 What is the purpose of this subpart?
63.7681 Am I subject to this subpart?
63.7682 What parts of my foundry does this subpart cover?
63.7683 When do I have to comply with this subpart?

EMISSIONS LIMITATIONS

63.7690 What emissions limitations must I meet?

WORK PRACTICE STANDARDS

63.7700 What work practice standards must I meet?

OPERATION AND MAINTENANCE REQUIREMENTS

63.7710 What are my operation and maintenance requirements?

GENERAL COMPLIANCE REQUIREMENTS

63.7720 What are my general requirements for complying with this subpart?

INITIAL COMPLIANCE REQUIREMENTS

63.7730 By what date must I conduct performance tests or other initial compliance demonstrations?
63.7731 When must I conduct subsequent performance tests?
63.7732 What test methods and other procedures must I use to demonstrate initial compliance with the emissions limitations?

63.7733 What procedures must I use to establish operating limits?
63.7734 How do I demonstrate initial compliance with the emissions limitations that apply to me?
63.7735 How do I demonstrate initial compliance with the work practice standards that apply to me?
63.7736 How do I demonstrate initial compliance with the operation and maintenance requirements that apply to me?

CONTINUOUS COMPLIANCE REQUIREMENTS

63.7740 What are my monitoring requirements?
63.7741 What are the installation, operation, and maintenance requirements for my monitors?
63.7742 How do I monitor and collect data to demonstrate continuous compliance?
63.7743 How do I demonstrate continuous compliance with the emissions limitations that apply to me?
63.7744 How do I demonstrate continuous compliance with the work practice standards that apply to me?
63.7745 How do I demonstrate continuous compliance with the operation and maintenance requirements that apply to me?
63.7746 What other requirements must I meet to demonstrate continuous compliance?
63.7747 How do I apply for alternative monitoring requirements for a continuous emissions monitoring system?

NOTIFICATIONS, REPORTS, AND RECORDS

63.7750 What notifications must I submit and when?
63.7751 What reports must I submit and when?
63.7752 What records must I keep?
63.7753 In what form and for how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.7760 What parts of the General Provisions apply to me?
63.7761 Who implements and enforces this subpart?

DEFINITIONS

63.7765 What definitions apply to this subpart?

TABLE 1 TO SUBPART EEEEE OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART EEEEE

Subpart FFFFF—National Emission Standards for Hazardous Air Pollutants for Integrated Iron and Steel Manufacturing Facilities

WHAT THIS SUBPART COVERS

63.7780 What is the purpose of this subpart?
63.7781 Am I subject to this subpart?
63.7782 What parts of my plant does this subpart cover?
63.7783 When do I have to comply with this subpart?

EMISSION LIMITATIONS

63.7790 What emission limitations must I meet?

OPERATION AND MAINTENANCE REQUIREMENTS

63.7800 What are my operation and maintenance requirements?

GENERAL COMPLIANCE REQUIREMENTS

63.7810 What are my general requirements for complying with this subpart?

INITIAL COMPLIANCE REQUIREMENTS

63.7820 By what date must I conduct performance tests or other initial compliance demonstrations?
63.7821 When must I conduct subsequent performance tests?
63.7822 What test methods and other procedures must I use to demonstrate initial compliance with the emission limits for particulate matter?
63.7823 What test methods and other procedures must I use to demonstrate initial compliance with the opacity limits?
63.7824 What test methods and other procedures must I use to establish and demonstrate initial compliance with the operating limits?
63.7825 How do I demonstrate initial compliance with the emission limitations that apply to me?
63.7826 How do I demonstrate initial compliance with the operation and maintenance requirements that apply to me?

CONTINUOUS COMPLIANCE REQUIREMENTS

63.7830 What are my monitoring requirements?
63.7831 What are the installation, operation, and maintenance requirements for my monitors?
63.7832 How do I monitor and collect data to demonstrate continuous compliance?
63.7833 How do I demonstrate continuous compliance with the emission limitations that apply to me?
63.7834 How do I demonstrate continuous compliance with the operation and maintenance requirements that apply to me?
63.7835 What other requirements must I meet to demonstrate continuous compliance?

NOTIFICATIONS, REPORTS, AND RECORDS

63.7840 What notifications must I submit and when?
63.7841 What reports must I submit and when?

63.7842 What records must I keep?
63.7843 In what form and how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.7850 What parts of the General Provisions apply to me?
63.7851 Who implements and enforces this subpart?
63.7852 What definitions apply to this subpart?
TABLE 1 TO SUBPART FFFFF OF PART 63—EMISSION AND OPACITY LIMITS
TABLE 2 TO SUBPART FFFFF OF PART 63—INITIAL COMPLIANCE WITH EMISSION AND OPACITY LIMITS
TABLE 3 TO SUBPART FFFFF OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION AND OPACITY LIMITS
TABLE 4 TO SUBPART FFFFF OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART FFFFF

Subpart GGGGG—National Emission Standards for Hazardous Air Pollutants: Site Remediation

WHAT THIS SUBPART COVERS

63.7880 What is the purpose of this subpart?
63.7881 Am I subject to this subpart?
63.7882 What site remediation sources at my facility does this subpart affect?
63.7883 When do I have to comply with this subpart?

GENERAL STANDARDS

63.7884 What are the general standards I must meet for each site remediation with affected sources?
63.7885 What are the general standards I must meet for my affected process vents?
63.7886 What are the general standards I must meet for my affected remediation material management units?
63.7887 What are the general standards I must meet for my affected equipment leak sources?
63.7888 How do I implement this rule at my facility using the cross-referenced requirements in other subparts?

PROCESS VENTS

63.7890 What emissions limitations and work practice standards must I meet for process vents?
63.7891 How do I demonstrate initial compliance with the emissions limitations and work practice standards for process vents?
63.7892 What are my inspection and monitoring requirements for process vents?
63.7893 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for process vents?

TANKS

63.7895 What emissions limitations and work practice standards must I meet for tanks?
63.7896 How do I demonstrate initial compliance with the emissions limitations and work practice standards for tanks?
63.7897 What are my inspection and monitoring requirements for tanks?
63.7898 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for tanks?

CONTAINERS

63.7900 What emissions limitations and work practice standards must I meet for containers?
63.7901 How do I demonstrate initial compliance with the emissions limitations and work practice standards for containers?
63.7902 What are my inspection and monitoring requirements for containers?
63.7903 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for containers?

SURFACE IMPOUNDMENTS

63.7905 What emissions limitations and work practice standards must I meet for surface impoundments?
63.7906 How do I demonstrate initial compliance with the emissions limitations and work practice standards for surface impoundments?
63.7907 What are my inspection and monitoring requirements for surface impoundments?
63.7908 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for surface impoundments?

SEPARATORS

63.7910 What emissions limitations and work practice standards must I meet for separators?
63.7911 How do I demonstrate initial compliance with the emissions limitations and work practice standards for separators?
63.7912 What are my inspection and monitoring requirements for separators?
63.7913 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for separators?

TRANSFER SYSTEMS

63.7915 What emissions limitations and work practice standards must I meet for transfer systems?
63.7916 How do I demonstrate initial compliance with the emissions limitations and

work practice standards for transfer systems?
63.7917 What are my inspection and monitoring requirements for transfer systems?
63.7918 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for transfer systems?

EQUIPMENT LEAKS

63.7920 What emissions limitations and work practice standards must I meet for equipment leaks?
63.7921 How do I demonstrate initial compliance with the emissions limitations and work practice standards for equipment leaks?
63.7922 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for equipment leaks?

CLOSED VENT SYSTEMS AND CONTROL DEVICES

63.7925 What emissions limitations and work practice standards must I meet for closed vent systems and control devices?
63.7926 How do I demonstrate initial compliance with the emissions limitations and work practice standards for closed vent systems and control devices?
63.7927 What are my inspection and monitoring requirements for closed vent systems and control devices?
63.7928 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for closed vent systems and control devices?

GENERAL COMPLIANCE REQUIREMENTS

63.7935 What are my general requirements for complying with this subpart?
63.7936 What requirements must I meet if I transfer remediation material off-site to another facility?
63.7937 How do I demonstrate initial compliance with the general standards?
63.7938 How do I demonstrate continuous compliance with the general standards?

PERFORMANCE TESTS

63.7940 By what date must I conduct performance tests or other initial compliance demonstrations?
63.7941 How do I conduct a performance test, design evaluation, or other type of initial compliance demonstration?
63.7942 When must I conduct subsequent performance tests?
63.7943 How do I determine the average VOHAP concentration of my remediation material?
63.7944 How do I determine the maximum HAP vapor pressure of my remediation material?

CONTINUOUS MONITORING SYSTEMS

63.7945 What are my monitoring installation, operation, and maintenance requirements?
63.7946 How do I monitor and collect data to demonstrate continuous compliance?
63.7947 What are my monitoring alternatives?

NOTIFICATIONS, REPORTS, AND RECORDS

63.7950 What notifications must I submit and when?
63.7951 What reports must I submit and when?
63.7952 What records must I keep?
63.7953 In what form and how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.7955 What parts of the General Provisions apply to me?
63.7956 Who implements and enforces this subpart?
63.7957 What definitions apply to this subpart?

TABLE 1 TO SUBPART GGGGG OF PART 63—LIST OF HAZARDOUS AIR POLLUTANTS
TABLE 2 TO SUBPART GGGGG OF PART 63—CONTROL LEVELS AS REQUIRED BY §63.7895(A) FOR TANKS MANAGING REMEDIATION MATERIAL WITH A MAXIMUM HAP VAPOR PRESSURE LESS THAN 76.6 KPA
TABLE 3 TO SUBPART GGGGG OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART GGGGG

Subpart HHHHH—National Emission Standards for Hazardous Air Pollutants: Miscellaneous Coating Manufacturing

WHAT THIS SUBPART COVERS

63.7980 What is the purpose of this subpart?
63.7985 Am I subject to the requirements in this subpart?
63.7990 What parts of my plant does this subpart cover?

COMPLIANCE DATES

63.7995 When do I have to comply with this subpart?

EMISSION LIMITS, WORK PRACTICE STANDARDS, AND COMPLIANCE REQUIREMENTS

63.8000 What are my general requirements for complying with this subpart?
63.8005 What requirements apply to my process vessels?
63.8010 What requirements apply to my storage tanks?
63.8015 What requirements apply to my equipment leaks?
63.8020 What requirements apply to my wastewater streams?
63.8025 What requirements apply to my transfer operations?

63.8030 What requirements apply to my heat exchange systems?

ALTERNATIVE MEANS OF COMPLIANCE

63.8050 How do I comply with emissions averaging for stationary process vessels at existing sources?
63.8055 How do I comply with a weight percent HAP limit in coating products?

NOTIFICATIONS, REPORTS, AND RECORDS

63.8070 What notifications must I submit and when?
63.8075 What reports must I submit and when?
63.8080 What records must I keep?

OTHER REQUIREMENTS AND INFORMATION

63.8090 What compliance options do I have if part of my plant is subject to both this subpart and another subpart?
63.8095 What parts of the General Provisions apply to me?
63.8100 Who implements and enforces this subpart?
63.8105 What definitions apply to this subpart?

TABLE 1 TO SUBPART HHHHH OF PART 63—EMISSION LIMITS AND WORK PRACTICE STANDARDS FOR PROCESS VESSELS
TABLE 2 TO SUBPART HHHHH OF PART 63—EMISSION LIMITS AND WORK PRACTICE STANDARDS FOR STORAGE TANKS
TABLE 3 TO SUBPART HHHHH OF PART 63—REQUIREMENTS FOR EQUIPMENT LEAKS
TABLE 4 TO SUBPART HHHHH OF PART 63—EMISSION LIMITS AND WORK PRACTICE STANDARDS FOR WASTEWATER STREAMS
TABLE 5 TO SUBPART HHHHH OF PART 63—EMISSION LIMITS AND WORK PRACTICE STANDARDS FOR TRANSFER OPERATIONS
TABLE 6 TO SUBPART HHHHH OF PART 63—REQUIREMENTS FOR HEAT EXCHANGE SYSTEMS
TABLE 7 TO SUBPART HHHHH OF PART 63—PARTIALLY SOLUBLE HAZARDOUS AIR POLLUTANTS
TABLE 8 TO SUBPART HHHHH OF PART 63—SOLUBLE HAZARDOUS AIR POLLUTANTS
TABLE 9 TO SUBPART HHHHH OF PART 63—REQUIREMENTS FOR REPORTS
TABLE 10 TO SUBPART HHHHH OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART HHHHH

Subpart IIIII—National Emission Standards for Hazardous Air Pollutants: Mercury Emissions From Mercury Cell Chlor-Alkali Plants

WHAT THIS SUBPART COVERS

63.8180 What is the purpose of this subpart?
63.8182 Am I subject to this subpart?
63.8184 What parts of my plant does this subpart cover?
63.8186 When do I have to comply with this subpart?

EMISSION LIMITATIONS AND WORK PRACTICE STANDARDS

63.8190 What emission limitations must I meet?
63.8192 What work practice standards must I meet?

OPERATION AND MAINTENANCE REQUIREMENTS

63.8222 What are my operation and maintenance requirements?

GENERAL COMPLIANCE REQUIREMENTS

63.8226 What are my general requirements for complying with this subpart?

INITIAL COMPLIANCE REQUIREMENTS

63.8230 By what date must I conduct performance tests or other initial compliance demonstrations?
63.8232 What test methods and other procedures must I use to demonstrate initial compliance with the emission limits?
63.8234 What equations and procedures must I use for the initial compliance demonstration?
63.8236 How do I demonstrate initial compliance with the emission limitations and work practice standards?

CONTINUOUS COMPLIANCE REQUIREMENTS

63.8240 What are my monitoring requirements?
63.8242 What are the installation, operation, and maintenance requirements for my continuous monitoring systems?
63.8243 What equations and procedures must I use to demonstrate continuous compliance?
63.8244 How do I monitor and collect data to demonstrate continuous compliance?
63.8246 How do I demonstrate continuous compliance with the emission limitations and work practice standards?
63.8248 What other requirements must I meet?

NOTIFICATIONS, REPORTS, AND RECORDS

63.8252 What notifications must I submit and when?
63.8254 What reports must I submit and when?
63.8256 What records must I keep?
63.8258 In what form and how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.8262 What parts of the General Provisions apply to me?
63.8264 Who implements and enforces this subpart?
63.8266 What definitions apply to this subpart?

TABLE 1 TO SUBPART IIIII OF PART 63—WORK PRACTICE STANDARDS—DESIGN, OPERATION, AND MAINTENANCE REQUIREMENTS
TABLE 2 TO SUBPART IIIII OF PART 63—WORK PRACTICE STANDARDS—REQUIRED INSPECTIONS
TABLE 3 TO SUBPART IIIII OF PART 63—WORK PRACTICE STANDARDS—REQUIRED ACTIONS FOR LIQUID MERCURY SPILLS AND ACCUMULATIONS AND HYDROGEN AND MERCURY VAPOR LEAKS
TABLE 4 TO SUBPART IIIII OF PART 63—WORK PRACTICE STANDARDS—REQUIREMENTS FOR MERCURY LIQUID COLLECTION
TABLE 5 TO SUBPART IIIII OF PART 63—REQUIRED ELEMENTS OF FLOOR-LEVEL MERCURY VAPOR MEASUREMENT AND CELL ROOM MONITORING PLANS
TABLE 6 TO SUBPART IIIII OF PART 63—EXAMPLES OF TECHNIQUES FOR EQUIPMENT PROBLEM IDENTIFICATION, LEAK DETECTION AND MERCURY VAPOR MEASUREMENTS
TABLE 7 TO SUBPART IIIII OF PART 63—REQUIRED ELEMENTS OF WASHDOWN PLANS
TABLE 8 TO SUBPART IIIII OF PART 63—REQUIREMENTS FOR CELL ROOM MONITORING PROGRAM
TABLE 9 TO SUBPART IIIII OF PART 63—REQUIRED RECORDS FOR WORK PRACTICE STANDARDS
TABLE 10 TO SUBPART IIIII OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART IIIII

Subpart JJJJJ—National Emission Standards for Hazardous Air Pollutants for Brick and Structural Clay Products Manufacturing

WHAT THIS SUBPART COVERS

63.8380 What is the purpose of this subpart?
63.8385 Am I subject to this subpart?
63.8390 What parts of my plant does this subpart cover?
63.8395 When do I have to comply with this subpart?

EMISSION LIMITATIONS

63.8405 What emission limitations must I meet?
63.8410 What are my options for meeting the emission limitations?

GENERAL COMPLIANCE REQUIREMENTS

63.8420 What are my general requirements for complying with this subpart?
63.8425 What do I need to know about operation, maintenance, and monitoring plans?

TESTING AND INITIAL COMPLIANCE REQUIREMENTS

63.8435 By what date must I conduct performance tests?
63.8440 When must I conduct subsequent performance tests?
63.8445 How do I conduct performance tests and establish operating limits?
63.8450 What are my monitoring installation, operation, and maintenance requirements?
63.8455 How do I demonstrate initial compliance with the emission limitations?

CONTINUOUS COMPLIANCE REQUIREMENTS

63.8465 How do I monitor and collect data to demonstrate continuous compliance?
63.8470 How do I demonstrate continuous compliance with the emission limitations?

NOTIFICATIONS, REPORTS, AND RECORDS

63.8480 What notifications must I submit and when?
63.8485 What reports must I submit and when?
63.8490 What records must I keep?
63.8495 In what form and for how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.8505 What parts of the General Provisions apply to me?
63.8510 Who implements and enforces this subpart?
63.8515 What definitions apply to this subpart?
TABLE 1 TO SUBPART JJJJJ OF PART 63—EMISSION LIMITS
TABLE 2 TO SUBPART JJJJJ OF PART 63—OPERATING LIMITS
TABLE 3 TO SUBPART JJJJJ OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS
TABLE 4 TO SUBPART JJJJJ OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS
TABLE 5 TO SUBPART JJJJJ OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITS AND OPERATING LIMITS
TABLE 6 TO SUBPART JJJJJ OF PART 63—REQUIREMENTS FOR REPORTS
TABLE 7 TO SUBPART JJJJJ OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART JJJJJ

Subpart KKKKK—National Emission Standards for Hazardous Air Pollutants for Clay Ceramics Manufacturing

WHAT THIS SUBPART COVERS

63.8530 What is the purpose of this subpart?
63.8535 Am I subject to this subpart?
63.8540 What parts of my plant does this subpart cover?
63.8545 When do I have to comply with this subpart?

EMISSION LIMITATIONS AND WORK PRACTICE STANDARDS

63.8555 What emission limitations and work practice standards must I meet?
63.8560 What are my options for meeting the emission limitations and work practice standards?

GENERAL COMPLIANCE REQUIREMENTS

63.8570 What are my general requirements for complying with this subpart?
63.8575 What do I need to know about operation, maintenance, and monitoring plans?

TESTING AND INITIAL COMPLIANCE REQUIREMENTS

63.8585 By what date must I conduct performance tests?
63.8590 When must I conduct subsequent performance tests?
63.8595 How do I conduct performance tests and establish operating limits?
63.8600 What are my monitoring installation, operation, and maintenance requirements?
63.8605 How do I demonstrate initial compliance with the emission limitations and work practice standards?

CONTINUOUS COMPLIANCE REQUIREMENTS

63.8615 How do I monitor and collect data to demonstrate continuous compliance?
63.8620 How do I demonstrate continuous compliance with the emission limitations and work practice standards?

NOTIFICATIONS, REPORTS, AND RECORDS

63.8630 What notifications must I submit and when?
63.8635 What reports must I submit and when?
63.8640 What records must I keep?
63.8645 In what form and for how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.8655 What parts of the General Provisions apply to me?
63.8660 Who implements and enforces this subpart?
63.8665 What definitions apply to this subpart?
TABLE 1 TO SUBPART KKKKK OF PART 63—EMISSION LIMITS
TABLE 2 TO SUBPART KKKKK OF PART 63—OPERATING LIMITS
TABLE 3 TO SUBPART KKKKK OF PART 63—WORK PRACTICE STANDARDS
TABLE 4 TO SUBPART KKKKK OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS
TABLE 5 TO SUBPART KKKKK OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS AND WORK PRACTICE STANDARDS
TABLE 6 TO SUBPART KKKKK OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITATIONS AND WORK PRACTICE STANDARDS
TABLE 7 TO SUBPART KKKKK OF PART 63—REQUIREMENTS FOR REPORTS
TABLE 8 TO SUBPART KKKKK OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART KKKKK

Subpart LLLLL—National Emission Standards for Hazardous Air Pollutants: Asphalt Processing and Asphalt Roofing Manufacturing

WHAT THIS SUBPART COVERS

63.8680 What is the purpose of this subpart?
63.8681 Am I subject to this subpart?
63.8682 What parts of my plant does this subpart cover?
63.8683 When must I comply with this subpart?

EMISSION LIMITATIONS

63.8684 What emission limitations must I meet?

GENERAL COMPLIANCE REQUIREMENTS

63.8685 What are my general requirements for complying with this subpart?

TESTING AND INITIAL COMPLIANCE REQUIREMENTS

63.8686 By what date must I conduct performance tests or other initial compliance demonstrations?
63.8687 What performance tests, design evaluations, and other procedures must I use?
63.8688 What are my monitoring installation, operation, and maintenance requirements?
63.8689 How do I demonstrate initial compliance with the emission limitations?

CONTINUOUS COMPLIANCE REQUIREMENTS

63.8690 How do I monitor and collect data to demonstrate continuous compliance?
63.8691 How do I demonstrate continuous compliance with the operating limits?

NOTIFICATIONS, REPORTS, AND RECORDS

63.8692 What notifications must I submit and when?
63.8693 What reports must I submit and when?
63.8694 What records must I keep?
63.8695 In what form and how long must I keep my records?

OTHER REQUIREMENTS AND INFORMATION

63.8696 What parts of the General Provisions apply to me?
63.8697 Who implements and enforces this subpart?

63.8698 What definitions apply to this subpart?
TABLE 1 TO SUBPART LLLLL OF PART 63—EMISSION LIMITATIONS
TABLE 2 TO SUBPART LLLLL OF PART 63—OPERATING LIMITS
TABLE 3 TO SUBPART LLLLL OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS
TABLE 4 TO SUBPART LLLLL OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS
TABLE 5 TO SUBPART LLLLL OF PART 63—CONTINUOUS COMPLIANCE WITH OPERATING LIMITS
TABLE 6 TO SUBPART LLLLL OF PART 63—REQUIREMENTS FOR REPORTS
TABLE 7 TO SUBPART LLLLL OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART LLLLL

Subpart MMMMM—National Emission Standards for Hazardous Air Pollutants: Flexible Polyurethane Foam Fabrication Operations

WHAT THIS SUBPART COVERS
63.8780 What is the purpose of this subpart?
63.8782 Am I subject to this subpart?
63.8784 What parts of my plant does this subpart cover?
63.8786 When do I have to comply with this subpart?
EMISSION LIMITATIONS
63.8790 What emission limitations must I meet?
GENERAL COMPLIANCE REQUIREMENTS
63.8794 What are my general requirements for complying with this subpart?
TESTING AND INITIAL COMPLIANCE REQUIREMENTS
63.8798 By what date must I conduct performance tests or other initial compliance demonstrations?
63.8800 What performance tests and other procedures must I use to demonstrate compliance with the emission limit for flame lamination?
63.8802 What methods must I use to demonstrate compliance with the emission limitation for loop slitter adhesive use?
63.8806 How do I demonstrate initial compliance with the emission limitations?
CONTINUOUS COMPLIANCE REQUIREMENTS
63.8810 How do I monitor and collect data to demonstrate continuous compliance?
63.8812 How do I demonstrate continuous compliance with the emission limitations?
NOTIFICATIONS, REPORTS, AND RECORDS
63.8816 What notifications must I submit and when?
63.8818 What reports must I submit and when?
63.8820 What records must I keep?
63.8822 In what form and how long must I keep my records?
OTHER REQUIREMENTS AND INFORMATION
63.8826 What parts of the General Provisions apply to me?
63.8828 Who implements and enforces this subpart?
63.8830 What definitions apply to this subpart?
TABLE 1 TO SUBPART MMMMM OF PART 63—EMISSION LIMITS
TABLE 2 TO SUBPART MMMMM OF PART 63—OPERATING LIMITS FOR NEW OR RECONSTRUCTED FLAME LAMINATION AFFECTED SOURCES
TABLE 3 TO SUBPART MMMMM OF PART 63—PERFORMANCE TEST REQUIREMENTS FOR NEW OR RECONSTRUCTED FLAME LAMINATION AFFECTED SOURCES
TABLE 4 TO SUBPART MMMMM OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITS
TABLE 5 TO SUBPART MMMMM OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITS AND OPERATING LIMITS
TABLE 6 TO SUBPART MMMMM OF PART 63—REQUIREMENTS FOR REPORTS
TABLE 7 TO SUBPART MMMMM OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART MMMMM

AUTHORITY: 42 U.S.C. 7401 *et seq.*

SOURCE: 57 FR 61992, Dec. 29, 1992, unless otherwise noted.

Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

SOURCE: 69 FR 33506, June 15, 2004, unless otherwise noted.

WHAT THIS SUBPART COVERS

§ 63.6580 What is the purpose of subpart ZZZZ?

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major sources

of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.

§ 63.6585 Am I subject to this subpart?

You are subject to this subpart if you own or operate a stationary RICE at a major source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

(a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

(b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.

§ 63.6590 What parts of my plant does this subpart cover?

This subpart applies to each affected source.

(a) *Affected source.* An affected source is any existing, new, or reconstructed stationary RICE with a site-rating of more than 500 brake horsepower located at a major source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

(1) *Existing stationary RICE.* A stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002. A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) *New stationary RICE.* A stationary RICE is new if you commenced construction of the stationary RICE on or after December 19, 2002.

(3) *Reconstructed stationary RICE.* A stationary RICE is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after December 19, 2002.

(b) *Stationary RICE subject to limited requirements.* (1) An affected source which meets either of the criteria in paragraph (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of § 63.6645(d).

(i) The stationary RICE is a new or reconstructed emergency stationary RICE; or

(ii) The stationary RICE is a new or reconstructed limited use stationary RICE.

(2) A new or reconstructed stationary RICE which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis must meet the initial notification requirements of § 63.6645(d) and the requirements of §§ 63.6625(c), 63.6650(g), and 63.6655(c). These stationary RICE do not have to meet the emission limitations and operating limitations of this subpart.

(3) A stationary RICE which is an existing spark ignition 2 stroke lean burn (2SLB) stationary RICE, an existing spark ignition 4 stroke lean burn (4SLB) stationary RICE, an existing compression ignition (CI) stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, does not have to meet the requirements of this subpart and of subpart A of this part. No initial notification is necessary.

§ 63.6595 When do I have to comply with this subpart?

(a) *Affected sources.* (1) If you have an existing stationary RICE, you must comply with the applicable emission limitations and operating limitations no later than June 15, 2007.

(2) If you start up your new or reconstructed stationary RICE before August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart no later than August 16, 2004.

(3) If you start up your new or reconstructed stationary RICE after August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(b) *Area sources that become major sources.* If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b)(1) and (2) of this section apply to you.

(1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.

(2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with this subpart within 3 years after your area source becomes a major source of HAP.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in §63.6645 and in 40 CFR part 63, subpart A.

EMISSION AND OPERATING LIMITATIONS

§63.6600 What emission limitations and operating limitations must I meet?

(a) If you own or operate an existing, new, or reconstructed spark ignition 4 stroke rich burn (4SRB) stationary RICE located at a major source of HAP emissions, you must comply with the emission limitations in Table 1a of this subpart and the operating limitations in Table 1b of this subpart which apply to you.

(b) If you own or operate a new or reconstructed 2SLB or 4SLB stationary RICE or a new or reconstructed CI stationary RICE located at a major source of HAP emissions, you must comply with the emission limitations in Table 2a of this subpart and the operating limitations in Table 2b of this subpart which apply to you.

(c) If you own or operate: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, or an existing CI stationary RICE; a stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis; an emergency stationary RICE; or a limited use stationary RICE, you do not need to comply with the emission limitations in Tables 1a and 2a of this subpart or operating limitations in Tables 1b and 2b of this subpart.

GENERAL COMPLIANCE REQUIREMENTS

§63.6605 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limitations and operating limitations in this subpart that apply to you at all times, except during periods of startup, shutdown, and malfunction.

(b) If you must comply with emission limitations and operating limitations, you must operate and maintain your stationary RICE, including air pollution control and monitoring equipment, in a manner consistent with good air pollution control practices for minimizing emissions at all times, including during startup, shutdown, and malfunction.

TESTING AND INITIAL COMPLIANCE REQUIREMENTS

§63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations?

(a) You must conduct the initial performance test or other initial compliance demonstrations in Table 4 of this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in §63.6595 and according to the provisions in §63.7(a)(2).

(b) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you must demonstrate initial compliance with either the proposed emission limitations or the promulgated emission limitations no later than February 10, 2005 or no later than 180 days after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

(c) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, and you chose to comply with the proposed emission

limitations when demonstrating initial compliance, you must conduct a second performance test to demonstrate compliance with the promulgated emission limitations by December 13, 2007 or after startup of the source, whichever is later, according to § 63.7(a)(2)(ix).

(d) An owner or operator is not required to conduct an initial performance test on units for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (d)(1) through (5) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

(2) The test must not be older than 2 years.

(3) The test must be reviewed and accepted by the Administrator.

(4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

(5) The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load.

§ 63.6615 When must I conduct subsequent performance tests?

If you must comply with the emission limitations and operating limitations, you must conduct subsequent performance tests as specified in Table 3 of this subpart.

§ 63.6620 What performance tests and other procedures must I use?

(a) You must conduct each performance test in Tables 3 and 4 of this subpart that applies to you.

(b) Each performance test must be conducted according to the requirements in § 63.7(e)(1) and under the specific conditions that this subpart specifies in Table 4. The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load.

(c) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in § 63.7(e)(1).

(d) You must conduct three separate test runs for each performance test required in this section, as specified in § 63.7(e)(3). Each test run must last at least 1 hour.

(e)(1) You must use Equation 1 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \qquad \text{(Eq. 1)}$$

Where:

C_i = concentration of CO or formaldehyde at the control device inlet,

C_o = concentration of CO or formaldehyde at the control device outlet, and

R = percent reduction of CO or formaldehyde emissions.

(2) You must normalize the carbon monoxide (CO) or formaldehyde concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen, or an equivalent percent carbon dioxide (CO_2). If pollutant concentrations are to be corrected to 15 percent oxygen and CO_2 concentration is measured in lieu of oxygen concentration measurement, a CO_2 correction factor is needed. Calculate the CO_2 correction factor as described in paragraphs (e)(2)(i) through (iii) of this section.

(i) Calculate the fuel-specific F_o value for the fuel burned during the test using values obtained from Method 19, section 5.2, and the following equation:

$$F_o = \frac{0.209\ F_d}{F_c} \qquad \text{(Eq. 2)}$$

Where:

F_o = Fuel factor based on the ratio of oxygen volume to the ultimate CO_2 volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is oxygen, percent/100.

F_d = Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19, dsm^3/J ($dscf/10^6$ Btu).

F_c = Ratio of the volume of CO_2 produced to the gross calorific value of the fuel from Method 19, dsm^3/J ($dscf/10^6$ Btu).

(ii) Calculate the CO_2 correction factor for correcting measurement data to 15 percent oxygen, as follows:

$$X_{co_2} = \frac{5.9}{F_o} \qquad \text{(Eq. 3)}$$

Where:

X_{co2} = CO_2 correction factor, percent.

5.9 = 20.9 percent O_2 − 15 percent O_2, the defined O_2 correction value, percent.

(iii) Calculate the NO_X and SO_2 gas concentrations adjusted to 15 percent O_2 using CO_2 as follows:

$$C_{adj} = C_d \frac{X_{co_2}}{\%CO_2} \qquad \text{(Eq. 4)}$$

Where:

$\%CO_2$ = Measured CO_2 concentration measured, dry basis, percent.

(f) If you comply with the emission limitation to reduce CO and you are not using an oxidation catalyst, if you comply with the emission limitation to reduce formaldehyde and you are not using NSCR, or if you comply with the emission limitation to limit the concentration of formaldehyde in the stationary RICE exhaust and you are not using an oxidation catalyst or NSCR, you must petition the Administrator for operating limitations to be established during the initial performance test and continuously monitored thereafter; or for approval of no operating limitations. You must not conduct the initial performance test until after the petition has been approved by the Administrator.

(g) If you petition the Administrator for approval of operating limitations, your petition must include the information described in paragraphs (g)(1) through (5) of this section.

(1) Identification of the specific parameters you propose to use as operating limitations;

(2) A discussion of the relationship between these parameters and HAP emissions, identifying how HAP emissions change with changes in these parameters, and how limitations on these parameters will serve to limit HAP emissions;

(3) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;

(4) A discussion identifying the methods you will use to measure and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and

(5) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.

(h) If you petition the Administrator for approval of no operating limitations, your petition must include the information described in paragraphs (h)(1) through (7) of this section.

(1) Identification of the parameters associated with operation of the stationary RICE and any emission control device which could change intentionally (*e.g.*, operator adjustment, automatic controller adjustment, etc.) or unintentionally (*e.g.*, wear and tear, error, etc.) on a routine basis or over time;

(2) A discussion of the relationship, if any, between changes in the parameters and changes in HAP emissions;

(3) For the parameters which could change in such a way as to increase HAP emissions, a discussion of whether establishing limitations on the parameters would serve to limit HAP emissions;

(4) For the parameters which could change in such a way as to increase HAP emissions, a discussion of how you could establish upper and/or lower values for the parameters which would establish limits on the parameters in operating limitations;

(5) For the parameters, a discussion identifying the methods you could use to measure them and the instruments you could use to monitor them, as well as the relative accuracy and precision of the methods and instruments;

(6) For the parameters, a discussion identifying the frequency and methods for recalibrating the instruments you could use to monitor them; and

(7) A discussion of why, from your point of view, it is infeasible or unreasonable to adopt the parameters as operating limitations.

(i) The engine percent load during a performance test must be determined by documenting the calculations, assumptions, and measurement devices used to measure or estimate the percent load in a specific application. A written report of the average percent

load determination must be included in the notification of compliance status. The following information must be included in the written report: the engine model number, the engine manufacturer, the year of purchase, the manufacturer's site-rated brake horsepower, the ambient temperature, pressure, and humidity during the performance test, and all assumptions that were made to estimate or calculate percent load during the performance test must be clearly explained. If measurement devices such as flow meters, kilowatt meters, beta analyzers, stain gauges, etc. are used, the model number of the measurement device, and an estimate of its accurate in percentage of true value must be provided.

§ 63.6625 What are my monitoring, installation, operation, and maintenance requirements?

(a) If you elect to install a CEMS as specified in Table 5 of this subpart, you must install, operate, and maintain a CEMS to monitor CO and either oxygen or CO_2 at both the inlet and the outlet of the control device according to the requirements in paragraphs (a)(1) through (4) of this section.

(1) Each CEMS must be installed, operated, and maintained according to the applicable performance specifications of 40 CFR part 60, appendix B.

(2) You must conduct an initial performance evaluation and an annual relative accuracy test audit (RATA) of each CEMS according to the requirements in § 63.8 and according to the applicable performance specifications of 40 CFR part 60, appendix B as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.

(3) As specified in § 63.8(c)(4)(ii), each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. You must have at least two data points, with each representing a different 15-minute period, to have a valid hour of data.

(4) The CEMS data must be reduced as specified in § 63.8(g)(2) and recorded in parts per million or parts per billion (as appropriate for the applicable limitation) at 15 percent oxygen or the equivalent CO_2 concentration.

(b) If you are required to install a continuous parameter monitoring system (CPMS) as specified in Table 5 of this subpart, you must install, operate, and maintain each CPMS according to the requirements in § 63.8.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must monitor and record your fuel usage daily with separate fuel meters to measure the volumetric flow rate of each fuel. In addition, you must operate your stationary RICE in a manner which reasonably minimizes HAP emissions.

§ 63.6630 How do I demonstrate initial compliance with the emission limitations and operating limitations?

(a) You must demonstrate initial compliance with each emission and operating limitation that applies to you according to Table 5 of this subpart.

(b) During the initial performance test, you must establish each operating limitation in Tables 1b and 2b of this subpart that applies to you.

(c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in § 63.6645.

CONTINUOUS COMPLIANCE REQUIREMENTS

§ 63.6635 How do I monitor and collect data to demonstrate continuous compliance?

(a) If you must comply with emission and operating limitations, you must monitor and collect data according to this section.

(b) Except for monitor malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), you must monitor continuously at all times that the stationary RICE is operating.

(c) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels. You

must, however, use all the valid data collected during all other periods.

§ 63.6640 How do I demonstrate continuous compliance with the emission limitations and operating limitations?

(a) You must demonstrate continuous compliance with each emission limitation and operating limitation in Tables 1a and 1b and Tables 2a and 2b of this subpart that apply to you according to methods specified in Table 6 of this subpart.

(b) You must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b and Tables 2a and 2b of this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in §63.6650. If you change your catalyst, you must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE.

(c) [Reserved]

(d) Consistent with §§63.6(e) and 63.7(e)(1), deviations from the emission or operating limitations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with §63.6(e)(1). For new, reconstructed, and rebuilt stationary RICE, deviations from the emission or operating limitations that occur during the first 200 hours of operation from engine startup (engine burn-in period) are not violations.

Rebuilt stationary RICE means a stationary RICE that has been rebuilt as that term is defined in 40 CFR §94.11(a).

(e) You must also report each instance in which you did not meet the requirements in Table 8 of this subpart that apply to you. If you own or operate an existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing CI stationary RICE, an existing emergency stationary RICE, an existing limited use emergency stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you do not need to comply with the requirements in Table 8 of this subpart. If you own or operate a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE, you do not need to comply with the requirements in Table 8 of this subpart, except for the initial notification requirements.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006]

NOTIFICATIONS, REPORTS, AND RECORDS

§ 63.6645 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified.

(b) As specified in §63.9(b)(2), if you start up your stationary RICE before the effective date of this subpart, you must submit an Initial Notification not later than December 13, 2004.

(c) If you start up your new or reconstructed stationary RICE on or after August 16, 2004, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(d) If you are required to submit an Initial Notification but are otherwise not affected by the requirements of this subpart, in accordance with §63.6590(b), your notification should include the information in §63.9(b)(2)(i) through (v), and a statement that your stationary RICE has no additional requirements and explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary RICE).

(e) If you are required to conduct a performance test, you must submit a Notification of Intent to conduct a performance test at least 60 days before

the performance test is scheduled to begin as required in § 63.7(b)(1).

(f) If you are required to conduct a performance test or other initial compliance demonstration as specified in Tables 4 and 5 to this subpart, you must submit a Notification of Compliance Status according to § 63.9(h)(2)(ii).

(1) For each initial compliance demonstration required in Table 5 of this subpart that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th day following the completion of the initial compliance demonstration.

(2) For each initial compliance demonstration required in Table 5 of this subpart that includes a performance test conducted according to the requirements in Table 4 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th day following the completion of the performance test according to § 63.10(d)(2).

§ 63.6650 What reports must I submit and when?

(a) You must submit each report in Table 7 of this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (5) of this section.

(1) The first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on June 30 or December 31, whichever date is the first date following the end of the first calendar half after the compliance date that is specified for your source in § 63.6595.

(2) The first Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first calendar half after the compliance date that is specified for your affected source in § 63.6595.

(3) Each subsequent Compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(5) For each stationary RICE that is subject to permitting regulations pursuant to 40 CFR part 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6 (a)(3)(iii)(A) or 40 CFR 71.6 (a)(3)(iii)(A), you may submit the first and subsequent Compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (4) of this section.

(c) The Compliance report must contain the information in paragraphs (c)(1) through (6) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with that official's name, title, and signature, certifying the accuracy of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a startup, shutdown, or malfunction during the reporting period, the compliance report must include the information in § 63.10(d)(5)(i).

(5) If there are no deviations from any emission or operating limitations that apply to you, a statement that there were no deviations from the emission or operating limitations during the reporting period.

(6) If there were no periods during which the continuous monitoring system (CMS), including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), a statement that there were no periods during which the CMS was out-of-control during the reporting period.

(d) For each deviation from an emission or operating limitation that occurs for a stationary RICE where you are not using a CMS to comply with the emission or operating limitations in this subpart, the Compliance report must contain the information in paragraphs (c)(1) through (4) of this section

and the information in paragraphs (d)(1) and (2) of this section.

(1) The total operating time of the stationary RICE at which the deviation occurred during the reporting period.

(2) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(e) For each deviation from an emission or operating limitation occurring for a stationary RICE where you are using a CMS to comply with the emission and operating limitations in this subpart, you must include information in paragraphs (c)(1) through (4) and (e)(1) through (12) of this section.

(1) The date and time that each malfunction started and stopped.

(2) The date, time, and duration that each CMS was inoperative, except for zero (low-level) and high-level checks.

(3) The date, time, and duration that each CMS was out-of-control, including the information in §63.8(c)(8).

(4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of malfunction or during another period.

(5) A summary of the total duration of the deviation during the reporting period, and the total duration as a percent of the total source operating time during that reporting period.

(6) A breakdown of the total duration of the deviations during the reporting period into those that are due to control equipment problems, process problems, other known causes, and other unknown causes.

(7) A summary of the total duration of CMS downtime during the reporting period, and the total duration of CMS downtime as a percent of the total operating time of the stationary RICE at which the CMS downtime occurred during that reporting period.

(8) An identification of each parameter and pollutant (CO or formaldehyde) that was monitored at the stationary RICE.

(9) A brief description of the stationary RICE.

(10) A brief description of the CMS.

(11) The date of the latest CMS certification or audit.

(12) A description of any changes in CMS, processes, or controls since the last reporting period.

(f) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6 (a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a Compliance report pursuant to Table 7 of this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the Compliance report includes all required information concerning deviations from any emission or operating limitation in this subpart, submission of the Compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a Compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority.

(g) If you are operating as a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must submit an annual report according to Table 7 of this subpart by the date specified unless the Administrator has approved a different schedule, according to the information described in paragraphs (b)(1) through (b)(5) of this section. You must report the data specified in (g)(1) through (g)(3) of this section.

(1) Fuel flow rate of each fuel and the heating values that were used in your calculations. You must also demonstrate that the percentage of heat input provided by landfill gas or digester gas is equivalent to 10 percent or more of the total fuel consumption on an annual basis.

(2) The operating limits provided in your federally enforceable permit, and any deviations from these limits.

(3) Any problems or errors suspected with the meters.

§ 63.6655 What records must I keep?

(a) If you must comply with the emission and operating limitations, you must keep the records described in paragraphs (a)(1) through (a)(3), (b)(1) through (b)(3) and (c) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in § 63.10(b)(2)(xiv).

(2) The records in § 63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.

(3) Records of performance tests and performance evaluations as required in § 63.10(b)(2)(viii).

(b) For each CEMS or CPMS, you must keep the records listed in paragraphs (b)(1) through (3) of this section.

(1) Records described in § 63.10(b)(2)(vi) through (xi).

(2) Previous (*i.e.*, superseded) versions of the performance evaluation plan as required in § 63.8(d)(3).

(3) Requests for alternatives to the relative accuracy test for CEMS or CPMS as required in § 63.8(f)(6)(i), if applicable.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must keep the records of your daily fuel usage monitors.

(d) You must keep the records required in Table 6 of this subpart to show continuous compliance with each emission or operating limitation that applies to you.

§ 63.6660 In what form and how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record readily accessible in hard copy or electronic form on-site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1). You can keep the records off-site for the remaining 3 years.

Other Requirements and Information

§ 63.6665 What parts of the General Provisions apply to me?

Table 8 of this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you. If you own or operate an existing 2SLB, an existing 4SLB stationary RICE, an existing CI stationary RICE, an existing stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency stationary RICE, or an existing limited use stationary RICE, you do not need to comply with any of the requirements of the General Provisions. If you own or operate a new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE, you do not need to comply with the requirements in the General Provisions except for the initial notification requirements.

§ 63.6670 Who implements and enforces this subpart?

(a) This subpart is implemented and enforced by the U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency (as well as the U.S. EPA) has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out whether this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are:

(1) Approval of alternatives to the non-opacity emission limitations and operating limitations in §63.6600 under §63.6(g).

(2) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90.

(3) Approval of major alternatives to monitoring under §63.8(f) and as defined in §63.90.

(4) Approval of major alternatives to recordkeeping and reporting under §63.10(f) and as defined in §63.90.

(5) Approval of a performance test which was conducted prior to the effective date of the rule, as specified in §63.6610(b).

§63.6675 What definitions apply to this subpart?

Terms used in this subpart are defined in the Clean Air Act (CAA); in 40 CFR 63.2, the General Provisions of this part; and in this section as follows:

Area source means any stationary source of HAP that is not a major source as defined in part 63.

Associated equipment as used in this subpart and as referred to in section 112(n)(4) of the CAA, means equipment associated with an oil or natural gas exploration or production well, and includes all equipment from the well bore to the point of custody transfer, except glycol dehydration units, storage vessels with potential for flash emissions, combustion turbines, and stationary RICE.

CAA means the Clean Air Act (42 U.S.C. 7401 *et seq.*, as amended by Public Law 101–549, 104 Stat. 2399).

Compression ignition engine means any stationary RICE in which a high boiling point liquid fuel injected into the combustion chamber ignites when the air charge has been compressed to a temperature sufficiently high for auto-ignition, including diesel engines, dual-fuel engines, and engines that are not spark ignition.

Custody transfer means the transfer of hydrocarbon liquids or natural gas: After processing and/or treatment in the producing operations, or from storage vessels or automatic transfer facilities or other such equipment, including product loading racks, to pipelines or any other forms of transportation. For the purposes of this subpart, the point at which such liquids or natural gas enters a natural gas processing plant is a point of custody transfer.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emission limitation or operating limitation;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or

(3) Fails to meet any emission limitation or operating limitation in this subpart during malfunction, regardless or whether or not such failure is permitted by this subpart.

(4) Fails to satisfy the general duty to minimize emissions established by §63.6(e)(1)(i).

Diesel engine means any stationary RICE in which a high boiling point liquid fuel injected into the combustion chamber ignites when the air charge has been compressed to a temperature sufficiently high for auto-ignition. This process is also known as compression ignition.

Diesel fuel means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is fuel oil number 2.

Digester gas means any gaseous by-product of wastewater treatment typically formed through the anaerobic decomposition of organic waste materials and composed principally of methane and CO_2.

Dual-fuel engine means any stationary RICE in which a liquid fuel (typically diesel fuel) is used for compression ignition and gaseous fuel (typically natural gas) is used as the primary fuel.

Emergency stationary RICE means any stationary RICE that operates in an emergency situation. Examples include stationary RICE used to produce power

for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility is interrupted, or stationary RICE used to pump water in the case of fire or flood, etc. Emergency stationary RICE may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by the manufacturer, the vendor, or the insurance company associated with the engine. Required testing of such units should be minimized, but there is no time limit on the use of emergency stationary RICE in emergency situations and for routine testing and maintenance. Emergency stationary RICE may also operate an additional 50 hours per year in non-emergency situations.

Four-stroke engine means any type of engine which completes the power cycle in two crankshaft revolutions, with intake and compression strokes in the first revolution and power and exhaust strokes in the second revolution.

Gaseous fuel means a material used for combustion which is in the gaseous state at standard atmospheric temperature and pressure conditions.

Glycol dehydration unit means a device in which a liquid glycol (including, but not limited to, ethylene glycol, diethylene glycol, or triethylene glycol) absorbent directly contacts a natural gas stream and absorbs water in a contact tower or absorption column (absorber). The glycol contacts and absorbs water vapor and other gas stream constituents from the natural gas and becomes ''rich'' glycol. This glycol is then regenerated in the glycol dehydration unit reboiler. The ''lean'' glycol is then recycled.

Hazardous air pollutants (HAP) means any air pollutants listed in or pursuant to section 112(b) of the CAA.

ISO standard day conditions means 288 degrees Kelvin (15 degrees Celsius), 60 percent relative humidity and 101.3 kilopascals pressure.

Landfill gas means a gaseous by-product of the land application of municipal refuse typically formed through the anaerobic decomposition of waste materials and composed principally of methane and CO_2.

Lean burn engine means any two-stroke or four-stroke spark ignited engine that does not meet the definition of a rich burn engine.

Limited use stationary RICE means any stationary RICE that operates less than 100 hours per year.

Liquefied petroleum gas means any liquefied hydrocarbon gas obtained as a by-product in petroleum refining of natural gas production.

Liquid fuel means any fuel in liquid form at standard temperature and pressure, including but not limited to diesel, residual/crude oil, kerosene/naphtha (jet fuel), and gasoline.

Major Source, as used in this subpart, shall have the same meaning as in § 63.2, except that:

(1) Emissions from any oil or gas exploration or production well (with its associated equipment (as defined in this section)) and emissions from any pipeline compressor station or pump station shall not be aggregated with emissions from other similar units, to determine whether such emission points or stations are major sources, even when emission points are in a contiguous area or under common control;

(2) For oil and gas production facilities, emissions from processes, operations, or equipment that are not part of the same oil and gas production facility, as defined in § 63.1271 of subpart HHH of this part, shall not be aggregated;

(3) For production field facilities, only HAP emissions from glycol dehydration units, storage vessel with the potential for flash emissions, combustion turbines and reciprocating internal combustion engines shall be aggregated for a major source determination; and

(4) Emissions from processes, operations, and equipment that are not part of the same natural gas transmission and storage facility, as defined in § 63.1271 of subpart HHH of this part, shall not be aggregated.

Malfunction means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner which causes, or has the potential to cause, the emission limitations in an applicable standard to be exceeded.

Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

Natural gas means a naturally occurring mixture of hydrocarbon and non-hydrocarbon gases found in geologic formations beneath the Earth's surface, of which the principal constituent is methane. May be field or pipeline quality.

Non-selective catalytic reduction (NSCR) means an add-on catalytic nitrogen oxides (NO_X) control device for rich burn engines that, in a two-step reaction, promotes the conversion of excess oxygen, NO_X, CO, and volatile organic compounds (VOC) into CO_2, nitrogen, and water.

Oil and gas production facility as used in this subpart means any grouping of equipment where hydrocarbon liquids are processed, upgraded (*i.e.*, remove impurities or other constituents to meet contract specifications), or stored prior to the point of custody transfer; or where natural gas is processed, upgraded, or stored prior to entering the natural gas transmission and storage source category. For purposes of a major source determination, facility (including a building, structure, or installation) means oil and natural gas production and processing equipment that is located within the boundaries of an individual surface site as defined in this section. Equipment that is part of a facility will typically be located within close proximity to other equipment located at the same facility. Pieces of production equipment or groupings of equipment located on different oil and gas leases, mineral fee tracts, lease tracts, subsurface or surface unit areas, surface fee tracts, surface lease tracts, or separate surface sites, whether or not connected by a road, waterway, power line or pipeline, shall not be considered part of the same facility. Examples of facilities in the oil and natural gas production source category include, but are not limited to, well sites, satellite tank batteries, central tank batteries, a compressor station that transports natural gas to a natural gas processing plant, and natural gas processing plants.

Oxidation catalyst means an add-on catalytic control device that controls CO and VOC by oxidation.

Peaking unit or engine means any standby engine intended for use during periods of high demand that are not emergencies.

Percent load means the fractional power of an engine compared to its maximum manufacturer's design capacity at engine site conditions. Percent load may range between 0 percent to above 100 percent.

Potential to emit means the maximum capacity of a stationary source to emit a pollutant under its physical and operational design. Any physical or operational limitation on the capacity of the stationary source to emit a pollutant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design if the limitation or the effect it would have on emissions is federally enforceable. For oil and natural gas production facilities subject to subpart HH of this part, the potential to emit provisions in §63.760(a) may be used. For natural gas transmission and storage facilities subject to subpart HHH of this part, the maximum annual facility gas throughput for storage facilities may be determined according to §63.1270(a)(1) and the maximum annual throughput for transmission facilities may be determined according to §63.1270(a)(2).

Production field facility means those oil and gas production facilities located prior to the point of custody transfer.

Production well means any hole drilled in the earth from which crude oil, condensate, or field natural gas is extracted.

Propane means a colorless gas derived from petroleum and natural gas, with the molecular structure C_3H_8.

Responsible official means responsible official as defined in 40 CFR 70.2.

Rich burn engine means any four-stroke spark ignited engine where the manufacturer's recommended operating air/fuel ratio divided by the stoichiometric air/fuel ratio at full load conditions is less than or equal to 1.1. Engines originally manufactured as

rich burn engines, but modified prior to December 19, 2002 with passive emission control technology for NO_X (such as pre-combustion chambers) will be considered lean burn engines. Also, existing engines where there are no manufacturer's recommendations regarding air/fuel ratio will be considered a rich burn engine if the excess oxygen content of the exhaust at full load conditions is less than or equal to 2 percent.

Site-rated HP means the maximum manufacturer's design capacity at engine site conditions.

Spark ignition engine means a type of engine in which a compressed air/fuel mixture is ignited by a timed electric spark generated by a spark plug.

Stationary reciprocating internal combustion engine (RICE) means any reciprocating internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a nonroad engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

Stationary RICE test cell/stand means an engine test cell/stand, as defined in subpart PPPPP of this part, that tests stationary RICE.

Stoichiometric means the theoretical air-to-fuel ratio required for complete combustion.

Storage vessel with the potential for flash emissions means any storage vessel that contains a hydrocarbon liquid with a stock tank gas-to-oil ratio equal to or greater than 0.31 cubic meters per liter and an American Petroleum Institute gravity equal to or greater than 40 degrees and an actual annual average hydrocarbon liquid throughput equal to or greater than 79,500 liters per day. Flash emissions occur when dissolved hydrocarbons in the fluid evolve from solution when the fluid pressure is reduced.

Subpart means 40 CFR part 63, subpart ZZZZ.

Surface site means any combination of one or more graded pad sites, gravel pad sites, foundations, platforms, or the immediate physical location upon which equipment is physically affixed.

Two-stroke engine means a type of engine which completes the power cycle in single crankshaft revolution by combining the intake and compression operations into one stroke and the power and exhaust operations into a second stroke. This system requires auxiliary scavenging and inherently runs lean of stoichiometric.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006]

TABLE 1a TO SUBPART ZZZZ OF PART 63—EMISSION LIMITATIONS FOR EXISTING, NEW, AND RECONSTRUCTED SPARK IGNITION, 4SRB STATIONARY RICE

[As stated in §§ 63.6600 and 63.6640, you must comply with the following emission limitations for existing, new and reconstructed 4SRB stationary RICE at 100 percent load plus or minus 10 percent]

For each . . .	You must meet *one* of the following emission limitations . . .
1. 4SRB RICE	a. Reduce formaldehyde emissions by 76 percent or more. If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may reduce formaldehyde emissions by 75 percent or more until June 15, 2007, or b. Limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O_2.

TABLE 1b TO SUBPART ZZZZ OF PART 63—OPERATING LIMITATIONS FOR EXISTING, NEW, AND RECONSTRUCTED SPARK IGNITION, 4SRB STATIONARY RICE

[As stated in §§ 63.6600, 63.6630 and 63.6640, you must comply with the following operating emission limitations for existing, new and reconstructed 4SRB stationary RICE]

For each . . .	You must meet the following emission limitation . . .
1. 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and using NSCR; or 4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O_2 and using NSCR.	a. Maintain your catalyst so that the pressure drop across the catalyst does not change by more than two inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst measured during the initial performance test; and b. Maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 750 °F and less than or equal to 1250 °F.
2. 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent if applicable) and not using NSCR; or 4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O_2 and not using NSCR.	Comply with any operating limitations approved by the Administrator.

TABLE 2a TO SUBPART ZZZZ OF PART 63—EMISSION LIMITATIONS FOR NEW AND RECONSTRUCTED LEAN BURN AND COMPRESSION IGNITION STATIONARY RICE

[As stated in §§ 63.6600 and 63.6640, you must comply with the following emission limitations for new and reconstructed lean burn and new and reconstructed compression ignition stationary RICE at 100 percent load plus or minus 10 percent]

For each . . .	You must meet the following emission limitation . . .
1. 2SLB stationary RICE	a. Reduce CO emissions by 58 percent or more; or b. Limit concentration of formaldehyde in the stationary RICE exhaust to 12 ppmvd or less at 15 percent O_2. If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may limit concentration of formaldehyde to 17 ppmvd or less at 15 percent O_2 until June 15, 2007.
2. 4SLB stationary RICE	a. Reduce CO emissions by 93 percent or more; or b. Limit concentration of formaldehyde in the stationary RICE exhaust to 14 ppmvd or less at 15 percent O_2.
3. CI stationary RICE	a. Reduce CO emissions by 70 percent or more; or b. Limit concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 percent O_2.

TABLE 2b TO SUBPART ZZZZ OF PART 63—OPERATING LIMITATIONS FOR NEW AND RECONSTRUCTED LEAN BURN AND COMPRESSION IGNITION STATIONARY RICE

[As stated in §§ 63.6600, 63.6630, and 63.6640, you must comply with the following operating limitations for new and reconstructed lean burn and new and reconstructed compression ignition stationary RICE]

For each . . .	You must meet the following operating limitation . . .
1. 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to reduce CO emissions and using an oxidation catalyst; or 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and using an oxidation catalyst.	a. Maintain your catalyst so that the pressure drop across the catalyst does not change by more than two inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst that was measured during the initial performance test; and b. Maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 °F.
2. 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to reduce CO emissions and not using an oxidation catalyst; or 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and not using an oxidation catalyst.	Comply with any operating limitations approved by the Administrator.

TABLE 3 TO SUBPART ZZZZ OF PART 63—SUBSEQUENT PERFORMANCE TESTS

[As stated in §§ 63.6615 and 63.6620, you must comply with the following subsequent performance test requirements]

For each . . .	Complying with the requirement to . . .	You must . . .
1. 2SLB and 4SLB stationary RICE and CI stationary RICE.	Reduce CO emissions and not using a CEMS.	Conduct subsequent performance tests semiannually.[1]
2. 4SRB stationary RICE with a brake horsepower ≥5,000.	Reduce formaldehyde emissions	Conduct subsequent performance tests semiannually.[1]
3. Stationary RICE (all stationary RICE subcategories and all brake horsepower ratings).	Limit the concentration of formaldehyde in the stationary RICE exhaust.	Conduct subsequent performance tests semiannually.[1]

[1] After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

TABLE 4 TO SUBPART ZZZZ OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS

[As stated in §§ 63.6610, 63.6620, and 63.6640, you must comply with the following requirements for performance tests]

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
1. 2SLB and 4SLB stationary RICE and CI stationary RICE.	a. Reduce CO emissions.	i. Measure the O_2 at the inlet and outlet of the control device; and	(1) Portable CO and O_2 analyzer.	(a) Using ASTM D6522–00[1] (incorporated by reference, see § 63.14). Measurements to determine O_2 must be made at the same time as the measurements for CO concentration.
		ii. Measure the CO at the inlet and the outlet of the control device.	(1) Portable CO and O_2 analyzer.	(a) Using ASTM D6522–00[1] (incorporated by reference, see § 63.14). The CO concentration must be at 15 percent O_2, dry basis.
2. 4SRB stationary RICE.	a. Reduce formaldehyde emissions.	i. Select sampling port location and the number of traverse points; and	(1) Method 1 or 1A of 40 CFR part 60 appendix A § 63.7(d)(1)(i).	(a) Sampling sites must be located at the inlet and outlet of the control device.
		ii. Measure O_2 at the inlet and outlet of the control device; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A.	(a) Measurements to determine O_2 concentration must be made at the same time as the measurements for formaldehyde concentration.
		iii. Measure moisture content at the inlet and outlet of the control device; and	(1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03.	(a) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde concentration.
		iv. Measure formaldehyde at the inlet and the outlet of the control device	(1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348–03[2], provided in ASTM D6348–03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130.	(a) Formaldehyde concentration must be at 15 percent O_2, dry basis. Results of this test consist of the average of the three 1-hour or longer runs.

[As stated in §§ 63.6610, 63.6620, and 63.6640, you must comply with the following requirements for performance tests]

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
3. Stationary RICE	a. Limit the concentration of formaldehyde in the stationary RICE exhaust.	i. Select the sampling port location and the number of traverse points; and	(1) Method 1 or 1A of 40 CFR part 60, appendix A § 63.7(d)(1)(i).	(a) If using a control device, the sampling site must be located at the outlet of the control device.
		ii. Determine the O_2 concentration of the stationary RICE exhaust at the sampling port location; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A.	(a) Measurements to determine O_2 concentration must be made at the same time and location as the measurements for formaldehyde concentration.
		iii. Measure moisture content of the stationary RICE exhaust at the sampling port location; and	(1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03.	(a) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde concentration.
		iv. Measure formaldehyde at the exhaust of the stationary RICE.	(1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348–03[2], provided in ASTM D6348–03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130.	(a) Formaldehyde concentration must be at 15 percent O_2, dry basis. Results of this test consist of the average of the three 1-hour or longer runs.

[1] You may also use Methods 3A and 10 as options to ASTM-D6522-00. You may obtain a copy of ASTM-D6522-00 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohochen, PA 19428–2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

[2] You may obtain a copy of ASTM-D6348-03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohochen, PA 19428–2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

TABLE 5 TO SUBPART ZZZZ OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS AND OPERATING LIMITATIONS

[As stated in §§ 63.6625 and 63.6630, you must initially comply with the emission and operating limitations as required by the following]

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
1. 2SLB and 4SLB stationary RICE and CI stationary RICE.	a. Reduce CO emissions and using oxidation catalyst, and using a CPMS.	i. the average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
2. 2SLB and 4SLB stationary RICE and CI stationary RICE.	a. Reduce CO emissions and not using oxidation catalyst.	i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and iii. You have recorded the approved operating parameters (if any) during the initial performance test.

[As stated in §§ 63.6625 and 63.6630, you must initially comply with the emission and operating limitations as required by the following]

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
3. 2SLB and 4SLB stationary RICE and CI stationary RICE.	a. Reduce CO emissions, and using a CEMS.	i. You have installed a CEMS to continuously monitor CO and either O_2 or CO_2 at both the inlet and outlet of the oxidation catalyst according to the requirements in § 63.6625(a); and ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and iii. The average reduction of CO calculated using § 63.6620 equals or exceeds the required percent reduction. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average percent reduction achieved during the 4-hour period.
4. 4SRB stationary RICE	a. Reduce formaldehyde emissions and using NSCR.	i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
5. 4SRB stationary RICE	a. Reduce formaldehyde emissions and not using NSCR.	i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and iii. You have recorded the approved operating parameters (if any) during the initial performance test.
6. Stationary RICE	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR.	i. The average formaldehyde concentration, corrected to 15 percent O_2, dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
7. Stationary RICE	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR.	i. The average formaldehyde concentration, corrected to 15 percent O_2, dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and iii. You have recorded the approved operating parameters (if any) during the initial performance test.

TABLE 6 TO SUBPART ZZZZ OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITATIONS AND OPERATING LIMITATIONS

[As stated in § 63.6640, you must continuously comply with the emissions and operating limitations as required by the following]

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
1. 2SLB and 4SLB stationary RICE and CI stationary RICE.	a. Reduce CO emissions and using an oxidation catalyst, and using a CPMS.	i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved [1]; and ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
2. 2SLB and 4SLB stationary RICE and CI stationary RICE.	a. Reduce CO emissions and not using an oxidation catalyst, and using a CPMS.	i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved [1]; and ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
3. 2SLB and 4SLB stationary RICE and CI stationary RICE.	a. Reduce CO emissions and using a CEMS.	i. Collecting the monitoring data according to § 63.6625(a), reducing the measurements to 1-hour averages, calculating the percent reduction of CO emissions according to § 63.6620; and ii. Demonstrating that the catalyst achieves the required percent reduction of CO emissions over the 4-hour averaging period; and iii. Conducting an annual RATA of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B, as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.
4. 4SRB stationary RICE	a. Reduce formaldehyde emissions and using NSCR.	i. Collecting the catalyst inlet temperature data according to § 63.6625(b); and ii. Reducing these data to 4-hour rolling averages; and iii. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and iv. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
5. 4SRB stationary RICE	a. Reduce formaldehyde emissions and not using NSCR.	i. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and ii. reducing these data to 4-hour rolling averages;

[As stated in § 63.6640, you must continuously comply with the emissions and operating limitations as required by the following]

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
		iii. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
6. 4SRB stationary RICE with a brake horsepower ≥5,000.	Reduce formaldehyde emissions	Conducting semiannual performance tests for formaldehyde to demonstrate that the required formaldehyde percent reduction is achieved [1].
7. Stationary RICE	Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR.	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit [1]; and ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
8. Stationary RICE	Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR.	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit [1]; and ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and ii. Reducing these data to 4-hour rolling averages; and iii. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.

[1] After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

TABLE 7 TO SUBPART ZZZZ OF PART 63—REQUIREMENTS FOR REPORTS

[As stated in § 63.6650, you must comply with the following requirements for reports]

You must submit a(n)	The report must contain . . .	You must submit the report . . .
1. Compliance report	a. If there are no deviations from any emission limitations or operating limitations that apply to you, a statement that there were no deviations from the emission limitations or operating limitations during the reporting period. If there were no periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), a statement that there were not periods during which the CMS was out-of-control during the reporting period; or	i. Semiannually according to the requirements in § 63.6650(b).

[As stated in § 63.6650, you must comply with the following requirements for reports]

You must submit a(n)	The report must contain . . .	You must submit the report . . .
	b. If you had a deviation from any emission limitation or operating limitation during the reporting period, the information in § 63.6650(d). If there were periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), the information in § 63.6650(e); or	i. Semiannually according to the requirements in § 63.6650(b).
	c. If you had a startup, shutdown or malfunction during the reporting period, the information in § 63.10(d)(5)(i).	i. Semiannually according to the requirements in § 63.6650(b).
2. An immediate startup, shutdown, and malfunction report if actions addressing the startup, shutdown, or malfunction were inconsistent with your startup, shutdown, or malfunction plan during the reporting period.	a. Actions taken for the event; and	i. By fax or telephone within 2 working days after starting actions inconsistent with the plan.
	b. The information in § 63.10(d)(5)(ii).	i. By letter within 7 working days after the end of the event unless you have made alternative arrangements with the permitting authorities. (§ 63.10(d)(5)(ii))
3. Report	a. The fuel flow rate of each fuel and the heating values that were used in your calculations, and you must demonstrate that the percentage of heat input provided by landfill gas or digester gas, is equivalent to 10 percent or more of the gross heat input on an annual basis; and	i. Annually, according to the requirements in § 63.6650.
	b. The operating limits provided in your federally enforceable permit, and any deviations from these limits; and	i. See item 3.a.i.
	c. Any problems or errors suspected with the meters.	i. See item 3.a.i.

TABLE 8 TO SUBPART ZZZZ OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART ZZZZ

[As stated in § 63.6665, you must comply with the following applicable general provisions]

General provisions citation	Subject of citation	Applies to subpart	Explanation
§ 63.1	General applicability of the General Provisions.	Yes.	
§ 63.2	Definitions	Yes	Additional terms defined in § 63.6675.
§ 63.3	Units and abbreviations	Yes.	
§ 63.4	Prohibited activities and circumvention.	Yes.	
§ 63.5	Construction and reconstruction	Yes.	
§ 63.6(a)	Applicability	Yes.	
§ 63.6(b)(1)–(4)	Compliance dates for new and reconstructed sources.	Yes.	
§ 63.6(b)(5)	Notification	Yes.	
§ 63.6(b)(6)	[Reserved]		
§ 63.6(b)(7)	Compliance dates for new and reconstructed area sources that become major sources.	Yes.	
§ 63.6(c)(1)–(2)	Compliance dates for existing sources.	Yes.	
§ 63.6(c)(3)–(4)	[Reserved]		
§ 63.6(c)(5)	Compliance dates for existing area sources that become major sources.	Yes.	
§ 63.6(d)	[Reserved]		
§ 63.6(e)(1)	Operation and maintenance	Yes.	
§ 63.6(e)(2)	[Reserved]		
§ 63.6(e)(3)	Startup, shutdown, and malfunction plan.	Yes.	

[As stated in § 63.6665, you must comply with the following applicable general provisions]

General provisions citation	Subject of citation	Applies to subpart	Explanation
§ 63.6(f)(1)	Applicability of standards except during startup shutdown malfunction (SSM).	Yes.	
§ 63.6(f)(2)	Methods for determining compliance.	Yes.	
§ 63.6(f)(3)	Finding of compliance	Yes.	
§ 63.6(g)(1)–(3)	Use of alternate standard	Yes.	
§ 63.6(h)	Opacity and visible emission standards.	No	Subpart ZZZZ does not contain opacity or visible emission standards.
§ 63.6(i)	Compliance extension procedures and criteria.	Yes.	
§ 63.6(j)	Presidential compliance exemption.	Yes.	
§ 63.7(a)(1)–(2)	Performance test dates	Yes	Subpart ZZZZ contains performance test dates at § 63.6610.
§ 63.7(a)(3)	CAA section 114 authority	Yes.	
§ 63.7(b)(1)	Notification of performance test	Yes.	
§ 63.7(b)(2)	Notification of rescheduling	Yes.	
§ 63.7(c)	Quality assurance/test plan	Yes.	
§ 63.7(d)	Testing facilities	Yes.	
§ 63.7(e)(1)	Conditions for conducting performance tests.	Yes.	
§ 63.7(e)(2)	Conduct of performance tests and reduction of data.	Yes	Subpart ZZZZ specifies test methods at § 63.6620.
§ 63.7(e)(3)	Test run duration	Yes.	
§ 63.7(e)(4)	Administrator may require other testing under section 114 of the CAA.	Yes.	
§ 63.7(f)	Alternative test method provisions.	Yes.	
§ 63.7(g)	Performance test data analysis, recordkeeping, and reporting.	Yes.	
§ 63.7(h)	Waiver of tests	Yes.	
§ 63.8(a)(1)	Applicability of monitoring requirements.	Yes	Subpart ZZZZ contains specific requirements for monitoring at § 63.6625.
§ 63.8(a)(2)	Performance specifications	Yes.	
§ 63.8(a)(3)	[Reserved]		
§ 63.8(a)(4)	Monitoring for control devices	No.	
§ 63.8(b)(1)	Monitoring	Yes.	
§ 63.8(b)(2)–(3)	Multiple effluents and multiple monitoring systems.	Yes.	
§ 63.8(c)(1)	Monitoring system operation and maintenance.	Yes.	
§ 63.8(c)(1)(i)	Routine and predictable SSM	Yes.	
§ 63.8(c)(1)(ii)	SSM not in Startup Shutdown Malfunction Plan.	Yes.	
§ 63.8(c)(1)(iii)	Compliance with operation and maintenance requirements.	Yes.	
§ 63.8(c)(2)–(3)	Monitoring system installation	Yes.	
§ 63.8(c)(4)	Continuous monitoring system (CMS) requirements.	Yes	Except that subpart ZZZZ does not require Continuous Opacity Monitoring System (COMS).
§ 63.8(c)(5)	COMS minimum procedures	No	Subpart ZZZZ does not require COMS.
§ 63.8(c)(6)–(8)	CMS requirements	Yes	Except that subpart ZZZZ does not require COMS.
§ 63.8(d)	CMS quality control	Yes.	
§ 63.8(e)	CMS performance evaluation	Yes	Except for § 63.8(e)(5)(ii), which applies to COMS.
§ 63.8(f)(1)–(5)	Alternative monitoring method	Yes.	
§ 63.8(f)(6)	Alternative to relative accuracy test.	Yes.	
§ 63.8(g)	Data reduction	Yes	Except that provisions for COMS are not applicable. Averaging periods for demonstrating compliance are specified at §§ 63.6635 and 63.6640.

[As stated in § 63.6665, you must comply with the following applicable general provisions]

General provisions citation	Subject of citation	Applies to subpart	Explanation
§ 63.9(a)	Applicability and State delegation of notification requirements.	Yes.	
§ 63.9(b)(1)–(5)	Initial notifications	Yes	Except that § 63.9(b)(3) is reserved.
§ 63.9(c)	Request for compliance extension.	Yes.	
§ 63.9(d)	Notification of special compliance requirements for new sources.	Yes.	
§ 63.9(e)	Notification of performance test	Yes.	
§ 63.9(f)	Notification of visible emission (VE)/opacity test.	No	Subpart ZZZZ does not contain opacity or VE standards.
§ 63.9(g)(1)	Notification of performance evaluation.	Yes.	
§ 63.9(g)(2)	Notification of use of COMS data.	No	Subpart ZZZZ does not contain opacity or VE standards.
§ 63.9(g)(3)	Notification that criterion for alternative to RATA is exceeded.	Yes	If alternative is in use.
§ 63.9(h)(1)–(6)	Notification of compliance status	Yes	Except that notifications for sources using a CEMS are due 30 days after completion of performance evaluations. § 63.9(h)(4) is reserved.
§ 63.9(i)	Adjustment of submittal deadlines.	Yes.	
§ 63.9(j)	Change in previous information	Yes.	
§ 63.10(a)	Administrative provisions for record- keeping/reporting.	Yes.	
§ 63.10(b)(1)	Record retention	Yes.	
§ 63.10(b)(2)(i)–(v)	Records related to SSM	Yes.	
§ 63.10(b)(2)(vi)–(xi)	Records	Yes.	
§ 63.10(b)(2)(xii)	Record when under waiver	Yes.	
§ 63.10(b)(2)(xiii)	Records when using alternative to RATA.	Yes	For CO standard if using RATA alternative.
§ 63.10(b)(2)(xiv)	Records of supporting documentation.	Yes.	
§ 63.10(b)(3)	Records of applicability determination.	Yes.	
§ 63.10(c)	Additional records for sources using CEMS.	Yes	Except that § 63.10(c)(2)–(4) and (9) are reserved.
§ 63.10(d)(1)	General reporting requirements	Yes.	
§ 63.10(d)(2)	Report of performance test results.	Yes.	
§ 63.10(d)(3)	Reporting opacity or VE observations.	No	Subpart ZZZZ does not contain opacity or VE standards.
§ 63.10(d)(4)	Progress reports	Yes.	
§ 63.10(d)(5)	Startup, shutdown, and malfunction reports.	Yes.	
§ 63.10(e)(1) and (2)(i)	Additional CMS reports	Yes.	
§ 63.10(e)(2)(ii)	COMS-related report	No	Subpart ZZZZ does not require COMS.
§ 63.10(e)(3)	Excess emission and parameter exceedances reports.	Yes	Except that § 63.10(e)(3)(i)(C) is reserved.
§ 63.10(e)(4)	Reporting COMS data	No	Subpart ZZZZ does not require COMS.
§ 63.10(f)	Waiver for recordkeeping/reporting.	Yes.	
§ 63.11	Flares	No.	
§ 63.12	State authority and delegations	Yes.	
§ 63.13	Addresses	Yes.	
§ 63.14	Incorporation by reference	Yes.	
§ 63.15	Availability of information	Yes.	

Subpart AAAAA—National Emission Standards for Hazardous Air Pollutants for Lime Manufacturing Plants

SOURCE: 69 FR 416, Jan. 5, 2004, unless otherwise noted.

WHAT THIS SUBPART COVERS

§ 63.7080 What is the purpose of this subpart?

This subpart establishes national emission standards for hazardous air pollutants (NESHAP) for lime manufacturing plants. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations.

§ 63.7081 Am I subject to this subpart?

(a) You are subject to this subpart if you own or operate a lime manufacturing plant (LMP) that is a major source, or that is located at, or is part of, a major source of hazardous air pollutant (HAP) emissions, unless the LMP is located at a kraft pulp mill, soda pulp mill, sulfite pulp mill, beet sugar manufacturing plant, or only processes sludge containing calcium carbonate from water softening processes.

(1) An LMP is an establishment engaged in the manufacture of lime product (calcium oxide, calcium oxide with magnesium oxide, or dead burned dolomite) by calcination of limestone, dolomite, shells or other calcareous substances.

(2) A major source of HAP is a plant site that emits or has the potential to emit any single HAP at a rate of 9.07 megagrams (10 tons) or more per year or any combination of HAP at a rate of 22.68 megagrams (25 tons) or more per year from all emission sources at the plant site.

(b) [Reserved]

§ 63.7082 What parts of my plant does this subpart cover?

(a) This subpart applies to each existing or new lime kiln(s) and their associated cooler(s), and processed stone handling (PSH) operations system(s) located at an LMP that is a major source.

(b) A new lime kiln is a lime kiln, and (if applicable) its associated lime cooler, for which construction or reconstruction began after December 20, 2002, if you met the applicability criteria in § 63.7081 at the time you began construction or reconstruction.

(c) A new PSH operations system is the equipment in paragraph (g) of this section, for which construction or reconstruction began after December 20, 2002, if you met the applicability criteria in § 63.7081 at the time you began construction or reconstruction.

(d) A lime kiln or PSH operations system is reconstructed if it meets the criteria for reconstruction defined in § 63.2.

(e) An existing lime kiln is any lime kiln, and (if applicable) its associated lime cooler, that does not meet the definition of a new kiln of paragraph (b) of this section.

(f) An existing PSH operations system is any PHS operations system that does not meet the definition of a new PSH operations system in paragraph (c) of this section.

(g) A PSH operations system includes all equipment associated with PSH operations beginning at the processed stone storage bin(s) or open storage pile(s) and ending where the processed stone is fed into the kiln. It includes man-made processed stone storage bins (but not open processed stone storage piles), conveying system transfer points, bulk loading or unloading systems, screening operations, surge bins, bucket elevators, and belt conveyors. No other materials processing operations are subject to this subpart.

(h) Nuisance dust collectors on lime coolers are part of the lime materials processing operations and are not covered by this subpart.

(i) Lime hydrators are not subject to this subpart.

(j) Open material storage piles are not subject to this subpart.

§ 63.7083 When do I have to comply with this subpart?

(a) If you have a new affected source, you must comply with this subpart according to paragraphs (a)(1) and (2) of this section.

(1) If you start up your affected source before January 5, 2004, you must

comply with the emission limitations no later than January 5, 2004, and you must have completed all applicable performance tests no later than July 5, 2004.

(2) If you start up your affected source after January 5, 2004, then you must comply with the emission limitations for new affected sources upon startup of your affected source and you must have completed all applicable performance tests no later than 180 days after startup.

(b) If you have an existing affected source, you must comply with the applicable emission limitations for the existing affected source, and you must have completed all applicable performance tests no later than January 5, 2007.

(c) If you have an LMP that is an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the deadlines specified in paragraphs (c)(1) and (2) of this section apply.

(1) New affected sources at your LMP you must be in compliance with this subpart upon startup.

(2) Existing affected sources at your LMP must be in compliance with this subpart within 3 years after your source becomes a major source of HAP.

(d) You must meet the notification requirements in §63.7130 according to the schedule in §63.7130 and in subpart A of this part. Some of the notifications must be submitted before you are required to comply with the emission limitations in this subpart.

EMISSION LIMITATIONS

§63.7090 What emission limitations must I meet?

(a) You must meet each emission limit in Table 1 to this subpart that applies to you.

(b) You must meet each operating limit in Table 2 to this subpart that applies to you.

GENERAL COMPLIANCE REQUIREMENTS

§63.7100 What are my general requirements for complying with this subpart?

(a) After your initial compliance date, you must be in compliance with the emission limitations (including operating limits) in this subpart at all times, except during periods of startup, shutdown, and malfunction.

(b) You must be in compliance with the opacity and visible emission (VE) limits in this subpart during the times specified in §63.6(h)(1).

(c) You must always operate and maintain your affected source, including air pollution control and monitoring equipment, according to the provisions in §63.6(e)(1)(i).

(d) You must prepare and implement for each LMP, a written operations, maintenance, and monitoring (OM&M) plan. You must submit the plan to the applicable permitting authority for review and approval as part of the application for a 40 CFR part 70 or 40 CFR part 71 permit. Any subsequent changes to the plan must be submitted to the applicable permitting authority for review and approval. Pending approval by the applicable permitting authority of an initial or amended plan, you must comply with the provisions of the submitted plan. Each plan must contain the following information:

(1) Process and control device parameters to be monitored to determine compliance, along with established operating limits or ranges, as applicable, for each emission unit.

(2) A monitoring schedule for each emission unit.

(3) Procedures for the proper operation and maintenance of each emission unit and each air pollution control device used to meet the applicable emission limitations and operating limits in Tables 1 and 2 to this subpart, respectively.

(4) Procedures for the proper installation, operation, and maintenance of monitoring devices or systems used to determine compliance, including:

(i) Calibration and certification of accuracy of each monitoring device;

(ii) Performance and equipment specifications for the sample interface, parametric signal analyzer, and the data collection and reduction systems;

(iii) Ongoing operation and maintenance procedures in accordance with the general requirements of §63.8(c)(1), (3), and (4)(ii); and

(iv) Ongoing data quality assurance procedures in accordance with the general requirements of §63.8(d).

(5) Procedures for monitoring process and control device parameters.

(6) Corrective actions to be taken when process or operating parameters or add-on control device parameters deviate from the operating limits specified in Table 2 to this subpart, including:

(i) Procedures to determine and record the cause of a deviation or excursion, and the time the deviation or excursion began and ended; and

(ii) Procedures for recording the corrective action taken, the time corrective action was initiated, and the time and date the corrective action was completed.

(7) A maintenance schedule for each emission unit and control device that is consistent with the manufacturer's instructions and recommendations for routine and long-term maintenance.

(e) You must develop a written start-up, shutdown, and malfunction plan (SSMP) according to the provisions in § 63.6(e)(3).

[69 FR 416, Jan. 5, 2004, as amended at 71 FR 20467, Apr. 20, 2006]

TESTING AND INITIAL COMPLIANCE REQUIREMENTS

§ 63.7110 By what date must I conduct performance tests and other initial compliance demonstrations?

(a) If you have an existing affected source, you must complete all applicable performance tests within January 5, 2007, according to the provisions in §§ 63.7(a)(2) and 63.7114.

(b) If you have a new affected source, and commenced construction or reconstruction between December 20, 2002, and January 5, 2004, you must demonstrate initial compliance with either the proposed emission limitation or the promulgated emission limitation no later than 180 calendar days after January 5, 2004 or within 180 calendar days after startup of the source, whichever is later, according to §§ 63.7(a)(2)(ix) and 63.7114.

(c) If you commenced construction or reconstruction between December 20, 2002, and January 5, 2004, and you chose to comply with the proposed emission limitation when demonstrating initial compliance, you must conduct a demonstration of compliance with the promulgated emission limitation within January 5, 2007 or after startup of the source, whichever is later, according to §§ 63.7(a)(2)(ix) and 63.7114.

(d) For each initial compliance requirement in Table 3 to this subpart that applies to you where the monitoring averaging period is 3 hours, the 3-hour period for demonstrating continuous compliance for emission units within existing affected sources at LMP begins at 12:01 a.m. on the compliance date for existing affected sources, that is, the day following completion of the initial compliance demonstration, and ends at 3:01 a.m. on the same day.

(e) For each initial compliance requirement in Table 3 to this subpart that applies to you where the monitoring averaging period is 3 hours, the 3-hour period for demonstrating continuous compliance for emission units within new or reconstructed affected sources at LMP begins at 12:01 a.m. on the day following completion of the initial compliance demonstration, as required in paragraphs (b) and (c) of this section, and ends at 3:01 a.m. on the same day.

§ 63.7111 When must I conduct subsequent performance tests?

You must conduct a performance test within 5 years following the initial performance test and within 5 years following each subsequent performance test thereafter.

§ 63.7112 What performance tests, design evaluations, and other procedures must I use?

(a) You must conduct each performance test in Table 4 to this subpart that applies to you.

(b) Each performance test must be conducted according to the requirements in § 63.7(e)(1) and under the specific conditions specified in Table 4 to this subpart.

(c) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in § 63.7(e)(1).

(d) Except for opacity and VE observations, you must conduct three separate test runs for each performance test required in this section, as specified in § 63.7(e)(3). Each test run must last at least 1 hour.

(e) The emission rate of particulate matter (PM) from each lime kiln (and each lime cooler if there is a separate exhaust to the atmosphere from the lime cooler) must be computed for each run using Equation 1 of this section:

$$E = \left(C_k Q_k + C_c Q_c\right)/PK \qquad \text{(Eq. 1)}$$

Where:

E = Emission rate of PM, pounds per ton (lb/ton) of stone feed.

C_k = Concentration of PM in the kiln effluent, grain/dry standard cubic feet (gr/dscf).

Q_k = Volumetric flow rate of kiln effluent gas, dry standard cubic feet per hour (dscf/hr).

C_c = Concentration of PM in the cooler effluent, grain/dscf. This value is zero if there is not a separate cooler exhaust to the atmosphere.

Q_c = Volumetric flow rate of cooler effluent gas, dscf/hr. This value is zero if there is not a separate cooler exhaust to the atmosphere.

P = Stone feed rate, tons per hour (ton/hr).

K = Conversion factor, 7000 grains per pound (grains/lb).

(f)(1) If you choose to meet a weighted average emission limit as specified in item 4 of Table 1 to this subpart, you must calculate a combined particulate emission rate from all kilns and coolers within your LMP using Equation 2 of this section:

$$E_T = \sum_{i=1}^{n} E_i P_i / \sum_{i=1}^{n} P_i \qquad \text{(Eq. 2)}$$

Where:

E_T = Emission rate of PM from all kilns and coolers, lb/ton of stone feed.

E_i = Emission rate of PM from kiln i, or from kiln/cooler combination i, lb/ton of stone feed.

P_i = Stone feed rate to kiln i, ton/hr.

n = Number of kilns you wish to include in averaging.

(2) You do not have to include every kiln in this calculation, only include kilns you wish to average. Kilns that have a PM emission limit of 0.60 lb/tsf are ineligible for any averaging.

(g) The weighted average PM emission limit from all kilns and coolers for which you are averaging must be calculated using Equation 3 of this section:

$$E_{TN} = \sum_{j=1}^{m} E_j P_j / \sum_{j=1}^{m} P_j \qquad \text{(Eq. 3)}$$

Where:

E_{TN} = Weighted average PM emission limit for all kilns and coolers being included in averaging at the LMP, lb/ton of stone feed.

E_j = PM emission limit (0.10 or 0.12) for kiln j, or for kiln/cooler combination j, lb/ton of stone feed.

P_j = Stone feed rate to kiln j, ton/hr.

m = Number of kilns and kiln/cooler combinations you are averaging at your LMP. You must include the same kilns in the calculation of E_T and E_{TN}. Kilns that have a PM emission limit of 0.60 lb/tsf are ineligible for any averaging.

(h) Performance test results must be documented in complete test reports that contain the information required by paragraphs (h)(1) through (10) of this section, as well as all other relevant information. The plan to be followed during testing must be made available to the Administrator at least 60 days prior to testing.

(1) A brief description of the process and the air pollution control system;

(2) Sampling location description(s);

(3) A description of sampling and analytical procedures and any modifications to standard procedures;

(4) Test results, including opacity;

(5) Quality assurance procedures and results;

(6) Records of operating conditions during the test, preparation of standards, and calibration procedures;

(7) Raw data sheets for field sampling and field and laboratory analyses;

(8) Documentation of calculations;

(9) All data recorded and used to establish operating limits; and

(10) Any other information required by the test method.

(i) [Reserved]

(j) You must establish any applicable 3-hour block average operating limit indicated in Table 2 to this subpart according to the applicable requirements in Table 3 to this subpart and paragraphs (j)(1) through (4) of this section.

(1) Continuously record the parameter during the PM performance test and include the parameter record(s) in the performance test report.

(2) Determine the average parameter value for each 15-minute period of each test run.

(3) Calculate the test run average for the parameter by taking the average of all the 15-minute parameter values for the run.

(4) Calculate the 3-hour operating limit by taking the average of the three test run averages.

(k) For each building enclosing any PSH operations that is subject to a VE limit, you must conduct a VE check according to item 18 in Table 4 to this subpart, and in accordance with paragraphs (k)(1) through (3) of this section.

(1) Conduct visual inspections that consist of a visual survey of the building over the test period to identify if there are VE, other than condensed water vapor.

(2) Select a position at least 15 but not more 1,320 feet from each side of the building with the sun or other light source generally at your back.

(3) The observer conducting the VE checks need not be certified to conduct EPA Method 9 in appendix A to part 60 of this chapter, but must meet the training requirements as described in EPA Method 22 in appendix A to part 60 of this chapter.

(l) When determining compliance with the opacity standards for fugitive emissions from PSH operations in item 7 of Table 1 to this subpart, you must conduct EPA Method 9 in appendix A to part 60 of this chapter according to item 17 in Table 4 to this subpart, and in accordance with paragraphs (l)(1) through (3) of this section.

(1) The minimum distance between the observer and the emission source shall be 4.57 meters (15 feet).

(2) The observer shall, when possible, select a position that minimizes interference from other fugitive emission sources (*e.g.*, road dust). The required observer position relative to the sun must be followed.

(3) If you use wet dust suppression to control PM from PSH operations, a visible mist is sometimes generated by the spray. The water mist must not be confused with particulate matter emissions and is not to be considered VE. When a water mist of this nature is present, you must observe emissions at a point in the plume where the mist is no longer visible.

§ 63.7113 What are my monitoring installation, operation, and maintenance requirements?

(a) You must install, operate, and maintain each continuous parameter monitoring system (CPMS) according to your OM&M plan required by § 63.7100(d) and paragraphs (a)(1) through (5) of this section, and you must install, operate, and maintain each continuous opacity monitoring system (COMS) as required by paragraph (g) of this section

(1) The CPMS must complete a minimum of one cycle of operation for each successive 15-minute period.

(2) To calculate a valid hourly value, you must have at least four equally spaced data values (or at least two, if that condition is included to allow for periodic calibration checks) for that hour from a CPMS that is not out of control according your OM&M plan, and use all valid data.

(3) To calculate the average for each 3-hour block averaging period, you must use all valid data, and you must have at least 66 percent of the hourly averages for that period using only hourly average values that are based on valid data (*i.e.*, not from out-of-control periods).

(4) You must conduct a performance evaluation of each CPMS in accordance with your OM&M plan.

(5) You must continuously operate and maintain the CPMS according to the OM&M plan, including, but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment.

(b) For each flow measurement device, you must meet the requirements in paragraphs (a)(1) through (5) and (b)(1) through (4) of this section.

(1) Use a flow sensor with a minimum tolerance of 2 percent of the flow rate.

(2) Reduce swirling flow or abnormal velocity distributions due to upstream and downstream disturbances.

(3) Conduct a flow sensor calibration check at least semiannually.

(4) At least monthly, inspect all components for integrity, all electrical connections for continuity, and all mechanical connections for leakage.

(c) For each pressure measurement device, you must meet the requirements in paragraphs (a)(1) through (5) and (c)(1) through (7) of this section.

(1) Locate the pressure sensor(s) in or as close to as possible a position that provides a representative measurement of the pressure.

(2) Minimize or eliminate pulsating pressure, vibration, and internal and external corrosion.

(3) Use a gauge with a minimum tolerance of 0.5 inch of water or a transducer with a minimum tolerance of 1 percent of the pressure range.

(4) Check pressure tap pluggage daily.

(5) Using a manometer, check gauge calibration quarterly and transducer calibration monthly.

(6) Conduct calibration checks any time the sensor exceeds the manufacturer's specified maximum operating pressure range or install a new pressure sensor.

(7) At least monthly, inspect all components for integrity, all electrical connections for continuity, and all mechanical connections for leakage.

(d) For each bag leak detection system (BLDS), you must meet any applicable requirements in paragraphs (a)(1) through (5) and (d)(1) through (8) of this section.

(1) The BLDS must be certified by the manufacturer to be capable of detecting PM emissions at concentrations of 10 milligrams per actual cubic meter (0.0044 grains per actual cubic foot) or less.

(2) The sensor on the BLDS must provide output of relative PM emissions.

(3) The BLDS must have an alarm that will sound automatically when it detects an increase in relative PM emissions greater than a preset level.

(4) The alarm must be located in an area where appropriate plant personnel will be able to hear it.

(5) For a positive-pressure fabric filter (FF), each compartment or cell must have a bag leak detector (BLD). For a negative-pressure or induced-air FF, the BLD must be installed downstream of the FF. If multiple BLD are required (for either type of FF), the detectors may share the system instrumentation and alarm.

(6) Bag leak detection systems must be installed, operated, adjusted, and maintained according to the manufacturer's written specifications and recommendations. Standard operating procedures must be incorporated into the OM&M plan.

(7) At a minimum, initial adjustment of the system must consist of establishing the baseline output in both of the following ways:

(i) Adjust the range and the averaging period of the device.

(ii) Establish the alarm set points and the alarm delay time.

(8) After initial adjustment, the range, averaging period, alarm set points, or alarm delay time may not be adjusted except as specified in the OM&M plan required by §63.7100(d). In no event may the range be increased by more than 100 percent or decreased by more than 50 percent over a 365-day period unless a responsible official, as defined in §63.2, certifies in writing to the Administrator that the FF has been inspected and found to be in good operating condition.

(e) For each PM detector, you must meet any applicable requirements in paragraphs (a)(1) through (5) and (e)(1) through (8) of this section.

(1) The PM detector must be certified by the manufacturer to be capable of detecting PM emissions at concentrations of 10 milligrams per actual cubic meter (0.0044 grains per actual cubic foot) or less.

(2) The sensor on the PM detector must provide output of relative PM emissions.

(3) The PM detector must have an alarm that will sound automatically when it detects an increase in relative PM emissions greater than a preset level.

(4) The alarm must be located in an area where appropriate plant personnel will be able to hear it.

(5) For a positive-pressure electrostatic precipitator (ESP), each compartment must have a PM detector. For a negative-pressure or induced-air ESP, the PM detector must be installed downstream of the ESP. If multiple PM detectors are required (for either type of ESP), the detectors may share the system instrumentation and alarm.

(6) Particulate matter detectors must be installed, operated, adjusted, and maintained according to the manufacturer's written specifications and recommendations. Standard operating procedures must be incorporated into the OM&M plan.

(7) At a minimum, initial adjustment of the system must consist of establishing the baseline output in both of the following ways:

(i) Adjust the range and the averaging period of the device.

(ii) Establish the alarm set points and the alarm delay time.

(8) After initial adjustment, the range, averaging period, alarm set points, or alarm delay time may not be adjusted except as specified in the OM&M plan required by § 63.7100(d). In no event may the range be increased by more than 100 percent or decreased by more than 50 percent over a 365-day period unless a responsible official as defined in § 63.2 certifies in writing to the Administrator that the ESP has been inspected and found to be in good operating condition.

(f) For each emission unit equipped with an add-on air pollution control device, you must inspect each capture/collection and closed vent system at least once each calendar year to ensure that each system is operating in accordance with the operating requirements in item 6 of Table 2 to this subpart and record the results of each inspection.

(g) For each COMS used to monitor an add-on air pollution control device, you must meet the requirements in paragraphs (g)(1) and (2) of this section.

(1) Install the COMS at the outlet of the control device.

(2) Install, maintain, calibrate, and operate the COMS as required by 40 CFR part 63, subpart A, General Provisions and according to Performance Specification (PS)–1 of appendix B to part 60 of this chapter. Facilities that operate COMS installed on or before February 6, 2001, may continue to meet the requirements in effect at the time of COMS installation unless specifically required to re-certify the COMS by their permitting authority.

§ 63.7114 How do I demonstrate initial compliance with the emission limitations standard?

(a) You must demonstrate initial compliance with each emission limit in Table 1 to this subpart that applies to you, according to Table 3 to this subpart. For existing lime kilns and their associated coolers, you may perform VE measurements in accordance with EPA Method 9 of appendix A to part 60 in lieu of installing a COMS or PM detector if any of the conditions in paragraphs (a)(1) through (3) of this section exist:

(1) You use a FF for PM control, and the FF is under positive pressure and has multiple stacks; or

(2) The control device exhausts through a monovent; or

(3) The installation of a COMS in accordance with PS–1 of appendix B to part 60 is infeasible.

(b) You must establish each site-specific operating limit in Table 2 to this subpart that applies to you according to the requirements in § 63.7112(j) and Table 4 to this subpart. Alternative parameters may be monitored if approval is obtained according to the procedures in § 63.8(f)

(c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in § 63.7130(e).

CONTINUOUS COMPLIANCE REQUIREMENTS

§ 63.7120 How do I monitor and collect data to demonstrate continuous compliance?

(a) You must monitor and collect data according to this section.

(b) Except for monitor malfunctions, associated repairs, required quality assurance or control activities (including, as applicable, calibration checks and required zero adjustments), and except for PSH operations subject to monthly VE testing, you must monitor continuously (or collect data at all required intervals) at all times that the emission unit is operating.

(c) Data recorded during the conditions described in paragraphs (c)(1) through (3) of this section may not be used either in data averages or calculations of emission or operating limits;

or in fulfilling a minimum data availability requirement. You must use all the data collected during all other periods in assessing the operation of the control device and associated control system.

(1) Monitoring system breakdowns, repairs, preventive maintenance, calibration checks, and zero (low-level) and high-level adjustments;

(2) Periods of non-operation of the process unit (or portion thereof), resulting in cessation of the emissions to which the monitoring applies; and

(3) Start-ups, shutdowns, and malfunctions.

§63.7121 How do I demonstrate continuous compliance with the emission limitations standard?

(a) You must demonstrate continuous compliance with each emission limitation in Tables 1 and 2 to this subpart that applies to you according to the methods specified in Tables 5 and 6 to this subpart.

(b) You must report each instance in which you did not meet each operating limit, opacity limit, and VE limit in Tables 2 and 6 to this subpart that applies to you. This includes periods of startup, shutdown, and malfunction. These instances are deviations from the emission limitations in this subpart. These deviations must be reported according to the requirements in §63.7131.

(c) [Reserved]

(d) Consistent with §§63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with §63.6(e)(1). The Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in §63.6(e).

(e) For each PSH operation subject to an opacity limit as specified in Table 1 to this subpart, and any vents from buildings subject to an opacity limit, you must conduct a VE check according to item 1 in Table 6 to this subpart, and as follows:

(1) Conduct visual inspections that consist of a visual survey of each stack or process emission point over the test period to identify if there are VE, other than condensed water vapor.

(2) Select a position at least 15 but not more 1,320 feet from the affected emission point with the sun or other light source generally at your back.

(3) The observer conducting the VE checks need not be certified to conduct EPA Method 9 in appendix A to part 60 of this chapter, but must meet the training requirements as described in EPA Method 22 of appendix A to part 60 of this chapter.

(f) For existing lime kilns and their associated coolers, you may perform VE measurements in accordance with EPA Method 9 of appendix A to part 60 in lieu of installing a COMS or PM detector if any of the conditions in paragraphs (f)(1) or (3) of this section exist:

(1) You use a FF for PM control, and the FF is under positive pressure and has multiple stacks; or

(2) The control device exhausts through a monovent; or

(3) The installation of a COMS in accordance with PS–1 of appendix B to part 60 is infeasible.

[69 FR 416, Jan. 5, 2004, as amended at 71 FR 20467, Apr. 20, 2006]

NOTIFICATION, REPORTS, AND RECORDS

§63.7130 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.6(h)(4) and (5); 63.7(b) and (c); 63.8(e); (f)(4) and (6); and 63.9 (a) through (j) that apply to you, by the dates specified.

(b) As specified in §63.9(b)(2), if you start up your affected source before January 5, 2004, you must submit an initial notification not later than 120 calendar days after January 5, 2004.

(c) If you startup your new or reconstructed affected source on or after January 5, 2004, you must submit an initial notification not later than 120 calendar days after you start up your affected source.

(d) If you are required to conduct a performance test, you must submit a notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin, as required in §63.7(b)(1).

(e) If you are required to conduct a performance test, design evaluation, opacity observation, VE observation, or other initial compliance demonstration as specified in Table 3 or 4 to this subpart, you must submit a Notification of Compliance Status according to § 63.9(h)(2)(ii).

(1) For each initial compliance demonstration required in Table 3 to this subpart that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th calendar day following the completion of the initial compliance demonstration.

(2) For each compliance demonstration required in Table 5 to this subpart that includes a performance test conducted according to the requirements in Table 4 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th calendar day following the completion of the performance test according to § 63.10(d)(2).

§ 63.7131 What reports must I submit and when?

(a) You must submit each report listed in Table 7 to this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date specified in Table 7 to this subpart and according to the requirements in paragraphs (b)(1) through (5) of this section:

(1) The first compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.7083 and ending on June 30 or December 31, whichever date is the first date following the end of the first half calendar year after the compliance date that is specified for your source in § 63.7083.

(2) The first compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first half calendar year after the compliance date that is specified for your affected source in § 63.7083.

(3) Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(5) For each affected source that is subject to permitting regulations pursuant to part 70 or part 71 of this chapter, if the permitting authority has established dates for submitting semiannual reports pursuant to §§ 70.6(a)(3)(iii)(A) or 71.6(a)(3)(iii)(A) of this chapter, you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates specified in paragraphs (b)(1) through (4) of this section.

(c) The compliance report must contain the information specified in paragraphs (c)(1) through (6) of this section.

(1) Company name and address.

(2) Statement by a responsible official with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a startup, shutdown or malfunction during the reporting period and you took actions consistent with your SSMP, the compliance report must include the information in § 63.10(d)(5)(i).

(5) If there were no deviations from any emission limitations (emission limit, operating limit, opacity limit, and VE limit) that apply to you, the compliance report must include a statement that there were no deviations from the emission limitations during the reporting period.

(6) If there were no periods during which the continuous monitoring systems (CMS) were out-of-control as specified in § 63.8(c)(7), a statement that there were no periods during which the CMS were out-of-control during the reporting period.

(d) For each deviation from an emission limitation (emission limit, operating limit, opacity limit, and VE limit) that occurs at an affected source

where you are not using a CMS to comply with the emission limitations in this subpart, the compliance report must contain the information specified in paragraphs (c)(1) through (4) and (d)(1) and (2) of this section. The deviations must be reported in accordance with the requirements in §63.10(d).

(1) The total operating time of each emission unit during the reporting period.

(2) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(e) For each deviation from an emission limitation (emission limit, operating limit, opacity limit, and VE limit) occurring at an affected source where you are using a CMS to comply with the emission limitation in this subpart, you must include the information specified in paragraphs (c)(1) through (4) and (e)(1) through (11) of this section. This includes periods of startup, shutdown, and malfunction.

(1) The date and time that each malfunction started and stopped.

(2) The date and time that each CMS was inoperative, except for zero (low-level) and high-level checks.

(3) The date, time and duration that each CMS was out-of-control, including the information in §63.8(c)(8).

(4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(5) A summary of the total duration of the deviations during the reporting period and the total duration as a percent of the total affected source operating time during that reporting period.

(6) A breakdown of the total duration of the deviations during the reporting period into those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and other unknown causes.

(7) A summary of the total duration of CMS downtime during the reporting period and the total duration of CMS downtime as a percent of the total emission unit operating time during that reporting period.

(8) A brief description of the process units.

(9) A brief description of the CMS.

(10) The date of the latest CMS certification or audit.

(11) A description of any changes in CMS, processes, or controls since the last reporting period.

(f) Each facility that has obtained a title V operating permit pursuant to part 70 or part 71 of this chapter must report all deviations as defined in this subpart in the semiannual monitoring report required by §§70.6(a)(3)(iii)(A) or 71.6(a)(3)(iii)(A) of this chapter. If you submit a compliance report specified in Table 7 to this subpart along with, or as part of, the semiannual monitoring report required by §§70.6(a)(3)(iii)(A) or 71.6(a)(3)(iii)(A) of this chapter, and the compliance report includes all required information concerning deviations from any emission limitation (including any operating limit), submission of the compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a compliance report shall not otherwise affect any obligation you may have to report deviations from permit requirements to the permit authority.

§63.7132 What records must I keep?

(a) You must keep the records specified in paragraphs (a)(1) through (3) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirements in §63.10(b)(2)(xiv).

(2) The records in §63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.

(3) Records of performance tests, performance evaluations, and opacity and VE observations as required in §63.10(b)(2)(viii).

(b) You must keep the records in §63.6(h)(6) for VE observations.

(c) You must keep the records required by Tables 5 and 6 to this subpart to show continuous compliance with each emission limitation that applies to you.

(d) You must keep the records which document the basis for the initial applicability determination as required under § 63.7081.

§ 63.7133 In what form and for how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review, according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record onsite for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1). You may keep the records offsite for the remaining 3 years.

OTHER REQUIREMENTS AND INFORMATION

§ 63.7140 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you. When there is overlap between subpart A and subpart AAAAA, as indicated in the ''Explanations'' column in Table 8, subpart AAAAA takes precedence.

§ 63.7141 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the U.S. EPA, or by a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency (as well as the U.S. EPA) has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out if this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under subpart E of this part, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are as specified in paragraphs (c)(1) through (6) of this section.

(1) Approval of alternatives to the non-opacity emission limitations in § 63.7090(a).

(2) Approval of alternative opacity emission limitations in § 63.7090(a).

(3) Approval of alternatives to the operating limits in § 63.7090(b).

(4) Approval of major alternatives to test methods under § 63.7(e)(2)(ii) and (f) and as defined in § 63.90.

(5) Approval of major alternatives to monitoring under § 63.8(f) and as defined in § 63.90.

(6) Approval of major alternatives to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.

§ 63.7142 What are the requirements for claiming area source status?

(a) If you wish to claim that your LMP is an area source, you must measure the emissions of hydrogen chloride from all lime kilns, except as provided in paragraph (c) of this section, at your plant using either:

(1) EPA Method 320 of appendix A to this part,

(2) EPA Method 321 of appendix A to this part, or

(3) ASTM Method D6735–01, Standard Test Method for Measurement of Gaseous Chlorides and Fluorides from Mineral Calcining Exhaust Sources—Impinger Method, provided that the provisions in paragraphs (a)(3)(i) through (vi) of this section are followed.

(i) A test must include three or more runs in which a pair of samples is obtained simultaneously for each run according to section 11.2.6 of ASTM Method D6735–01.

(ii) You must calculate the test run standard deviation of each set of paired samples to quantify data precision, according to Equation 1 of this section:

$$RSD_a = (100)\ \text{Absolute Value}\left[\frac{C1_a - C2_a}{C1_a + C2_a}\right] \qquad \text{(Eq. 1)}$$

Where:

RSD_a = The test run relative standard deviation of sample pair a, percent.

$C1_a$ and $C2_a$ = The HCl concentrations, milligram/dry standard cubic meter(mg/dscm), from the paired samples.

(iii) You must calculate the test average relative standard deviation according to Equation 2 of this section:

$$RSD_{TA} = \frac{\sum_{a=1}^{p} RSD_a}{p} \qquad \text{(Eq. 2)}$$

Where:

RSD_{TA} = The test average relative standard deviation, percent.

RSD_a = The test run relative standard deviation for sample pair a.

p = The number of test runs, ≥3.

(iv) If RSD^{TA} is greater than 20 percent, the data are invalid and the test must be repeated.

(v) The post-test analyte spike procedure of section 11.2.7 of ASTM Method D6735–01 is conducted, and the percent recovery is calculated according to section 12.6 of ASTM Method D6735–01.

(vi) If the percent recovery is between 70 percent and 130 percent, inclusive, the test is valid. If the percent recovery is outside of this range, the data are considered invalid, and the test must be repeated.

(b) If you conduct tests to determine the rates of emission of specific organic HAP from lime kilns at LMP for use in applicability determinations under §63.7081, you may use either:

(1) Method 320 of appendix A to this part, or

(2) Method 18 of appendix A to part 60 of this chapter, or

(3) ASTM D6420–99, Standard Test Method for Determination of Gaseous Organic Compounds by Direct Interface Gas Chromatography-Mass Spectrometry (GC/MS), provided that the provisions of paragraphs (b)(3)(i) through (iv) of this section are followed:

(i) The target compound(s) are those listed in section 1.1 of ASTM D6420–99;

(ii) The target concentration is between 150 parts per billion by volume and 100 parts per million by volume;

(iii) For target compound(s) not listed in Table 1.1 of ASTM D6420–99, but potentially detected by mass spectrometry, the additional system continuing calibration check after each run, as detailed in section 10.5.3 of ASTM D6420–99, is conducted, met, documented, and submitted with the data report, even if there is no moisture condenser used or the compound is not considered water soluble; and

(iv) For target compound(s) not listed in Table 1.1 of ASTM D6420–99, and not amenable to detection by mass spectrometry, ASTM D6420–99 may not be used.

(c) It is left to the discretion of the permitting authority whether or not idled kilns must be tested for (HCl) to claim area source status. If the facility has kilns that use common feed materials and fuel, are essentially identical in design, and use essentially identical emission controls, the permitting authority may also determine if one kiln can be tested, and the HCl emissions for the other essentially identical kilns be estimated from that test.

§63.7143 What definitions apply to this subpart?

Terms used in this subpart are defined in the Clean Air Act, in §63.2, and in this section as follows:

Bag leak detector system (BLDS) is a type of PM detector used on FF to identify an increase in PM emissions resulting from a broken filter bag or other malfunction and sound an alarm.

Belt conveyor means a conveying device that transports *processed stone* from one location to another by means of an endless belt that is carried on a series of idlers and routed around a pulley at each end.

Bucket elevator means a *processed stone* conveying device consisting of a head and foot assembly which supports and drives an endless single or double

strand chain or belt to which buckets are attached.

Building means any frame structure with a roof.

Capture system means the equipment (including enclosures, hoods, ducts, fans, dampers, etc.) used to capture and transport PM to a control device.

Control device means the air pollution control equipment used to reduce PM emissions released to the atmosphere from one or more process operations at an LMP.

Conveying system means a device for transporting *processed stone* from one piece of equipment or location to another location within a plant. Conveying systems include but are not limited to feeders, belt conveyors, bucket elevators and pneumatic systems.

Deviation means any instance in which an affected source, subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emission limitation (including any operating limit);

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or

(3) Fails to meet any emission limitation (including any operating limit) in this subpart during startup, shutdown, or malfunction, regardless of whether or not such failure is allowed by this subpart.

Emission limitation means any emission limit, opacity limit, operating limit, or VE limit.

Emission unit means a lime kiln, lime cooler, storage bin, conveying system transfer point, bulk loading or unloading operation, bucket elevator or belt conveyor at an LMP.

Fugitive emission means PM that is not collected by a capture system.

Hydrator means the device used to produce hydrated lime or calcium hydroxide via the chemical reaction of the lime product with water.

Lime cooler means the device external to the lime kiln (or part of the lime kiln itself) used to reduce the temperature of the lime produced by the kiln.

Lime kiln means the device, including any associated preheater, used to produce a lime product from stone feed by calcination. Kiln types include, but are not limited to, rotary kiln, vertical kiln, rotary hearth kiln, double-shaft vertical kiln, and fluidized bed kiln.

Lime manufacturing plant (LMP) means any plant which uses a lime kiln to produce lime product from limestone or other calcareous material by calcination.

Lime product means the product of the lime kiln calcination process including, calcitic lime, dolomitic lime, and dead-burned dolomite.

Limestone means the material comprised primarily of calcium carbonate (referred to sometimes as calcitic or high calcium limestone), magnesium carbonate, and/or the double carbonate of both calcium and magnesium (referred to sometimes as dolomitic limestone or dolomite).

Monovent means an exhaust configuration of a building or emission control device (*e.g.,* positive pressure FF) that extends the length of the structure and has a width very small in relation to its length (*i.e.,* length-to-width ratio is typically greater than 5:1). The exhaust may be an open vent with or without a roof, louvered vents, or a combination of such features.

Particulate matter (PM) detector means a system that is continuously capable of monitoring PM loading in the exhaust of FF or ESP in order to detect bag leaks, upset conditions, or control device malfunctions and sounds an alarm at a preset level. A PM detector system includes, but is not limited to, an instrument that operates on triboelectric, light scattering, light transmittance, or other effects to continuously monitor relative particulate loadings. A BLDS is a type of PM detector.

Positive pressure FF or ESP means a FF or ESP with the fan(s) on the upstream side of the control device.

Process stone handling operations means the equipment and transfer points between the equipment used to transport *processed stone,* and includes, storage bins, conveying system transfer points, bulk loading or unloading

systems, screening operations, bucket elevators, and belt conveyors.

Processed stone means limestone or other calcareous material that has been processed to a size suitable for feeding into a lime kiln.

Screening operation means a device for separating material according to size by passing undersize material through one or more mesh surfaces (screens) in series and retaining oversize material on the mesh surfaces (screens).

Stack emissions means the PM that is released to the atmosphere from a capture system or control device.

Storage bin means a manmade enclosure for storage (including surge bins) of *processed stone* prior to the lime kiln.

Transfer point means a point in a conveying operation where the material is transferred to or from a belt conveyor.

Vent means an opening through which there is mechanically induced air flow for the purpose of exhausting from a building air carrying PM emissions from one or more emission units.

TABLE 1 TO SUBPART AAAAA OF PART 63—EMISSION LIMITS

As required in §63.7090(a), you must meet each emission limit in the following table that applies to you.

For . . .	You must meet the following emission limit
1. Existing lime kilns and their associated lime coolers that did not have a wet scrubber installed and operating prior to January 5, 2004.	PM emissions must not exceed 0.12 pounds per ton of stone feed (lb/tsf).
2. Existing lime kilns and their associated lime coolers that have a wet scrubber, where the scrubber itself was installed and operating prior to January 5, 2004.	PM emissions must not exceed 0.60 lb/tsf. If at any time after January 5, 2004 the kiln changes to a dry control system, then the PM emission limit in item 1 of this Table 1 applies, and the kiln is hereafter ineligible for the PM emission limit in item 2 of this Table 1 regardless of the method of PM control.
3. New lime kilns and their associated lime coolers	PM emissions must not exceed 0.10 lb/tsf.
4. All existing and new lime kilns and their associated coolers at your LMP, and you choose to average PM emissions, except that any kiln that is allowed to meet the 0.60 lb/tsf PM emission limit is ineligible for averaging.	Weighted average PM emissions calculated according to Eq. 2 in §63.7112 must not exceed 0.12 lb/tsf (if you are averaging only existing kilns) or 0.10 lb/tsf (if you are averaging only new kilns). If you are averaging existing and new kilns, your weighted average PM emissions must not exceed the weighted average emission limit calculated according to Eq. 3 in §63.7112, except that no new kiln and its associated cooler considered alone may exceed an average PM emissions limit of 0.10 lb/tsf.
5. Stack emissions from all PSH operations at a new or existing affected source.	PM emissions must not exceed 0.05 grams per dry standard cubic meter (g/dscm).
6. Stack emissions from all PSH operations at a new or existing affected source, unless the stack emissions are discharged through a wet scrubber control device.	Emissions must not exceed 7 percent opacity.
7. Fugitive emissions from all PSH operations at a new or existing affected source, except as provided by item 8 of this Table 1.	Emissions must not exceed 10 percent opacity.
8. All PSH operations at a new or existing affected source enclosed in a building.	All of the individually affected PSH operations must comply with the applicable PM and opacity emission limitations in items 5 through 7 of this Table 1, or the building must comply with the following: There must be no VE from the building, except from a vent; and vent emissions must not exceed the stack emissions limitations in items 5 and 6 of this Table 1.
9. Each FF that controls emissions from only an individual, enclosed storage bin.	Emissions must not exceed 7 percent opacity.
10. Each set of multiple storage bins at a new or existing affected source, with combined stack emissions.	You must comply with the emission limits in items 5 and 6 of this Table 1.

TABLE 2 TO SUBPART AAAAA OF PART 63—OPERATING LIMITS

As required in §63.7090(b), you must meet each operating limit in the following table that applies to you.

For . . .	You must . . .
1. Each lime kiln and each lime cooler (if there is a separate exhaust to the atmosphere from the associated lime cooler) equipped with an FF.	Maintain and operate the FF such that the BLDS or PM detector alarm condition does not exist for more than 5 percent of the total operating time in a 6-month period; and comply with the requirements in §63.7113(d) through (f) and Table 5 to this subpart. In lieu of a BLDS or PM detector maintain the FF such that the 6-minute average opacity for any 6-minute block period does not exceed 15 percent; and comply with the requirements in §63.7113(f) and (g) and Table 5 to this subpart.
2. Each lime kiln equipped with a wet scrubber	Maintain the 3-hour block exhaust gas stream pressure drop across the wet scrubber greater than or equal to the pressure drop operating limit established during the most recent PM performance test; and maintain the 3-hour block scrubbing liquid flow rate greater than the flow rate operating limit established during the most recent performance test.
3. Each lime kiln equipped with an electrostatic precipitator	Install a PM detector and maintain and operate the ESP such that the PM detector alarm is not activated and alarm condition does not exist for more than 5 percent of the total operating time in a 6-month period, and comply with §63.7113(e); or, maintain the ESP such that the 6-minute average opacity for any 6-minute block period does not exceed 15 percent, and comply with the requirements in §63.7113(g); and comply with the requirements in §63.7113(f) and Table 5 to this subpart.
4. Each PSH operation subject to a PM limit which uses a wet scrubber.	Maintain the 3-hour block average exhaust gas stream pressure drop across the wet scrubber greater than or equal to the pressure drop operating limit established during the PM performance test; and maintain the 3-hour block average scrubbing liquid flow rate greater than or equal to the flow rate operating limit established during the performance test.
5. All affected sources	Prepare a written OM&M plan; the plan must include the items listed in §63.7100(d) and the corrective actions to be taken when required in Table 5 to this subpart.
6. Each emission unit equipped with an add-on air pollution control device.	a. Vent captured emissions through a closed system, except that dilution air may be added to emission streams for the purpose of controlling temperature at the inlet to an FF; and b. Operate each capture/collection system according to the procedures and requirements in the OM&M plan.

TABLE 3 TO SUBPART AAAAA OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITS

As required in §63.7114, you must demonstrate initial compliance with each emission limitation that applies to you, according to the following table.

For . . .	For the following emission limit . . .	You have demonstrated initial compliance, if after following the requirements in §63.7112 . . .
1. All new or existing lime kilns and their associated lime coolers (kilns/coolers).	PM emissions must not exceed 0.12 lb/tsf for all existing kilns/coolers with dry controls, 0.60 lb/tsf for existing kilns/coolers with wet scrubbers, 0.10 lb/tsf for all new kilns/coolers, or a weighted average calculated according to Eq. 3 in §63.7112.	The kiln outlet PM emissions (and if applicable, summed with the separate cooler PM emissions), based on the PM emissions measured using Method 5 in appendix A to part 60 of this chapter and the stone feed rate measurement over the period of initial performance test, do not exceed the emission limit; if the lime kiln is controlled by an FF or ESP and you are opting to monitor PM emissions with a BLDS or PM detector, you have installed and are operating the monitoring device according to the requirements in §63.7113(d) or (e), respectively; and if the lime kiln is controlled by an FF or ESP and you are opting to monitor PM emissions using a COMS, you have installed and are operating the COMS according to the requirements in §63.7113(g).

For . . .	For the following emission limit . . .	You have demonstrated initial compliance, if after following the requirements in § 63.7112 . . .
2. Stack emissions from all PHS operations at a new or existing affected source.	PM emissions must not exceed 0.05 g/dscm.	The outlet PM emissions, based on Method 5 or Method 17 in appendix A to part 60 of this chapter, over the period of the initial performance test do not exceed 0.05 g/dscm; and if the emission unit is controlled with a wet scrubber, you have a record of the scrubber's pressure drop and liquid flow rate operating parameters over the 3-hour performance test during which emissions did not exceed the emissions limitation.
3. Stack emissions from all PSH operations at a new or existing affected source, unless the stack emissions are discharged through a wet scrubber control device.	Emissions must not exceed 7 percent opacity.	Each of the thirty 6-minute opacity averages during the initial compliance period, using Method 9 in appendix A to part 60 of this chapter, does not exceed the 7 percent opacity limit. At least thirty 6-minute averages must be obtained.
4. Fugitive emissions from all PSH operations at a new or existing affected source.	Emissions must not exceed 10 percent opacity.	Each of the 6-minute opacity averages during the initial compliance period, using Method 9 in appendix A to part 60 of this chapter, does not exceed the 10 percent opacity limit.
5. All PSH operations at a new or existing affected source, enclosed in building.	All of the individually affected PSH operations must comply with the applicable PM and opacity emission limitations for items 2 through 4 of this Table 3, or the building must comply with the following: There must be no VE from the building, except from a vent, and vent emissions must not exceed the emission limitations in items 2 and 3 of this Table 3.	All the PSH operations enclosed in the building have demonstrated initial compliance according to the applicable requirements for items 2 through 4 of this Table 3; or if you are complying with the building emission limitations, there are no VE from the building according to item 18 of Table 4 to this subpart and § 63.7112(k), and you demonstrate initial compliance with applicable building vent emissions limitations according to the requirements in items 2 and 3 of this Table 3.
6. Each FF that controls emissions from only an individual storage bin.	Emissions must not exceed 7 percent opacity.	Each of the ten 6-minute averages during the 1-hour initial compliance period, using Method 9 in appendix A to part 60 of this chapter, does not exceed the 7 percent opacity limit.
7. Each set of multiple storage bins with combined stack emissions.	You must comply with emission limitations in items 2 and 3 of this Table 3.	You demonstrate initial compliance according to the requirements in items 2 and 3 of this Table 3.

TABLE 4 TO SUBPART AAAAA OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS

As required in § 63.7112, you must conduct each performance test in the following table that applies to you.

For . . .	You must . . .	Using . . .	According to the following requirements . . .
1. Each lime kiln and each associated lime cooler, if there is a separate exhaust to the atmosphere from the associated lime cooler.	Select the location of the sampling port and the number of traverse ports.	Method 1 or 1A of appendix A to part 60 of this chapter; and § 63.6(d)(1)(i).	Sampling sites must be located at the outlet of the control device(s) and prior to any releases to the atmosphere.
2. Each lime kiln and each associated lime cooler, if there is a separate exhaust to the atmosphere from the associated lime cooler.	Determine velocity and volumetric flow rate.	Method 2, 2A, 2C, 2D, 2F, or 2G in appendix A to part 60 of this chapter.	Not applicable.
3. Each lime kiln and each associated lime cooler, if there is a separate exhaust to the atmosphere from the associated lime cooler.	Conduct gas molecular weight analysis.	Method 3, 3A, or 3B in appendix A to part 60 of this chapter.	Not applicable.

For . . .	You must . . .	Using . . .	According to the following requirements . . .
4. Each lime kiln and each associated lime cooler, if there is a separate exhaust to the atmosphere from the associated lime cooler.	Measure moisture content of the stack gas.	Method 4 in appendix A to part 60 of this chapter.	Not applicable.
5. Each lime kiln and each associated lime cooler, if there is a separate exhaust to the atmosphere from the associated lime cooler, and which uses a negative pressure PM control device.	Measure PM emissions	Method 5 in appendix A to part 60 of this chapter.	Conduct the test(s) when the source is operating at representative operating conditions in accordance with § 63.7(e); the minimum sampling volume must be 0.85 dry standard cubic meter (dscm) (30 dry standard cubic foot (dscf)); if there is a separate lime cooler exhaust to the atmosphere, you must conduct the Method 5 test of the cooler exhaust concurrently with the kiln exhaust test.
6. Each lime kiln and each associated lime cooler, if there is a separate exhaust to the atmosphere from the associated lime cooler, and which uses a positive pressure FF or ESP.	Measure PM emissions	Method 5D in appendix A to part 60 of this chapter.	Conduct the test(s) when the source is operating at representative operating conditions in accordance with § 63.7(e); if there is a separate lime cooler exhaust to the atmosphere, you must conduct the Method 5 test of the separate cooler exhaust concurrently with the kiln exhaust test.
7. Each lime kiln	Determine the mass rate of stone feed to the kiln during the kiln PM emissions test.	Any suitable device	Calibrate and maintain the device according to manufacturer's instructions; the measuring device used must be accurate to within ±5 percent of the mass rate of stone feed over its operating range.
8. Each lime kiln equipped with a wet scrubber.	Establish the operating limit for the average gas stream pressure drop across the wet scrubber.	Data for the gas stream pressure drop measurement device during the kiln PM performance test.	The continuous pressure drop measurement device must be accurate within plus or minus 1 percent; you must collect the pressure drop data during the period of the performance test and determine the operating limit according to § 63.7112(j).
9. Each lime kiln equipped with a wet scrubber.	Establish the operating limit for the average liquid flow rate to the scrubber.	Data from the liquid flow rate measurement device during the kiln PM performance test.	The continuous scrubbing liquid flow rate measuring device must be accurate within plus or minus 1 percent; you must collect the flow rate data during the period of the performance test and determine the operating limit according to § 63.7112(j).
10. Each lime kiln equipped with a FF or ESP that is monitored with a PM detector.	Have installed and have operating the BLDS or PM detector prior to the performance test.	Standard operating procedures incorporated into the OM&M plan.	According to the requirements in § 63.7113(d) or (e), respectively.

For . . .	You must . . .	Using . . .	According to the following requirements . . .
11. Each lime kiln equipped with a FF or ESP that is monitored with a COMS.	Have installed and have operating the COMS prior to the performance test.	Standard operating procedures incorporated into the OM&M plan and as required by 40 CFR part 63, subpart A, General Provisions and according to PS–1 of appendix B to part 60 of this chapter, except as specified in § 63.7113(g)(2).	According to the requirements in § 63.7113(g).
12. Each stack emission from a PSH operation, vent from a building enclosing a PSH operation, or set of multiple storage bins with combined stack emissions, which is subject to a PM emission limit.	Measure PM emissions	Method 5 or Method 17 in appendix A to part 60 of this chapter.	The sample volume must be at least 1.70 dscm (60 dscf); for Method 5, if the gas stream being sampled is at ambient temperature, the sampling probe and filter may be operated without heaters; and if the gas stream is above ambient temperature, the sampling probe and filter may be operated at a temperature high enough, but no higher than 121 °C (250 °F), to prevent water condensation on the filter (Method 17 may be used only with exhaust gas temperatures of not more than 250 °F).
13. Each stack emission from a PSH operation, vent from a building enclosing a PSH operation, or set of multiple storage bins with combined stack emissions, which is subject to an opacity limit.	Conduct opacity observations	Method 9 in appendix A to part 60 of this chapter.	The test duration must be for at least 3 hours and you must obtain at least thirty, 6-minute averages.
14. Each stack emissions source from a PSH operation subject to a PM or opacity limit, which uses a wet scrubber.	Establish the average gas stream pressure drop across the wet scrubber.	Data for the gas stream pressure drop measurement device during the PSH operation stack PM performance test.	The pressure drop measurement device must be accurate within plus or minus 1 percent; you must collect the pressure drop data during the period of the performance test and determine the operating limit according to § 63.7112(j).
15. Each stack emissions source from a PSH operation subject to a PM or opacity limit, which uses a wet scrubber.	Establish the operating limit for the average liquid flow rate to the scrubber.	Data from the liquid flow rate measurement device during the PSH operation stack PM performance test.	The continuous scrubbing liquid flow rate measuring device must be accurate within plus or minus 1 percent; you must collect the flow rate data during the period of the performance test and determine the operating limit according to § 63.7112(j).
16. Each FF that controls emissions from only an individual, enclosed, new or existing storage bin.	Conduct opacity observations	Method 9 in appendix A to part 60 of this chapter.	The test duration must be for at least 1 hour and you must obtain ten 6-minute averages.
17. Fugitive emissions from any PSH operation subject to an opacity limit.	Conduct opacity observations	Method 9 in appendix A to part 60 of this chapter.	The test duration must be for at least 3 hours, but the 3-hour test may be reduced to 1 hour if, during the first 1-hour period, there are no individual readings greater than 10 percent opacity and there are no more than three readings of 10 percent during the first 1-hour period.

For . . .	You must . . .	Using . . .	According to the following requirements . . .
18. Each building enclosing any PSH operation, that is subject to a VE limit.	Conduct VE check	The specifications in §63.7112(k).	The performance test must be conducted while all affected PSH operations within the building are operating; the performance test for each affected building must be at least 75 minutes, with each side of the building and roof being observed for at least 15 minutes.

TABLE 5 TO SUBPART AAAAA OF PART 63—CONTINUOUS COMPLIANCE WITH OPERATING LIMITS

As required in §63.7121, you must demonstrate continuous compliance with each operating limit that applies to you, according to the following table:

For . . .	For the following operating limit . . .	You must demonstrate continuous compliance by . . .
1. Each lime kiln controlled by a wet scrubber.	Maintain the 3-hour block average exhaust gas stream pressure drop across the wet scrubber greater than or equal to the pressure drop operating limit established during the PM performance test; and maintain the 3-hour block average scrubbing liquid flow rate greater than or equal to the flow rate operating limit established during the performance test.	Collecting the wet scrubber operating data according to all applicable requirements in §63.7113 and reducing the data according to §63.7113(a); maintaining the 3-hour block average exhaust gas stream pressure drop across the wet scrubber greater than or equal to the pressure drop operating limit established during the PM performance test; and maintaining the 3-hour block average scrubbing liquid flow rate greater than or equal to the flow rate operating limit established during the performance test (the continuous scrubbing liquid flow rate measuring device must be accurate within ±1% and the continuous pressure drop measurement device must be accurate within ±1%).
2. Each lime kiln or lime cooler equipped with a FF and using a BLDS, and each lime kiln equipped with an ESP or FF using a PM detector.	a. Maintain and operate the FF or ESP such that the bag leak or PM detector alarm, is not activated and alarm condition does not exist for more than 5 percent of the total operating time in each 6-month period.	(i) Operating the FF or ESP so that the alarm on the bag leak or PM detection system is not activated and an alarm condition does not exist for more than 5 percent of the total operating time in each 6-month reporting period; and continuously recording the output from the BLD or PM detection system; and (ii) Each time the alarm sounds and the owner or operator initiates corrective actions within 1 hour of the alarm, 1 hour of alarm time will be counted (if the owner or operator takes longer than 1 hour to initiate corrective actions, alarm time will be counted as the actual amount of time taken by the owner or operator to initiate corrective actions); if inspection of the FF or ESP system demonstrates that no corrective actions are necessary, no alarm time will be counted.

For . . .	For the following operating limit . . .	You must demonstrate continuous compliance by . . .
3. Each stack emissions source from a PSH operation subject to an opacity limit, which is controlled by a wet scrubber.	Maintain the 3-hour block average exhaust gas stream pressure drop across the wet scrubber greater than or equal to the pressure drop operating limit established during the PM performance test; and maintain the 3-hour block average scrubbing liquid flow rate greater than or equal to the flow rate operating limit established during the performance test.	Collecting the wet scrubber operating data according to all applicable requirements in §63.7113 and reducing the data according to §63.7113(a); maintaining the 3-hour block average exhaust gas stream pressure drop across the wet scrubber greater than or equal to the pressure drop operating limit established during the PM performance test; and maintaining the 3-hour block average scrubbing liquid flow rate greater than or equal to the flow rate operating limit established during the performance test (the continuous scrubbing liquid flow rate measuring device must be accurate within ±1% and the continuous pressure drop measurement device must be accurate within ±1%).
4. For each lime kiln or lime cooler equipped with a FF or an ESP that uses a COMS as the monitoring device.	a. Maintain and operate the FF or ESP such that the average opacity for any 6-minute block period does not exceed 15 percent.	i. Installing, maintaining, calibrating and operating a COMS as required by 40 CFR part 63, subpart A, General Provisions and according to PS–1 of appendix B to part 60 of this chapter, except as specified in §63.7113(g)(2); and ii. Collecting the COMS data at a frequency of at least once every 15 seconds, determining block averages for each 6-minute period and demonstrating for each 6-minute block period the average opacity does not exceed 15 percent.

TABLE 6 TO SUBPART AAAAA OF PART 63—PERIODIC MONITORING FOR COMPLIANCE WITH OPACITY AND VISIBLE EMISSIONS LIMITS

As required in §63.7121 you must periodically demonstrate compliance with each opacity and VE limit that applies to you, according to the following table:

For . . .	For the following emission limitation . . .	You must demonstrate ongoing compliance . . .
1. Each PSH operation subject to an opacity limitation as required in Table 1 to this subpart, or any vents from buildings subject to an opacity limitation.	a. 7–10 percent opacity, depending on the PSH operation, as required in Table 1 to this subpart.	(i) Conducting a monthly 1-minute VE check of each emission unit in accordance with §63.7121(e); the check must be conducted while the affected source is in operation; (ii) If no VE are observed in 6 consecutive monthly checks for any emission unit, you may decrease the frequency of VE checking from monthly to semiannually for that emission unit; if VE are observed during any semiannual check, you must resume VE checking of that emission unit on a monthly basis and maintain that schedule until no VE are observed in 6 consecutive monthly checks; (iii) If no VE are observed during the semiannual check for any emission unit, you may decrease the frequency of VE checking from semi-annually to annually for that emission unit; if VE are observed during any annual check, you must resume VE checking of that emission unit on a monthly basis and maintain that schedule until no VE are observed in 6 consecutive monthly checks; and

For . . .	For the following emission limitation . . .	You must demonstrate ongoing compliance . . .
		(iv) If VE are observed during any VE check, you must conduct a 6-minute test of opacity in accordance with Method 9 of appendix A to part 60 of this chapter; you must begin the Method 9 test within 1 hour of any observation of VE and the 6-minute opacity reading must not exceed the applicable opacity limit.
2. Any building subject to a VE limit, according to item 8 of Table 1 to this subpart.	a. No VE	(i) Conducting a monthly VE check of the building, in accordance with the specifications in §63.7112(k); the check must be conducted while all the enclosed PSH operations are operating; (ii) The check for each affected building must be at least 5 minutes, with each side of the building and roof being observed for at least 1 minute; (iii) If no VE are observed in 6 consecutive monthly checks of the building, you may decrease the frequency of checking from monthly to semi-annually for that affected source; if VE are observed during any semi-annual check, you must resume checking on a monthly basis and maintain that schedule until no VE are observed in 6 consecutive monthly checks; and (iv) If no VE are observed during the semi-annual check, you may decrease the frequency of checking from semi-annually to annually for that affected source; and if VE are observed during any annual check, you must resume checking of that emission unit on a monthly basis and maintain that schedule until no VE are observed in 6 consecutive monthly checks (the source is in compliance if no VE are observed during any of these checks).

TABLE 7 TO SUBPART AAAAA OF PART 63—REQUIREMENTS FOR REPORTS

As required in §63.7131, you must submit each report in this table that applies to you.

You must submit a . . .	The report must contain . . .	You must submit the report . . .
1. Compliance report	a. If there are no deviations from any emission limitations (emission limit, operating limit, opacity limit, and VE limit) that applies to you, a statement that there were no deviations from the emission limitations during the reporting period;	Semiannually according to the requirements in §63.7131(b).
	b. If there were no periods during which the CMS, including any operating parameter monitoring system, was out-of-control as specified in §63.8(c)(7), a statement that there were no periods during which the CMS was out-of-control during the reporting period;	Semiannually according to the requirements in §63.7131(b).
	c. If you have a deviation from any emission limitation (emission limit, operating limit, opacity limit, and VE limit) during the reporting period, the report must contain the information in §63.7131(d);	Semiannually according to the requirements in §63.7131(b).

You must submit a . . .	The report must contain . . .	You must submit the report . . .
	d. If there were periods during which the CMS, including any operating parameter monitoring system, was out-of-control, as specified in § 63.8(c)(7), the report must contain the information in § 63.7131(e); and	Semiannually according to the requirements in § 63.7131(b).
	e. If you had a startup, shutdown or malfunction during the reporting period and you took actions consistent with your SSMP, the compliance report must include the information in § 63.10(d)(5)(i).	Semiannually according to the requirements in § 63.7131(b).
2. An immediate startup, shutdown, and malfunction report if you had a startup, shutdown, or malfunction during the reporting period that is not consistent with your SSMP.	Actions taken for the event	By fax or telephone within 2 working days after starting actions inconsistent with the SSMP.
3. An immediate startup, shutdown, and malfunction report if you had a startup, shutdown, or malfunction during the reporting period that is not consistent with your SSMP.	The information in § 63.10(d)(5)(ii)	By letter within 7 working days after the end of the event unless you have made alternative arrangements with the permitting authority. See § 63.10(d)(5)(ii).

TABLE 8 TO SUBPART AAAAA OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART AAAAA

As required in § 63.7140, you must comply with the applicable General Provisions requirements according to the following table:

Citation	Summary of requirement	Am I subject to this requirement?	Explanations
§ 63.1(a)(1)–(4)	Applicability	Yes.	
§ 63.1(a)(5)		No.	
§ 63.1(a)(6)	Applicability	Yes.	
§ 63.1(a)(7)–(a)(9)		No.	
§ 63.1(a)(10)–(a)(14)	Applicability	Yes.	
§ 63.1(b)(1)	Initial Applicability Determination.	Yes	§§ 63.7081 and 63.7142 specify additional applicability determination requirements.
§ 63.1(b)(2)		No.	
§ 63.1(b)(3)	Initial Applicability Determination.	Yes.	
§ 63.1(c)(1)	Applicability After Standard Established.	Yes.	
§ 63.1(c)(2)	Permit Requirements	No	Area sources not subject to subpart AAAAA, except all sources must make initial applicability determination.
§ 63.1(c)(3)		No.	
§ 63.1(c)(4)–(5)	Extensions, Notifications	Yes.	
§ 63.1(d)		No.	
§ 63.1(e)	Applicability of Permit Program.	Yes.	
§ 63.2	Definitions		Additional definitions in § 63.7143.
§ 63.3(a)–(c)	Units and Abbreviations	Yes.	
§ 63.4(a)(1)–(a)(2)	Prohibited Activities	Yes.	
§ 3.4(a)(3)–(a)(5)		No.	
§ 63.4(b)–(c)	Circumvention, Severability	Yes.	
§ 63.5(a)(1)–(2)	Construction/Reconstruction	Yes.	
§ 63.5(b)(1)	Compliance Dates	Yes.	
§ 63.5(b)(2)		No.	
§ 63.5(b)(3)–(4)	Construction Approval, Applicability.	Yes.	
§ 63.5(b)(5)		No.	
§ 63.5(b)(6)	Applicability	Yes.	
§ 63.5(c)		No.	
§ 63.5(d)(1)–(4)	Approval of Construction/Reconstruction.	Yes.	
§ 63.5(e)	Approval of Construction/Reconstruction.	Yes.	

Citation	Summary of requirement	Am I subject to this requirement?	Explanations
§ 63.5(f)(1)–(2)	Approval of Construction/Reconstruction.	Yes.	
§ 63.6(a)	Compliance for Standards and Maintenance.	Yes.	
§ 63.6(b)(1)–(5)	Compliance Dates	Yes.	
§ 63.6(b)(6)		No.	
§ 63.6(b)(7)	Compliance Dates	Yes.	
§ 63.6(c)(1)–(2)	Compliance Dates	Yes.	
§ 63.6(c)(3)–(c)(4)		No.	
§ 63.6(c)(5)	Compliance Dates	Yes.	
§ 63.6(d)		No.	
§ 63.6(e)(1)	Operation & Maintenance	Yes	See § 63.7100 for OM&M requirements.
§ 63.6(e)(2)		No.	
§ 63.6(e)(3)	Startup, Shutdown Malfunction Plan.	Yes.	
§ 63.6(f)(1)–(3)	Compliance with Emission Standards.	Yes.	
§ 63.6(g)(1)–(g)(3)	Alternative Standard	Yes.	
§ 63.6(h)(1)–(2)	Opacity/VE Standards	Yes.	
§ 63.6(h)(3)		No.	
§ 63.6(h)(4)–(h)(5)(i)	Opacity/VE Standards	Yes	This requirement only applies to opacity and VE performance checks required in Table 4 to subpart AAAAA.
§ 63.6(h)(5) (ii)–(iii)	Opacity/VE Standards	No	Test durations are specified in subpart AAAAA; subpart AAAAA takes precedence.
§ 63.6(h)(5)(iv)	Opacity/VE Standards	No.	
§ 63.6(h)(5)(v)	Opacity/VE Standards	Yes.	
§ 63.6(h)(6)	Opacity/VE Standards	Yes.	
§ 63.6(h)(7)	COM Use	Yes.	
§ 63.6(h)(8)	Compliance with Opacity and VE.	Yes.	
§ 63.6(h)(9)	Adjustment of Opacity Limit	Yes.	
§ 63.6(i)(1)–(i)(14)	Extension of Compliance	Yes.	
§ 63.6(i)(15)		No.	
§ 63.6(i)(16)	Extension of Compliance	Yes.	
§ 63.6(j)	Exemption from Compliance	Yes.	
§ 63.7(a)(1)–(a)(3)	Performance Testing Requirements.	Yes	§ 63.7110 specifies deadlines; § 63.7112 has additional specific requirements.
§ 63.7(b)	Notification	Yes.	
§ 63.7(c)	Quality Assurance/Test Plan	Yes.	
§ 63.7(d)	Testing Facilities	Yes.	
§ 63.7(e)(1)–(4)	Conduct of Tests	Yes.	
§ 63.7(f)	Alternative Test Method	Yes.	
§ 63.7(g)	Data Analysis	Yes.	
§ 63.7(h)	Waiver of Tests	Yes.	
§ 63.8(a)(1)	Monitoring Requirements	Yes	See § 63.7113.
§ 63.8(a)(2)	Monitoring	Yes.	
§ 63.8(a)(3)		No.	
§ 63.8(a)(4)	Monitoring	No	Flares not applicable.
§ 63.8(b)(1)–(3)	Conduct of Monitoring	Yes.	
§ 63.8(c)(1)–(3)	CMS Operation/Maintenance	Yes.	
§ 63.8(c)(4)	CMS Requirements	No	See § 63.7121.
§ 63.8(c)(4)(i)–(ii)	Cycle Time for COM and CEMS.	Yes	No CEMS are required under subpart AAAAA; see § 63.7113 for CPMS requirements.
§ 63.8(c)(5)	Minimum COM procedures	Yes	COM not required.
§ 63.8(c)(6)	CMS Requirements	No	See § 63.7113.
§ 63.8(c)(7)–(8)	CMS Requirements	Yes.	
§ 63.8(d)	Quality Control	No	See § 63.7113.
§ 63.8(e)	Performance Evaluation for CMS.	No.	
§ 63.8(f)(1)–(f)(5)	Alternative Monitoring Method	Yes.	
§ 63.8(f)(6)	Alternative to Relative Accuracy test.	No.	
§ 63.8(g)(1)–(g)(5)	Data Reduction; Data That Cannot Be Used.	No	See data reduction requirements in §§ 63.7120 and 63.7121.
§ 63.9(a)	Notification Requirements	Yes	See § 63.7130.

Citation	Summary of requirement	Am I subject to this requirement?	Explanations
§63.9(b)	Initial Notifications	Yes.	
§63.9(c)	Request for Compliance Extension.	Yes.	
§63.9(d)	New Source Notification for Special Compliance Requirements.	Yes.	
§63.9(e)	Notification of Performance Test.	Yes.	
§63.9(f)	Notification of VE/Opacity Test.	Yes	This requirement only applies to opacity and VE performance tests required in Table 4 to subpart AAAAA. Notification not required for VE/opacity test under Table 6 to subpart AAAAA.
§63.9(g)	Additional CMS Notifications	No	Not required for operating parameter monitoring.
§63.9(h)(1)–(h)(3)	Notification of Compliance Status.	Yes.	
§63.9(h)(4)		No.	
§63.9(h)(5)–(h)(6)	Notification of Compliance Status.	Yes.	
§63.9(i)	Adjustment of Deadlines	Yes.	
§63.9(j)	Change in Previous Information.	Yes.	
§63.10(a)	Recordkeeping/Reporting General Requirements.	Yes	See §§63.7131 through 63.7133.
§63.10(b)(1)–(b)(2)(xii)	Records	Yes.	
§63.10(b)(2)(xiii)	Records for Relative Accuracy Test.	No.	
§63.10(b)(2)(xiv)	Records for Notification	Yes.	
§63.10(b)(3)	Applicability Determinations	Yes.	
§63.10(c)	Additional CMS Recordkeeping.	No	See §63.7132.
§63.10(d)(1)	General Reporting Requirements.	Yes.	
§63.10(d)(2)	Performance Test Results	Yes.	
§63.10(d)(3)	Opacity or VE Observations	Yes	For the periodic monitoring requirements in Table 6 to subpart AAAAA, report according to §63.10(d)(3) only if VE observed and subsequent visual opacity test is required.
§63.10(d)(4)	Progress Reports	Yes.	
§63.10(d)(5)	Startup, Shutdown, Malfunction Reports.	Yes.	
§63.10(e)	Additional CMS Reports	No	See specific requirements in subpart AAAAA, see §63.7131.
§63.10(f)	Waiver for Recordkeeping/Reporting.	Yes.	
§63.11(a)–(b)	Control Device Requirements	No	Flares not applicable.
§63.12(a)–(c)	State Authority and Delegations.	Yes.	
§63.13(a)–(c)	State/Regional Addresses	Yes.	
§63.14(a)–(b)	Incorporation by Reference	No.	
§63.15(a)–(b)	Availability of Information	Yes.	

Subpart BBBBB—National Emission Standards for Hazardous Air Pollutants for Semiconductor Manufacturing

SOURCE: 68 FR 27925, May 22, 2003, unless otherwise noted.

WHAT THIS SUBPART COVERS

§63.7180 What is the purpose of this subpart?

This subpart establishes national emission standards for hazardous air pollutants (NESHAP) for semiconductor manufacturing facilities. This subpart also establishes requirements

to demonstrate initial and continuous compliance with the emission standards.

§ 63.7181 Am I subject to this subpart?

(a) You are subject to this subpart if you own or operate a semiconductor manufacturing process unit that is a major source of hazardous air pollutants (HAP) emissions or that is located at, or is part of, a major source of HAP emissions.

(b) A major source of HAP emissions is any stationary source or group of stationary sources located within a contiguous area and under common control that emits or has the potential to emit, considering controls, in the aggregate, any single HAP at a rate of 10 tons per year (tpy) or more or any combination of HAP at a rate of 25 tpy or more.

§ 63.7182 What parts of my facility does this subpart cover?

(a) This subpart applies to each new, reconstructed, or existing affected source that you own or operate that manufactures semiconductors.

(b) An affected source subject to this subpart is the collection of all semiconductor manufacturing process units used to manufacture p-type and n-type semiconductors and active solid-state devices from a wafer substrate, including research and development activities integrated into a semiconductor manufacturing process unit. A semiconductor manufacturing process unit includes the equipment assembled and connected by ductwork or hard-piping including furnaces and associated unit operations; associated wet and dry work benches; associated recovery devices; feed, intermediate, and product storage tanks; product transfer racks and connected ducts and piping; pumps, compressors, agitators, pressure-relief devices, sampling connecting systems, open-ended valves or lines, valves, connectors, and instrumentation systems; and control devices.

(c) Your affected source is a new affected source if you commence construction of the affected source after May 8, 2002, and you meet the applicability criteria in § 63.7181 at the time you commence construction.

(d) Your affected source is a reconstructed affected source if you meet the criteria for ''reconstruction,'' as defined in § 63.2.

(e) Your source is an existing affected source if it is not a new or reconstructed affected source.

§ 63.7183 When do I have to comply with this subpart?

(a) If you have a new or reconstructed affected source, you must comply with this subpart according to paragraphs (a)(1) and (2) of this section.

(1) If you start up your affected source before May 22, 2003, then you must comply with the emission standards for new and reconstructed sources in this subpart no later than May 22, 2003.

(2) If you start up your affected source after May 22, 2003, then you must comply with the emission standards for new and reconstructed sources in this subpart upon startup of your affected source.

(b) If you have an existing affected source, you must comply with the emission standards for existing sources no later than 3 years from May 22, 2003.

(c) If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP and an affected source subject to this subpart, paragraphs (c)(1) and (2) of this section apply.

(1) Any portion of your existing facility that is a new affected source as specified at § 63.7182(c), or a reconstructed affected source as specified at § 63.7182(d), must be in compliance with this subpart upon startup.

(2) Any portion of your facility that is an existing affected source, as specified at § 63.7182(e), must be in compliance with this subpart by not later than 3 years after it becomes a major source.

(d) You must meet the notification requirements in § 63.7189 and in subpart A of this part. You must submit some of the notifications (*e.g.*, Initial Notification) before the date you are required to comply with the emission limitations in this subpart.

EMISSION STANDARDS

§63.7184 What emission limitations, operating limits, and work practice standards must I meet?

(a) If you have a new, reconstructed, or existing affected source, as defined in §63.7182(b), you must comply with all applicable emission limitations in this section on and after the compliance dates specified in §63.7183.

(b) *Process vents—organic HAP emissions.* For each process vent that emits organic HAP, other than process vents from storage tanks, you must limit organic HAP emissions to the level specified in paragraph (b)(1) or (2) of this section. These limitations can be met by venting emissions from your process vent through a closed vent system to any combination of control devices meeting the requirements of §63.982(a)(2).

(1) Reduce the emissions of organic HAP from the process vent stream by 98 percent by weight.

(2) Reduce or maintain the concentration of emitted organic HAP from the process vent to less than or equal to 20 parts per million by volume (ppmv).

(c) *Process vents—inorganic HAP emissions.* For each process vent that emits inorganic HAP, other than process vents from storage tanks, you must limit inorganic HAP emissions to the level specified in paragraph (c)(1) or (2) of this section. These limitations can be met by venting emissions from your process vent through a closed vent system to a halogen scrubber meeting the requirements of §§63.983 (closed vent system requirements) and 63.994 (halogen scrubber requirements); the applicable general monitoring requirements of §63.996; the applicable performance test requirements; and the monitoring, recordkeeping and reporting requirements referenced therein.

(1) Reduce the emissions of inorganic HAP from the process vent stream by 95 percent by weight.

(2) Reduce or maintain the concentration of emitted inorganic HAP from the process vent to less than or equal to 0.42 ppmv.

(d) *Storage tanks.* For each storage tank, 1,500 gallons or larger, you must limit total HAP emissions to the level specified in paragraph (d)(1) or (2) of this section if the emissions from the storage tank vent contains greater than 0.42 ppmv inorganic HAP. These limitations can be met by venting emissions from your storage tank through a closed vent system to a halogen scrubber meeting the requirements of §§63.983 (closed vent system requirements) and 63.994 (halogen scrubber requirements); the applicable general monitoring requirements of §63.996; the applicable performance test requirements; and the monitoring, recordkeeping and reporting requirements referenced therein.

(1) Reduce the emissions of inorganic HAP from each storage tank by 95 percent by weight.

(2) Reduce or maintain the concentration of emitted inorganic HAP from the process vent to less than or equal to 0.42 ppmv.

(e) You must comply with the applicable work practice standards and operating limits contained in §63.982(a)(1) and (2). The closed vent system inspection requirements of §63.983(c), as referenced by §63.982(a)(1) and (2), do not apply.

COMPLIANCE REQUIREMENTS

§63.7185 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the requirements of §63.7184 at all times, except during periods of startup, shutdown, or malfunction.

(b) You must always operate and maintain your affected source, including air pollution control and monitoring equipment, according to the provisions in §63.6(e)(1)(i).

(c) You must develop a written startup, shutdown, and malfunction plan (SSMP). Your SSMP must be prepared in accordance with the provisions in §63.6(e)(3).

(d) You must perform all the items listed in paragraphs (d)(1) through (3) of this section:

(1) Submit the necessary notifications in accordance with §63.7189.

(2) Submit the necessary reports in accordance with §63.7190.

(3) Maintain all necessary records you have used to demonstrate compliance with this subpart in accordance with § 63.7191.

[68 FR 27925, May 22, 2003, as amended at 71 FR 20467, Apr. 20, 2006]

§ 63.7186 By what date must I conduct performance tests or other initial compliance demonstrations?

For each process vent or storage tank vent emission limitation in § 63.7184 for which initial compliance is demonstrated by meeting a percent by weight HAP emissions reduction, or a HAP concentration limitation, you must conduct performance tests or an initial compliance demonstration within 180 days after the compliance date that is specified for your source in § 63.7183 and according to the provisions in § 63.7(a)(2).

§ 63.7187 What performance tests and other compliance procedures must I use?

(a) You must conduct each performance test in Table 1 to this subpart that applies to you as specified for process vents in § 63.982(a)(2) and storage tanks in § 63.982(a)(1). Performance tests must be conducted under maximum operating conditions or HAP emissions potential. Section 63.982(a)(1) and (2) only includes methods to measure the total organic regulated material or total organic carbon (TOC) concentration. The EPA Methods 26 and 26A are included in Table 1 to this subpart in addition to the test methods contained within § 63.982(a)(1) and (2). The EPA Method 26 or 26A must be used for testing regulated material containing inorganic HAP. Method 320 of 40 CFR part 63, appendix A, must be used to measure total vapor phase organic and inorganic HAP concentrations.

(b) If, without the use of a control device, your process vent stream has an organic HAP concentration of 20 ppmv or less or an inorganic HAP concentration of 0.42 ppmv or less, or your storage tank vent stream has an inorganic HAP concentration of 0.42 ppmv or less, you may demonstrate that the vent stream is compliant by engineering assessments and calculations or by conducting the applicable performance test requirements specified in Table 1 to this subpart. Your engineering assessments and calculations, as with performance tests (as specified in § 63.982(a)(1) and (2)), must represent your maximum operating conditions or HAP emissions potential and must be approved by the Administrator. You must demonstrate continuous compliance by certifying that your operations will not exceed the maximum operating conditions or HAP emissions potential represented by your engineering assessments, calculations, or performance test.

(c) If you are using a control device to comply with the emission limitations in § 63.7184 and the inlet concentration of HAP to the control device is 20 ppmv or less, then you may demonstrate that the control device meets the percent by weight HAP emission reduction limitation in § 63.7184(c)(1) or (d)(1) by conducting a design evaluation as specified in paragraph (i) of this section. Your design evaluation must represent your maximum operating conditions or HAP emissions potential and must be approved by the Administrator. You must demonstrate continuous compliance by certifying that your operations will not exceed the maximum operating conditions or HAP emissions potential represented by your design evaluation.

(d) [Reserved]

(e) For each monitoring system required in this section, you must develop and submit for approval a site-specific monitoring plan that addresses the criteria specified in paragraphs (e)(1) through (3) of this section.

(1) Installation of the continuous monitoring system (CMS) sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the exhaust emissions (*e.g.*, on or downstream of the last control device);

(2) Performance and equipment specifications for the sample interface, the pollutant concentration or parametric signal analyzer, and the data collection and reduction system; and

(3) Performance evaluation procedures and acceptance criteria (*e.g.*, calibrations).

(f) In your site-specific monitoring plan, you must also address the procedural processes in paragraphs (f)(1) through (3) of this section.

(1) Ongoing operation and maintenance procedures in accordance with the general requirements of §63.8(c)(1), (3), (4)(ii), (7), and (8);

(2) Ongoing data quality assurance procedures in accordance with the general requirements of §63.8(d); and

(3) Ongoing recordkeeping and reporting procedures in accordance with the general requirements of §63.10(c), (e)(1), and (e)(2)(i).

(g) You must conduct a performance evaluation of each CMS in accordance with your site-specific monitoring plan.

(h) You must operate and maintain the CMS in continuous operation according to the site-specific monitoring plan.

(i) *Design evaluation*. To demonstrate that a control device meets the required percent by weight inorganic HAP emission reduction limitation in §63.7184(c)(1) or (d)(1), a design evaluation must address the composition of the inorganic HAP concentration of the vent stream entering the control device. A design evaluation also must address other vent stream characteristics and control device operating parameters as specified in any one of paragraphs (i)(1) through (5) of this section, depending on the type of control device that is used. If the vent stream is not the only inlet to the control device, the efficiency demonstration must also consider all other vapors, gases, and liquids, other than fuels, received by the control device.

(1) For a condenser, the design evaluation shall consider the vent stream flow rate, relative humidity, and temperature and shall establish the design outlet organic HAP compound concentration level, design average temperature of the condenser exhaust vent stream, and the design average temperatures of the coolant fluid at the condenser inlet and outlet. The temperature of the gas stream exiting the condenser must be measured and used to establish the outlet organic HAP concentration.

(2) For a carbon adsorption system that regenerates the carbon bed directly onsite in the control device such as a fixed-bed adsorber, the design evaluation shall consider the vent stream flow rate, relative humidity, and temperature and shall establish the design exhaust vent stream organic compound concentration level, adsorption cycle time, number and capacity of carbon beds, type and working capacity of activated carbon used for carbon beds, design total regeneration stream mass or volumetric flow over the period of each complete carbon bed regeneration cycle, design carbon bed temperature after regeneration, design carbon bed regeneration time, and design service life of carbon. For vacuum desorption, the pressure drop shall be included.

(3) For a carbon adsorption system that does not regenerate the carbon bed directly onsite in the control device such as a carbon canister, the design evaluation shall consider the vent stream mass or volumetric flow rate, relative humidity, and temperature and shall establish the design exhaust vent stream organic compound concentration level, capacity of carbon bed, type and working capacity of activated carbon used for carbon bed, and design carbon replacement interval based on the total carbon working capacity of the control device and source operating schedule.

(4) For a scrubber, the design evaluation shall consider the vent stream composition, constituent concentrations, liquid-to-vapor ratio, scrubbing liquid flow rate and concentration, temperature, and the reaction kinetics of the constituents with the scrubbing liquid. The design evaluation shall establish the design exhaust vent stream organic compound concentration level and will include the additional information in paragraphs (i)(5)(i) and (ii) of this section for trays and a packed column scrubber.

(i) Type and total number of theoretical and actual trays;

(ii) Type and total surface area of packing for entire column, and for individual packed sections if column contains more than one packed section.

[68 FR 27925, May 22, 2003, as amended at 71 FR 20467, Apr. 20, 2006]

§ 63.7188 What are my monitoring installation, operation, and maintenance requirements?

If you comply with the emission limitations of § 63.7184 by venting the emissions of your semiconductor process vent through a closed vent system to a control device, you must comply with the requirements of paragraphs (a) and (b) of this section.

(a) You must meet the applicable general monitoring, installation, operation, and maintenance requirements specified in § 63.996.

(b) You must meet the monitoring, installation, operation, and maintenance requirements specified for closed vent systems and applicable control devices in §§ 63.983 through 63.995. If you used the design evaluation procedure in § 63.7187(i) to demonstrate compliance, you must use the information from the design evaluation to establish the operating parameter level for monitoring of the control device.

APPLICATIONS, NOTIFICATIONS, REPORTS, AND RECORDS

§ 63.7189 What applications and notifications must I submit and when?

(a) You must submit all of the applications and notifications in §§ 63.7(b) and (c); 63.8(e), (f)(4) and (f)(6); and 63.9(b) through (e), (g) and (h) that apply to you by the dates specified.

(b) As specified in § 63.9(b)(2), if you start up your affected source before May 22, 2003, you must submit an Initial Notification not later than 120 calendar days after May 22, 2003.

(c) As specified in § 63.9(b)(3), if you start up your new or reconstructed affected source on or after May 22, 2003. you must submit an Initial Notification not later than 120 calendar days after you become subject to this subpart.

(d) If you are required to conduct a performance test, you must submit a notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin as required in § 63.7(b)(1).

(e) If you are required to conduct a performance test or other initial compliance demonstration, you must submit a Notification of Compliance Status according to § 63.9(h)(2)(ii) and according to paragraphs (e)(1) and (2) of this section.

(1) For each initial compliance demonstration that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th calendar day following the completion of the initial compliance demonstration. If you used the design evaluation procedure in § 63.7187(i) to demonstrate compliance, you must include the results of the design evaluation in the Notification of Compliance Status.

(2) For each initial compliance demonstration required that includes a performance test conducted according to the requirements in Table 1 to this subpart, you must submit a notification of the date of the performance evaluation at least 60 days prior to the date the performance evaluation is scheduled to begin as required in § 63.8(e)(2).

§ 63.7190 What reports must I submit and when?

(a) You must submit each of the following reports that apply to you.

(1) *Periodic compliance reports.* You must submit a periodic compliance report that contains the information required under paragraphs (c) through (e) of this section, and any requirements specified to be reported for process vents in § 63.982(a)(2) and storage tanks in § 63.982(a)(1).

(2) *Immediate startup, shutdown, and malfunction report.* You must submit an Immediate Startup, Shutdown, and Malfunction Report if you had a startup, shutdown, or malfunction during the reporting period that is not consistent with your SSMP. Your report must contain actions taken during the event. You must submit this report by fax or telephone within 2 working days after starting actions inconsistent with you SSMP. You are required to follow up this report with a report specifying the information in § 63.10(d)(5)(ii) by letter within 7 working days after the end of the event unless you have made alternative arrangements with your permitting authority.

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date

according to paragraphs (b)(1) through (5) of this section.

(1) The first periodic compliance report must cover the period beginning on the compliance date that is specified for your affected source in §63.7183 and ending on June 30 or December 31, whichever date is the first date following the end of the first 12 calendar months after the compliance date that is specified for your source in §63.7183.

(2) The first periodic compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first 12 calendar months after the compliance date that is specified for your affected source in §63.7183.

(3) Each subsequent periodic compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent periodic compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(5) For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), you may submit the first and subsequent periodic compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (4) of this section.

(c) The periodic compliance report must contain the information specified in paragraphs (c)(1) through (5) of this section.

(1) Company name and address.

(2) Statement by a responsible official with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If there are no deviations from any emission limitations that apply to you, a statement that there were no deviations from the emission limitations during the reporting period and that no CMS was inoperative, inactive, malfunctioning, out-of-control, repaired, or adjusted.

(5) If you had a startup, shutdown, or malfunction during the reporting period and you took actions consistent with your SSMP, your periodic compliance report must include the information in §63.10(d)(5) for each startup, shutdown, and malfunction.

(d) For each deviation from an emission limitation that occurs at an affected source where you are not using a CMS to comply with the emission limitations, the periodic compliance report must contain the information in paragraphs (d)(1) through (2) of this section.

(1) The total operating time of each affected source during the reporting period.

(2) Information on the number, duration, and cause of deviations (including unknown cause), if applicable.

(e) For each deviation from an emission limitation occurring at an affected source where you are using a CMS to demonstrate compliance with the emission limitation, you must include the information in paragraphs (e)(1) through (8) of this section.

(1) The date and time that each malfunction started and stopped, and the reason it was inoperative.

(2) The date and time that each CMS was inoperative, except for calibration checks.

(3) The date and time that each CMS was out-of-control, including the information in §63.8(c)(8).

(4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction or during another period, and the cause of the deviation.

(5) A summary of the total duration of the deviation during the reporting period, and the total duration as a percent of the total source operating time during that reporting period.

(6) A summary of the total duration of CMS downtime during the reporting period, and the total duration of CMS downtime as a percent of the total source operating time during the reporting period.

(7) An identification of each HAP that was monitored at the affected source.

(8) The date of the latest CMS certification or audit.

§ 63.7191 What records must I keep?

(a) You must keep the records listed in paragraphs (a)(1) through (3) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Notification of Compliance Status and periodic report of compliance that you submitted, according to the requirements in § 63.10(b)(2)(xiv).

(2) The records in § 63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunctions.

(3) Records of performance tests and performance evaluations as required in § 63.10(b)(2)(viii).

(b) For each CMS, you must keep the records listed in paragraphs (b)(1) through (5) of this section.

(1) Records described in § 63.10(b)(2)(vi) through (xi).

(2) All required measurements needed to demonstrate compliance with a relevant standard (*e.g.*, 30-minute averages of CMS data, raw performance testing measurements, raw performance evaluation measurements).

(3) All required CMS measurements (including monitoring data recorded during unavoidable CMS breakdowns and out-of-control periods).

(4) Records of the date and time that each deviation started and stopped, and whether the deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(5) Records for process vents according to the requirements specified in § 63.982(a)(2) and storage tank vents according to the requirements specified in § 63.982(a)(1).

§ 63.7192 In what form and how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review, according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record on site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1). You can keep the records offsite for the remaining 3 years.

OTHER REQUIREMENTS AND INFORMATION

§ 63.7193 What parts of the General Provisions apply to me?

Table 2 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.13 apply to you.

§ 63.7194 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the U.S. Environmental Protection Agency (EPA), or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out if this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the U.S. EPA Administrator and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are as listed in paragraphs (c)(1) through (4) of this section.

(1) Approval of alternatives to the non-opacity emission limitations in § 63.7184 under § 63.6(g).

(2) Approval of major alternatives to test methods under § 63.7(e)(2)(ii) and (f) and as defined in § 63.90.

(3) Approval of major alternatives to monitoring under § 63.8(f) and as defined in § 63.90.

(4) Approval of major alternatives to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.

§ 63.7195 What definitions apply to this subpart?

Terms used in this subpart are defined in the Clean Air Act, in §§ 63.2 and 63.981, the General Provisions of this part (40 CFR part 63, subpart A), and in this section as follows:

Control device means a combustion device, recovery device, recapture device, or any combination of these devices used for the primary purpose of reducing emissions to comply with this subpart. Devices that are inherent to a process or are integral to the operation of a process are not considered control devices for the purposes of this subpart, even though these devices may have the secondary effect of reducing emissions.

Process vent means the point at which HAP emissions are released to the atmosphere from a semiconductor manufacturing process unit or storage tank by means of a stack, chimney, vent, or other functionally equivalent opening. The HAP emission points originating from wastewater treatment equipment, other than storage tanks, are not considered to be a process vent, unless the wastewater treatment equipment emission points are connected to a common vent or exhaust plenum with other process vents.

Semiconductor manufacturing means the collection of semiconductor manufacturing process units used to manufacture p-type and n-type semiconductors or active solid state devices from a wafer substrate, including processing from crystal growth through wafer fabrication, and testing and assembly. Examples of semiconductor or related solid state devices include semiconductor diodes, semiconductor stacks, rectifiers, integrated circuits, and transistors.

Semiconductor manufacturing process unit means the collection of equipment used to carry out a discrete operation in the semiconductor manufacturing process. These operations include, but are not limited to, crystal growing; solvent stations used to prepare and clean materials for subsequent processing or for parts cleaning; wet chemical stations used for cleaning (other than solvent cleaning); photoresist application, developing, and stripping; etching; gaseous operation stations used for stripping, cleaning, doping, etching, and layering; separation; encapsulation; and testing. Research and development operations associated with semiconductor manufacturing and conducted at a semiconductor manufacturing facility are considered to be semiconductor manufacturing process units.

Storage tank means a stationary unit that is constructed primarily from nonearthen materials (such as wood, concrete, steel, fiberglass, or plastic) which provides structural support and is designed to hold an accumulation of liquids or other materials used in or generated by a semiconductor manufacturing process unit. The following are not storage tanks for the purposes of this subpart:

(1) Tanks permanently attached to motor vehicles such as trucks, railcars, barges, or ships;

(2) Flow-through tanks where wastewater undergoes treatment (such as pH adjustment) before discharge, and are not used to accumulate wastewater;

(3) Bottoms receiver tanks; and

(4) Surge control tanks.

TABLE 1 TO SUBPART BBBBB OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS

As stated in § 63.7187, you must comply with the requirements for performance tests in the following table:

For . . .	You must . . .	Using . . .	According to the following requirements . . .
1. Process or storage tank vent streams.	a. Select sampling port's location and the number of traverse ports.	Method 1 or 1A of 40 CFR part 60, appendix A.	Sampling sites must be located at the inlet (if emission reduction or destruction efficiency testing is required) and outlet of the control device and prior to any releases to the atmosphere.
	b. Determine velocity and volumetric flow rate.	Method 2, 2A, 2C, 2D, 2F, or 2G of 40 CFR part 60, appendix A.	For HAP reduction efficiency testing only; not necessary for determining compliance with a ppmv concentration limit.

For . . .	You must . . .	Using . . .	According to the following requirements . . .
	c. Conduct gas molecular weight analysis.	i. Method 3, 3A, or 3B of 40 CFR part 60, appendix A. ii. ASME PTC 19.10–1981–Part 10.	For flow rate determination only. You may use ASME PTC 19.10–1981–Part 10 (available for purchase from Three Park Avenue, New York, NY 10016–5990) as an alternative to EPA Method 3B.
	d. Measure moisture content of the stack gas.	Method 4 of 40 CFR part 60, appendix A.	For flow rate determination and correction to dry basis, if necessary.
2. Process vent stream ...	a. Measure organic and inorganic HAP concentration (two method option).	i. Method 18, 25, or 25A of 40 CFR part 60, appendix A, AND ii. Method 26 or 26A of 40 CFR part 60, appendix A.	(1) To determine compliance with the percent by weight emission reduction limit, conduct simultaneous sampling at inlet and outlet of control device and analyze for same organic and inorganic HAP at both inlet and outlet; and (2) If you use Method 25A to determine the TOC concentration for compliance with the 20 ppmv emission limitation, the instrument must be calibrated on methane or the predominant HAP. If you calibrate on the predominant HAP, you must comply with each of the following: —The organic HAP used as the calibration gas must be the single organic HAP representing the largest percent of emissions by volume. —The results are acceptable if the response from the high level calibration gas is at least 20 times the standard deviation of the response from the zero calibration gas when the instrument is zeroed on its most sensitive scale. —The span value of the analyzer must be less than 100 ppmv. To determine compliance with 98 percent reduction limit, conduct simultaneous sampling at inlet and outlet of control device and analyze for same organic and inorganic HAP at both inlet and outlet.
	c. Measure organic and inorganic HAP simultaneously (one method option).	Method 320 of 40 CFR part 63, appendix A.	To determine compliance with the percent by weight emission reduction limit, conduct simultaneous sampling at inlet and outlet of control device and analyze for same organic and inorganic HAP at both inlet and outlet.
3. Storage tank vent stream.	Measure inorganic HAP concentration.	Method 26 or 26A of 40 CFR part 60, appendix A, or Method 320 of 40 CFR part 63, appendix A.	To determine compliance with percent by weight emission reduction limit, conduct simultaneous sampling at inlet and outlet of control device and analyze for same inorganic HAP at both inlet and outlet.

TABLE 2 TO SUBPART BBBBB OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART BBBBB

As stated in §63.7193, you must comply with the applicable General Provisions requirements according to the following table:

Citation	Subject	Applicable to Subpart BBBBB?
§63.1	Applicability	Yes.
§63.2	Definitions	Yes.
§63.3	Units and Abbreviations	Yes.
§63.4	Prohibited Activities and Circumvention	Yes.
§63.5	Construction and Reconstruction	Yes.
§63.6	Compliance with Standards and Maintenance	Yes.
§63.7	Performance Testing Requirements	Yes, with the exception of §63.7(e)(1). The requirements of §63.7(e)(1) do not apply. Performance testing requirements that apply are specified in this subpart, and in §63.982(a)(1) and (2).

Citation	Subject	Applicable to Subpart BBBBB?
§63.8	Monitoring Requirements	Monitoring requirements are specified in this subpart and in §63.982(a)(1) and (2). The closed vent system inspection requirements of §63.983(c), as referenced by §63.982(a)(1) and (2), do not apply.
§63.9	Notification Requirements	Yes.
§63.10	Recordkeeping and Reporting Requirements	Yes, with the exception of §63.10(e). The requirements of §63.10(e) do not apply. In addition, the recordkeeping and reporting requirements specified in this subpart apply.
§63.11	Flares	Yes.
§63.12	Delegation	Yes.
§63.13	Addresses	Yes.
§63.14	Incorporation by Reference	Yes.
§63.15	Availability of Information	Yes.

Subpart CCCCC—National Emission Standards for Hazardous Air Pollutants for Coke Ovens: Pushing, Quenching, and Battery Stacks

SOURCE: 68 FR 18025, Apr. 14, 2003, unless otherwise noted.

WHAT THIS SUBPART COVERS

§63.7280 What is the purpose of this subpart?

This subpart establishes national emission standards for hazardous air pollutants (NESHAP) for pushing, soaking, quenching, and battery stacks at coke oven batteries. This subpart also establishes requirements to demonstrate initial and continuous compliance with all applicable emission limitations, work practice standards, and operation and maintenance requirements in this subpart.

§63.7281 Am I subject to this subpart?

You are subject to this subpart if you own or operate a coke oven battery at a coke plant that is (or is part of) a major source of hazardous air pollutant (HAP) emissions. A major source of HAP is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons or more per year or any combination of HAP at a rate of 25 tons or more per year.

§63.7282 What parts of my plant does this subpart cover?

(a) This subpart applies to each new or existing affected source at your coke plant. The affected source is each coke oven battery.

(b) This subpart covers emissions from pushing, soaking, quenching, and battery stacks from each affected source.

(c) An affected source at your coke plant is existing if you commenced construction or reconstruction of the affected source before July 3, 2001.

(d) An affected source at your coke plant is new if you commenced construction or reconstruction of the affected source on or after July 3, 2001. An affected source is reconstructed if it meets the definition of ''reconstruction'' in §63.2.

§63.7283 When do I have to comply with this subpart?

(a) If you have an existing affected source, you must comply with each emission limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you no later than April 14, 2006.

(b) If you have a new affected source and its initial startup date is on or before April 14, 2003, you must comply with each emission limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you by April 14, 2003.

(c) If you have a new affected source and its initial startup date is after April 14, 2003, you must comply with each emission limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you upon initial startup.

(d) You must meet the notification and schedule requirements in §63.7340.

Several of these notifications must be submitted before the compliance date for your affected source.

[68 FR 18025, Apr. 14, 2003; 68 FR 19885, Apr. 22, 2003]

EMISSION LIMITATIONS AND WORK PRACTICE STANDARDS

§ 63.7290 What emission limitations must I meet for capture systems and control devices applied to pushing emissions?

(a) You must not discharge to the atmosphere emissions of particulate matter from a control device applied to pushing emissions from a new or existing coke oven battery that exceed the applicable limit in paragraphs (a)(1) through (4) of this section:

(1) 0.01 grain per dry standard cubic foot (gr/dscf) if a cokeside shed is used to capture emissions;

(2) 0.02 pound per ton (lb/ton) of coke if a moveable hood vented to a stationary control device is used to capture emissions;

(3) If a mobile scrubber car that does not capture emissions during travel is used:

(i) 0.03 lb/ton of coke for a control device applied to pushing emissions from a short battery, or

(ii) 0.01 lb/ton of coke for a control device applied to pushing emissions from a tall battery; and

(4) 0.04 lb/ton of coke if a mobile control device that captures emissions during travel is used.

(b) You must meet each operating limit in paragraphs (b)(1) through (4) of this section that applies to you for a new or existing coke oven battery.

(1) For each venturi scrubber applied to pushing emissions, you must maintain the daily average pressure drop and scrubber water flow rate at or above the minimum levels established during the initial performance test.

(2) For each hot water scrubber applied to pushing emissions, you must maintain the daily average water pressure and water temperature at or above the minimum levels established during the initial performance test.

(3) For each capture system applied to pushing emissions, you must maintain the daily average volumetric flow rate at the inlet of the control device at or above the minimum level established during the initial performance test; or

(i) For each capture system that uses an electric motor to drive the fan, you must maintain the daily average fan motor amperes at or above the minimum level established during the initial performance test; and

(ii) For each capture system that does not use a fan driven by an electric motor, you must maintain the daily average static pressure at the inlet to the control device at an equal or greater vacuum than the level established during the initial performance test or maintain the daily average fan revolutions per minute (RPM) at or above the minimum level established during the initial performance test.

(4) For each multicyclone, you must maintain the daily average pressure drop at or below the minimum level established during the initial performance test.

[68 FR 18025, Apr. 14, 2003, as amended at 69 FR 60818, Oct. 13, 2004]

§ 63.7291 What work practice standards must I meet for fugitive pushing emissions if I have a by-product coke oven battery with vertical flues?

(a) You must meet each requirement in paragraphs (a)(1) through (7) of this section for each new or existing by-product coke oven battery with vertical flues.

(1) Observe and record the opacity of fugitive pushing emissions from each oven at least once every 90 days. If an oven cannot be observed during a 90-day period due to circumstances that were not reasonably avoidable, you must observe the opacity of the first push of that oven following the close of the 90-day period that is capable of being observed in accordance with the procedures in § 63.7334(a), and you must document why the oven was not observed within a 90-day period. All opacity observations of fugitive pushing emissions for batteries with vertical flues must be made using the procedures in § 63.7334(a).

(2) If two or more batteries are served by the same pushing equipment and

total no more than 90 ovens, the batteries as a unit can be considered a single battery.

(3) Observe and record the opacity of fugitive pushing emissions for at least four consecutive pushes per battery each day. Exclude any push during which the observer's view is obstructed or obscured by interferences and observe the next available push to complete the set of four pushes. If necessary due to circumstances that were not reasonably avoidable, you may observe fewer than four consecutive pushes in a day; however, you must observe and record as many consecutive pushes as possible and document why four consecutive pushes could not be observed. You may observe and record one or more non-consecutive pushes in addition to any consecutive pushes observed in a day.

(4) Do not alter the pushing schedule to change the sequence of consecutive pushes to be observed on any day. Keep records indicating the legitimate operational reason for any change in your pushing schedule which results in a change in the sequence of consecutive pushes observed on any day.

(5) If the average opacity for any individual push exceeds 30 percent opacity for any short battery or 35 percent opacity for any tall battery, you must take corrective action and/or increase coking time for that oven. You must complete corrective action or increase coking time within either 10 calendar days or the number of days determined using Equation 1 of this section, whichever is greater:

$$X = 0.55 * Y \qquad \text{(Eq. 1)}$$

Where:

X = Number of calendar days allowed to complete corrective action or increase coking time; and

Y = Current coking time for the oven, hours.

For the purpose of determining the number of calendar days allowed under Equation 1 of this section, day one is the first day following the day you observed an opacity in excess of 30 percent for any short battery or 35 percent for any tall battery. Any fraction produced by Equation 1 of this section must be counted as a whole day. Days during which the oven is removed from service are not included in the number of days allowed to complete corrective action.

(6)(i) You must demonstrate that the corrective action and/or increased coking time was successful. After a period of time no longer than the number of days allowed in paragraph (a)(5) of this section, observe and record the opacity of the first two pushes for the oven capable of being observed using the procedures in §63.7334(a). The corrective action and/or increased coking time was successful if the average opacity for each of the two pushes is 30 percent or less for a short battery or 35 percent or less for a tall battery. If the corrective action and/or increased coking time was successful, you may return the oven to the 90-day reading rotation described in paragraph (a)(1) of this section. If the average opacity of either push exceeds 30 percent for a short battery or 35 percent for a tall battery, the corrective action and/or increased coking time was unsuccessful, and you must complete additional corrective action and/or increase coking time for that oven within the number of days allowed in paragraph (a)(5) of this section.

(ii) After implementing any additional corrective action and/or increased coking time required under paragraph (a)(6)(i) or (a)(7)(ii) of this section, you must demonstrate that corrective action and/or increased coking time was successful. After a period of time no longer than the number of days allowed in paragraph (a)(5) of this section, you must observe and record the opacity of the first two pushes for the oven capable of being observed using the procedures in §63.7334(a). The corrective action and/or increased coking time was successful if the average opacity for each of the two pushes is 30 percent or less for a short battery or 35 percent or less for a tall battery. If the corrective action and/or increased coking time was successful, you may return the oven to the 90-day reading rotation described in paragraph (a)(1) of this section. If the average opacity of either push exceeds 30 percent for a short battery or 35 percent for a tall battery, the corrective action and/or increased coking time was unsuccessful, and you must follow the procedures in paragraph (a)(6)(iii) of this section.

(iii) If the corrective action and/or increased coking time was unsuccessful as described in paragraph (a)(6)(ii) of this section, you must repeat the procedures in paragraph (a)(6)(ii) of this section until the corrective action and/or increased coking time is successful. You must report to the permitting authority as a deviation each unsuccessful attempt at corrective action and/or increased coking time under paragraph (a)(6)(ii) of this section.

(7)(i) If at any time you place an oven on increased coking time as a result of fugitive pushing emissions that exceed 30 percent for a short battery or 35 percent for a tall battery, you must keep the oven on the increased coking time until the oven qualifies for decreased coking time using the procedures in paragraph (a)(7)(ii) or (a)(7)(iii) of this section.

(ii) To qualify for a decreased coking time for an oven placed on increased coking time in accordance with paragraph (a)(5) or (6) of this section, you must operate the oven on the decreased coking time. After no more than two coking cycles on the decreased coking time, you must observe and record the opacity of the first two pushes that are capable of being observed using the procedures in § 63.7334(a). If the average opacity for each of the two pushes is 30 percent or less for a short battery or 35 percent or less for a tall battery, you may keep the oven on the decreased coking time and return the oven to the 90-day reading rotation described in paragraph (a)(1) of this section. If the average opacity of either push exceeds 30 percent for a short battery or 35 percent for a tall battery, the attempt to qualify for a decreased coking time was unsuccessful. You must then return the oven to the previously established increased coking time, or implement other corrective action(s) and/or increased coking time. If you implement other corrective action and/or a coking time that is shorter than the previously established increased coking time, you must follow the procedures in paragraph (a)(6)(ii) of this section to confirm that the corrective action(s) and/or increased coking time was successful.

(iii) If the attempt to qualify for decreased coking time was unsuccessful as described in paragraph (a)(7)(ii) of this section, you may again attempt to qualify for decreased coking time for the oven. To do this, you must operate the oven on the decreased coking time. After no more than two coking cycles on the decreased coking time, you must observe and record the opacity of the first two pushes that are capable of being observed using the procedures in § 63.7334(a). If the average opacity for each of the two pushes is 30 percent or less for a short battery or 35 percent or less for a tall battery, you may keep the oven on the decreased coking time and return the oven to the 90-day reading rotation described in paragraph (a)(1) of this section. If the average opacity of either push exceeds 30 percent for a short battery or 35 percent for a tall battery, the attempt to qualify for a decreased coking time was unsuccessful. You must then return the oven to the previously established increased coking time, or implement other corrective action(s) and/or increased coking time. If you implement other corrective action and/or a coking time that is shorter than the previously established increased coking time, you must follow the procedures in paragraph (a)(6)(ii) of this section to confirm that the corrective action(s) and/or increased coking time was successful.

(iv) You must report to the permitting authority as a deviation the second and any subsequent consecutive unsuccessful attempts on the same oven to qualify for decreased coking time as described in paragraph (a)(7)(iii) of this section.

(b) As provided in § 63.6(g), you may request to use an alternative to the work practice standards in paragraph (a) of this section.

§ 63.7292 What work practice standards must I meet for fugitive pushing emissions if I have a by-product coke oven battery with horizontal flues?

(a) You must comply with each of the requirements in paragraphs (a)(1) through (4) of this section.

(1) Prepare and operate by a written plan that will eliminate or minimize incomplete coking for each by-product coke oven battery with horizontal flues. You must submit the plan and

supporting documentation to the Administrator (or delegated authority) for approval no later than 90 days after completing all observations and measurements required for the study in paragraph (a)(3) of this section or April 14, 2004, whichever is earlier. You must begin operating by the plan requirements by the compliance date that is specified in §63.7283. The written plan must identify minimum flue temperatures for different coking times and a battery-wide minimum acceptable flue temperature for any oven at any coking time.

(2) Submit the written plan and supporting documentation to the Administrator (or delegated authority) for review and approval. Include all data collected during the study described in paragraph (a)(3) of this section. If the Administrator (or delegated authority) disapproves the plan, you must revise the plan as directed by the Administrator (or delegated authority) and submit the amended plan for approval. The Administrator (or delegated authority) may require you to collect and submit additional data. You must operate according to your submitted plan (or submitted amended plan, if any) until the Administrator (or delegated authority) approves your plan.

(3) You must base your written plan on a study that you conduct that meets each of the requirements listed in paragraphs (a)(3)(i) through (x) of this section.

(i) Initiate the study by July 14, 2003. Notify the Administrator (or delegated authority) at least 7 days prior to initiating the study according to the requirements in §63.7340(f).

(ii) Conduct the study under representative operating conditions, including but not limited to the range of moisture content and volatile matter in the coal that is charged.

(iii) Include every oven in the study and observe at least two pushes from each oven.

(iv) For each push observed, measure and record the temperature of every flue within 2 hours before the scheduled pushing time. Document the oven number, date, and time the oven was charged and pushed, and calculate the net coking time.

(v) For each push observed, document the factors to be used to identify pushes that are incompletely coked. These factors must include (but are not limited to): average opacity during the push, average opacity during travel to the quench tower, average of six highest consecutive observations during both push and travel, highest single opacity reading, color of the emissions (especially noting any yellow or brown emissions), presence of excessive smoke during travel to the quench tower, percent volatile matter in the coke, percent volatile matter and percent moisture in the coal that is charged, and the date the oven was last rebuilt or completely relined. Additional documentation may be provided in the form of pictures or videotape of emissions during the push and travel. All opacity observations must be conducted in accordance with the procedures in §63.7334(a)(3) through (7).

(vi) Inspect the inside walls of the oven after each observed push for cool spots as indicated by a flue that is darker than others (the oven walls should be red hot) and record the results.

(vii) For each push observed, note where incomplete coking occurs if possible (*e.g.*, coke side end, pusher side end, top, or center of the coke mass). For any push with incomplete coking, investigate and document the probable cause.

(viii) Use the documented factors in paragraph (a)(3)(v) of this section to identify pushes that were completely coked and those that were not completely coked. Provide a rationale for the determination based on the documentation of factors observed during the study.

(ix) Use only the flue temperature and coking time data for pushes that were completely coked to identify minimum flue temperatures for various coking times. Submit the criteria used to determine complete coking, as well as a table of coking times and corresponding temperatures for complete coking as part of your plan.

(x) Determine the battery-wide minimum acceptable flue temperature for any oven. This temperature will be equal to the lowest temperature that

provided complete coking as determined in paragraph (a)(3)(ix) of this section.

(4) You must operate according to the coking times and temperatures in your approved plan and the requirements in paragraphs (a)(4)(i) through (viii) of this section.

(i) Measure and record the percent volatile matter in the coal that is charged.

(ii) Measure and record the temperature of all flues on two ovens per day within 2 hours before the scheduled pushing time for each oven. Measure and record the temperature of all flues on each oven at least once each month.

(iii) For each oven observed in accordance with paragraph (a)(4)(ii) of this section, record the time each oven is charged and pushed and calculate and record the net coking time. If any measured flue temperature for an oven is below the minimum flue temperature for an oven's scheduled coking time as established in the written plan, increase the coking time for the oven to the coking time in the written plan for the observed flue temperature before pushing the oven.

(iv) If you increased the coking time for any oven in accordance with paragraph (a)(4)(iii) of this section, you must investigate the cause of the low flue temperature and take corrective action to fix the problem. You must continue to measure and record the temperature of all flues for the oven within 2 hours before each scheduled pushing time until the measurements meet the minimum temperature requirements for the increased coking time for two consecutive pushes. If any measured flue temperature for an oven on increased coking time falls below the minimum flue temperature for the increased coking time, as established in the written plan, you must increase the coking time for the oven to the coking time specified in the written plan for the observed flue temperature before pushing the oven. The oven must continue to operate at this coking time (or at a longer coking time if the temperature falls below the minimum allowed for the increased coking time) until the problem has been corrected, and you have confirmed that the corrective action was successful as required by paragraph (a)(4)(v) of this section.

(v) Once the heating problem has been corrected, the oven may be returned to the battery's normal coking schedule. You must then measure and record the flue temperatures for the oven within 2 hours before the scheduled pushing time for the next two consecutive pushes. If any flue temperature measurement is below the minimum flue temperature for that coking time established in the written plan, repeat the procedures in paragraphs (a)(4)(iii) and (iv) of this section.

(vi) If any flue temperature measurement is below the battery-wide minimum acceptable temperature for complete coking established in the written plan for any oven at any coking time, you must remove the oven from service for repairs.

(vii) For an oven that has been repaired and returned to service after being removed from service in accordance with paragraph (a)(4)(vi) of this section, you must measure and record the temperatures of all flues for the oven within 2 hours before the first scheduled pushing time. If any flue temperature measurement is below the minimum flue temperature for the scheduled coking time, as established in the written plan, you must repeat the procedures described in paragraphs (a)(4)(iii) and (iv) of this section.

(viii) For an oven that has been repaired and returned to service after removal from service in accordance with paragraph (a)(4)(vi) of this section, you must report as a deviation to the permitting authority any flue temperature measurement made during the initial coking cycle after return to service that is below the lowest acceptable minimum flue temperature.

(b) As provided in § 63.6(g), you may request to use an alternative to the work practice standards in paragraph (a) of this section.

§ 63.7293 What work practice standards must I meet for fugitive pushing emissions if I have a non-recovery coke oven battery?

(a) You must meet the requirements in paragraphs (a)(1) and (2) of this section for each new and existing non-recovery coke oven battery.

(1) You must visually inspect each oven prior to pushing by opening the door damper and observing the bed of coke.

(2) Do not push the oven unless the visual inspection indicates that there is no smoke in the open space above the coke bed and that there is an unobstructed view of the door on the opposite side of the oven.

(b) As provided in §63.6(g), you may request to use an alternative to the work practice standard in paragraph (a) of this section.

§63.7294 What work practice standard must I meet for soaking?

(a) For each new and existing by-product coke oven battery, you must prepare and operate at all times according to a written work practice plan for soaking. Each plan must include measures and procedures to:

(1) Train topside workers to identify soaking emissions that require corrective actions.

(2) Damper the oven off the collecting main prior to opening the standpipe cap.

(3) Determine the cause of soaking emissions that do not ignite automatically, including emissions that result from raw coke oven gas leaking from the collecting main through the damper, and emissions that result from incomplete coking.

(4) If soaking emissions are caused by leaks from the collecting main, take corrective actions to eliminate the soaking emissions. Corrective actions may include, but are not limited to, reseating the damper, cleaning the flushing liquor piping, using aspiration, putting the oven back on the collecting main, or igniting the emissions.

(5) If soaking emissions are not caused by leaks from the collecting main, notify a designated responsible party. The responsible party must determine whether the soaking emissions are due to incomplete coking. If incomplete coking is the cause of the soaking emissions, you must put the oven back on the collecting main until it is completely coked or you must ignite the emissions.

(b) As provided in §63.6(g), you may request to use an alternative to the work practice standard in paragraph (a) of this section.

§63.7295 What requirements must I meet for quenching?

(a) You must meet the requirements in paragraphs (a)(1) and (2) of this section for each quench tower and backup quench station at a new or existing coke oven battery.

(1) For the quenching of hot coke, you must meet the requirements in paragraph (a)(1)(i) or (ii) of this section.

(i) The concentration of total dissolved solids (TDS) in the water used for quenching must not exceed 1,100 milligrams per liter (mg/L); or

(ii) The sum of the concentrations of benzene, benzo(a)pyrene, and naphthalene in the water used for quenching must not exceed the applicable site-specific limit approved by the permitting authority.

(2) You must use acceptable makeup water, as defined in §63.7352, as makeup water for quenching.

(b) For each quench tower at a new or existing coke oven battery and each backup quench station at a new coke oven battery, you must meet each of the requirements in paragraphs (b)(1) through (4) of this section.

(1) You must equip each quench tower with baffles such that no more than 5 percent of the cross sectional area of the tower may be uncovered or open to the sky.

(2) You must wash the baffles in each quench tower once each day that the tower is used to quench coke, except as specified in paragraphs (b)(2)(i) and (ii) of this section.

(i) You are not required to wash the baffles in a quench tower if the highest measured ambient temperature remains less than 30 degrees Fahrenheit throughout that day (24-hour period). If the measured ambient temperature rises to 30 degrees Fahrenheit or more during the day, you must resume daily washing according to the schedule in your operation and maintenance plan.

(ii) You must continuously record the ambient temperature on days that the baffles were not washed.

(3) You must inspect each quench tower monthly for damaged or missing baffles and blockage.

(4) You must initiate repair or replacement of damaged or missing baffles within 30 days and complete as soon as practicable.

(c) As provided in § 63.6(g), you may request to use an alternative to the work practice standards in paragraph (b) of this section.

§ 63.7296 What emission limitations must I meet for battery stacks?

You must not discharge to the atmosphere any emissions from any battery stack at a new or existing by-product coke oven battery that exhibit an opacity greater than the applicable limit in paragraphs (a) and (b) of this section.

(a) Daily average of 15 percent opacity for a battery on a normal coking cycle.

(b) Daily average of 20 percent opacity for a battery on batterywide extended coking.

OPERATION AND MAINTENANCE REQUIREMENTS

§ 63.7300 What are my operation and maintenance requirements?

(a) As required by § 63.6(e)(1)(i), you must always operate and maintain your affected source, including air pollution control and monitoring equipment, in a manner consistent with good air pollution control practices for minimizing emissions at least to the levels required by this subpart.

(b) You must prepare and operate at all times according to a written operation and maintenance plan for the general operation and maintenance of new or existing by-product coke oven batteries. Each plan must address, at a minimum, the elements listed in paragraphs (b)(1) through (6) of this section.

(1) Frequency and method of recording underfiring gas parameters.

(2) Frequency and method of recording battery operating temperature, including measurement of individual flue and cross-wall temperatures.

(3) Procedures to prevent pushing an oven before it is fully coked.

(4) Procedures to prevent overcharging and undercharging of ovens, including measurement of coal moisture, coal bulk density, and procedures for determining volume of coal charged.

(5) Frequency and procedures for inspecting flues, burners, and nozzles.

(6) Schedule and procedures for the daily washing of baffles.

(c) You must prepare and operate at all times according to a written operation and maintenance plan for each capture system and control device applied to pushing emissions from a new or existing coke oven battery. Each plan must address at a minimum the elements in paragraphs (c)(1) through (3) of this section.

(1) Monthly inspections of the equipment that are important to the performance of the total capture system (*e.g.,* pressure sensors, dampers, and damper switches). This inspection must include observations of the physical appearance of the equipment (*e.g.,* presence of holes in ductwork or hoods, flow constrictions caused by dents or accumulated dust in ductwork, and fan erosion). In the event a defect or deficiency is found in the capture system (during a monthly inspection or between inspections), you must complete repairs within 30 days after the date that the defect or deficiency is discovered. If you determine that the repairs cannot be completed within 30 days, you must submit a written request for an extension of time to complete the repairs that must be received by the permitting authority not more than 20 days after the date that the defect or deficiency is discovered. The request must contain a description of the defect or deficiency, the steps needed and taken to correct the problem, the interim steps being taken to mitigate the emissions impact of the defect or deficiency, and a proposed schedule for completing the repairs. The request shall be deemed approved unless and until such time as the permitting authority notifies you that it objects to the request. The permitting authority may consider all relevant factors in deciding whether to approve or deny the request (including feasibility and safety). Each approved schedule must provide for completion of repairs as expeditiously as practicable, and the permitting authority may request modifications to the proposed schedule as part of the approval process.

(2) Preventative maintenance for each control device, including a preventative maintenance schedule that is consistent with the manufacturer's instructions for routine and long-term maintenance.

(3) Corrective action for all baghouses applied to pushing emissions. In the event a bag leak detection system alarm is triggered, you must initiate corrective action to determine the cause of the alarm within 1 hour of the alarm, initiate corrective action to correct the cause of the problem within 24 hours of the alarm, and complete the corrective action as soon as practicable. Actions may include, but are not limited to:

(i) Inspecting the baghouse for air leaks, torn or broken bags or filter media, or any other condition that may cause an increase in emissions.

(ii) Sealing off defective bags or filter media.

(iii) Replacing defective bags or filter media or otherwise repairing the control device.

(iv) Sealing off a defective baghouse compartment.

(v) Cleaning the bag leak detection system probe, or otherwise repairing the bag leak detection system.

(vi) Shutting down the process producing the particulate emissions.

[68 FR 18025, Apr. 14, 2003, as amended at 70 FR 44289, Aug. 2, 2005]

GENERAL COMPLIANCE REQUIREMENTS

§63.7310 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limitations, work practice standards, and operation and maintenance requirements in this subpart at all times, except during periods of startup, shutdown, and malfunction as defined in §63.2.

(b) During the period between the compliance date specified for your affected source in §63.7283 and the date upon which continuous monitoring systems have been installed and certified and any applicable operating limits have been set, you must maintain a log detailing the operation and maintenance of the process and emissions control equipment.

(c) You must develop a written startup, shutdown, and malfunction plan according to the provisions in §63.6(e)(3).

[68 FR 18025, Apr. 14, 2003, as amended at 71 FR 20467, Apr. 20, 2006]

INITIAL COMPLIANCE REQUIREMENTS

§63.7320 By what date must I conduct performance tests or other initial compliance demonstrations?

(a) As required in §63.7(a)(2), you must conduct a performance test to demonstrate compliance with each limit in §63.7290(a) for emissions of particulate matter from a control device applied to pushing emissions that applies to you within 180 calendar days after the compliance date that is specified in §63.7283.

(b) You must conduct performance tests to demonstrate compliance with the TDS limit or constituent limit for quench water in §63.7295(a)(1) and each opacity limit in §63.7297(a) for a byproduct coke oven battery stack by the compliance date that is specified in §63.7283.

(c) For each work practice standard and operation and maintenance requirement that applies to you, you must demonstrate initial compliance within 30 calendar days after the compliance date that is specified in §63.7283.

(d) If you commenced construction or reconstruction between July 3, 2001 and April 14, 2003, you must demonstrate initial compliance with either the proposed emission limit or the promulgated emission limit no later than October 14, 2003, or no later than 180 calendar days after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

(e) If you commenced construction or reconstruction between July 3, 2001 and April 14, 2003, and you chose to comply with the proposed emission limit when demonstrating initial compliance, you must conduct a second performance test to demonstrate compliance with the promulgated emission limit by October 11, 2006, or after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

§ 63.7321 When must I conduct subsequent performance tests?

For each control device subject to an emission limit for particulate matter in § 63.7290(a), you must conduct subsequent performance tests no less frequently than twice (at mid-term and renewal) during each term of your title V operating permit.

§ 63.7322 What test methods and other procedures must I use to demonstrate initial compliance with the emission limits for particulate matter?

(a) You must conduct each performance test that applies to your affected source according to the requirements in paragraph (b) of this section.

(b) To determine compliance with the emission limit for particulate matter from a control device applied to pushing emissions where a cokeside shed is the capture system, follow the test methods and procedures in paragraphs (b)(1) and (2) of this section. To determine compliance with a process-weighted mass rate of particulate matter (lb/ton of coke) from a control device applied to pushing emissions where a cokeside shed is not used, follow the test methods and procedures in paragraphs (b)(1) through (4) of this section.

(1) Determine the concentration of particulate matter according to the following test methods in appendix A to 40 CFR part 60.

(i) Method 1 to select sampling port locations and the number of traverse points. Sampling sites must be located at the outlet of the control device and prior to any releases to the atmosphere.

(ii) Method 2, 2F, or 2G to determine the volumetric flow rate of the stack gas.

(iii) Method 3, 3A, or 3B to determine the dry molecular weight of the stack gas.

(iv) Method 4 to determine the moisture content of the stack gas.

(v) Method 5 or 5D, as applicable, to determine the concentration of front half particulate matter in the stack gas.

(2) During each particulate matter test run, sample only during periods of actual pushing when the capture system fan and control device are engaged. Collect a minimum sample volume of 30 dry standard cubic feet of gas during each test run. Three valid test runs are needed to comprise a performance test. Each run must start at the beginning of a push and finish at the end of a push (*i.e.*, sample for an integral number of pushes).

(3) Determine the total combined weight in tons of coke pushed during the duration of each test run according to the procedures in your source test plan for calculating coke yield from the quantity of coal charged to an individual oven.

(4) Compute the process-weighted mass emissions (E_p) for each test run using Equation 1 of this section as follows:

$$E_p = \frac{C \times Q \times T}{P \times K} \qquad \text{(Eq. 1)}$$

Where:

E_p = Process weighted mass emissions of particulate matter, lb/ton;

C = Concentration of particulate matter, gr/dscf;

Q = Volumetric flow rate of stack gas, dscf/hr;

T = Total time during a run that a sample is withdrawn from the stack during pushing, hr;

P = Total amount of coke pushed during the test run, tons; and

K = Conversion factor, 7,000 gr/lb.

[68 FR 18025, Apr. 14, 2003, as amended at 70 FR 44289, Aug. 2, 2005]

§ 63.7323 What procedures must I use to establish operating limits?

(a) For a venturi scrubber applied to pushing emissions from a coke oven battery, you must establish site-specific operating limits for pressure drop and scrubber water flow rate according to the procedures in paragraphs (a)(1) and (2) of this section.

(1) Using the continuous parameter monitoring systems (CPMS) required in § 63.7330(b), measure and record the pressure drop and scrubber water flow rate for each particulate matter test run during periods of pushing. A minimum of one pressure drop measurement and one scrubber water flow rate measurement must be obtained for each push.

(2) Compute and record the average pressure drop and scrubber water flow

rate for each test run. Your operating limits are the lowest average pressure drop and scrubber water flow rate values recorded during any of the three runs that meet the applicable emission limit.

(b) For a hot water scrubber applied to pushing emissions from a coke oven battery, you must establish site-specific operating limits for water pressure and water temperature according to the procedures in paragraphs (b)(1) and (2) of this section.

(1) Using the CPMS required in §63.7330(c), measure and record the hot water pressure and temperature for each particulate matter test run during periods of pushing. A minimum of one pressure measurement and one temperature measurement must be made just prior to each push by monitoring the hot water holding tank on the mobile scrubber car.

(2) Compute and record the average water pressure and temperature for each test run. Your operating limits are the lowest pressure and temperature values recorded during any of the three runs that meet the applicable emission limit.

(c) For a capture system applied to pushing emissions from a coke oven battery, you must establish a site-specific operating limit according to the procedures in paragraphs (c)(1), (2), or (3) of this section.

(1) If you elect the operating limit in §63.7290(b)(3) for volumetric flow rate, measure and record the total volumetric flow rate at the inlet of the control device during each push sampled for each particulate matter test run. Your operating limit is the lowest volumetric flow rate recorded during any of the three runs that meet the emission limit.

(2) If you elect the operating limit in §63.7290(b)(3)(i) for fan motor amperes, measure and record the fan motor amperes during each push sampled for each particulate matter test run. Your operating limit is the lowest fan motor amperes recorded during any of the three runs that meet the emission limit.

(3) If you elect the operating limit in §63.7290(b)(3)(ii) for static pressure or fan RPM, measure and record the static pressure at the inlet of the control device or fan RPM during each push sampled for each particulate matter test run. Your operating limit for static pressure is the minimum vacuum recorded during any of the three runs that meets the emission limit. Your operating limit for fan RPM is the lowest fan RPM recorded during any of the three runs that meets the emission limit.

(d) For a multicyclone applied to pushing emissions from a coke oven battery, you must establish a site-specific operating limit for pressure drop according to the procedures in paragraphs (d)(1) and (2) of this section.

(1) Using the CPMS required in §63.7330(f), measure and record the pressure drop for each particulate matter test run during periods of pushing. A minimum of one pressure drop measurement must be obtained for each push.

(2) Compute and record the average pressure drop for each test run. Your operating limit is the highest average pressure drop value recorded during any of the three runs that meet the emission limit.

(e) You may change the operating limit for a venturi scrubber, capture system, or mobile control device that captures emissions during pushing if you meet the requirements in paragraphs (e)(1) through (3) of this section.

(1) Submit a written notification to the Administrator of your request to conduct a new performance test to revise the operating limit.

(2) Conduct a performance test to demonstrate that emissions of particulate matter from the control device do not exceed the applicable limit in §63.7290(a).

(3) Establish revised operating limits according to the applicable procedures in paragraphs (a) through (d) of this section.

[68 FR 18025, Apr. 14, 2003, as amended at 69 FR 60818, Oct. 13, 2004]

§63.7324 What procedures must I use to demonstrate initial compliance with the opacity limits?

(a) You must conduct each performance test that applies to your affected source according to the requirements in paragraph (b) of this section.

(b) To determine compliance with the daily average opacity limit for stacks of 15 percent for a by-product coke oven battery on a normal coking cycle or 20 percent for a by-product coke oven battery on batterywide extended coking, follow the test methods and procedures in paragraphs (b)(1) through (3) of this section.

(1) Using the continuous opacity monitoring system (COMS) required in § 63.7330(e), measure and record the opacity of emissions from each battery stack for a 24-hour period.

(2) Reduce the monitoring data to hourly averages as specified in § 63.8(g)(2).

(3) Compute and record the 24-hour (daily) average of the COMS data.

§ 63.7325 What test methods and other procedures must I use to demonstrate initial compliance with the TDS or constituent limits for quench water?

(a) If you elect the TDS limit for quench water in § 63.7295(a)(1)(i), you must conduct each performance test that applies to your affected source according to the conditions in paragraphs (a)(1) and (2) of this section.

(1) Take the quench water sample from a location that provides a representative sample of the quench water as applied to the coke (*e.g.*, from the header that feeds water to the quench tower reservoirs). Conduct sampling under normal and representative operating conditions.

(2) Determine the TDS concentration of the sample using Method 160.1 in 40 CFR part 136.3 (see ''residue—filterable''), except that you must dry the total filterable residue at 103 to 105 °C (degrees Centigrade) instead of 180 °C.

(b) If at any time you elect to meet the alternative requirements for quench water in § 63.7295(a)(1)(ii), you must establish a site-specific constituent limit according to the procedures in paragraphs (b)(1) through (4) of this section.

(1) Take a minimum of nine quench water samples from a location that provides a representative sample of the quench water as applied to the coke (*e.g.*, from the header that feeds water to the quench tower reservoirs). Conduct sampling under normal and representative operating conditions.

(2) For each sample, determine the TDS concentration according to the requirements in paragraph (a)(2) of this section and the concentration of benzene, benzo(a)pyrene, and naphthalene using the applicable methods in 40 CFR part 136 or an approved alternative method.

(3) Determine and record the highest sum of the concentrations of benzene, benzo(a)pyrene, and naphthalene in any sample that has a TDS concentration less than or equal to the TDS limit of 1,100 mg/L. This concentration is the site-specific constituent limit.

(4) Submit the site-specific limit, sampling results, and all supporting data and calculations to your permitting authority for review and approval.

(c) If you elect the constituent limit for quench water in § 63.7295(a)(1)(ii), you must conduct each performance test that applies to your affected source according to the conditions in paragraphs (c)(1) and (2) of this section.

(1) Take a quench water sample from a location that provides a representative sample of the quench water as applied to the coke (*e.g.*, from the header that feeds water to the quench tower reservoirs). Conduct sampling under normal and representative operating conditions.

(2) Determine the sum of the concentration of benzene, benzo(a)pyrene, and naphthalene in the sample using the applicable methods in 40 CFR part 136 or an approved alternative method.

§ 63.7326 How do I demonstrate initial compliance with the emission limitations that apply to me?

(a) For each coke oven battery subject to the emission limit for particulate matter from a control device applied to pushing emissions, you have demonstrated initial compliance if you meet the requirements in paragraphs (a)(1) through (4) of this section that apply to you.

(1) The concentration of particulate matter, measured in accordance with the performance test procedures in § 63.7322(b)(1) and (2), did not exceed 0.01 gr/dscf for a control device where a cokeside shed is used to capture pushing emissions or the process-weighted mass rate of particulate matter (lb/ton of coke), measured in accordance with

the performance test procedures in §63.7322(b)(1) through (4), did not exceed:

(i) 0.02 lb/ton of coke if a moveable hood vented to a stationary control device is used to capture emissions;

(ii) If a mobile scrubber car that does not capture emissions during travel is used, 0.03 lb/ton of coke from a control device applied to pushing emissions from a short coke oven battery or 0.01 lb/ton of coke from a control device applied to pushing emissions from a tall coke oven battery; and

(iii) 0.04 lb/ton of coke if a mobile control device that captures emissions during travel is used.

(2) For each venturi scrubber applied to pushing emissions, you have established appropriate site-specific operating limits and have a record of the pressure drop and scrubber water flow rate measured during the performance test in accordance with §63.7323(a).

(3) For each hot water scrubber applied to pushing emissions, you have established appropriate site-specific operating limits and have a record of the water pressure and temperature measured during the performance test in accordance with §63.7323(b).

(4) For each capture system applied to pushing emissions, you have established an appropriate site-specific operating limit, and:

(i) If you elect the operating limit in §63.7290(b)(3) for volumetric flow rate, you have a record of the total volumetric flow rate at the inlet of the control device measured during the performance test in accordance with §63.7323(c)(1); or

(ii) If you elect the operating limit in §63.7290(b)(3)(i) for fan motor amperes, you have a record of the fan motor amperes during the performance test in accordance with §63.7323(c)(2); or

(iii) If you elect the operating limit in §63.7290(b)(3)(ii) for static pressure or fan RPM, you have a record of the static pressure at the inlet of the control device or fan RPM measured during the performance test in accordance with §63.7323(c)(3).

(5) For each multicyclone applied to pushing emissions, you have established an appropriate site-specific operating limit and have a record of the pressure drop measured during the performance test in accordance with §63.7323(d).

(b) For each new or existing by-product coke oven battery subject to the opacity limit for stacks in §63.7296(a), you have demonstrated initial compliance if the daily average opacity, as measured according to the performance test procedures in §63.7324(b), is no more than 15 percent for a battery on a normal coking cycle or 20 percent for a battery on batterywide extended coking.

(c) For each new or existing by-product coke oven battery subject to the TDS limit or constituent limits for quench water in §63.7295(a)(1),

(1) You have demonstrated initial compliance with the TDS limit in §63.7295(a)(1)(i) if the TDS concentration, as measured according to the performance test procedures in §63.7325(a), does not exceed 1,100 mg/L.

(2) You have demonstrated initial compliance with the constituent limit in §63.7295(a)(1)(ii) if:

(i) You have established a site-specific constituent limit according to the procedures in §63.7325(b); and

(ii) The sum of the constituent concentrations, as measured according to the performance test procedures in §63.7325(c), is less than or equal to the site-specific limit.

(d) For each by-product coke oven battery stack subject to an opacity limit in §63.7296(a) and each by-product coke oven battery subject to the requirements for quench water in §63.7295(a)(1), you must submit a notification of compliance status containing the results of the COMS performance test for battery stacks and the quench water performance test (TDS or constituent limit) according to §63.7340(e)(1). For each particulate matter emission limitation that applies to you, you must submit a notification of compliance status containing the results of the performance test according to §63.7340(e)(2).

[68 FR 18025, Apr. 14, 2003, as amended at 69 FR 60819, Oct. 13, 2004]

§63.7327 How do I demonstrate initial compliance with the work practice standards that apply to me?

(a) For each by-product coke oven battery with vertical flues subject to

the work practice standards for fugitive pushing emissions in § 63.7291(a), you have demonstrated initial compliance if you certify in your notification of compliance status that you will meet each of the work practice requirements beginning no later than the compliance date that is specified in § 63.7283.

(b) For each by-product coke oven battery with horizontal flues subject to the work practice standards for fugitive pushing emissions in § 63.7292(a), you have demonstrated initial compliance if you have met the requirements of paragraphs (b)(1) and (2) of this section:

(1) You have prepared and submitted a written plan and supporting documentation establishing appropriate minimum flue temperatures for different coking times and the lowest acceptable temperature to the Administrator (or delegated authority) for review and approval; and

(2) You certify in your notification of compliance status that you will meet each of the work practice requirements beginning no later than the compliance date that is specified in § 63.7283.

(c) For each non-recovery coke oven battery subject to the work practice standards for fugitive pushing emissions in § 63.7293(a), you have demonstrated initial compliance if you certify in your notification of compliance status that you will meet each of the work practice requirements beginning no later than the compliance date that is specified in § 63.7283.

(d) For each by-product coke oven battery subject to the work practice standards for soaking in § 63.7294, you have demonstrated initial compliance if you have met the requirements of paragraphs (d)(1) and (2) of this section:

(1) You have prepared and submitted a written work practice plan in accordance with § 63.7294(a); and

(2) You certify in your notification of compliance status that you will meet each of the work practice requirements beginning no later than the compliance date that is specified in § 63.7283.

(e) For each coke oven battery, you have demonstrated initial compliance with the work practice standards for quenching in § 63.7295(b) if you certify in your notification of compliance status that you have met the requirements of paragraphs (e)(1) and (2) of this section:

(1) You have installed the required equipment in each quench tower; and

(2) You will meet each of the work practice requirements beginning no later than the compliance date that is specified in § 63.7283.

(f) For each work practice standard that applies to you, you must submit a notification of compliance status according to the requirements in § 63.7340(e)(1).

§ 63.7328 How do I demonstrate initial compliance with the operation and maintenance requirements that apply to me?

You have demonstrated initial compliance if you certify in your notification of compliance status that you have met the requirements of paragraphs (a) through (d) of this section:

(a) You have prepared the operation and maintenance plans according to the requirements in § 63.7300(b) and (c);

(b) You will operate each by-product coke oven battery and each capture system and control device applied to pushing emissions from a coke oven battery according to the procedures in the plans beginning no later than the compliance date that is specified in § 63.7283;

(c) You have prepared a site-specific monitoring plan according to the requirements in § 63.7331(b); and

(d) You submit a notification of compliance status according to the requirements in § 63.7340(e).

CONTINUOUS COMPLIANCE REQUIREMENTS

§ 63.7330 What are my monitoring requirements?

(a) For each baghouse applied to pushing emissions from a coke oven battery, you must at all times monitor the relative change in particulate matter loadings using a bag leak detection system according to the requirements in § 63.7331(a) and conduct inspections at their specified frequency according to the requirements in paragraphs (a)(1) through (8) of this section.

(1) Monitor the pressure drop across each baghouse cell each day to ensure pressure drop is within the normal operating range identified in the manual;

(2) Confirm that dust is being removed from hoppers through weekly visual inspections or equivalent means of ensuring the proper functioning of removal mechanisms;

(3) Check the compressed air supply for pulse-jet baghouses each day;

(4) Monitor cleaning cycles to ensure proper operation using an appropriate methodology;

(5) Check bag cleaning mechanisms for proper functioning through monthly visual inspection or equivalent means;

(6) Make monthly visual checks of bag tension on reverse air and shaker-type baghouses to ensure that bags are not kinked (kneed or bent) or laying on their sides. You do not have to make this check for shaker-type baghouses using self-tensioning (spring-loaded) devices;

(7) Confirm the physical integrity of the baghouse through quarterly visual inspections of the baghouse interior for air leaks; and

(8) Inspect fans for wear, material buildup, and corrosion through quarterly visual inspections, vibration detectors, or equivalent means.

(b) For each venturi scrubber applied to pushing emissions, you must at all times monitor the pressure drop and water flow rate using a CPMS according to the requirements in §63.7331(e).

(c) For each hot water scrubber applied to pushing emissions, you must at all times monitor the water pressure and temperature using a CPMS according to the requirements in §63.7331(f).

(d) For each capture system applied to pushing emissions, you must at all times monitor the volumetric flow rate according to the requirements in §63.7331(g), the fan motor amperes according to the requirements in §63.7331(h), or the static pressure or the fan RPM according to the requirements in §63.7331(i).

(e) For each by-product coke oven battery, you must monitor at all times the opacity of emissions exiting each stack using a COMS according to the requirements in §63.7331(j).

(f) For each multicyclone applied to pushing emissions, you must monitor at all times the pressure drop using a CPMS according to the requirements in §63.7331(k).

[68 FR 18025, Apr. 14, 2003, as amended at 69 FR 60819, Oct. 13, 2004]

§63.7331 What are the installation, operation, and maintenance requirements for my monitors?

(a) For each baghouse applied to pushing emissions, you must install, operate, and maintain each bag leak detection system according to the requirements in paragraphs (a)(1) through (7) of this section.

(1) The system must be certified by the manufacturer to be capable of detecting emissions of particulate matter at concentrations of 10 milligrams per actual cubic meter (0.0044 grains per actual cubic foot) or less;

(2) The system must provide output of relative changes in particulate matter loadings;

(3) The system must be equipped with an alarm that will sound when an increase in relative particulate loadings is detected over a preset level. The alarm must be located such that it can be heard by the appropriate plant personnel;

(4) Each system that works based on the triboelectric effect must be installed, operated, and maintained in a manner consistent with the guidance document, ''Fabric Filter Bag Leak Detection Guidance'' (EPA–454/R–98–015, September 1997). You may install, operate, and maintain other types of bag leak detection systems in a manner consistent with the manufacturer's written specifications and recommendations;

(5) To make the initial adjustment of the system, establish the baseline output by adjusting the sensitivity (range) and the averaging period of the device. Then, establish the alarm set points and the alarm delay time;

(6) Following the initial adjustment, do not adjust the sensitivity or range, averaging period, alarm set points, or alarm delay time, except as detailed in your operation and maintenance plan. Do not increase the sensitivity by more than 100 percent or decrease the sensitivity by more than 50 percent over a 365-day period unless a responsible official certifies, in writing, that the

baghouse has been inspected and found to be in good operating condition; and

(7) Where multiple detectors are required, the system's instrumentation and alarm may be shared among detectors.

(b) For each CPMS required in § 63.7330, you must develop and make available for inspection upon request by the permitting authority a site-specific monitoring plan that addresses the requirements in paragraphs (b)(1) through (6) of this section.

(1) Installation of the CPMS sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the exhaust emissions (*e.g.*, on or downstream of the last control device);

(2) Performance and equipment specifications for the sample interface, the parametric signal analyzer, and the data collection and reduction system;

(3) Performance evaluation procedures and acceptance criteria (*e.g.*, calibrations);

(4) Ongoing operation and maintenance procedures in accordance with the general requirements of §§ 63.8(c)(1), (3), (4)(ii), (7), and (8);

(5) Ongoing data quality assurance procedures in accordance with the general requirements of § 63.8(d); and

(6) Ongoing recordkeeping and reporting procedures in accordance the general requirements of §§ 63.10(c), (e)(1), and (e)(2)(i).

(c) You must conduct a performance evaluation of each CPMS in accordance with your site-specific monitoring plan.

(d) You must operate and maintain the CPMS in continuous operation according to the site-specific monitoring plan.

(e) For each venturi scrubber applied to pushing emissions, you must install, operate, and maintain CPMS to measure and record the pressure drop across the scrubber and scrubber water flow rate during each push according to the requirements in paragraphs (b) through (d) of this section except as specified in paragraphs (e)(1) through (3) of this section.

(1) Each CPMS must complete a measurement at least once per push;

(2) Each CPMS must produce valid data for all pushes; and

(3) Each CPMS must determine and record the daily (24-hour) average of all recorded readings.

(f) For each hot water scrubber applied to pushing emissions, you must install, operate, and maintain CPMS to measure and record the water pressure and temperature during each push according to the requirements in paragraphs (b) through (d) of this section, except as specified in paragraphs (e)(1) through (3) of this section.

(g) If you elect the operating limit in § 63.7290(b)(3) for a capture system applied to pushing emissions, you must install, operate, and maintain a device to measure the total volumetric flow rate at the inlet of the control device.

(h) If you elect the operating limit in § 63.7290(b)(3)(i) for a capture system applied to pushing emissions, you must install, operate, and maintain a device to measure the fan motor amperes.

(i) If you elect the operating limit in § 63.7290(b)(3)(ii) for a capture system applied to pushing emissions, you must install, operate and maintain a device to measure static pressure at the inlet of the control device or the fan RPM.

(j) For each by-product coke oven battery, you must install, operate, and maintain a COMS to measure and record the opacity of emissions exiting each stack according to the requirements in paragraphs (j)(1) through (5) of this section.

(1) You must install, operate, and maintain each COMS according to the requirements in § 63.8(e) and Performance Specification 1 in 40 CFR part 60, appendix B. Identify periods the COMS is out-of-control, including any periods that the COMS fails to pass a daily calibration drift assessment, quarterly performance audit, or annual zero alignment audit.

(2) You must conduct a performance evaluation of each COMS according to the requirements in § 63.8 and Performance Specification 1 in appendix B to 40 CFR part 60;

(3) You must develop and implement a quality control program for operating and maintaining each COMS according to the requirements in § 63.8(d). At minimum, the quality control program must include a daily calibration

drift assessment, quarterly performance audit, and an annual zero alignment audit of each COMS;

(4) Each COMS must complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period. You must reduce the COMS data as specified in §63.8(g)(2).

(5) You must determine and record the hourly and daily (24-hour) average opacity according to the procedures in §63.7324(b) using all the 6-minute averages collected for periods during which the COMS is not out-of-control.

(k) For each multicyclone applied to pushing emissions, you must install, operate, and maintain CPMS to measure and record the pressure drop across each multicyclone during each push according to the requirements in paragraphs (b) through (d) of this section except as specified in paragraphs (e)(1) through (3) of this section.

[68 FR 18025, Apr. 14, 2003, as amended at 69 FR 60819, Oct. 13, 2004]

§63.7332 How do I monitor and collect data to demonstrate continuous compliance?

(a) Except for monitor malfunctions, associated repairs, and required quality assurance or control activities (including as applicable, calibration checks and required zero and span adjustments), you must monitor continuously (or collect data at all required intervals) at all times the affected source is operating.

(b) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels, or in fulfilling a minimum data availability requirement, if applicable. You must use all the data collected during all other periods in assessing compliance. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitor to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

§63.7333 How do I demonstrate continuous compliance with the emission limitations that apply to me?

(a) For each control device applied to pushing emissions and subject to the emission limit in §63.7290(a), you must demonstrate continuous compliance by meeting the requirements in paragraphs (a)(1) and (2) of this section:

(1) Maintaining emissions of particulate matter at or below the applicable limits in paragraphs §63.7290(a)(1) through (4); and

(2) Conducting subsequent performance tests to demonstrate continuous compliance no less frequently than twice during each term of your title V operating permit (at mid-term and renewal).

(b) For each venturi scrubber applied to pushing emissions and subject to the operating limits in §63.7290(b)(1), you must demonstrate continuous compliance by meeting the requirements in paragraphs (b)(1) through (3) of this section.

(1) Maintaining the daily average pressure drop and scrubber water flow rate at levels no lower than those established during the initial or subsequent performance test.

(2) Operating and maintaining each CPMS according to §63.7331(b) and recording all information needed to document conformance with these requirements.

(3) Collecting and reducing monitoring data for pressure drop and scrubber water flow rate according to §63.7331(e)(1) through (3).

(c) For each hot water scrubber applied to pushing emissions and subject to the operating limits in §63.7290(b)(2), you must demonstrate continuous compliance by meeting the requirements in paragraphs (c)(1) through (3) of this section.

(1) Maintaining the daily average water pressure and temperature at levels no lower than those established during the initial or subsequent performance test.

(2) Operating and maintaining each CPMS according to §63.7331(b) and recording all information needed to document conformance with these requirements.

(3) Collecting and reducing monitoring data for water pressure and temperature according to § 63.7331(f).

(d) For each capture system applied to pushing emissions and subject to the operating limit in § 63.7290(b)(3), you must demonstrate continuous compliance by meeting the requirements in paragraph (d)(1), (2), or (3) of this section:

(1) If you elect the operating limit for volumetric flow rate in § 63.7290(b)(3):

(i) Maintaining the daily average volumetric flow rate at the inlet of the control device at or above the minimum level established during the initial or subsequent performance test; and

(ii) Checking the volumetric flow rate at least every 8 hours to verify the daily average is at or above the minimum level established during the initial or subsequent performance test and recording the results of each check.

(2) If you elect the operating limit for fan motor amperes in § 63.7290(b)(3)(i):

(i) Maintaining the daily average fan motor amperages at or above the minimum level established during the initial or subsequent performance test; and

(ii) Checking the fan motor amperage at least every 8 hours to verify the daily average is at or above the minimum level established during the initial or subsequent performance test and recording the results of each check.

(3) If you elect the operating limit for static pressure or fan RPM in § 63.7290(b)(3)(ii):

(i) Maintaining the daily average static pressure at the inlet to the control device at an equal or greater vacuum than established during the initial or subsequent performance test or the daily average fan RPM at or above the minimum level established during the initial or subsequent performance test; and

(ii) Checking the static pressure or fan RPM at least every 8 hours to verify the daily average static pressure at the inlet to the control device is at an equal or greater vacuum than established during the initial or subsequent performance test or the daily average fan RPM is at or above the minimum level established during the initial or subsequent performance test and recording the results of each check.

(e) Beginning on the first day compliance is required under § 63.7283, you must demonstrate continuous compliance for each by-product coke oven battery subject to the opacity limit for stacks in § 63.7296(a) by meeting the requirements in paragraphs (e)(1) and (2) of this section:

(1) Maintaining the daily average opacity at or below 15 percent for a battery on a normal coking cycle or 20 percent for a battery on batterywide extended coking; and

(2) Operating and maintaining a COMS and collecting and reducing the COMS data according to § 63.7331(j).

(f) Beginning on the first day compliance is required under § 63.7283, you must demonstrate continuous compliance with the TDS limit for quenching in § 63.7295(a)(1)(i) by meeting the requirements in paragraphs (f)(1) and (2) of this section:

(1) Maintaining the TDS content of the water used to quench hot coke at 1,100 mg/L or less; and

(2) Determining the TDS content of the quench water at least weekly according to the requirements in § 63.7325(a) and recording the sample results.

(g) Beginning on the first day compliance is required under § 63.7283, you must demonstrate continuous compliance with the constituent limit for quenching in § 63.7295(a)(1)(ii) by meeting the requirements in paragraphs (g)(1) and (2) of this section:

(1) Maintaining the sum of the concentrations of benzene, benzo(a)pyrene, and naphthalene in the water used to quench hot coke at levels less than or equal to the site-specific limit approved by the permitting authority; and

(2) Determining the sum of the constituent concentrations at least monthly according to the requirements in § 63.7325(c) and recording the sample results.

(h) For each multicyclone applied to pushing emissions and subject to the operating limit in § 63.7290(b)(4), you must demonstrate compliance by meeting the requirements in paragraphs (h)(1) through (3) of this section.

(1) Maintaining the daily average pressure drop at a level at or below the level established during the initial or subsequent performance test.

(2) Operating and maintaining each CPMS according to §63.7331(k) and recording all information needed to document conformance with these requirements.

(3) Collecting and reducing monitoring data for pressure drop according to §63.7331(e)(1) through (3).

[68 FR 18025, Apr. 14, 2003, as amended at 69 FR 60819, Oct. 13, 2004]

§63.7334 How do I demonstrate continuous compliance with the work practice standards that apply to me?

(a) For each by-product coke oven battery with vertical flues subject to the work practice standards for fugitive pushing emissions in §63.7291(a), you must demonstrate continuous compliance according to the requirements of paragraphs (a)(1) through (8) of this section:

(1) Observe and record the opacity of fugitive emissions for four consecutive pushes per operating day, except you may make fewer or non-consecutive observations as permitted by §63.7291(a)(3). Maintain records of the pushing schedule for each oven and records indicating the legitimate operational reason for any change in the pushing schedule according to §63.7291(a)(4).

(2) Observe and record the opacity of fugitive emissions from each oven in a battery at least once every 90 days. If an oven cannot be observed during a 90-day period, observe and record the opacity of the first push of that oven following the close of the 90-day period that can be read in accordance with the procedures in paragraphs (a)(1) through (8) of this section.

(3) Make all observations and calculations for opacity observations of fugitive pushing emissions in accordance with Method 9 in appendix A to 40 CFR part 60 using a Method 9 certified observer unless you have an approved alternative procedure under paragraph (a)(7) of this section.

(4) Record pushing opacity observations at 15-second intervals as required in section 2.4 of Method 9 (appendix A to 40 CFR part 60). The requirement in section 2.4 of Method 9 for a minimum of 24 observations does not apply, and the data reduction requirements in section 2.5 of Method 9 do not apply. The requirement in §63.6(h)(5)(ii)(B) for obtaining at least 3 hours of observations (thirty 6-minute averages) to demonstrate initial compliance does not apply.

(5) If fewer than six but at least four 15-second observations can be made, use the average of the total number of observations to calculate average opacity for the push. Missing one or more observations during the push (*e.g.,* as the quench car passes behind a building) does not invalidate the observations before or after the interference for that push. However, a minimum of four 15-second readings must be made for a valid observation.

(6) Begin observations for a push at the first detectable movement of the coke mass. End observations of a push when the quench car enters the quench tower.

(i) For a battery without a cokeside shed, observe fugitive pushing emissions from a position at least 10 meters from the quench car that provides an unobstructed view and avoids interferences from the topside of the battery. This may require the observer to be positioned at an angle to the quench car rather than perpendicular to it. Typical interferences to avoid include emissions from open standpipes and charging. Observe the opacity of emissions above the battery top with the sky as the background where possible. Record the oven number of any push not observed because of obstructions or interferences.

(ii) For a battery with a cokeside shed, the observer must be in a position that provides an unobstructed view and avoids interferences from the topside of the battery. Typical interferences to avoid include emissions from open standpipes and charging. Observations must include any fugitive emissions that escape from the top of the shed, from the ends of the shed, or from the area where the shed is joined to the battery. If the observer does not have a clear view to identify when a push starts or ends, a second person can be positioned to signal the start or

end of the push and notify the observer when to start or end the observations. Radio communications with other plant personnel (*e.g.*, pushing ram operator or quench car operator) may also serve to notify the observer of the start or end of a push. Record the oven number of any push not observed because of obstructions or interferences.

(iii) You may reposition after the push to observe emissions during travel if necessary.

(7) If it is infeasible to implement the procedures in paragraphs (a)(1) through (6) of this section for an oven due to physical obstructions, nighttime pushes, or other reasons, you may apply to your permitting authority for permission to use an alternative procedure. The application must provide a detailed explanation of why it is infeasible to use the procedures in paragraphs (a)(1) through (6) of this section, identify the oven and battery numbers, and describe the alternative procedure. An alternative procedure must identify whether the coke in that oven is not completely coked, either before, during, or after an oven is pushed.

(8) For each oven observed that exceeds an opacity of 30 percent for any short battery or 35 percent for any tall battery, you must take corrective action and/or increase the coking time in accordance with §63.7291(a). Maintain records documenting conformance with the requirements in §63.7291(a).

(b) For each by-product coke oven battery with horizontal flues subject to the work practice standards for fugitive pushing emissions in §63.7292(a), you must demonstrate continuous compliance by having met the requirements of paragraphs (b)(1) through (3) of this section:

(1) Measuring and recording the temperature of all flues on two ovens per day within 2 hours before the oven's scheduled pushing time and ensuring that the temperature of each oven is measured and recorded at least once every month;

(2) Recording the time each oven is charged and pushed and calculating and recording the net coking time for each oven; and

(3) Increasing the coking time for each oven that falls below the minimum flue temperature trigger established for that oven's coking time in the written plan required in §63.7292(a)(1), assigning the oven to the oven-directed program, and recording all relevant information according to the requirements in §63.7292(a)(4) including, but not limited to, daily pushing schedules, diagnostic procedures, corrective actions, and oven repairs.

(c) For each non-recovery coke oven battery subject to the work practice standards in §63.7293(a), you must demonstrate continuous compliance by maintaining records that document each visual inspection of an oven prior to pushing and that the oven was not pushed unless there was no smoke in the open space above the coke bed and there was an unobstructed view of the door on the opposite side of the oven.

(d) For each by-product coke oven battery subject to the work practice standard for soaking in §63.7294(a), you must demonstrate continuous compliance by maintaining records that document conformance with requirements in §63.7294(a)(1) through (5).

(e) For each coke oven battery subject to the work practice standard for quenching in §63.7295(b), you must demonstrate continuous compliance according to the requirements of paragraphs (e)(1) through (3) of this section:

(1) Maintaining baffles in each quench tower such that no more than 5 percent of the cross-sectional area of the tower is uncovered or open to the sky as required in §63.7295(b)(1);

(2) Maintaining records that document conformance with the washing, inspection, and repair requirements in §63.7295(b)(2), including records of the ambient temperature on any day that the baffles were not washed; and

(3) Maintaining records of the source of makeup water to document conformance with the requirement for acceptable makeup water in §63.7295(a)(2).

§63.7335 How do I demonstrate continuous compliance with the operation and maintenance requirements that apply to me?

(a) For each by-product coke oven battery, you must demonstrate continuous compliance with the operation and maintenance requirements in §63.7300(b) by adhering at all times to the plan requirements and recording

all information needed to document conformance.

(b) For each coke oven battery with a capture system or control device applied to pushing emissions, you must demonstrate continuous compliance with the operation and maintenance requirements in §63.7300(c) by meeting the requirements of paragraphs (b)(1) through (3) of this section:

(1) Making monthly inspections of capture systems according to §63.7300(c)(1) and recording all information needed to document conformance with these requirements;

(2) Performing preventative maintenance for each control device according to §63.7300(c)(2) and recording all information needed to document conformance with these requirements; and

(3) Initiating and completing corrective action for a bag leak detection system alarm according to §63.7300(c)(3) and recording all information needed to document conformance with these requirements. This includes records of the times the bag leak detection system alarm sounds, and for each valid alarm, the time you initiated corrective action, the corrective action(s) taken, and the date on which corrective action is completed.

(c) To demonstrate continuous compliance with the operation and maintenance requirements for a baghouse applied to pushing emissions from a coke oven battery in §63.7331(a), you must inspect and maintain each baghouse according to the requirements in §63.7331(a)(1) through (8) and record all information needed to document conformance with these requirements. If you increase or decrease the sensitivity of the bag leak detection system beyond the limits specified in §63.7331(a)(6), you must include a copy of the required written certification by a responsible official in the next semiannual compliance report.

(d) You must maintain a current copy of the operation and maintenance plans required in §63.7300(b) and (c) onsite and available for inspection upon request. You must keep the plans for the life of the affected source or until the affected source is no longer subject to the requirements of this subpart.

§63.7336 What other requirements must I meet to demonstrate continuous compliance?

(a) *Deviations.* You must report each instance in which you did not meet each emission limitation in this subpart that applies to you. This includes periods of startup, shutdown, and malfunction. You must also report each instance in which you did not meet each work practice standard or operation and maintenance requirement in this subpart that applies to you. These instances are deviations from the emission limitations (including operating limits), work practice standards, and operation and maintenance requirements in this subpart. These deviations must be reported according to the requirements in §63.7341.

(b) *Startup, shutdowns, and malfunctions.* (1) Consistent with §§63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with §63.6(e)(1).

(2) The Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in §63.6(e).

[68 FR 18025, Apr. 14, 2003, as amended at 71 FR 20467, Apr. 20, 2006]

NOTIFICATION, REPORTS, AND RECORDS

§63.7340 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.6(h)(4) and (5), 63.7(b) and (c), 63.8(e) and (f)(4), and 63.9(b) through (h) that apply to you by the specified dates.

(b) As specified in §63.9(b)(2), if you startup your affected source before April 14, 2003, you must submit your initial notification no later than August 12, 2003.

(c) As specified in §63.9(b)(3), if you startup your new affected source on or after April 14, 2003, you must submit your initial notification no later than 120 calendar days after you become subject to this subpart.

(d) If you are required to conduct a performance test, you must submit a

notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin as required in § 63.7(b)(1).

(e) If you are required to conduct a performance test, opacity observation, or other initial compliance demonstration, you must submit a notification of compliance status according to § 63.9(h)(2)(ii).

(1) For each initial compliance demonstration that does not include a performance test, you must submit the notification of compliance status before the close of business on the 30th calendar day following the completion of the initial compliance demonstration.

(2) For each initial compliance demonstration that does include a performance test, you must submit the notification of compliance status, including the performance test results, before the close of business on the 60th calendar day following completion of the performance test according to § 63.10(d)(2).

(f) For each by-product coke oven battery with horizontal flues, you must notify the Administrator (or delegated authority) of the date on which the study of flue temperatures required by § 63.7292(a)(3) will be initiated. You must submit this notification no later than 7 days prior to the date you initiate the study.

§ 63.7341 What reports must I submit and when?

(a) *Compliance report due dates.* Unless the Administrator has approved a different schedule, you must submit quarterly compliance reports for battery stacks and semiannual compliance reports for all other affected sources to your permitting authority according to the requirements in paragraphs (a)(1) through (4) of this section.

(1) The first quarterly compliance report for battery stacks must cover the period beginning on the compliance date that is specified for your affected source in § 63.7283 and ending on the last date of the third calendar month. Each subsequent compliance report must cover the next calendar quarter.

(2) The first semiannual compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.7283 and ending on June 30 or December 31, whichever date comes first after the compliance date that is specified for your affected source. Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(3) All quarterly compliance reports for battery stacks must be postmarked or delivered no later than one calendar month following the end of the quarterly reporting period. All semiannual compliance reports must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(4) For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (a)(1) through (3) of this section.

(b) *Quarterly compliance report contents.* Each quarterly report must provide information on compliance with the emission limitations for battery stacks in § 63.7296. The reports must include the information in paragraphs (c)(1) through (3), and as applicable, paragraphs (c)(4) through (8) of this section.

(c) *Semiannual compliance report contents.* Each compliance report must provide information on compliance with the emission limitations, work practice standards, and operation and maintenance requirements for all affected sources except battery stacks. The reports must include the information in paragraphs (c)(1) through (3) of this section, and as applicable, paragraphs (c)(4) through (8) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with the official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a startup, shutdown, or malfunction during the reporting period and you took actions consistent with your startup, shutdown, and malfunction plan, the compliance report must include the information in §63.10(d)(5)(i).

(5) If there were no deviations from the continuous compliance requirements in §63.7333(e) for battery stacks, a statement that there were no deviations from the emission limitations during the reporting period. If there were no deviations from the continuous compliance requirements in §§63.7333 through 63.7335 that apply to you (for all affected sources other than battery stacks), a statement that there were no deviations from the emission limitations, work practice standards, or operation and maintenance requirements during the reporting period.

(6) If there were no periods during which a continuous monitoring system (including COMS, continuous emission monitoring system (CEMS), or CPMS) was out-of-control as specified in §63.8(c)(7), a statement that there were no periods during which a continuous monitoring system was out-of-control during the reporting period.

(7) For each deviation from an emission limitation in this subpart (including quench water limits) and for each deviation from the requirements for work practice standards in this subpart that occurs at an affected source where you are not using a continuous monitoring system (including a COMS, CEMS, or CPMS) to comply with the emission limitations in this subpart, the compliance report must contain the information in paragraphs (c)(4) and (7)(i) and (ii) of this section. This includes periods of startup, shutdown, and malfunction.

(i) The total operating time of each affected source during the reporting period.

(ii) Information on the number, duration, and cause of deviations (including unknown cause, if applicable) as applicable and the corrective action taken.

(8) For each deviation from an emission limitation occurring at an affected source where you are using a continuous monitoring system (including COMS, CEMS, or CPMS) to comply with the emission limitation in this subpart, you must include the information in paragraphs (c)(4) and (8)(i) through (xii) of this section. This includes periods of startup, shutdown, and malfunction.

(i) The date and time that each malfunction started and stopped.

(ii) The date and time that each continuous monitoring system (including COMS, CEMS, or CPMS) was inoperative, except for zero (low-level) and high-level checks.

(iii) The date, time, and duration that each continuous monitoring system (including COMS, CEMS, or CPMS) was out-of-control, including the information in §63.8(c)(8).

(iv) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(v) A summary of the total duration of the deviation during the reporting period and the total duration as a percent of the total source operating time during that reporting period.

(vi) A breakdown of the total duration of the deviations during the reporting period into those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and other unknown causes.

(vii) A summary of the total duration of continuous monitoring system downtime during the reporting period and the total duration of continuous monitoring system downtime as a percent of the total source operating time during the reporting period.

(viii) An identification of each HAP that was monitored at the affected source.

(ix) A brief description of the process units.

(x) A brief description of the continuous monitoring system.

(xi) The date of the latest continuous monitoring system certification or audit.

(xii) A description of any changes in continuous monitoring systems, processes, or controls since the last reporting period.

(d) *Immediate startup, shutdown, and malfunction report.* If you had a startup,

shutdown, or malfunction during the semiannual reporting period that was not consistent with your startup, shutdown, and malfunction plan, you must submit an immediate startup, shutdown, and malfunction report according to the requirements in § 63.10(d)(5)(ii).

(e) *Part 70 monitoring report.* If you have obtained a title V operating permit for an affected source pursuant to 40 CFR part 70 or 40 CFR part 71, you must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If you submit a compliance report for an affected source along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all the required information concerning deviations from any emission limitation or work practice standard in this subpart, submission of the compliance report satisfies any obligation to report the same deviations in the semiannual monitoring report. However, submission of a compliance report does not otherwise affect any obligation you may have to report deviations from permit requirements to your permitting authority.

§ 63.7342 What records must I keep?

(a) You must keep the records specified in paragraphs (a)(1) through (3) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any initial notification or notification of compliance status that you submitted, according to the requirements in § 63.10(b)(2)(xiv).

(2) The records in § 63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.

(3) Records of performance tests, performance evaluations, and opacity observations as required in § 63.10(b)(2)(viii).

(b) For each COMS or CEMS, you must keep the records specified in paragraphs (b)(1) through (4) of this section.

(1) Records described in § 63.10(b)(2)(vi) through (xi).

(2) Monitoring data for COMS during a performance evaluation as required in § 63.6(h)(7)(i) and (ii).

(3) Previous (that is, superceded) versions of the performance evaluation plan as required in § 63.8(d)(3).

(4) Records of the date and time that each deviation started and stopped, and whether the deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(c) You must keep the records in § 63.6(h)(6) for visual observations.

(d) You must keep the records required in §§ 63.7333 through 63.7335 to show continuous compliance with each emission limitation, work practice standard, and operation and maintenance requirement that applies to you.

§ 63.7343 In what form and how long must I keep my records?

(a) You must keep your records in a form suitable and readily available for expeditious review, according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record on site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1). You can keep the records offsite for the remaining 3 years.

OTHER REQUIREMENTS AND INFORMATION

§ 63.7350 What parts of the General Provisions apply to me?

Table 1 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you.

§ 63.7351 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the United States Environmental Protection Agency (U.S. EPA), or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency has the authority to implement and

enforce this subpart. You should contact your U.S. EPA Regional Office to find out if this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under subpart E of this part, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities in paragraphs (c)(1) through (6) of this section will not be delegated to State, local, or tribal agencies.

(1) Approval of alternatives to work practice standards for fugitive pushing emissions in §63.7291(a) for a by-product coke oven battery with vertical flues, fugitive pushing emissions in §63.7292(a) for a by-product coke oven battery with horizontal flues, fugitive pushing emissions in §63.7293 for a non-recovery coke oven battery, soaking for a by-product coke oven battery in §63.7294(a), and quenching for a coke oven battery in §63.7295(b) under §63.6(g).

(2) Approval of alternative opacity emission limitations for a by-product coke oven battery under §63.6(h)(9).

(3) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90, except for alternative procedures in §63.7334(a)(7).

(4) Approval of major alternatives to monitoring under §63.8(f) and as defined in §63.90.

(5) Approval of major alternatives to recordkeeping and reporting under §63.10(f) and as defined in §63.90.

(6) Approval of the work practice plan for by-product coke oven batteries with horizontal flues submitted under §63.7292(a)(1).

§63.7352 What definitions apply to this subpart?

Terms used in this subpart are defined in the Clean Air Act (CAA), in §63.2, and in this section as follows:

Acceptable makeup water means surface water from a river, lake, or stream; water meeting drinking water standards; storm water runoff and production area clean up water except for water from the by-product recovery plant area; process wastewater treated to meet effluent limitations guidelines in 40 CFR part 420; water from any of these sources that has been used only for non-contact cooling or in water seals; or water from scrubbers used to control pushing emissions.

Backup quench station means a quenching device that is used for less than 5 percent of the quenches from any single coke oven battery in the 12-month period from July 1 to June 30.

Baffles means an apparatus comprised of obstructions for checking or deflecting the flow of gases. Baffles are installed in a quench tower to remove droplets of water and particles from the rising vapors by providing a point of impact. Baffles may be installed either inside or on top of quench towers and are typically constructed of treated wood, steel, or plastic.

Battery stack means the stack that is the point of discharge to the atmosphere of the combustion gases from a battery's underfiring system.

Batterywide extended coking means increasing the average coking time for all ovens in the coke oven battery by 25 percent or more over the manufacturer's specified design rate.

By-product coke oven battery means a group of ovens connected by common walls, where coal undergoes destructive distillation under positive pressure to produce coke and coke oven gas from which by-products are recovered.

By-product recovery plant area means that area of the coke plant where process units subject to subpart L in part 61 are located.

Coke oven battery means a group of ovens connected by common walls, where coal undergoes destructive distillation to produce coke. A coke oven battery includes by-product and non-recovery processes.

Coke plant means a facility that produces coke from coal in either a by-product coke oven battery or a non-recovery coke oven battery.

Cokeside shed means a structure used to capture pushing emissions that encloses the cokeside of the battery and ventilates the emissions to a control device.

Coking time means the time interval that starts when an oven is charged

with coal and ends when the oven is pushed.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart including, but not limited to, any emission limitation (including operating limits) or work practice standard;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or

(3) Fails to meet any emission limitation or work practice standard in this subpart during startup, shutdown, or malfunction, regardless of whether or not such failure is permitted by this subpart.

Emission limitation means any emission limit, opacity limit, or operating limit.

Four consecutive pushes means four pushes observed successively.

Fugitive pushing emissions means emissions from pushing that are not collected by a capture system.

Horizontal flue means a type of coke oven heating system used on Semet-Solvay batteries where the heating flues run horizontally from one end of the oven to the other end, and the flues are not shared with adjacent ovens.

Hot water scrubber means a mobile scrubber used to control pushing emissions through the creation of an induced draft formed by the expansion of pressurized hot water through a nozzle.

Increased coking time means increasing the charge-to-push time for an individual oven.

Non-recovery coke oven battery means a group of ovens connected by common walls and operated as a unit, where coal undergoes destructive distillation under negative pressure to produce coke, and which is designed for the combustion of the coke oven gas from which by-products are not recovered.

Oven means a chamber in the coke oven battery in which coal undergoes destructive distillation to produce coke.

Pushing means the process of removing the coke from the oven. Pushing begins with the first detectable movement of the coke mass and ends when the quench car enters the quench tower.

Quenching means the wet process of cooling (wet quenching) the hot incandescent coke by direct contact with water that begins when the quench car enters the quench tower and ends when the quench car exits the quench tower.

Quench tower means the structure in which hot incandescent coke in the quench car is deluged or quenched with water.

Remove from service means that an oven is not charged with coal and is not used for coking. When removed from service, the oven may remain at the operating temperature or it may be cooled down for repairs.

Responsible official means responsible official as defined in § 63.2.

Short battery means a by-product coke oven battery with ovens less than five meters in height.

Soaking means that period in the coking cycle that starts when an oven is dampered off the collecting main and vented to the atmosphere through an open standpipe prior to pushing and ends when the coke begins to be pushed from the oven.

Soaking emissions means the discharge from an open standpipe during soaking of visible emissions due to either incomplete coking or leakage into the standpipe from the collecting main.

Standpipe means an apparatus on the oven that provides a passage for gases from an oven to the atmosphere when the oven is dampered off the collecting main and the standpipe cap is opened. This includes mini-standpipes that are not connected to the collecting main.

Tall battery means a by-product coke oven battery with ovens five meters or more in height.

Vertical flue means a type of coke oven heating system in which the heating flues run vertically from the bottom to the top of the oven, and flues are shared between adjacent ovens.

Work practice standard means any design, equipment, work practice, or operational standard, or combination thereof, that is promulgated pursuant to section 112(h) of the CAA.

TABLE 1 TO SUBPART CCCCC OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART CCCCC

As required in §63.7350, you must comply with each applicable requirement of the NESHAP General Provisions (40 CFR part 63, subpart A) as shown in the following table:

Citation	Subject	Applies to Subpart CCCCC?	Explanation
§63.1	Applicability	Yes.	
§63.2	Definitions	Yes.	
§63.3	Units and Abbreviations	Yes.	
§63.4	Prohibited Activities	Yes.	
§63.5	Construction/Reconstruction	Yes.	
§63.6(a), (b), (c), (d), (e), (f), (g), (h)(2)–(8).	Compliance with Standards and Maintenance Requirements.	Yes.	
§63.6(h)(9)	Adjustment to an Opacity Emission Standard.	Yes.	
§63.7(a)(3), (b), (c)–(h)	Performance Testing Requirements	Yes.	
§63.7(a)(1)–(2)	Applicability and Performance Test Dates.	No	Subpart CCCCC specifies applicability and dates.
§63.8(a)(1)–(3), (b), (c)(1)–(3), (c)(4)(i)–(ii), (c)(5)–(8), (d), (e), (f)(1)–(5), (g)(1)–(4).	Monitoring Requirements	Yes	CMS requirements in §63.8(c)(4)(i)–(ii), (c)(5), and (c)(6) apply only to COMS for battery stacks.
§63.8(a)(4)	Additional Monitoring Requirements for Control Devices in §63.11.	No	Flares are not a control device for Subpart CCCCC affected sources.
§63.8(c)(4)	Continuous Monitoring System (CMS) Requirements.	No	Subpart CCCCC specifies requirements for operation of CMS.
§63.8(e)(4)–(5)	Performance Evaluations	Yes	Except COMS performance evaluation must be conducted before the compliance date.
§63.8(f)(6)	RATA Alternative	No	Subpart CCCCC does not require CEMS.
§63.8(g)(5)	Data Reduction	No	Subpart CCCCC specifies data that can't be used in computing averages for COMS.
§63.9	Notification Requirements	Yes	Additional notifications for CMS in §63.9(g) apply only to COMS for battery stacks.
§63.10(a), (b)(1)–(b)(2)(xii), (b)(2)(xiv), (b)(3), (c)(1)–(6), (c)(9)–(15), (d), (e)(1)–(2), (e)(4), (f).	Recordkeeping and Reporting Requirements.	Yes.	Additional records for CMS in §63.10(c)(1)–(6), (9)–(15), and reports in §63.10(d)(1)–(2) apply only to COMS for battery stacks.
§63.10(b)(2) (xi)–(xii)	CMS Records for RATA Alternative	No	Subpart CCCCC doesn't require CEMS.
§63.10(c)(7)–(8)	Records of Excess Emissions and Parameter Monitoring Exceedances for CMS.	No	Subpart CCCCC specifies record requirements.
§63.10(e)(3)	Excess Emission Reports	No	Subpart CCCCC specifies reporting requirements.
§63.11	Control Device Requirements	No	Subpart CCCCC does not require flares.
§63.12	State Authority and Delegations.	Yes.	
§§63.13–63.15	Addresses, Incorporation by Reference, Availability of Information.	Yes.	

Subpart DDDDD—National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters

SOURCE: 69 FR 55253, Sept. 13, 2004, unless otherwise noted.

WHAT THIS SUBPART COVERS

§63.7480 What is the purpose of this subpart?

This subpart establishes national emission limits and work practice standards for hazardous air pollutants (HAP) emitted from industrial, commercial, and institutional boilers and process heaters. This subpart also establishes requirements to demonstrate

initial and continuous compliance with the emission limits and work practice standards.

§ 63.7485 Am I subject to this subpart?

You are subject to this subpart if you own or operate an industrial, commercial, or institutional boiler or process heater as defined in § 63.7575 that is located at, or is part of, a major source of HAP as defined in § 63.2 or § 63.761 (40 CFR part 63, subpart HH, National Emission Standards for Hazardous Air Pollutants from Oil and Natural Gas Production Facilities), except as specified in § 63.7491.

§ 63.7490 What is the affected source of this subpart?

(a) This subpart applies to new, reconstructed, or existing affected sources as described in paragraphs (a)(1) and (2) of this section.

(1) The affected source of this subpart is the collection of all existing industrial, commercial, and institutional boilers and process heaters within a subcategory located at a major source as defined in § 63.7575.

(2) The affected source of this subpart is each new or reconstructed industrial, commercial, or institutional boiler or process heater located at a major source as defined in § 63.7575.

(b) A boiler or process heater is new if you commence construction of the boiler or process heater after January 13, 2003, and you meet the applicability criteria at the time you commence construction.

(c) A boiler or process heater is reconstructed if you meet the reconstruction criteria as defined in § 63.2, you commence reconstruction after January 13, 2003, and you meet the applicability criteria at the time you commence reconstruction.

(d) A boiler or process heater is existing if it is not new or reconstructed.

§ 63.7491 Are any boilers or process heaters not subject to this subpart?

The types of boilers and process heaters listed in paragraphs (a) through (o) of this section are not subject to this subpart.

(a) A municipal waste combustor covered by 40 CFR part 60, subpart AAAA, subpart BBBB, subpart Cb or subpart Eb.

(b) A hospital/medical/infectious waste incinerator covered by 40 CFR part 60, subpart Ce or subpart Ec.

(c) An electric utility steam generating unit that is a fossil fuel-fired combustion unit of more than 25 megawatts that serves a generator that produces electricity for sale. A fossil fuel-fired unit that cogenerates steam and electricity, and supplies more than one-third of its potential electric output capacity, and more than 25 megawatts electrical output to any utility power distribution system for sale is considered an electric utility steam generating unit.

(d) A boiler or process heater required to have a permit under section 3005 of the Solid Waste Disposal Act or covered by 40 CFR part 63, subpart EEE (*e.g.*, hazardous waste boilers).

(e) A commercial and industrial solid waste incineration unit covered by 40 CFR part 60, subpart CCCC or subpart DDDD.

(f) A recovery boiler or furnace covered by 40 CFR part 63, subpart MM.

(g) A boiler or process heater that is used specifically for research and development. This does not include units that only provide heat or steam to a process at a research and development facility.

(h) A hot water heater as defined in this subpart.

(i) A refining kettle covered by 40 CFR part 63, subpart X.

(j) An ethylene cracking furnace covered by 40 CFR part 63, subpart YY.

(k) Blast furnace stoves as described in the EPA document, entitled ''National Emission Standards for Hazardous Air Pollutants (NESHAP) for Integrated Iron and Steel Plants—Background Information for Proposed Standards,'' (EPA–453/R–01–005).

(l) Any boiler and process heater specifically listed as an affected source in another standard(s) under 40 CFR part 63.

(m) Any boiler and process heater specifically listed as an affected source in another standard(s) established under section 129 of the Clean Air Act (CAA).

(n) Temporary boilers as defined in this subpart.

(o) Blast furnace gas fuel-fired boilers and process heaters as defined in this subpart.

§ 63.7495 When do I have to comply with this subpart?

(a) If you have a new or reconstructed boiler or process heater, you must comply with this subpart by November 12, 2004 or upon startup of your boiler or process heater, whichever is later.

(b) If you have an existing boiler or process heater, you must comply with this subpart no later than September 13, 2007.

(c) If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, paragraphs (c)(1) and (2) of this section apply to you.

(1) Any new or reconstructed boiler or process heater at the existing facility must be in compliance with this subpart upon startup.

(2) Any existing boiler or process heater at the existing facility must be in compliance with this subpart within 3 years after the facility becomes a major source.

(d) You must meet the notification requirements in § 63.7545 according to the schedule in § 63.7545 and in subpart A of this part. Some of the notifications must be submitted before you are required to comply with the emission limits and work practice standards in this subpart.

EMISSION LIMITS AND WORK PRACTICE STANDARDS

§ 63.7499 What are the subcategories of boilers and process heaters?

The subcategories of boilers and process heaters are large solid fuel, limited use solid fuel, small solid fuel, large liquid fuel, limited use liquid fuel, small liquid fuel, large gaseous fuel, limited use gaseous fuel, and small gaseous fuel. Each subcategory is defined in § 63.7575.

§ 63.7500 What emission limits, work practice standards, and operating limits must I meet?

(a) You must meet the requirements in paragraphs (a)(1) and (2) of this section.

(1) You must meet each emission limit and work practice standard in Table 1 to this subpart that applies to your boiler or process heater, except as provided under § 63.7507.

(2) You must meet each operating limit in Tables 2 through 4 to this subpart that applies to your boiler or process heater. If you use a control device or combination of control devices not covered in Tables 2 through 4 to this subpart, or you wish to establish and monitor an alternative operating limit and alternative monitoring parameters, you must apply to the United States Environmental Protection Agency (EPA) Administrator for approval of alternative monitoring under § 63.8(f).

(b) As provided in § 63.6(g), EPA may approve use of an alternative to the work practice standards in this section.

GENERAL COMPLIANCE REQUIREMENTS

§ 63.7505 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limits (including operating limits) and the work practice standards in this subpart at all times, except during periods of startup, shutdown, and malfunction.

(b) You must always operate and maintain your affected source, including air pollution control and monitoring equipment, according to the provisions in § 63.6(e)(1)(i).

(c) You can demonstrate compliance with any applicable emission limit using fuel analysis if the emission rate calculated according to § 63.7530(d) is less than the applicable emission limit. Otherwise, you must demonstrate compliance using performance testing.

(d) If you demonstrate compliance with any applicable emission limit through performance testing, you must develop a site-specific monitoring plan according to the requirements in paragraphs (d)(1) through (4) of this section. This requirement also applies to you if you petition the EPA Administrator for alternative monitoring parameters under § 63.8(f).

(1) For each continuous monitoring system (CMS) required in this section, you must develop and submit to the

EPA Administrator for approval a site-specific monitoring plan that addresses paragraphs (d)(1)(i) through (iii) of this section. You must submit this site-specific monitoring plan at least 60 days before your initial performance evaluation of your CMS.

(i) Installation of the CMS sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the exhaust emissions (*e.g.*, on or downstream of the last control device);

(ii) Performance and equipment specifications for the sample interface, the pollutant concentration or parametric signal analyzer, and the data collection and reduction systems; and

(iii) Performance evaluation procedures and acceptance criteria (*e.g.*, calibrations).

(2) In your site-specific monitoring plan, you must also address paragraphs (d)(2)(i) through (iii) of this section.

(i) Ongoing operation and maintenance procedures in accordance with the general requirements of § 63.8(c)(1), (c)(3), and (c)(4)(ii);

(ii) Ongoing data quality assurance procedures in accordance with the general requirements of § 63.8(d); and

(iii) Ongoing recordkeeping and reporting procedures in accordance with the general requirements of § 63.10(c), (e)(1), and (e)(2)(i).

(3) You must conduct a performance evaluation of each CMS in accordance with your site-specific monitoring plan.

(4) You must operate and maintain the CMS in continuous operation according to the site-specific monitoring plan.

(e) If you have an applicable emission limit or work practice standard, you must develop a written startup, shutdown, and malfunction plan (SSMP) according to the provisions in § 63.6(e)(3).

[69 FR 55253, Sept. 13, 2004, as amended at 71 FR 20467, Apr. 20, 2006]

§ 63.7506 Do any boilers or process heaters have limited requirements?

(a) New or reconstructed boilers and process heaters in the large liquid fuel subcategory or the limited use liquid fuel subcategory that burn only fossil fuels and other gases and do not burn any residual oil are subject to the emission limits and applicable work practice standards in Table 1 to this subpart. You are not required to conduct a performance test to demonstrate compliance with the emission limits. You are not required to set and maintain operating limits to demonstrate continuous compliance with the emission limits. However, you must meet the requirements in paragraphs (a)(1) and (2) of this section and meet the CO work practice standard in Table 1 to this subpart.

(1) To demonstrate initial compliance, you must include a signed statement in the Notification of Compliance Status report required in § 63.7545(e) that indicates you burn only liquid fossil fuels other than residual oils, either alone or in combination with gaseous fuels.

(2) To demonstrate continuous compliance with the applicable emission limits, you must also keep records that demonstrate that you burn only liquid fossil fuels other than residual oils, either alone or in combination with gaseous fuels. You must also include a signed statement in each semiannual compliance report required in § 63.7550 that indicates you burned only liquid fossil fuels other than residual oils, either alone or in combination with gaseous fuels, during the reporting period.

(b) The affected boilers and process heaters listed in paragraphs (b)(1) through (3) of this section are subject to only the initial notification requirements in § 63.9(b) (*i.e.*, they are not subject to the emission limits, work practice standards, performance testing, monitoring, SSMP, site-specific monitoring plans, recordkeeping and reporting requirements of this subpart or any other requirements in subpart A of this part).

(1) Existing large and limited use gaseous fuel units.

(2) Existing large and limited use liquid fuel units.

(3) New or reconstructed small liquid fuel units that burn only gaseous fuels or distillate oil. New or reconstructed small liquid fuel boilers and process heaters that commence burning of any other type of liquid fuel must comply with all applicable requirements of this

subpart and subpart A of this part upon startup of burning the other type of liquid fuel.

(c) The affected boilers and process heaters listed in paragraphs (c)(1) through (4) of this section are not subject to the initial notification requirements in §63.9(b) and are not subject to any requirements in this subpart or in subpart A of this part (*i.e.*, they are not subject to the emission limits, work practice standards, performance testing, monitoring, SSM plans, site-specific monitoring plans, recordkeeping and reporting requirements of this subpart, or any other requirements in subpart A of this part.

(1) Existing small solid fuel boilers and process heaters.

(2) Existing small liquid fuel boilers and process heaters.

(3) Existing small gaseous fuel boilers and process heaters.

(4) New or reconstructed small gaseous fuel units.

§63.7507 What are the health-based compliance alternatives for the hydrogen chloride (HCl) and total selected metals (TSM) standards?

(a) As an alternative to the requirement to demonstrate compliance with the HCl emission limit in table 1 to this subpart, you may demonstrate eligibility for the health-based compliance alternative for HCl emissions under the procedures prescribed in appendix A to this subpart.

(b) As an alternative to the requirement to demonstrate compliance with the TSM emission limit in table 1 to this subpart based on the sum of emissions for the eight selected metals, you may demonstrate eligibility for the health-based alternative for manganese emissions under the procedures prescribed in appendix A to this subpart and comply with the TSM emission standards in table 1 based on the sum of emissions for seven selected metals (by excluding manganese emissions from the summation of TSM emissions).

[70 FR 76933, Dec. 28, 2005]

TESTING, FUEL ANALYSES, AND INITIAL COMPLIANCE REQUIREMENTS

§63.7510 What are my initial compliance requirements and by what date must I conduct them?

(a) For affected sources that elect to demonstrate compliance with any of the emission limits of this subpart through performance testing, your initial compliance requirements include conducting performance tests according to §63.7520 and Table 5 to this subpart, conducting a fuel analysis for each type of fuel burned in your boiler or process heater according to §63.7521 and Table 6 to this subpart, establishing operating limits according to §63.7530 and Table 7 to this subpart, and conducting CMS performance evaluations according to §63.7525.

(b) For affected sources that elect to demonstrate compliance with the emission limits for HCl, mercury, or TSM through fuel analysis, your initial compliance requirement is to conduct a fuel analysis for each type of fuel burned in your boiler or process heater according to §63.7521 and Table 6 to this subpart and establish operating limits according to §63.7530 and Table 8 to this subpart.

(c) For affected sources that have an applicable work practice standard, your initial compliance requirements depend on the subcategory and rated capacity of your boiler or process heater. If your boiler or process heater is in any of the limited use subcategories or has a heat input capacity less than 100 MMBtu per hour, your initial compliance demonstration is conducting a performance test for carbon monoxide according to Table 5 to this subpart. If your boiler or process heater is in any of the large subcategories and has a heat input capacity of 100 MMBtu per hour or greater, your initial compliance demonstration is conducting a performance evaluation of your continuous emission monitoring system for carbon monoxide according to §63.7525(a).

(d) For existing affected sources, you must demonstrate initial compliance no later than 180 days after the compliance date that is specified for your source in §63.7495 and according to the

applicable provisions in §63.7(a)(2) as cited in Table 10 to this subpart.

(e) If your new or reconstructed affected source commenced construction or reconstruction between January 13, 2003 and November 12, 2004, you must demonstrate initial compliance with either the proposed emission limits and work practice standards or the promulgated emission limits and work practice standards no later than 180 days after November 12, 2004 or within 180 days after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

(f) If your new or reconstructed affected source commenced construction or reconstruction between January 13, 2003, and November 12, 2004, and you chose to comply with the proposed emission limits and work practice standards when demonstrating initial compliance, you must conduct a second compliance demonstration for the promulgated emission limits and work practice standards within 3 years after November 12, 2004 or within 3 years after startup of the affected source, whichever is later.

(g) If your new or reconstructed affected source commences construction or reconstruction after November 12, 2004, you must demonstrate initial compliance with the promulgated emission limits and work practice standards no later than 180 days after startup of the source.

§63.7515 When must I conduct subsequent performance tests or fuel analyses?

(a) You must conduct all applicable performance tests according to §63.7520 on an annual basis, unless you follow the requirements listed in paragraphs (b) through (d) of this section. Annual performance tests must be completed between 10 and 12 months after the previous performance test, unless you follow the requirements listed in paragraphs (b) through (d) of this section.

(b) You can conduct performance tests less often for a given pollutant if your performance tests for the pollutant (particulate matter, HCl, mercury, or TSM) for at least 3 consecutive years show that you comply with the emission limit. In this case, you do not have to conduct a performance test for that pollutant for the next 2 years. You must conduct a performance test during the third year and no more than 36 months after the previous performance test.

(c) If your boiler or process heater continues to meet the emission limit for particulate matter, HCl, mercury, or TSM, you may choose to conduct performance tests for these pollutants every third year, but each such performance test must be conducted no more than 36 months after the previous performance test.

(d) If a performance test shows noncompliance with an emission limit for particulate matter, HCl, mercury, or TSM, you must conduct annual performance tests for that pollutant until all performance tests over a consecutive 3-year period show compliance.

(e) If you have an applicable work practice standard for carbon monoxide and your boiler or process heater is in any of the limited use subcategories or has a heat input capacity less than 100 MMBtu per hour, you must conduct annual performance tests for carbon monoxide according to §63.7520. Each annual performance test must be conducted between 10 and 12 months after the previous performance test.

(f) You must conduct a fuel analysis according to §63.7521 for each type of fuel burned no later than 5 years after the previous fuel analysis for each fuel type. If you burn a new type of fuel, you must conduct a fuel analysis before burning the new type of fuel in your boiler or process heater. You must still meet all applicable continuous compliance requirements in §63.7540.

(g) You must report the results of performance tests and fuel analyses within 60 days after the completion of the performance tests or fuel analyses. This report should also verify that the operating limits for your affected source have not changed or provide documentation of revised operating parameters established according to §63.7530 and Table 7 to this subpart, as applicable. The reports for all subsequent performance tests and fuel analyses should include all applicable information required in §63.7550.

§63.7520 What performance tests and procedures must I use?

(a) You must conduct all performance tests according to §63.7(c), (d), (f), and (h). You must also develop a site-specific test plan according to the requirements in §63.7(c) if you elect to demonstrate compliance through performance testing.

(b) You must conduct each performance test according to the requirements in Table 5 to this subpart.

(c) New or reconstructed boilers or process heaters in one of the liquid fuel subcategories that burn only fossil fuels and other gases and do not burn any residual oil must demonstrate compliance according to §63.7506(a).

(d) You must conduct each performance test under the specific conditions listed in Tables 5 and 7 to this subpart. You must conduct performance tests at the maximum normal operating load while burning the type of fuel or mixture of fuels that have the highest content of chlorine, mercury, and total selected metals, and you must demonstrate initial compliance and establish your operating limits based on these tests. These requirements could result in the need to conduct more than one performance test.

(e) You may not conduct performance tests during periods of startup, shutdown, or malfunction.

(f) You must conduct three separate test runs for each performance test required in this section, as specified in §63.7(e)(3). Each test run must last at least 1 hour.

(g) To determine compliance with the emission limits, you must use the F-Factor methodology and equations in sections 12.2 and 12.3 of EPA Method 19 of appendix A to part 60 of this chapter to convert the measured particulate matter concentrations, the measured HCl concentrations, the measured TSM concentrations, and the measured mercury concentrations that result from the initial performance test to pounds per million Btu heat input emission rates using F-factors.

§63.7521 What fuel analyses and procedures must I use?

(a) You must conduct fuel analyses according to the procedures in paragraphs (b) through (e) of this section and Table 6 to this subpart, as applicable.

(b) You must develop and submit a site-specific fuel analysis plan to the EPA Administrator for review and approval according to the following procedures and requirements in paragraphs (b)(1) and (2) of this section.

(1) You must submit the fuel analysis plan no later than 60 days before the date that you intend to demonstrate compliance.

(2) You must include the information contained in paragraphs (b)(2)(i) through (vi) of this section in your fuel analysis plan.

(i) The identification of all fuel types anticipated to be burned in each boiler or process heater.

(ii) For each fuel type, the notification of whether you or a fuel supplier will be conducting the fuel analysis.

(iii) For each fuel type, a detailed description of the sample location and specific procedures to be used for collecting and preparing the composite samples if your procedures are different from paragraph (c) or (d) of this section. Samples should be collected at a location that most accurately represents the fuel type, where possible, at a point prior to mixing with other dissimilar fuel types.

(iv) For each fuel type, the analytical methods, with the expected minimum detection levels, to be used for the measurement of selected total metals, chlorine, or mercury.

(v) If you request to use an alternative analytical method other than those required by Table 6 to this subpart, you must also include a detailed description of the methods and procedures that will be used.

(vi) If you will be using fuel analysis from a fuel supplier in lieu of site-specific sampling and analysis, the fuel supplier must use the analytical methods required by Table 6 to this subpart.

(c) At a minimum, you must obtain three composite fuel samples for each fuel type according to the procedures in paragraph (c)(1) or (2) of this section.

(1) If sampling from a belt (or screw) feeder, collect fuel samples according to paragraphs (c)(1)(i) and (ii) of this section.

(i) Stop the belt and withdraw a 6-inch wide sample from the full cross-

section of the stopped belt to obtain a minimum two pounds of sample. Collect all the material (fines and coarse) in the full cross-section. Transfer the sample to a clean plastic bag.

(ii) Each composite sample will consist of a minimum of three samples collected at approximately equal intervals during the testing period.

(2) If sampling from a fuel pile or truck, collect fuel samples according to paragraphs (c)(2)(i) through (iii) of this section.

(i) For each composite sample, select a minimum of five sampling locations uniformly spaced over the surface of the pile.

(ii) At each sampling site, dig into the pile to a depth of 18 inches. Insert a clean flat square shovel into the hole and withdraw a sample, making sure that large pieces do not fall off during sampling.

(iii) Transfer all samples to a clean plastic bag for further processing.

(d) Prepare each composite sample according to the procedures in paragraphs (d)(1) through (7) of this section.

(1) Throughly mix and pour the entire composite sample over a clean plastic sheet.

(2) Break sample pieces larger than 3 inches into smaller sizes.

(3) Make a pie shape with the entire composite sample and subdivide it into four equal parts.

(4) Separate one of the quarter samples as the first subset.

(5) If this subset is too large for grinding, repeat the procedure in paragraph (d)(3) of this section with the quarter sample and obtain a one-quarter subset from this sample.

(6) Grind the sample in a mill.

(7) Use the procedure in paragraph (d)(3) of this section to obtain a one-quarter subsample for analysis. If the quarter sample is too large, subdivide it further using the same procedure.

(e) Determine the concentration of pollutants in the fuel (mercury, chlorine, and/or total selected metals) in units of pounds per million Btu of each composite sample for each fuel type according to the procedures in Table 6 to this subpart.

§ 63.7522 Can I use emission averaging to comply with this subpart?

(a) As an alternative to meeting the requirements of § 63.7500, if you have more than one existing large solid fuel boiler located at your facility, you may demonstrate compliance by emission averaging according to the procedures in this section in a State that does not choose to exclude emission averaging.

(b) For each existing large solid fuel boiler in the averaging group, the emission rate achieved during the initial compliance test for the HAP being averaged must not exceed the emission level that was being achieved on November 12, 2004 or the control technology employed during the initial compliance test must not be less effective for the HAP being averaged than the control technology employed on November 12, 2004.

(c) You may average particulate matter or TSM, HCl, and mercury emissions from existing large solid fuel boilers to demonstrate compliance with the limits in Table 1 to this subpart if you satisfy the requirements in paragraphs (d), (e), and (f) of this section.

(d) The weighted average emissions from the existing large solid fuel boilers participating in the emissions averaging option must be in compliance with the limits in Table 1 to this subpart at all times following the compliance date specified in § 63.7495.

(e) You must demonstrate initial compliance according to paragraphs (e)(1) or (2) of this section.

(1) You must use Equation 1 of this section to demonstrate that the particulate matter or TSM, HCl, and mercury emissions from all existing large solid fuel boilers participating in the emissions averaging option do not exceed the emission limits in Table 1 to this subpart.

$$\text{AveWeighted Emissions} = \sum_{i=1}^{n}(\text{Er} \times \text{Hm}) \div \sum_{i=1}^{n}\text{Hm} \qquad \text{(Eq. 1)}$$

Where:

AveWeighted = Average weighted emissions for particulate matter or TSM, HCl, or mercury, in units of pounds per million Btu of heat input.

Er = Emission rate (as calculated according to Table 5 to this subpart) or fuel analysis (as calculated by the applicable equation in §63.7530(d)) for boiler, i, for particulate matter or TSM, HCl, or mercury, in units of pounds per million Btu of heat input.

Hm = Maximum rated heat input capacity of boiler, i, in units of million Btu per hour.

n = Number of large solid fuel boilers participating in the emissions averaging option.

(2) If you are not capable of monitoring heat input, you can use Equation 2 of this section as an alternative to using equation 1 of this section to demonstrate that the particulate matter or TSM, HCl, and mercury emissions from all existing large solid fuel boilers participating in the emissions averaging option do not exceed the emission limits in Table 1 to this subpart.

$$\text{AveWeighted Emissions} = \sum_{i=1}^{n}(\text{Er} \times \text{Sm} \times \text{Cf}) \div \sum_{i=1}^{n}\text{Sm} \times \text{Cf} \qquad \text{(Eq. 2)}$$

Where:

AveWeighted = Average weighted emission level for PM or TSM, HCl, or mercury, in units of pounds per million Btu of heat input.

Er = Emission rate (as calculated according to Table 5 to this subpart) or fuel analysis (as calculated by the applicable equation in §63.7530(d)) for boiler, i, for particulate matter or TSM, HCl, or mercury, in units of pounds per million Btu of heat input.

Sm = Maximum steam generation by boiler, i, in units of pounds.

Cf = Conversion factor, calculated from the most recent compliance test, in units of million Btu of heat input per pounds of steam generated.

(f) You must demonstrate continuous compliance on a 12-month rolling average basis determined at the end of every month (12 times per year) according to paragraphs (f)(1) and (2). The first 12-month rolling-average period begins on the compliance date specified in §63.7495.

(1) For each calendar month, you must use Equation 3 of this section to calculate the 12-month rolling average weighted emission limit using the actual heat capacity for each existing large solid fuel boiler participating in the emissions averaging option.

$$\text{AveWeighted Emissions} = \sum_{i=1}^{n}(\text{Er} \times \text{Hb}) \div \sum_{i=1}^{n}\text{Hb} \qquad \text{(Eq. 3)}$$

Where:

AveWeighted Emissions = 12-month rolling average weighted emission level for particulate matter or TSM, HCl, or mercury, in units of pounds per million Btu of heat input.

Er = Emission rate, calculated during the most recent compliance test, (as calculated according to Table 5 to this subpart) or fuel analysis (as calculated by the applicable equation in §63.7530(d)) for boiler, i, for particulate matter or TSM, HCl, or mercury, in units of pounds per million Btu of heat input.

Hb = The average heat input for each calendar month of boiler, i, in units of million Btu.

n = Number of large solid fuel boilers participating in the emissions averaging option.

(2) If you are not capable of monitoring heat input, you can use Equation 4 of this section as an alternative to using Equation 3 of this section to calculate the 12-month rolling average weighted emission limit using the actual steam generation from the large solid fuel boilers participating in the emissions averaging option.

$$\text{AveWeighted Emissions} = \sum_{i=1}^{n}(Er \times Sa \times Cf) \div \sum_{i=1}^{n} Sa \times Cf \qquad \text{(Eq. 4)}$$

Where:

AveWeighted Emissions = 12-month rolling average weighted emission level for PM or TSM, HCl, or mercury, in units of pounds per million Btu of heat input.

Er = Emission rate, calculated during the most recent compliance test (as calculated according to Table 5 to this subpart) or fuel analysis (as calculated by the applicable equation in § 63.7530(d)) for boiler, i, for particulate matter or TSM, HCl, or mercury, in units of pounds per million Btu of heat input.

Sa = Actual steam generation for each calender month by boiler, i, in units of pounds.

Cf = Conversion factor, as calculated during the most recent compliance test, in units of million Btu of heat input per pounds of steam generated.

(g) You must develop and submit an implementation plan for emission averaging to the applicable regulatory authority for review and approval according to the following procedures and requirements in paragraphs (g)(1) through (4).

(1) You must submit the implementation plan no later than 180 days before the date that the facility intends to demonstrate compliance using the emission averaging option.

(2) You must include the information contained in paragraphs (g)(2)(i) through (vii) of this section in your implementation plan for all emission sources included in an emissions average:

(i) The identification of all existing large solid fuel boilers in the averaging group, including for each either the applicable HAP emission level or the control technology installed on;

(ii) The process parameter (heat input or steam generated) that will be monitored for each averaging group of large solid fuel boilers;

(iii) The specific control technology or pollution prevention measure to be used for each emission source in the averaging group and the date of its installation or application. If the pollution prevention measure reduces or eliminates emissions from multiple sources, the owner or operator must identify each source;

(iv) The test plan for the measurement of particulate matter (or TSM), HCl, or mercury emissions in accordance with the requirements in § 63.7520;

(v) The operating parameters to be monitored for each control system or device and a description of how the operating limits will be determined;

(vi) If you request to monitor an alternative operating parameter pursuant to § 63.7525, you must also include:

(A) A description of the parameter(s) to be monitored and an explanation of the criteria used to select the parameter(s); and

(B) A description of the methods and procedures that will be used to demonstrate that the parameter indicates proper operation of the control device; the frequency and content of monitoring, reporting, and recordkeeping requirements; and a demonstration, to the satisfaction of the applicable regulatory authority, that the proposed monitoring frequency is sufficient to represent control device operating conditions; and

(vii) A demonstration that compliance with each of the applicable emission limit(s) will be achieved under representative operating conditions.

(3) Upon receipt, the regulatory authority shall review and approve or disapprove the plan according to the following criteria:

(i) Whether the content of the plan includes all of the information specified in paragraph (g)(2) of this section; and

(ii) Whether the plan presents sufficient information to determine that compliance will be achieved and maintained.

(4) The applicable regulatory authority shall not approve an emission averaging implementation plan containing any of the following provisions:

(i) Any averaging between emissions of differing pollutants or between differing sources; or

(ii) The inclusion of any emission source other than an existing large solid fuel boiler.

§63.7525 What are my monitoring, installation, operation, and maintenance requirements?

(a) If you have an applicable work practice standard for carbon monoxide, and your boiler or process heater is in any of the large subcategories and has a heat input capacity of 100 MMBtu per hour or greater, you must install, operate, and maintain a continuous emission monitoring system (CEMS) for carbon monoxide according to the procedures in paragraphs (a)(1) through (6) of this section by the compliance date specified in §63.7495.

(1) Each CEMS must be installed, operated, and maintained according to Performance Specification (PS) 4A of 40 CFR part 60, appendix B, and according to the site-specific monitoring plan developed according to §63.7505(d).

(2) You must conduct a performance evaluation of each CEMS according to the requirements in §63.8 and according to PS 4A of 40 CFR part 60, appendix B.

(3) Each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

(4) The CEMS data must be reduced as specified in §63.8(g)(2).

(5) You must calculate and record a 30-day rolling average emission rate on a daily basis. A new 30-day rolling average emission rate is calculated as the average of all of the hourly CO emission data for the preceding 30 operating days.

(6) For purposes of calculating data averages, you must not use data recorded during periods of monitoring malfunctions, associated repairs, out-of-control periods, required quality assurance or control activities, or when your boiler or process heater is operating at less than 50 percent of its rated capacity. You must use all the data collected during all other periods in assessing compliance. Any period for which the monitoring system is out of control and data are not available for required calculations constitutes a deviation from the monitoring requirements.

(b) If you have an applicable opacity operating limit, you must install, operate, certify and maintain each continuous opacity monitoring system (COMS) according to the procedures in paragraphs (b)(1) through (7) of this section by the compliance date specified in §63.7495.

(1) Each COMS must be installed, operated, and maintained according to PS 1 of 40 CFR part 60, appendix B.

(2) You must conduct a performance evaluation of each COMS according to the requirements in §63.8 and according to PS 1 of 40 CFR part 60, appendix B.

(3) As specified in §63.8(c)(4)(i), each COMS must complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

(4) The COMS data must be reduced as specified in §63.8(g)(2).

(5) You must include in your site-specific monitoring plan procedures and acceptance criteria for operating and maintaining each COMS according to the requirements in §63.8(d). At a minimum, the monitoring plan must include a daily calibration drift assessment, a quarterly performance audit, and an annual zero alignment audit of each COMS.

(6) You must operate and maintain each COMS according to the requirements in the monitoring plan and the requirements of §63.8(e). Identify periods the COMS is out of control including any periods that the COMS fails to pass a daily calibration drift assessment, a quarterly performance audit, or an annual zero alignment audit.

(7) You must determine and record all the 6-minute averages (and 1-hour block averages as applicable) collected for periods during which the COMS is not out of control.

(c) If you have an operating limit that requires the use of a CMS, you must install, operate, and maintain each continuous parameter monitoring system (CPMS) according to the procedures in paragraphs (c)(1) through (5) of this section by the compliance date specified in §63.7495.

(1) The CPMS must complete a minimum of one cycle of operation for each successive 15-minute period. You

must have a minimum of four successive cycles of operation to have a valid hour of data.

(2) Except for monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), you must conduct all monitoring in continuous operation at all times that the unit is operating. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

(3) For purposes of calculating data averages, you must not use data recorded during monitoring malfunctions, associated repairs, out of control periods, or required quality assurance or control activities. You must use all the data collected during all other periods in assessing compliance. Any period for which the monitoring system is out-of-control and data are not available for required calculations constitutes a deviation from the monitoring requirements.

(4) Determine the 3-hour block average of all recorded readings, except as provided in paragraph (c)(3) of this section.

(5) Record the results of each inspection, calibration, and validation check.

(d) If you have an operating limit that requires the use of a flow measurement device, you must meet the requirements in paragraphs (c) and (d)(1) through (4) of this section.

(1) Locate the flow sensor and other necessary equipment in a position that provides a representative flow.

(2) Use a flow sensor with a measurement sensitivity of 2 percent of the flow rate.

(3) Reduce swirling flow or abnormal velocity distributions due to upstream and downstream disturbances.

(4) Conduct a flow sensor calibration check at least semiannually.

(e) If you have an operating limit that requires the use of a pressure measurement device, you must meet the requirements in paragraphs (c) and (e)(1) through (6) of this section.

(1) Locate the pressure sensor(s) in a position that provides a representative measurement of the pressure.

(2) Minimize or eliminate pulsating pressure, vibration, and internal and external corrosion.

(3) Use a gauge with a minimum tolerance of 1.27 centimeters of water or a transducer with a minimum tolerance of 1 percent of the pressure range.

(4) Check pressure tap pluggage daily.

(5) Using a manometer, check gauge calibration quarterly and transducer calibration monthly.

(6) Conduct calibration checks any time the sensor exceeds the manufacturer's specified maximum operating pressure range or install a new pressure sensor.

(f) If you have an operating limit that requires the use of a pH measurement device, you must meet the requirements in paragraphs (c) and (f)(1) through (3) of this section.

(1) Locate the pH sensor in a position that provides a representative measurement of scrubber effluent pH.

(2) Ensure the sample is properly mixed and representative of the fluid to be measured.

(3) Check the pH meter's calibration on at least two points every 8 hours of process operation.

(g) If you have an operating limit that requires the use of equipment to monitor voltage and secondary current (or total power input) of an electrostatic precipitator (ESP), you must use voltage and secondary current monitoring equipment to measure voltage and secondary current to the ESP.

(h) If you have an operating limit that requires the use of equipment to monitor sorbent injection rate (*e.g.*, weigh belt, weigh hopper, or hopper flow measurement device), you must meet the requirements in paragraphs (c) and (h)(1) through (3) of this section.

(1) Locate the device in a position(s) that provides a representative measurement of the total sorbent injection rate.

(2) Install and calibrate the device in accordance with manufacturer's procedures and specifications.

(3) At least annually, calibrate the device in accordance with the manufacturer's procedures and specifications.

(i) If you elect to use a fabric filter bag leak detection system to comply with the requirements of this subpart, you must install, calibrate, maintain, and continuously operate a bag leak detection system as specified in paragraphs (i)(1) through (8) of this section.

(1) You must install and operate a bag leak detection system for each exhaust stack of the fabric filter.

(2) Each bag leak detection system must be installed, operated, calibrated, and maintained in a manner consistent with the manufacturer's written specifications and recommendations and in accordance with the guidance provided in EPA–454/R–98–015, September 1997.

(3) The bag leak detection system must be certified by the manufacturer to be capable of detecting particulate matter emissions at concentrations of 10 milligrams per actual cubic meter or less.

(4) The bag leak detection system sensor must provide output of relative or absolute particulate matter loadings.

(5) The bag leak detection system must be equipped with a device to continuously record the output signal from the sensor.

(6) The bag leak detection system must be equipped with an alarm system that will sound automatically when an increase in relative particulate matter emissions over a preset level is detected. The alarm must be located where it is easily heard by plant operating personnel.

(7) For positive pressure fabric filter systems that do not duct all compartments of cells to a common stack, a bag leak detection system must be installed in each baghouse compartment or cell.

(8) Where multiple bag leak detectors are required, the system's instrumentation and alarm may be shared among detectors.

§63.7530 How do I demonstrate initial compliance with the emission limits and work practice standards?

(a) You must demonstrate initial compliance with each emission limit and work practice standard that applies to you by either conducting initial performance tests and establishing operating limits, as applicable, according to §63.7520, paragraph (c) of this section, and Tables 5 and 7 to this subpart OR conducting initial fuel analyses to determine emission rates and establishing operating limits, as applicable, according to §63.7521, paragraph (d) of this section, and Tables 6 and 8 to this subpart.

(b) New or reconstructed boilers or process heaters in one of the liquid fuel subcategories that burn only fossil fuels and other gases and do not burn any residual oil must demonstrate compliance according to §63.7506(a).

(c) If you demonstrate compliance through performance testing, you must establish each site-specific operating limit in Tables 2 through 4 to this subpart that applies to you according to the requirements in §63.7520, Table 7 to this subpart, and paragraph (c)(4) of this section, as applicable. You must also conduct fuel analyses according to §63.7521 and establish maximum fuel pollutant input levels according to paragraphs (c)(1) through (3) of this section, as applicable.

(1) You must establish the maximum chlorine fuel input (C_{input}) during the initial performance testing according to the procedures in paragraphs (c)(1)(i) through (iii) of this section.

(i) You must determine the fuel type or fuel mixture that you could burn in your boiler or process heater that has the highest content of chlorine.

(ii) During the performance testing for HCl, you must determine the fraction of the total heat input for each fuel type burned (Q_i) based on the fuel mixture that has the highest content of chlorine, and the average chlorine concentration of each fuel type burned (C_i).

(iii) You must establish a maximum chlorine input level using Equation 5 of this section.

$$Cl_{input} = \sum_{i=1}^{n}\left[(C_i)(Q_i)\right] \qquad \text{(Eq. 5)}$$

Where:

Cl_{input} = Maximum amount of chlorine entering the boiler or process heater through fuels burned in units of pounds per million Btu.

C_i = Arithmetic average concentration of chlorine in fuel type, i, analyzed according to §63.7521, in units of pounds per million Btu.

Q_i = Fraction of total heat input from fuel type, i, based on the fuel mixture that has the highest content of chlorine. If you do not burn multiple fuel types during the performance testing, it is not necessary to determine the value of this term. Insert a value of ''1'' for Q_i.

n = Number of different fuel types burned in your boiler or process heater for the mixture that has the highest content of chlorine.

(2) If you choose to comply with the alternative TSM emission limit instead of the particulate matter emission limit, you must establish the maximum TSM fuel input level (TSM_{input}) during the initial performance testing according to the procedures in paragraphs (c)(2)(i) through (iii) of this section.

(i) You must determine the fuel type or fuel mixture that you could burn in your boiler or process heater that has the highest content of TSM.

(ii) During the performance testing for TSM, you must determine the fraction of total heat input from each fuel burned (Q_i) based on the fuel mixture that has the highest content of total selected metals, and the average TSM concentration of each fuel type burned (M_i).

(iii) You must establish a baseline TSM input level using Equation 6 of this section.

$$TSM_{input} = \sum_{i=1}^{n}\left[(M_i)(Q_i)\right] \qquad \text{(Eq. 6)}$$

Where:

TSM_{input} = Maximum amount of TSM entering the boiler or process heater through fuels burned in units of pounds per million Btu.

M_i = Arithmetic average concentration of TSM in fuel type, i, analyzed according to §63.7521, in units of pounds per million Btu.

Q_i = Fraction of total heat input from based fuel type, i, based on the fuel mixture that has the highest content of TSM. If you do not burn multiple fuel types during the performance test, it is not necessary to determine the value of this term. Insert a value of ''1'' for Q_i.

n = Number of different fuel types burned in your boiler or process heater for the mixture that has the highest content of TSM.

(3) You must establish the maximum mercury fuel input level ($Mercury_{input}$) during the initial performance testing using the procedures in paragraphs (c)(3)(i) through (iii) of this section.

(i) You must determine the fuel type or fuel mixture that you could burn in your boiler or process heater that has the highest content of mercury.

(ii) During the compliance demonstration for mercury, you must determine the fraction of total heat input for each fuel burned (Q_i) based on the fuel mixture that has the highest content of mercury, and the average mercury concentration of each fuel type burned (HG_i).

(iii) You must establish a maximum mercury input level using Equation 7 of this section.

$$Mercury_{input} = \sum_{i=1}^{n}\left[(HG_i)(Q_i)\right] \qquad \text{(Eq. 7)}$$

Where:

$Mercury_{input}$ = Maximum amount of mercury entering the boiler or process heater through fuels burned in units of pounds per million Btu.

HG_i = Arithmetic average concentration of mercury in fuel type, i, analyzed according to §63.7521, in units of pounds per million Btu.

Q_i = Fraction of total heat input from fuel type, i, based on the fuel mixture that has the highest mercury content. If you do not burn multiple fuel types during the performance test, it is not necessary to determine the value of this term. Insert a value of ''1'' for Q_i.

n = Number of different fuel types burned in your boiler or process heater for the mixture that has the highest content of mercury.

(4) You must establish parameter operating limits according to paragraphs (c)(4)(i) through (iv) of this section.

(i) For a wet scrubber, you must establish the minimum scrubber effluent pH, liquid flowrate, and pressure drop as defined in §63.7575, as your operating limits during the three-run performance test. If you use a wet scrubber and you conduct separate performance tests for particulate matter, HCl, and mercury emissions, you must establish one set of minimum scrubber effluent pH, liquid flowrate, and pressure drop operating limits. The minimum scrubber effluent pH operating limit must be

established during the HCl performance test. If you conduct multiple performance tests, you must set the minimum liquid flowrate and pressure drop operating limits at the highest minimum values established during the performance tests.

(ii) For an electrostatic precipitator, you must establish the minimum voltage and secondary current (or total power input), as defined in §63.7575, as your operating limits during the three-run performance test.

(iii) For a dry scrubber, you must establish the minimum sorbent injection rate, as defined in §63.7575, as your operating limit during the three-run performance test.

(iv) The operating limit for boilers or process heaters with fabric filters that choose to demonstrate continuous compliance through bag leak detection systems is that a bag leak detection system be installed according to the requirements in §63.7525, and that each fabric filter must be operated such that the bag leak detection system alarm does not sound more than 5 percent of the operating time during a 6-month period.

(d) If you elect to demonstrate compliance with an applicable emission limit through fuel analysis, you must conduct fuel analyses according to §63.7521 and follow the procedures in paragraphs (d)(1) through (5) of this section.

(1) If you burn more than one fuel type, you must determine the fuel mixture you could burn in your boiler or process heater that would result in the maximum emission rates of the pollutants that you elect to demonstrate compliance through fuel analysis.

(2) You must determine the 90th percentile confidence level fuel pollutant concentration of the composite samples analyzed for each fuel type using the one-sided z-statistic test described in Equation 8 of this section.

$$P_{90} = \text{mean} + (SD \times t) \qquad \text{(Eq. 8)}$$

Where:

P_{90} = 90th percentile confidence level pollutant concentration, in pounds per million Btu.

mean = Arithmetic average of the fuel pollutant concentration in the fuel samples analyzed according to §63.7521, in units of pounds per million Btu.

SD = Standard deviation of the pollutant concentration in the fuel samples analyzed according to §63.7521, in units of pounds per million Btu.

t = t distribution critical value for 90th percentile (0.1) probability for the appropriate degrees of freedom (number of samples minus one) as obtained from a Distribution Critical Value Table.

(3) To demonstrate compliance with the applicable emission limit for HCl, the HCl emission rate that you calculate for your boiler or process heater using Equation 9 of this section must be less than the applicable emission limit for HCl.

$$HCl = \sum_{i=1}^{n}\left[(C_{i90})(Q_i)(1.028)\right] \qquad \text{(Eq. 9)}$$

Where:

HCl = HCl emission rate from the boiler or process heater in units of pounds per million Btu.

C_{i90} = 90th percentile confidence level concentration of chlorine in fuel type, i, in units of pounds per million Btu as calculated according to Equation 8 of this section.

Q_i = Fraction of total heat input from fuel type, i, based on the fuel mixture that has the highest content of chlorine. If you do not burn multiple fuel types, it is not necessary to determine the value of this term. Insert a value of ''1'' for Q_i.

n = Number of different fuel types burned in your boiler or process heater for the mixture that has the highest content of chlorine.

1.028 = Molecular weight ratio of HCl to chlorine.

(4) To demonstrate compliance with the applicable emission limit for TSM, the TSM emission rate that you calculate for your boiler or process heater using Equation 10 of this section must be less than the applicable emission limit for TSM.

$$TSM = \sum_{i=1}^{n}\left[(M_{i90})(Q_i)\right] \qquad \text{(Eq. 10)}$$

Where:

TSM = TSM emission rate from the boiler or process heater in units of pounds per million Btu.

M_{i90} = 90th percentile confidence level concentration of TSM in fuel, i, in units of pounds per million Btu as calculated according to Equation 8 of this section.

Q_i = Fraction of total heat input from fuel type, i, based on the fuel mixture that has

the highest content of total selected metals. If you do not burn multiple fuel types, it is not necessary to determine the value of this term. Insert a value of ''1'' for Q_i.

n = Number of different fuel types burned in your boiler or process heater for the mixture that has the highest content of TSM.

(5) To demonstrate compliance with the applicable emission limit for mercury, the mercury emission rate that you calculate for your boiler or process heater using Equation 11 of this section must be less than the applicable emission limit for mercury.

$$\text{Mercury} = \sum_{i=1}^{n}\left[\left(HG_{i90}\right)\left(Q_i\right)\right] \qquad \text{(Eq. 11)}$$

Where:

Mercury = Mercury emission rate from the boiler or process heater in units of pounds per million Btu.

HG_{i90} = 90th percentile confidence level concentration of mercury in fuel, i, in units of pounds per million Btu as calculated according to Equation 8 of this section.

Q_i = Fraction of total heat input from fuel type, i, based on the fuel mixture that has the highest mercury content. If you do not burn multiple fuel types, it is not necessary to determine the value of this term. Insert a value of ''1'' for Q_i.

n = Number of different fuel types burned in your boiler or process heater for the mixture that has the highest mercury content.

(e) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in § 63.7545(e).

CONTINUOUS COMPLIANCE REQUIREMENTS

§ 63.7535 How do I monitor and collect data to demonstrate continuous compliance?

(a) You must monitor and collect data according to this section and the site-specific monitoring plan required by § 63.7505(d).

(b) Except for monitor malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), you must monitor continuously (or collect data at all required intervals) at all times that the affected source is operating.

(c) You may not use data recorded during monitoring malfunctions, associated repairs, or required quality assurance or control activities in data averages and calculations used to report emission or operating levels. You must use all the data collected during all other periods in assessing the operation of the control device and associated control system. Boilers and process heaters that have an applicable carbon monoxide work practice standard and are required to install and operate a CEMS, may not use data recorded during periods when the boiler or process heater is operating at less than 50 percent of its rated capacity.

§ 63.7540 How do I demonstrate continuous compliance with the emission limits and work practice standards?

(a) You must demonstrate continuous compliance with each emission limit, operating limit, and work practice standard in Tables 1 through 4 to this subpart that applies to you according to the methods specified in Table 8 to this subpart and paragraphs (a)(1) through (10) of this section.

(1) Following the date on which the initial performance test is completed or is required to be completed under §§ 63.7 and 63.7510, whichever date comes first, you must not operate above any of the applicable maximum operating limits or below any of the applicable minimum operating limits listed in Tables 2 through 4 to this subpart at all times except during periods of startup, shutdown and malfunction. Operating limits do not apply during performance tests. Operation above the established maximum or below the established minimum operating limits shall constitute a deviation of established operating limits.

(2) You must keep records of the type and amount of all fuels burned in each boiler or process heater during the reporting period to demonstrate that all fuel types and mixtures of fuels burned would either result in lower emissions of TSM, HCl, and mercury, than the applicable emission limit for each pollutant (if you demonstrate compliance through fuel analysis), or result in lower fuel input of TSM, chlorine, and mercury than the maximum values calculated during the last performance

tests (if you demonstrate compliance through performance testing).

(3) If you demonstrate compliance with an applicable HCl emission limit through fuel analysis and you plan to burn a new type of fuel, you must recalculate the HCl emission rate using Equation 9 of §63.7530 according to paragraphs (a)(3)(i) through (iii) of this section.

(i) You must determine the chlorine concentration for any new fuel type in units of pounds per million Btu, based on supplier data or your own fuel analysis, according to the provisions in your site-specific fuel analysis plan developed according to §63.7521(b).

(ii) You must determine the new mixture of fuels that will have the highest content of chlorine.

(iii) Recalculate the HCl emission rate from your boiler or process heater under these new conditions using Equation 9 of §63.7530. The recalculated HCl emission rate must be less than the applicable emission limit.

(4) If you demonstrate compliance with an applicable HCl emission limit through performance testing and you plan to burn a new type of fuel type or a new mixture of fuels, you must recalculate the maximum chlorine input using Equation 5 of §63.7530. If the results of recalculating the maximum chlorine input using Equation 5 of §63.7530 are higher than the maximum chlorine input level established during the previous performance test, then you must conduct a new performance test within 60 days of burning the new fuel type or fuel mixture according to the procedures in §63.7520 to demonstrate that the HCl emissions do not exceed the emission limit. You must also establish new operating limits based on this performance test according to the procedures in §63.7530(c).

(5) If you demonstrate compliance with an applicable TSM emission limit through fuel analysis, and you plan to burn a new type of fuel, you must recalculate the TSM emission rate using Equation 10 of §63.7530 according to the procedures specified in paragraphs (a)(5)(i) through (iii) of this section.

(i) You must determine the TSM concentration for any new fuel type in units of pounds per million Btu, based on supplier data or your own fuel analysis, according to the provisions in your site-specific fuel analysis plan developed according to §63.7521(b).

(ii) You must determine the new mixture of fuels that will have the highest content of TSM.

(iii) Recalculate the TSM emission rate from your boiler or process heater under these new conditions using Equation 10 of §63.7530. The recalculated TSM emission rate must be less than the applicable emission limit.

(6) If you demonstrate compliance with an applicable TSM emission limit through performance testing, and you plan to burn a new type of fuel or a new mixture of fuels, you must recalculate the maximum TSM input using Equation 6 of §63.7530. If the results of recalculating the maximum total selected metals input using Equation 6 of §63.7530 are higher than the maximum TSM input level established during the previous performance test, then you must conduct a new performance test within 60 days of burning the new fuel type or fuel mixture according to the procedures in §63.7520 to demonstrate that the TSM emissions do not exceed the emission limit. You must also establish new operating limits based on this performance test according to the procedures in §63.7530(c).

(7) If you demonstrate compliance with an applicable mercury emission limit through fuel analysis, and you plan to burn a new type of fuel, you must recalculate the mercury emission rate using Equation 11 of §63.7530 according to the procedures specified in paragraphs (a)(7)(i) through (iii) of this section.

(i) You must determine the mercury concentration for any new fuel type in units of pounds per million Btu, based on supplier data or your own fuel analysis, according to the provisions in your site-specific fuel analysis plan developed according to §63.7521(b).

(ii) You must determine the new mixture of fuels that will have the highest content of mercury.

(iii) Recalculate the mercury emission rate from your boiler or process heater under these new conditions using Equation 11 of §63.7530. The recalculated mercury emission rate must be less than the applicable emission limit.

(8) If you demonstrate compliance with an applicable mercury emission limit through performance testing, and you plan to burn a new type of fuel or a new mixture of fuels, you must recalculate the maximum mercury input using Equation 7 of § 63.7530. If the results of recalculating the maximum mercury input using Equation 7 of § 63.7530 are higher than the maximum mercury input level established during the previous performance test, then you must conduct a new performance test within 60 days of burning the new fuel type or fuel mixture according to the procedures in § 63.7520 to demonstrate that the mercury emissions do not exceed the emission limit. You must also establish new operating limits based on this performance test according to the procedures in § 63.7530(c).

(9) If your unit is controlled with a fabric filter, and you demonstrate continuous compliance using a bag leak detection system, you must initiate corrective action within 1 hour of a bag leak detection system alarm and complete corrective actions as soon as practical, and operate and maintain the fabric filter system such that the alarm does not sound more than 5 percent of the operating time during a 6-month period. You must also keep records of the date, time, and duration of each alarm, the time corrective action was initiated and completed, and a brief description of the cause of the alarm and the corrective action taken. You must also record the percent of the operating time during each 6-month period that the alarm sounds. In calculating this operating time percentage, if inspection of the fabric filter demonstrates that no corrective action is required, no alarm time is counted. If corrective action is required, each alarm shall be counted as a minimum of 1 hour. If you take longer than 1 hour to initiate corrective action, the alarm time shall be counted as the actual amount of time taken to initiate corrective action.

(10) If you have an applicable work practice standard for carbon monoxide, and you are required to install a CEMS according to § 63.7525(a), then you must meet the requirements in paragraphs (a)(10)(i) through (iii) of this section.

(i) You must continuously monitor carbon monoxide according to §§ 63.7525(a) and 63.7535.

(ii) Maintain a carbon monoxide emission level below your applicable carbon monoxide work practice standard in Table 1 to this subpart at all times except during periods of startup, shutdown, malfunction, and when your boiler or process heater is operating at less than 50 percent of rated capacity.

(iii) Keep records of carbon monoxide levels according to § 63.7555(b).

(b) You must report each instance in which you did not meet each emission limit, operating limit, and work practice standard in Tables 1 through 4 to this subpart that apply to you. You must also report each instance during a startup, shutdown, or malfunction when you did not meet each applicable emission limit, operating limit, and work practice standard. These instances are deviations from the emission limits and work practice standards in this subpart. These deviations must be reported according to the requirements in § 63.7550.

(c) [Reserved]

(d) Consistent with §§ 63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the EPA Administrator's satisfaction that you were operating in accordance with § 63.6(e)(1). The EPA Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in § 63.6(e).

[69 FR 55253, Sept. 13, 2004, as amended at 71 FR 20467, Apr. 20, 2006]

§ 63.7541 How do I demonstrate continuous compliance under the emission averaging provision?

(a) Following the compliance date, the owner or operator must demonstrate compliance with this subpart on a continuous basis by meeting the requirements of paragraphs (a)(1) through (4) of this section.

(1) For each calendar month, demonstrate compliance with the average

weighted emissions limit for the existing large solid fuel boilers participating in the emissions averaging option as determined in §63.7522(f) and (g);

(2) For each existing solid fuel boiler participating in the emissions averaging option that is equipped with a dry control system, maintain opacity at or below the applicable limit;

(3) For each existing solid fuel boiler participating in the emissions averaging option that is equipped with a wet scrubber, maintain the 3-hour average parameter values at or below the operating limits established during the most recent performance test; and

(4) For each existing solid fuel boiler participating in the emissions averaging option that has an approved alternative operating plan, maintain the 3-hour average parameter values at or below the operating limits established in the most recent performance test.

(b) Any instance where the owner or operator fails to comply with the continuous monitoring requirements in paragraphs (a)(1) through (4) of this section, except during periods of startup, shutdown, and malfunction, is a deviation.

NOTIFICATION, REPORTS, AND RECORDS

§63.7545 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.7(b) and (c), 63.8 (e), (f)(4) and (6), and 63.9 (b) through (h) that apply to you by the dates specified.

(b) As specified in §63.9(b)(2), if you startup your affected source before November 12, 2004, you must submit an Initial Notification not later than 120 days after November 12, 2004. The Initial Notification must include the information required in paragraphs (b)(1) and (2) of this section, as applicable.

(1) If your affected source has an annual capacity factor of greater than 10 percent, your Initial Notification must include the information required by §63.9(b)(2).

(2) If your affected source has a federally enforceable permit that limits the annual capacity factor to less than or equal to 10 percent such that the unit is in one of the limited use subcategories (the limited use solid fuel subcategory, the limited use liquid fuel subcategory, or the limited use gaseous fuel subcategory), your Initial Notification must include the information required by §63.9(b)(2) and also a signed statement indicating your affected source has a federally enforceable permit that limits the annual capacity factor to less than or equal to 10 percent.

(c) As specified in §63.9(b)(4) and (b)(5), if you startup your new or reconstructed affected source on or after November 12, 2004, you must submit an Initial Notification not later than 15 days after the actual date of startup of the affected source.

(d) If you are required to conduct a performance test you must submit a Notification of Intent to conduct a performance test at least 30 days before the performance test is scheduled to begin.

(e) If you are required to conduct an initial compliance demonstration as specified in §63.7530(a), you must submit a Notification of Compliance Status according to §63.9(h)(2)(ii). For each initial compliance demonstration, you must submit the Notification of Compliance Status, including all performance test results and fuel analyses, before the close of business on the 60th day following the completion of the performance test and/or other initial compliance demonstrations according to §63.10(d)(2). The Notification of Compliance Status report must contain all the information specified in paragraphs (e)(1) through (9), as applicable.

(1) A description of the affected source(s) including identification of which subcategory the source is in, the capacity of the source, a description of the add-on controls used on the source description of the fuel(s) burned, and justification for the fuel(s) burned during the performance test.

(2) Summary of the results of all performance tests, fuel analyses, and calculations conducted to demonstrate initial compliance including all established operating limits.

(3) Identification of whether you are complying with the particulate matter emission limit or the alternative total selected metals emission limit.

(4) Identification of whether you plan to demonstrate compliance with each applicable emission limit through performance testing or fuel analysis.

(5) Identification of whether you plan to demonstrate compliance by emissions averaging.

(6) A signed certification that you have met all applicable emission limits and work practice standards.

(7) A summary of the carbon monoxide emissions monitoring data and the maximum carbon monoxide emission levels recorded during the performance test to show that you have met any applicable work practice standard in Table 1 to this subpart.

(8) If your new or reconstructed boiler or process heater is in one of the liquid fuel subcategories and burns only liquid fossil fuels other than residual oil either alone or in combination with gaseous fuels, you must submit a signed statement certifying this in your Notification of Compliance Status report.

(9) If you had a deviation from any emission limit or work practice standard, you must also submit a description of the deviation, the duration of the deviation, and the corrective action taken in the Notification of Compliance Status report.

§ 63.7550 What reports must I submit and when?

(a) You must submit each report in Table 9 to this subpart that applies to you.

(b) Unless the EPA Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date in Table 9 to this subpart and according to the requirements in paragraphs (b)(1) through (5) of this section.

(1) The first compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.7495 and ending on June 30 or December 31, whichever date is the first date that occurs at least 180 days after the compliance date that is specified for your source in § 63.7495.

(2) The first compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the first calendar half after the compliance date that is specified for your source in § 63.7495.

(3) Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(5) For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (4) of this section.

(c) The compliance report must contain the information required in paragraphs (c)(1) through (11) of this section.

(1) Company name and address.

(2) Statement by a responsible official with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) The total fuel use by each affected source subject to an emission limit, for each calendar month within the semiannual reporting period, including, but not limited to, a description of the fuel and the total fuel usage amount with units of measure.

(5) A summary of the results of the annual performance tests and documentation of any operating limits that were reestablished during this test, if applicable.

(6) A signed statement indicating that you burned no new types of fuel. Or, if you did burn a new type of fuel, you must submit the calculation of chlorine input, using Equation 5 of § 63.7530, that demonstrates that your source is still within its maximum

chlorine input level established during the previous performance testing (for sources that demonstrate compliance through performance testing) or you must submit the calculation of HCl emission rate using Equation 9 of §63.7530 that demonstrates that your source is still meeting the emission limit for HCl emissions (for boilers or process heaters that demonstrate compliance through fuel analysis). If you burned a new type of fuel, you must submit the calculation of TSM input, using Equation 6 of §63.7530, that demonstrates that your source is still within its maximum TSM input level established during the previous performance testing (for sources that demonstrate compliance through performance testing), or you must submit the calculation of TSM emission rate using Equation 10 of §63.7530 that demonstrates that your source is still meeting the emission limit for TSM emissions (for boilers or process heaters that demonstrate compliance through fuel analysis). If you burned a new type of fuel, you must submit the calculation of mercury input, using Equation 7 of §63.7530, that demonstrates that your source is still within its maximum mercury input level established during the previous performance testing (for sources that demonstrate compliance through performance testing), or you must submit the calculation of mercury emission rate using Equation 11 of §63.7530 that demonstrates that your source is still meeting the emission limit for mercury emissions (for boilers or process heaters that demonstrate compliance through fuel analysis).

(7) If you wish to burn a new type of fuel and you can not demonstrate compliance with the maximum chlorine input operating limit using Equation 5 of §63.7530, the maximum TSM input operating limit using Equation 6 of §63.7530, or the maximum mercury input operating limit using Equation 7 of §63.7530, you must include in the compliance report a statement indicating the intent to conduct a new performance test within 60 days of starting to burn the new fuel.

(8) The hours of operation for each boiler and process heater that is subject to an emission limit for each calendar month within the semiannual reporting period. This requirement applies only to limited use boilers and process heaters.

(9) If you had a startup, shutdown, or malfunction during the reporting period and you took actions consistent with your SSMP, the compliance report must include the information in §63.10(d)(5)(i).

(10) If there are no deviations from any emission limits or operating limits in this subpart that apply to you, and there are no deviations from the requirements for work practice standards in this subpart, a statement that there were no deviations from the emission limits, operating limits, or work practice standards during the reporting period.

(11) If there were no periods during which the CMSs, including CEMS, COMS, and CPMS, were out of control as specified in §63.8(c)(7), a statement that there were no periods during which the CMSs were out of control during the reporting period.

(d) For each deviation from an emission limit or operating limit in this subpart and for each deviation from the requirements for work practice standards in this subpart that occurs at an affected source where you are not using a CMSs to comply with that emission limit, operating limit, or work practice standard, the compliance report must contain the information in paragraphs (c)(1) through (10) of this section and the information required in paragraphs (d)(1) through (4) of this section. This includes periods of startup, shutdown, and malfunction.

(1) The total operating time of each affected source during the reporting period.

(2) A description of the deviation and which emission limit, operating limit, or work practice standard from which you deviated.

(3) Information on the number, duration, and cause of deviations (including unknown cause), as applicable, and the corrective action taken.

(4) A copy of the test report if the annual performance test showed a deviation from the emission limit for particulate matter or the alternative TSM limit, a deviation from the HCl emission limit, or a deviation from the mercury emission limit.

(e) For each deviation from an emission limitation and operating limit or work practice standard in this subpart occurring at an affected source where you are using a CMS to comply with that emission limit, operating limit, or work practice standard, you must include the information in paragraphs (c)(1) through (10) of this section and the information required in paragraphs (e)(1) through (12) of this section. This includes periods of startup, shutdown, and malfunction and any deviations from your site-specific monitoring plan as required in § 63.7505(d).

(1) The date and time that each malfunction started and stopped and description of the nature of the deviation (*i.e.*, what you deviated from).

(2) The date and time that each CMS was inoperative, except for zero (low-level) and high-level checks.

(3) The date, time, and duration that each CMS was out of control, including the information in § 63.8(c)(8).

(4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(5) A summary of the total duration of the deviation during the reporting period and the total duration as a percent of the total source operating time during that reporting period.

(6) A breakdown of the total duration of the deviations during the reporting period into those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and other unknown causes.

(7) A summary of the total duration of CMSs downtime during the reporting period and the total duration of CMS downtime as a percent of the total source operating time during that reporting period.

(8) An identification of each parameter that was monitored at the affected source for which there was a deviation, including opacity, carbon monoxide, and operating parameters for wet scrubbers and other control devices.

(9) A brief description of the source for which there was a deviation.

(10) A brief description of each CMS for which there was a deviation.

(11) The date of the latest CMS certification or audit for the system for which there was a deviation.

(12) A description of any changes in CMSs, processes, or controls since the last reporting period for the source for which there was a deviation.

(f) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 40 CFR part 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a compliance report pursuant to Table 9 to this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all required information concerning deviations from any emission limit, operating limit, or work practice requirement in this subpart, submission of the compliance report satisfies any obligation to report the same deviations in the semiannual monitoring report. However, submission of a compliance report does not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority.

(g) If you operate a new gaseous fuel unit that is subject to the work practice standard specified in Table 1 to this subpart, and you intend to use a fuel other than natural gas or equivalent to fire the affected unit, you must submit a notification of alternative fuel use within 48 hours of the declaration of a period of natural gas curtailment or supply interruption, as defined in § 63.7575. The notification must include the information specified in paragraphs (g)(1) through (5) of this section.

(1) Company name and address.

(2) Identification of the affected unit.

(3) Reason you are unable to use natural gas or equivalent fuel, including the date when the natural gas curtailment was declared or the natural gas supply interruption began.

(4) Type of alternative fuel that you intend to use.

(5) Dates when the alternative fuel use is expected to begin and end.

§63.7555 What records must I keep?

(a) You must keep records according to paragraphs (a)(1) through (3) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status or semiannual compliance report that you submitted, according to the requirements in §63.10(b)(2)(xiv).

(2) The records in §63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.

(3) Records of performance tests, fuel analyses, or other compliance demonstrations, performance evaluations, and opacity observations as required in §63.10(b)(2)(viii).

(b) For each CEMS, CPMS, and COMS, you must keep records according to paragraphs (b)(1) through (5) of this section.

(1) Records described in §63.10(b)(2)(vi) through (xi).

(2) Monitoring data for continuous opacity monitoring system during a performance evaluation as required in §63.6(h)(7)(i) and (ii).

(3) Previous (*i.e.*, superseded) versions of the performance evaluation plan as required in §63.8(d)(3).

(4) Request for alternatives to relative accuracy test for CEMS as required in §63.8(f)(6)(i).

(5) Records of the date and time that each deviation started and stopped, and whether the deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(c) You must keep the records required in Table 8 to this subpart including records of all monitoring data and calculated averages for applicable operating limits such as opacity, pressure drop, carbon monoxide, and pH to show continuous compliance with each emission limit, operating limit, and work practice standard that applies to you.

(d) For each boiler or process heater subject to an emission limit, you must also keep the records in paragraphs (d)(1) through (5) of this section.

(1) You must keep records of monthly fuel use by each boiler or process heater, including the type(s) of fuel and amount(s) used.

(2) You must keep records of monthly hours of operation by each boiler or process heater. This requirement applies only to limited-use boilers and process heaters.

(3) A copy of all calculations and supporting documentation of maximum chlorine fuel input, using Equation 5 of §63.7530, that were done to demonstrate continuous compliance with the HCl emission limit, for sources that demonstrate compliance through performance testing. For sources that demonstrate compliance through fuel analysis, a copy of all calculations and supporting documentation of HCl emission rates, using Equation 9 of §63.7530, that were done to demonstrate compliance with the HCl emission limit. Supporting documentation should include results of any fuel analyses and basis for the estimates of maximum chlorine fuel input or HCl emission rates. You can use the results from one fuel analysis for multiple boilers and process heaters provided they are all burning the same fuel type. However, you must calculate chlorine fuel input, or HCl emission rate, for each boiler and process heater.

(4) A copy of all calculations and supporting documentation of maximum TSM fuel input, using Equation 6 of §63.7530, that were done to demonstrate continuous compliance with the TSM emission limit for sources that demonstrate compliance through performance testing. For sources that demonstrate compliance through fuel analysis, a copy of all calculations and supporting documentation of TSM emission rates, using Equation 10 of §63.7530, that were done to demonstrate compliance with the TSM emission limit. Supporting documentation should include results of any fuel analyses and basis for the estimates of maximum TSM fuel input or TSM emission rates. You can use the results from one fuel analysis for multiple boilers and process heaters provided they are all burning the same fuel type. However, you must calculate TSM fuel input, or TSM emission rates, for each boiler and process heater.

(5) A copy of all calculations and supporting documentation of maximum mercury fuel input, using Equation 7 of §63.7530, that were done to demonstrate

continuous compliance with the mercury emission limit for sources that demonstrate compliance through performance testing. For sources that demonstrate compliance through fuel analysis, a copy of all calculations and supporting documentation of mercury emission rates, using Equation 11 of § 63.7530, that were done to demonstrate compliance with the mercury emission limit. Supporting documentation should include results of any fuel analyses and basis for the estimates of maximum mercury fuel input or mercury emission rates. You can use the results from one fuel analysis for multiple boilers and process heaters provided they are all burning the same fuel type. However, you must calculate mercury fuel input, or mercury emission rates, for each boiler and process heater.

(e) If your boiler or process heater is subject to an emission limit or work practice standard in Table 1 to this subpart and has a federally enforceable permit that limits the annual capacity factor to less than or equal to 10 percent such that the unit is in one of the limited use subcategories, you must keep the records in paragraphs (e)(1) and (2) of this section.

(1) A copy of the federally enforceable permit that limits the annual capacity factor of the source to less than or equal to 10 percent.

(2) Fuel use records for the days the boiler or process heater was operating.

§ 63.7560 In what form and how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review, according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record on site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1). You can keep the records off site for the remaining 3 years.

OTHER REQUIREMENTS AND INFORMATION

§ 63.7565 What parts of the General Provisions apply to me?

Table 10 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you.

§ 63.7570 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency (as well as the U.S. EPA) has the authority to implement and enforce this subpart. You should contact your EPA Regional Office to find out if this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities listed in paragraphs (b)(1) through (5) of this section are retained by the EPA Administrator and are not transferred to the State, local, or tribal agency, however, the U.S. EPA retains oversight of this subpart and can take enforcement actions, as appropriate.

(1) Approval of alternatives to the non-opacity emission limits and work practice standards in § 63.7500(a) and (b) under § 63.6(g).

(2) Approval of alternative opacity emission limits in § 63.7500(a) under § 63.6(h)(9).

(3) Approval of major change to test methods in Table 5 to this subpart under § 63.7(e)(2)(ii) and (f) and as defined in § 63.90.

(4) Approval of major change to monitoring under § 63.8(f) and as defined in § 63.90.

(5) Approval of major change to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.

§ 63.7575 What definitions apply to this subpart?

Terms used in this subpart are defined in the CAA, in § 63.2 (the General Provisions), and in this section as follows:

Annual capacity factor means the ratio between the actual heat input to a boiler or process heater from the fuels burned during a calendar year, and the potential heat input to the boiler or process heater had it been operated for 8,760 hours during a year at the maximum steady state design heat input capacity.

Bag leak detection system means an instrument that is capable of monitoring particulate matter loadings in the exhaust of a fabric filter (*i.e.*, baghouse) in order to detect bag failures. A bag leak detection system includes, but is not limited to, an instrument that operates on electrodynamic, triboelectric, light scattering, light transmittance, or other principle to monitor relative particulate matter loadings.

Biomass fuel means unadulterated wood as defined in this subpart, wood residue, and wood products (*e.g.*, trees, tree stumps, tree limbs, bark, lumber, sawdust, sanderdust, chips, scraps, slabs, millings, and shavings); animal litter; vegetative agricultural and silvicultural materials, such as logging residues (slash), nut and grain hulls and chaff (*e.g.*, almond, walnut, peanut, rice, and wheat), bagasse, orchard prunings, corn stalks, coffee bean hulls and grounds.

Blast furnace gas fuel-fired boiler or process heater means an industrial/commercial/institutional boiler or process heater that receives 90 percent or more of its total heat input (based on an annual average) from blast furnace gas.

Boiler means an enclosed device using controlled flame combustion and having the primary purpose of recovering thermal energy in the form of steam or hot water. Waste heat boilers are excluded from this definition.

Coal means all solid fuels classifiable as anthracite, bituminous, sub-bituminous, or lignite by the American Society for Testing and Materials in ASTM D388–991$^{\epsilon 1}$, ''Standard Specification for Classification of Coals by Rank^{1}'' (incorporated by reference, see §63.14(b)), coal refuse, and petroleum coke. Synthetic fuels derived from coal for the purpose of creating useful heat including but not limited to, solvent-refined coal, coal-oil mixtures, and coal-water mixtures, for the purposes of this subpart. Coal derived gases are excluded from this definition.

Coal refuse means any by-product of coal mining or coal cleaning operations with an ash content greater than 50 percent (by weight) and a heating value less than 13,900 kilojoules per kilogram (6,000 Btu per pound) on a dry basis.

Commercial/institutional boiler means a boiler used in commercial establishments or institutional establishments such as medical centers, research centers, institutions of higher education, hotels, and laundries to provide electricity, steam, and/or hot water.

Construction/demolition material means waste building material that result from the construction or demolition operations on houses and commercial and industrial buildings.

Deviation. (1) Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(i) Fails to meet any requirement or obligation established by this subpart including, but not limited to, any emission limit, operating limit, or work practice standard;

(ii) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or

(iii) Fails to meet any emission limit, operating limit, or work practice standard in this subpart during start-up, shutdown, or malfunction, regardless or whether or not such failure is permitted by this subpart.

(2) A deviation is not always a violation. The determination of whether a deviation constitutes a violation of the standard is up to the discretion of the entity responsible for enforcement of the standards.

Distillate oil means fuel oils, including recycled oils, that comply with the specifications for fuel oil numbers 1 and 2, as defined by the American Society for Testing and Materials in ASTM D396–02a, ''Standard Specifications for Fuel Oils^{1}'' (incorporated by reference, see §63.14(b)).

Dry scrubber means an add-on air pollution control system that injects dry alkaline sorbent (dry injection) or sprays an alkaline sorbent (spray

dryer) to react with and neutralize acid gas in the exhaust stream forming a dry powder material. Sorbent injection systems in fluidized bed boilers and process heaters are included in this definition.

Electric utility steam generating unit means a fossil fuel-fired combustion unit of more than 25 megawatts that serves a generator that produces electricity for sale. A fossil fuel-fired unit that cogenerates steam and electricity and supplies more than one-third of its potential electric output capacity and more than 25 megawatts electrical output to any utility power distribution system for sale is considered an electric utility steam generating unit.

Electrostatic precipitator means an add-on air pollution control device used to capture particulate matter by charging the particles using an electrostatic field, collecting the particles using a grounded collecting surface, and transporting the particles into a hopper.

Fabric filter means an add-on air pollution control device used to capture particulate matter by filtering gas streams through filter media, also known as a baghouse.

Federally enforceable means all limitations and conditions that are enforceable by the EPA Administrator, including the requirements of 40 CFR parts 60 and 61, requirements within any applicable State implementation plan, and any permit requirements established under 40 CFR 52.21 or under 40 CFR 51.18 and 40 CFR 51.24.

Firetube boiler means a boiler in which hot gases of combustion pass through the tubes and water contacts the outside surfaces of the tubes.

Fossil fuel means natural gas, petroleum, coal, and any form of solid, liquid, or gaseous fuel derived from such materials.

Fuel type means each category of fuels that share a common name or classification. Examples include, but are not limited to, bituminous coal, subbituminous coal, lignite, anthracite, biomass, construction/demolition material, salt water laden wood, creosote treated wood, tires, residual oil. Individual fuel types received from different suppliers are not considered new fuel types except for construction/demolition material.

Gaseous fuel includes, but is not limited to, natural gas, process gas, landfill gas, coal derived gas, refinery gas, and biogas. Blast furnace gas is exempted from this definition.

Heat input means heat derived from combustion of fuel in a boiler or process heater and does not include the heat input from preheated combustion air, recirculated flue gases, or exhaust gases from other sources such as gas turbines, internal combustion engines, kilns, etc.

Hot water heater means a closed vessel with a capacity of no more than 120 U.S. gallons in which water is heated by combustion of gaseous or liquid fuel and is withdrawn for use external to the vessel at pressures not exceeding 160 psig, including the apparatus by which the heat is generated and all controls and devices necessary to prevent water temperatures from exceeding 210 °F (99 °C).

Industrial boiler means a boiler used in manufacturing, processing, mining, and refining or any other industry to provide steam, hot water, and/or electricity.

Large gaseous fuel subcategory includes any watertube boiler or process heater that burns gaseous fuels not combined with any solid fuels, burns liquid fuel only during periods of gas curtailment or gas supply emergencies, has a rated capacity of greater than 10 MMBtu per hour heat input, and has an annual capacity factor of greater than 10 percent.

Large liquid fuel subcategory includes any watertube boiler or process heater that does not burn any solid fuel and burns any liquid fuel either alone or in combination with gaseous fuels, has a rated capacity of greater than 10 MMBtu per hour heat input, and has an annual capacity factor of greater than 10 percent. Large gaseous fuel boilers and process heaters that burn liquid fuel during periods of gas curtailment or gas supply emergencies are not included in this definition.

Large solid fuel subcategory includes any watertube boiler or process heater

that burns any amount of solid fuel either alone or in combination with liquid or gaseous fuels, has a rated capacity of greater than 10 MMBtu per hour heat input, and has an annual capacity factor of greater than 10 percent.

Limited use gaseous fuel subcategory includes any watertube boiler or process heater that burns gaseous fuels not combined with any liquid or solid fuels, burns liquid fuel only during periods of gas curtailment or gas supply emergencies, has a rated capacity of greater than 10 MMBtu per hour heat input, and has a federally enforceable annual average capacity factor of equal to or less than 10 percent.

Limited use liquid fuel subcategory includes any watertube boiler or process heater that does not burn any solid fuel and burns any liquid fuel either alone or in combination with gaseous fuels, has a rated capacity of greater than 10 MMBtu per hour heat input, and has a federally enforceable annual average capacity factor of equal to or less than 10 percent. Limited use gaseous fuel boilers and process heaters that burn liquid fuel during periods of gas curtailment or gas supply emergencies are not included in this definition.

Limited use solid fuel subcategory includes any watertube boiler or process heater that burns any amount of solid fuel either alone or in combination with liquid or gaseous fuels, has a rated capacity of greater than 10 MMBtu per hour heat input, and has a federally enforceable annual average capacity factor of equal to or less than 10 percent.

Liquid fossil fuel means petroleum, distillate oil, residual oil and any form of liquid fuel derived from such material.

Liquid fuel includes, but is not limited to, distillate oil, residual oil, waste oil, and process liquids.

Minimum pressure drop means 90 percent of the lowest test-run average pressure drop measured according to Table 7 to this subpart during the most recent performance test demonstrating compliance with the applicable emission limit.

Minimum scrubber effluent pH means 90 percent of the lowest test-run average effluent pH measured at the outlet of the wet scrubber according to Table 7 to this subpart during the most recent performance test demonstrating compliance with the applicable hydrogen chloride emission limit.

Minimum scrubber flow rate means 90 percent of the lowest test-run average flow rate measured according to Table 7 to this subpart during the most recent performance test demonstrating compliance with the applicable emission limit.

Minimum sorbent flow rate means 90 percent of the lowest test-run average sorbent (or activated carbon) flow rate measured according to Table 7 to this subpart during the most recent performance test demonstrating compliance with the applicable emission limits.

Minimum voltage or amperage means 90 percent of the lowest test-run average voltage or amperage to the electrostatic precipitator measured according to Table 7 to this subpart during the most recent performance test demonstrating compliance with the applicable emission limits.

Natural gas means:

(1) A naturally occurring mixture of hydrocarbon and nonhydrocarbon gases found in geologic formations beneath the earth's surface, of which the principal constituent is methane; or

(2) Liquid petroleum gas, as defined by the American Society for Testing and Materials in ASTM D1835–03a, ''Standard Specification for Liquid Petroleum Gases'' (incorporated by reference, see §63.14(b)).

Opacity means the degree to which emissions reduce the transmission of light and obscure the view of an object in the background.

Particulate matter means any finely divided solid or liquid material, other than uncombined water, as measured by the test methods specified under this subpart, or an alternative method.

Period of natural gas curtailment or supply interruption means a period of time during which the supply of natural gas to an affected facility is halted for reasons beyond the control of the facility. An increase in the cost or unit price of natural gas does not constitute a period of natural gas curtailment or supply interruption.

Process heater means an enclosed device using controlled flame, that is not a boiler, and the unit's primary purpose is to transfer heat indirectly to a process material (liquid, gas, or solid) or to a heat transfer material for use in a process unit, instead of generating steam. Process heaters are devices in which the combustion gases do not directly come into contact with process materials. Process heaters do not include units used for comfort heat or space heat, food preparation for on-site consumption, or autoclaves.

Residual oil means crude oil, and all fuel oil numbers 4, 5 and 6, as defined by the American Society for Testing and Materials in ASTM D396–02a, ''Standard Specifications for Fuel Oils[1]'' (incorporated by reference, see § 63.14(b)).

Responsible official means responsible official as defined in 40 CFR 70.2.

Small gaseous fuel subcategory includes any firetube boiler that burns gaseous fuels not combined with any solid fuels and burns liquid fuel only during periods of gas curtailment or gas supply emergencies, and any boiler or process heater that burns gaseous fuels not combined with any solid fuels, burns liquid fuel only during periods of gas curtailment or gas supply emergencies, and has a rated capacity of less than or equal to 10 MMBtu per hour heat input.

Small liquid fuel subcategory includes any firetube boiler that does not burn any solid fuel and burns any liquid fuel either alone or in combination with gaseous fuels, and any boiler or process heater that does not burn any solid fuel and burns any liquid fuel either alone or in combination with gaseous fuels, and has a rated capacity of less than or equal to 10 MMBtu per hour heat input. Small gaseous fuel boilers and process heaters that burn liquid fuel during periods of gas curtailment or gas supply emergencies are not included in this definition.

Small solid fuel subcategory includes any firetube boiler that burns any amount of solid fuel either alone or in combination with liquid or gaseous fuels, and any other boiler or process heater that burns any amount of solid fuel either alone or in combination with liquid or gaseous fuels and has a rated capacity of less than or equal to 10 MMBtu per hour heat input.

Solid fuel includes, but is not limited to, coal, wood, biomass, tires, plastics, and other nonfossil solid materials.

Temporary boiler means any gaseous or liquid fuel boiler that is designed to, and is capable of, being carried or moved from one location to another. A temporary boiler that remains at a location for more than 180 consecutive days is no longer considered to be a temporary boiler. Any temporary boiler that replaces a temporary boiler at a location and is intended to perform the same or similar function will be included in calculating the consecutive time period.

Total selected metals means the combination of the following metallic HAP: arsenic, beryllium, cadmium, chromium, lead, manganese, nickel and selenium.

Unadulterated wood means wood or wood products that have not been painted, pigment-stained, or pressure treated with compounds such as chromate copper arsenate, pentachlorophenol, and creosote. Plywood, particle board, oriented strand board, and other types of wood products bound by glues and resins are included in this definition.

Waste heat boiler means a device that recovers normally unused energy and converts it to usable heat. Waste heat boilers incorporating duct or supplemental burners that are designed to supply 50 percent or more of the total rated heat input capacity of the waste heat boiler are not considered waste heat boilers, but are considered boilers. Waste heat boilers are also referred to as heat recovery steam generators.

Watertube boiler means a boiler in which water passes through the tubes and hot gases of combustion pass over the outside surfaces of the tubes.

Wet scrubber means any add-on air pollution control device that mixes an aqueous stream or slurry with the exhaust gases from a boiler or process heater to control emissions of particulate matter and/or to absorb and neutralize acid gases, such as hydrogen chloride.

Work practice standard means any design, equipment, work practice, or operational standard, or combination

thereof, that is promulgated pursuant to section 112(h) of the CAA.

TABLES TO SUBPART DDDDD OF PART 63

TABLE 1 TO SUBPART DDDDD OF PART 63—EMISSION LIMITS AND WORK PRACTICE STANDARDS

As stated in § 63.7500, you must comply with the following applicable emission limits and work practice standards:

If your boiler or process heater is in this subcategory . . .	For the following pollutants . . .	You must meet the following emission limits and work practice standards . . .
1. New or reconstructed large solid fuel ...	a. Particulate Matter (or Total Selected Metals).	0.025 lb per MMBtu of heat input; or (0.0003 lb per MMBtu of heat input).
	b. Hydrogen Chloride	0.02 lb per MMBtu of heat input.
	c. Mercury	0.000003 lb per MMBtu of heat input.
	d. Carbon Monoxide	400 ppm by volume on a dry basis corrected to 7 percent oxygen (30-day rolling average for units 100 MMBtu/hr or greater, 3-run average for units less than 100 MMBtu/hr).
2. New or reconstructed limited use solid fuel.	a. Particulate Matter (or Total Selected Metals).	0.025 lb per MMBtu of heat input; or (0.0003 lb per MMBtu of heat input).
	b. Hydrogen Chloride	0.02 lb per MMBtu of heat input.
	c. Mercury	0.000003 lb per MMBtu of heat input.
	d. Carbon Monoxide	400 ppm by volume on a dry basis corrected to 7 percent oxygen (3-run average).
3. New or reconstructed small solid fuel ...	a. Particulate Matter (or Total Selected Metals).	0.025 lb per MMBtu of heat input; or (0.0003 lb per MMBtu of heat input).
	b. Hydrogen Chloride	0.02 lb per MMBtu of heat input.
	c. Mercury	0.000003 lb per MMBtu of heat input.
4. New reconstructed large liquid fuel	a. Particulate Matter	0.03 lb per MMBtu of heat input.
	b. Hydrogen Chloride	0.0005 lb per MMBtu of heat input.
	c. Carbon Monoxide	400 ppm by volume on a dry basis corrected to 3 percent oxygen (30-day rolling average for units 100 MMBtu/hr or greater, 3-run average for units less than 100 MMBtu/hr).
5. New or reconstructed limited use liquid fuel.	a. Particulate Matter	0.03 lb per MMBtu of heat input.
	b. Hydrogen Chloride	0.0009 lb per MMBtu of heat input.
	c. Carbon Monoxide	400 ppm by volume on a dry basis liquid corrected to 3 percent oxygen (3-run average).
6. New or reconstructed small liquid fuel ..	a. Particulate Matter	0.03 lb per MMBtu of heat input.
	b. Hydrogen Chloride	0.0009 lb per MMBtu of heat input.
7. New reconstructed large gaseous fuel	Carbon Monoxide	400 ppm by volume on a dry basis corrected to 3 percent oxygen (30-day rolling average for units 100 MMBtu/hr or greater, 3-run average for units less than 100 MMBtu/hr).
8. New or reconstructed limited use gaseous fuel.	Carbon Monoxide	400 ppm by volume on a dry basis corrected to 3 percent oxygen (3-run average).
9. Existing large solid fuel	a. Particulate Matter (or Total Selected Metals).	0.07 lb per MMBtu of heat input; or (0.001 lb per MMBtu of heat input).
	b. Hydrogen Chloride	0.09 lb per MMBtu of heat input.
	c. Mercury	0.000009 lb per MMBtu of heat input.
10. Existing limited use solid fuel	Particulate Matter (or Total Selected Metals).	0.21 lb per MMBtu of heat input; or (0.004 lb per MMBtu of heat input).

TABLE 2 TO SUBPART DDDDD OF PART 63—OPERATING LIMITS FOR BOILERS AND PROCESS HEATERS WITH PARTICULATE MATTER EMISSION LIMITS

As stated in § 63.7500, you must comply with the applicable operating limits:

If you demonstrate compliance with applicable particulate matter emission limits using . . .	You must meet these operating limits . . .
1. Wet scrubber control	a. Maintain the minimum pressure drop and liquid flow-rate at or above the operating levels established during the performance test according to § 63.7530(c) and Table 7 to this subpart that demonstrated compliance with the applicable emission limit for particulate matter.

As stated in § 63.7500, you must comply with the applicable operating limits:

If you demonstrate compliance with applicable particulate matter emission limits using . . .	You must meet these operating limits . . .
2. Fabric filter control	a. Install and operate a bag leak detection system according to § 63.7525 and operate the fabric filter such that the bag leak detection system alarm does not sound more than 5 percent of the operating time during each 6-month period; or b. This option is for boilers and process heaters that operate dry control systems. Existing boilers and process heaters must maintain opacity to less than or equal to 20 percent (6-minute average) except for one 6-minute period per hour of not more than 27 percent. New boilers and process heaters must maintain opacity to less than or equal to 10 percent opacity (1-hour block average).
3. Electrostatic precipitator control	a. This option is for boilers and process heaters that operate dry control systems. Existing boilers and process heaters must maintain opacity to less than or equal to 20 percent (6-minute average) except for one 6-minute period per hour of not more than 27 percent. New boilers and process heaters must maintain opacity to less than or equal to 10 percent opacity (1-hour block average); or b. This option is only for boilers and process heaters that operate additional wet control systems. Maintain the minimum voltage and secondary current or total power input of the electrostatic precipitator at or above the operating limits established during the performance test according to § 63.7530(c) and Table 7 to this subpart that demonstrated compliance with the applicable emission limit for particulate matter.
4. Any other control type	This option is for boilers and process heaters that operate dry control systems. Existing boilers and process heaters must maintain opacity to less than or equal to 20 percent (6-minute average) except for one 6-minute period per hour of not more than 27 percent. New boilers and process heaters must maintain opacity to less than or equal to 10 percent opacity (1-hour block average).

TABLE 3 TO SUBPART DDDDD OF PART 63—OPERATING LIMITS FOR BOILERS AND PROCESS HEATERS WITH MERCURY EMISSION LIMITS AND BOILERS AND PROCESS HEATERS THAT CHOOSE TO COMPLY WITH THE ALTERNATIVE TOTAL SELECTED METALS EMISSION LIMITS

As stated in § 63.7500, you must comply with the applicable operating limits:

If you demonstrate compliance with applicable mercury and/or total selected metals emission limits using . . .	You must meet these operating limits . . .
1. Wet scrubber control	Maintain the minimum pressure drop and liquid flow-rate at or above the operating levels established during the performance test according to § 63.7530(c) and Table 7 to this subpart that demonstrated compliance with the applicable emission limits for mercury and/or total selected metals.
2. Fabric filter control	a. Install and operate a bag leak detection system according to § 63.7525 and operate the fabric filter such that the bag leak detection system alarm does not sound more than 5 percent of the operating time during a 6-month period; or b. This option is for boilers and process heaters that operate dry control systems. Existing sources must maintain opacity to less than or equal to 20 percent (6-minute average) except for one 6-minute period per hour of not more than 27 percent. New sources must maintain opacity to less than or equal to 10 percent opacity (1-hour block average).
3. Electrostatic precipitator control	a. This option is for boilers and process heaters that operate dry control systems. Existing sources must maintain opacity to less than or equal to 20 percent (6-minute average) except for one 6-minute period per hour of not more than 27 percent. New sources must maintain opacity to less than or equal to 10 percent opacity (1-hour block average); or

As stated in § 63.7500, you must comply with the applicable operating limits:

If you demonstrate compliance with applicable mercury and/or total selected metals emission limits using . . .	You must meet these operating limits . . .
	b. This option is only for boilers and process heaters that operate additional wet control systems. Maintain the minimum voltage and secondary current or total power input of the electrostatic precipitator at or above the operating limits established during the performance test according to § 63.7530(c) and Table 7 to this subpart that demonstrated compliance with the applicable emission limits for mercury and/or total selected metals.
4. Dry scrubber or carbon injection control	Maintain the minimum sorbent or carbon injection rate at or above the operating levels established during the performance test according to § 63.7530(c) and Table 7 to this subpart that demonstrated compliance with the applicable emission limit for mercury.
5. Any other control type	This option is only for boilers and process heaters that operate dry control systems. Existing sources must maintain opacity to less than or equal to 20 percent (6-minute average) except for one 6-minute period per hour of not more than 27 percent. New sources must maintain opacity to less than or equal to 10 percent opacity (1-hour block average).
6. Fuel analysis	Maintain the fuel type or fuel mixture such that the mercury and/or total selected metals emission rates calculated according to § 63.7530(d)(4) and/or (5) is less than the applicable emission limits for mercury and/or total selected metals.

TABLE 4 TO SUBPART DDDDD OF PART 63—OPERATING LIMITS FOR BOILERS AND PROCESS HEATERS WITH HYDROGEN CHLORIDE EMISSION LIMITS

As stated in § 63.7500, you must comply with the following applicable operating limits:

If you demonstrate compliance with applicable hydrogen chloride emission limits using . . .	You must meet these operating limits . . .
1. Wet scrubber control	Maintain the minimum scrubber effluent pH, pressure drop, and liquid flow-rate at or above the operating levels established during the performance test according to § 63.7530(c) and Table 7 to this subpart that demonstrated compliance with the applicable emission limit for hydrogen chloride.
2. Dry scrubber control	Maintain the minimum sorbent injection rate at or above the operating levels established during the performance test according to § 63.7530(c) and Table 7 to this subpart that demonstrated compliance with the applicable emission limit for hydrogen chloride.
3. Fuel analysis	Maintain the fuel type or fuel mixture such that the hydrogen chloride emission rate calculated according to § 63.7530(d)(3) is less than the applicable emission limit for hydrogen chloride.

TABLE 5 TO SUBPART DDDDD OF PART 63—PERFORMANCE TESTING REQUIREMENTS

As stated in § 63.7520, you must comply with the following requirements for performance test for existing, new or reconstructed affected sources:

To conduct a performance test for the following pollutant . . .	You must . . .	Using . . .
1. Particulate Matter	a. Select sampling ports location and the number of traverse points.	Method 1 in appendix A to part 60 of this chapter.
	b. Determine velocity and volumetric flow-rate of the stack gas.	Method 2, 2F, or 2G in appendix A to part 60 of this chapter.
	c. Determine oxygen and carbon dioxide concentrations of the stack gas.	Method 3A or 3B in appendix A to part 60 of this chapter, or ASME PTC 19, Part 10 (1981) (IBR, see § 63.14(i)).
	d. Measure the moisture content of the stack gas.	Method 4 in appendix A to part 60 of this chapter.
	e. Measure the particulate matter emission concentration.	Method 5 or 17 (positive pressure fabric filters must use Method 5D) in appendix A to part 60 of this chapter.
	f. Convert emissions concentration to lb per MMBtu emission rates.	Method 19 F-factor methodology in appendix A to part 60 of this chapter.

As stated in § 63.7520, you must comply with the following requirements for performance test for existing, new or reconstructed affected sources:

To conduct a performance test for the following pollutant . . .	You must . . .	Using . . .
2. Total selected metals	a. Select sampling ports location and the number of traverse points.	Method 1 in appendix A to part 60 of this chapter.
	b. Determine velocity and volumetric flow-rate of the stack gas.	Method 2, 2F, or 2G in appendix A to part 60 of this chapter.
	c. Determine oxygen and carbon dioxide concentrations of the stack gas.	Method 3A or 3B in appendix A to part 60 of this chapter, or ASME PTC 19, Part 10 (1981) (IBR, see § 63.14(i)).
	d. Measure the moisture content of the stack gas.	Method 4 in appendix A to part 60 of this chapter.
	e. Measure the total selected metals emission concentration.	Method 29 in appendix A to part 60 of this chapter.
	f. Convert emissions concentration to lb per MMBtu emission rates.	Method 19 F-factor methodology in appendix A to part 60 of this chapter.
3. Hydrogen chloride	a. Select sampling ports location and the number of traverse points.	Method 1 in appendix A to part 60 of this chapter.
	b. Determine velocity and volumetric flow-rate of the stack gas.	Method 2, 2F, or 2G in appendix A to part 60 of this chapter.
	c. Determine oxygen and carbon dioxide concentrations of the stack gas.	Method 3A or 3B in appendix A to part 60 of this chapter, or ASME PTC 19, Part 10 (1981) (IBR, see § 63.14(i)).
	d. Measure the moisture content of the stack gas.	Method 4 in appendix A to part 60 of this chapter.
	e. Measure the hydrogen chloride emission concentration.	Method 26 or 26A in appendix A to part 60 of this chapter.
	f. Convert emissions concentration to lb per MMBtu emission rates.	Method 19 F-factor methodology in appendix A to part 60 of this chapter.
4. Mercury	a. Select sampling ports location and the number of traverse points.	Method 1 in appendix A to part 60 of this chapter.
	b. Determine velocity and volumetric flow-rate of the stack gas.	Method 2, 2F, or 2G in appendix A to part 60 of this chapter.
	c. Determine oxygen and carbon dioxide concentrations of the stack gas.	Method 3A or 3B in appendix A to part 60 of this chapter, or ASME PTC 19, Part 10 (1981) (IBR, see § 62.14(i)).
	d. Measure the moisture content of the stack gas.	Method 4 in appendix A to part 60 of this chapter.
	e. Measure the mercury emission concentration.	Method 29 in appendix A to part 60 of this chapter or Method 101A in appendix B to part 61 of this chapter or ASTM Method D6784–02 (IBR, see § 63.14(b)).
	f. Convert emissions concentration to lb per MMBtu emission rates.	Method 19 F-factor methodology in appendix A to part 60 of this chapter.
5. Carbon Monoxide	a. Select the sampling ports location and the number of traverse points.	Method 1 in appendix A to part 60 of this chapter.
	b. Determine oxygen and carbon dioxide concentrations of the stack gas.	Method 3A or 3B in appendix A to part 60 of this chapter, or ASTM D6522–00 (IBR, see § 63.14(b)), or ASME PTC 19, Part 10 (1981) (IBR, see § 63.14(i)).
	c. Measure the moisture content of the stack gas.	Method 4 in appendix A to part 60 of this chapter.
	d. Measure the carbon monoxide emission concentration.	Method 10, 10A, or 10B in appendix A to part 60 of this chapter, or ASTM D6522–00 (IBR, see § 63.14(b)) when the fuel is natural gas.

TABLE 6 TO SUBPART DDDDD OF PART 63—FUEL ANALYSIS REQUIREMENTS

As stated in § 63.7521, you must comply with the following requirements for fuel analysis testing for existing, new or reconstructed affected sources:

To conduct a fuel analysis for the following pollutant . . .	You must . . .	Using . . .
1. Mercury	a. Collect fuel samples	Procedure in § 63.7521(c) or ASTM D2234–00 ε1 (for coal)(IBR, see § 63.14(b)) or ASTM D6323–98 (2003)(for biomass)(IBR, see § 63.14(b)) or equivalent.
	b. Composite fuel samples	Procedure in § 63.7521(d) or equivalent.

As stated in § 63.7521, you must comply with the following requirements for fuel analysis testing for existing, new or reconstructed affected sources:

To conduct a fuel analysis for the following pollutant . . .	You must . . .	Using . . .
	c. Prepare composited fuel samples	SW–846–3050B (for solid samples) or SW–846–3020A (for liquid samples) or ASTM D2013–01 (for coal) (IBR, see § 63.14(b)) or ASTM D5198–92 (2003) (for biomass)(IBR, see § 63.14(b)) or equivalent.
	d. Determine heat content of the fuel type.	ASTM D5865–03a (for coal)(IBR, see § 63.14(b)) or ASTM E711–87 (1996) (for biomass)(IBR, see § 63.14(b)) or equivalent.
	e. Determine moisture content of the fuel type.	ASTM D3173–02 (IBR, see § 63.14(b)) or ASTM E871–82 (1998)(IBR, see § 63.14(b)) or equivalent.
	f. Measure mercury concentration in fuel sample.	ASTM D3684–01 (for coal)(IBR, see § 63.14(b)) or SW–846–7471A (for solid samples) or SW–846 7470A (for liquid samples).
	g. Convert concentrations into units of pounds of pollutant per MMBtu of heat content.	
2. Total selected metals	a. Collect fuel samples	Procedure in § 63.7521(c) or ASTM D2234–00 ε1 (for coal)(IBR, see § 63.14(b)) or ASTM D6323–98 (2003) (for biomass)(IBR, see § 63.14(b)) or equivalent.
	b. Composite fuel samples	Procedure in § 63.7521(d) or equivalent.
	c. Prepare composited fuel samples	SW–846–3050B (for solid samples) or SW–846–3020A (for liquid samples) or ASTM D2013–01 (for coal)(IBR, see § 63.14(b)) or ASTM D5198–92 (2003)(for biomass)(IBR, see § 63.14(b)) or equivalent.
	d. Determine heat content of the fuel type.	ASTM D5865–03a (for coal)(IBR, see § 63.14(b)) or ASTM E 711–87 (for biomass)(IBR, see § 63.14(b)) or equivalent.
	e. Determine moisture content of the fuel type.	ASTM D3173–02 (IBR, see § 63.14(b)) or ASTM E871 (IBR, see § 63.14(b)) or equivalent.
	f. Measure total selected metals concentration in fuel sample.	SW–846–6010B or ASTM D3683–94 (2000) (for coal) (IBR, see § 63.14(b)) or ASTM E885–88 (1996) (for biomass)(IBR, see § 63.14(b)).
	g. Convert concentrations into units of pounds of pollutant per MMBtu of heat content.	
3. Hydrogen chloride	a. Collect fuel samples	Procedure in § 63.7521(c) or ASTM D2234 ε1 (for coal)(IBR, see § 63.14(b)) or ASTM D6323–98 (2003) (for biomass)(IBR, see § 63.14(b)) or equivalent.
	b. Composite fuel samples	Procedure in § 63.7521(d) or equivalent.
	c. Prepare composited fuel samples	SW–846–3050B (for solid samples) or SW–846–3020A (for liquid samples) or ASTM D2013–01 (for coal)(IBR, see § 63.14(b)) or ASTM D5198–92 (2003) (for biomass)(IBR, see § 63.14(b)) or equivalent.
	d. Determine heat content of the fuel type.	ASTM D5865–03a (for coal)(IBR, see § 63.14(b)) or ASTM E711–87 (1996) (for biomass)(IBR, see § 63.14(b)) or equivalent.
	e. Determine moisture content of the fuel type.	ASTM D3173–02 (IBR, see § 63.14(b)) or ASTM E871–82 (1998)(IBR, see § 63.14(b)) or equivalent.
	f. Measure chlorine concentration in fuel sample.	SW–846–9250 or ASTM E776–87 (1996) (for biomass)(IBR, see § 63.14(b)) or equivalent.

As stated in § 63.7521, you must comply with the following requirements for fuel analysis testing for existing, new or reconstructed affected sources:

To conduct a fuel analysis for the following pollutant . . .	You must . . .	Using . . .
	g. Convert concentrations into units of pounds of pollutant per MMBtu of heat content.	

TABLE 7 TO SUBPART DDDDD OF PART 63—ESTABLISHING OPERATING LIMITS

As stated in § 63.7520, you must comply with the following requirements for establishing operating limits:

If you have an applicable emission limit for . . .	And your operating limits are based on . . .	You must . . .	Using . . .	According to the following requirements
1. Particulate matter, mercury, or total selected metals.	a. Wet scrubber operating parameters.	i. Establish a site-specific minimum pressure drop and minimum flow rate operating limit according to § 63.7530(c).	(1) Data from the pressure drop and liquid flow rate monitors and the particulate matter, mercury, or total selected metals performance test.	(a) You must collect pressure drop and liquid flow-rate data every 15 minutes during the entire period of the performance tests; (b) Determine the average pressure drop and liquid flow-rate for each individual test run in the three-run performance test by computing the average of all the 15-minute readings taken during each test run.
	b. Electrostatic precipitator operating parameters (option only for units with additional wet scrubber control).	i. Establish a site-specific minimum voltage and secondary current or total power input according to § 63.7530(c).	(1) Data from the pressure drop and liquid flow rate monitors and the particulate matter, mercury, or total selected metals performance test.	(a) You must collect voltage and secondary current or total power input data every 15 minutes during the entire period of the performance tests; (b) Determine the average voltage and secondary current or total power input for each individual test run in the three-run performance test by computing the average of all the 15-minute readings taken during each test run.
2. Hydrogen Chloride	a. Wet scrubber operating parameters.	i. Establish a site-specific minimum pressure drop and minimum flow rate operating limit according to § 63.7530(c).	(1) Data from the pH, pressure drop, and liquid flow-rate monitors and the hydrogen chloride performance test.	(a) You must collect pH, pressure drop, and liquid flow-rate data every 15 minutes during the entire period of the performance tests; (b) Determine the average pH, pressure drop, and liquid flow-rate for each individual test run in the three-run performance test by computing the average of all the 15-minute readings taken during each test run.
	b. Dry scrubber operating parameters.	i. Establish a site-specific minimum sorbent injection rate operating limit according to § 63.7530(c).	(1) Data from the sorbent injection rate monitors and hydrogen chloride performance test.	(a) You must collect sorbent injection rate data every 15 minutes during the entire period of the performance tests; (b) Determine the average sorbent injection rate for each individual test run in the three-run performance test by computing the average of all the 15-minute readings taken during each test run.

TABLE 8 TO SUBPART DDDDD OF PART 63—DEMONSTRATING CONTINUOUS COMPLIANCE

As stated in § 63.7540, you must show continuous compliance with the emission limitations for affected sources according to the following:

If you must meet the following operating limits or work practice standards . . .	You must demonstrate continuous compliance by . . .
1. Opacity	a. Collecting the opacity monitoring system data according to §§ 63.7525(b) and 63.7535; and b. Reducing the opacity monitoring data to 6-minute averages; and c. Maintaining opacity to less than or equal to 20 percent (6-minute average) except for one 6-minute period per hour of not more than 27 percent for existing sources; or maintaining opacity to less than or equal to 10 percent (1-hour block average) for new sources.
2. Fabric Filter Bag Leak Detection Operation	Installing and operating a bag leak detection system according to § 63.7525 and operating the fabric filter such that the requirements in § 63.7540(a)(9) are met.
3. Wet Scrubber Pressure Drop and Liquid Flow-rate	a. Collecting the pressure drop and liquid flow rate monitoring system data according to §§ 63.7525 and 63.7535; and b. Reducing the data to 3-hour block averages; and c. Maintaining the 3-hour average pressure drop and liquid flow-rate at or above the operating limits established during the performance test according to § 63.7530(c).
4. Wet Scrubber pH	a. Collecting the pH monitoring system data according to §§ 63.7525 and 63.7535; and b. Reducing the data to 3-hour block averages; and c. Maintaining the 3-hour average pH at or above the operating limit established during the performance test according to § 63.7530(c).
5. Dry Scrubber Sorbent or Carbon Injection Rate	a. Collecting the sorbent or carbon injection rate monitoring system data for the dry scrubber according to §§ 63.7525 and 63.7535; and b. Reducing the data to 3-hour block averages; and c. Maintaining the 3-hour average sorbent or carbon injection rate at or above the operating limit established during the performance test according to §§ 63.7530(c).
6. Electrostatic Precipitator Secondary Current and Voltage or Total Power Input.	a. Collecting the secondary current and voltage or total power input monitoring system data for the electrostatic precipitator according to §§ 63.7525 and 63.7535; and b. Reducing the data to 3-hour block averages; and c. Maintaining the 3-hour average secondary current and voltage or total power input at or above the operating limits established during the performance test according to §§ 63.7530(c).
7. Fuel Pollutant Content	a. Only burning the fuel types and fuel mixtures used to demonstrate compliance with the applicable emission limit according to § 63.7530(c) or (d) as applicable; and b. Keeping monthly records of fuel use according to § 63.7540(a).

TABLE 9 TO SUBPART DDDDD OF PART 63—REPORTING REQUIREMENTS

As stated in § 63.7550, you must comply with the following requirements for reports:

You must submit a(n)	The report must contain . . .	You must submit the report . . .
1. Compliance report	a. Information required in § 63.7550(c)(1) through (11); and	Semiannually according to the requirements in § 63.7550(b).

As stated in § 63.7550, you must comply with the following requirements for reports:

You must submit a(n)	The report must contain . . .	You must submit the report . . .
	b. If there are no deviations from any emission limitation (emission limit and operating limit) that applies to you and there are no deviations from the requirements for work practice standards in Table 8 to this subpart that apply to you, a statement that there were no deviations from the emission limitations and work practice standards during the reporting period. If there were no periods during which the CMSs, including continuous emissions monitoring system, continuous opacity monitoring system, and operating parameter monitoring systems, were out-of-control as specified in § 63.8(c)(7), a statement that there were no periods during which the CMSs were out-of-control during the reporting period; and c. If you have a deviation from any emission limitation (emission limit and operating limit) or work practice standard during the reporting period, the report must contain the information in § 63.7550(d). If there were periods during which the CMSs, including continuous emissions monitoring system, continuous opacity monitoring system, and operating parameter monitoring systems, were out-of-control, as specified in § 63.8(c)(7), the report must contain the information in § 63.7550(e); and d. If you had a startup, shutdown, or malfunction during the reporting period and you took actions consistent with your startup, shutdown, and malfunction plan, the compliance report must include the information in § 63.10(d)(5)(i)	
2. An immediate startup, shutdown, and malfunction report if you had a startup, shutdown, or malfunction during the reporting period that is not consistent with your startup, shutdown, and malfunction plan, and the source exceeds any applicable emission limitation in the relevant emission standard.	a. Actions taken for the event; and	i. By fax or telephone within 2 working days after starting actions inconsistent with the plan; and
	b. The information in § 63.10(d)(5)(ii)	ii. By letter within 7 working days after the end of the event unless you have made alternative arrangements with the permitting authority.

TABLE 10 TO SUBPART DDDDD OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART DDDDD

As stated in § 63.7565, you must comply with the applicable General Provisions according to the following:

Citation	Subject	Brief description	Applicable
§ 63.1	Applicability	Initial Applicability Determination; Applicability After Standard Established; Permit Requirements; Extensions, Notifications.	Yes.
§ 63.2	Definitions	Definitions for part 63 standards	Yes.
§ 63.3	Units and Abbreviations	Units and abbreviations for part 63 standards	Yes.
§ 63.4	Prohibited Activities	Prohibited Activities; Compliance date; Circumvention, Severability.	Yes.
§ 63.5	Construction/Reconstruction	Applicability; applications; approvals	Yes.
§ 63.6(a)	Applicability	GP apply unless compliance extension; and GP apply to area sources that become major.	Yes.
§ 63.6(b)(1)–(4)	Compliance Dates for New and Reconstructed sources	Standards apply at effective date; 3 years after effective date; upon startup; 10 years after construction or reconstruction commences for 112(f).	Yes.
§ 63.6(b)(5)	Notification	Must notify if commenced construction or reconstruction after proposal.	Yes.
§ 63.6(b)(6)	[Reserved]		
§ 63.6(b)(7)	Compliance Dates for New and Reconstructed Area Sources That Become Major.	Area sources that become major must comply with major source standards immediately upon becoming major, regardless of whether required to comply when they were an area source.	Yes.
§ 63.6(c)(1)–(2)	Compliance Dates for Existing Sources	Comply according to date in subpart, which must be no later than 3 years after effective date; and for 112(f) standards, comply within 90 days of effective date unless compliance extension.	Yes.
§ 63.6(c)(3)–(4)	[Reserved]		
§ 63.6(c)(5)	Compliance Dates for Existing Area Sources That Become Major.	Area sources that become major must comply with major source standards by date indicated in subpart or by equivalent time period (for example, 3 years).	Yes.
§ 63.6(d)	[Reserved]		
§ 63.6(e)(1)–(2)	Operation & Maintenance	Operate to minimize emissions at all times; and Correct malfunctions as soon as practicable; and Operation and maintenance requirements independently enforceable; information Administrator will use to determine if operation and maintenance requirements were met.	Yes.
§ 63.6(e)(3)	Startup, Shutdown, and Malfunction Plan (SSMP)	Requirement for SSM and startup, shutdown, malfunction plan; and content of SSMP.	Yes.
§ 63.6(f)(1)	Compliance Except During SSM	Comply with emission standards at all times except during SSM.	Yes.
§ 63.6(f)(2)–(3)	Methods for Determining Compliance	Compliance based on performance test, operation and maintenance plans, records, inspection.	Yes.
§ 63.6(g)(1)–(3)	Alternative Standard	Procedures for getting an alternative standard	Yes.
§ 63.6(h)(1)	Compliance with Opacity/VE Standards	Comply with opacity/VE emission limitations at all times except during SSM.	Yes.

§ 63.6(h)(2)(i)	Determining Compliance with Opacity/Visible Emission (VE) Standards.	If standard does not state test method, use Method 9 for opacity and Method 22 for VE.	No.
§ 63.6(h)(2)(ii)	[Reserved]		
§ 63.6(h)(2)(iii)	Using Previous Tests to Demonstrate Compliance with Opacity/VE Standards	Criteria for when previous opacity/VE testing can be used to show compliance with this subpart.	Yes.
§ 63.6(h)(3)	[Reserved]		
§ 63.6(h)(4)	Notification of Opacity/VE Observation Date	Notify Administrator of anticipated date of observation	No.
§ 63.6(h)(5)(i),(iii)–(v)	Conducting Opacity/VE Observations	Dates and Schedule for conducting opacity/VE observations.	No.
§ 63.6(h)(5)(ii)	Opacity Test Duration and Averaging Times	Must have at least 3 hours of observation with thirty, 6-minute averages.	No.
§ 63.6(h)(6)	Records of Conditions During Opacity/VE observations	Keep records available and allow Administrator to inspect.	No.
§ 63.6(h)(7)(i)	Report continuous opacity monitoring system Monitoring Data from Performance Test.	Submit continuous opacity monitoring system data with other performance test data.	Yes.
§ 63.6(h)(7)(ii)	Using continuous opacity monitoring system instead of Method 9.	Can submit continuous opacity monitoring system data instead of Method 9 results even if subpart requires Method 9, but must notify Administrator before performance test.	No.
§ 63.6(h)(7)(iii)	Averaging time for continuous opacity monitoring system during performance test.	To determine compliance, must reduce continuous opacity monitoring system data to 6-minute averages.	Yes.
§ 63.6(h)(7)(iv)	Continuous opacity monitoring system requirements	Demonstrate that continuous opacity monitoring system performance evaluations are conducted according to §§ 63.8(e), continuous opacity monitoring systems are properly maintained and operated according to § 63.8(c) and data quality as § 63.8(d).	Yes.
§ 63.6(h)(7)(v)	Determining Compliance with Opacity/VE Standards	Continuous opacity monitoring system is probative but not conclusive evidence of compliance with opacity standard, even if Method 9 observation shows otherwise. Requirements for continuous opacity monitoring system to be probative evidence-proper maintenance, meeting PS 1, and data have not been altered.	Yes.
§ 63.6(h)(8)	Determining Compliance with Opacity/VE Standards	Administrator will use all continuous opacity monitoring system, Method 9, and Method 22 results, as well as information about operation and maintenance to determine compliance.	Yes.
§ 63.6(h)(9)	Adjusted Opacity Standard	Procedures for Administrator to adjust an opacity standard.	Yes.
§ 63.6(i)(1)–(14)	Compliance Extension	Procedures and criteria for Administrator to grant compliance extension.	Yes.
§ 63.6(j)	Presidential Compliance Exemption	President may exempt source category from requirement to comply with rule.	Yes.
§ 63.7(a)(1)	Performance Test Dates	Dates for Conducting Initial Performance Testing and Other Compliance Demonstrations.	Yes.
§ 63.7(a)(2)	Performance Test Dates	New source with initial startup date before effective date has 180 days after effective date to demonstrate compliance	Yes.
§ 63.7(a)(2)(ii–viii)	[Reserved]		

As stated in § 63.7565, you must comply with the applicable General Provisions according to the following:

Citation	Subject	Brief description	Applicable
§ 63.7(a)(2)(ix)	Performance Test Dates	1. New source that commenced construction between proposal and promulgation dates, when promulgated standard is more stringent than proposed standard, has 180 days after effective date or 180 days after startup of source, whichever is later, to demonstrate compliance; and.	Yes.
		2. If source initially demonstrates compliance with less stringent proposed standard, it has 3 years and 180 days after the effective date of the standard or 180 days after startup of source, whichever is later, to demonstrate compliance with promulgated standard.	No.
§ 63.7(a)(3)	Section 114 Authority	Administrator may require a performance test under CAA Section 114 at any time.	Yes.
§ 63.7(b)(1)	Notification of Performance Test	Must notify Administrator 60 days before the test	No.
§ 63.7(b)(2)	Notification of Rescheduling	If rescheduling a performance test is necessary, must notify Administrator 5 days before scheduled date of rescheduled date.	Yes.
§ 63.7(c)	Quality Assurance/Test Plan	Requirement to submit site-specific test plan 60 days before the test or on date Administrator agrees with: test plan approval procedures; and performance audit requirements; and internal and external QA procedures for testing.	Yes.
§ 63.7(d)	Testing Facilities	Requirements for testing facilities	Yes.
§ 63.7(e)(1)	Conditions for Conducting Performance Tests	1. Performance tests must be conducted under representative conditions; and	No.
		2. Cannot conduct performance tests during SSM; and	Yes.
		3. Not a deviation to exceed standard during SSM; and	Yes.
		4. Upon request of Administrator, make available records necessary to determine conditions of performance tests.	Yes.
§ 63.7(e)(2)	Conditions for Conducting Performance Tests	Must conduct according to rule and EPA test methods unless Administrator approves alternative.	Yes.
§ 63.7(e)(3)	Test Run Duration	Must have three separate test runs; and Compliance is based on arithmetic mean of three runs; and conditions when data from an additional test run can be used.	Yes.
§ 63.7(e)(4)	Interaction with other sections of the Act	Nothing in § 63.7(e)(1) through (4) can abrogate the Administrator's authority to require testing under Section 114 of the Act.	Yes.
§ 63.7(f)	Alternative Test Method	Procedures by which Administrator can grant approval to use an alternative test method.	Yes.
§ 63.7(g)	Performance Test Data Analysis	Must include raw data in performance test report; and must submit performance test data 60 days after end of test with the Notification of Compliance Status; and keep data for 5 years.	Yes.

§ 63.7(h)	Waiver of Tests	Procedures for Administrator to waive performance test.	Yes.
§ 63.8(a)(1)	Applicability of Monitoring Requirements	Subject to all monitoring requirements in standard	Yes.
§ 63.8(a)(2)	Performance Specifications	Performance Specifications in appendix B of part 60 apply.	Yes.
§ 63.8(a)(3)	[Reserved]		
§ 63.8(a)(4)	Monitoring with Flares	Unless your rule says otherwise, the requirements for flares in § 63.11 apply.	No.
§63.8(b)(1)(i)–(ii)	Monitoring	Must conduct monitoring according to standard unless Administrator approves alternative.	Yes.
§ 63.8(b)(1)(iii)	Monitoring	Flares not subject to this section unless otherwise specified in relevant standard.	No.
§ 63.8(b)(2)–(3)	Multiple Effluents and Multiple Monitoring Systems	Specific requirements for installing monitoring systems; and must install on each effluent before it is combined and before it is released to the atmosphere unless Administrator approves otherwise; and if more than one monitoring system on an emission point, must report all monitoring system results, unless one monitoring system is a backup.	Yes.
§ 63.8(c)(1)	Monitoring System Operation and Maintenance	Maintain monitoring system in a manner consistent with good air pollution control practices.	Yes.
§ 63.8(c)(1)(i)	Routine and Predictable SSM	Maintain and operate CMS according to § 63.6(e)(1)	Yes.
§ 63.8(c)(1)(ii)	SSM not in SSMP	Must keep necessary parts available for routine repairs of CMSs.	Yes.
§ 63.8(c)(1)(iii)	Compliance with Operation and Maintenance	Must develop an SSMP for CMS	Yes.
§ 63.8(c)(2)–(3)	Monitoring System Installation	Must install to get representative emission and parameter measurements; and must verify operational status before or at performance test.	Yes.
§ 63.8(c)(4)	Continuous Monitoring System (CMS) Requirements	CMSs must be operating except during breakdown, out-of-control, repair, maintenance, and high-level calibration drifts.	No.
§ 63.8(c)(4)(i)	Continuous Monitoring System (CMS) Requirements	Continuous opacity monitoring system must have a minimum of one cycle of sampling and analysis for each successive 10-second period and one cycle of data recording for each successive 6-minute period.	Yes.
§ 63.8(c)(4)(ii)	Continuous Monitoring System (CMS) Requirements	Continuous emissions monitoring system must have a minimum of one cycle of operation for each successive 15-minute period.	No.
§ 63.8(c)(5)	Continuous Opacity Monitoring system (COMS) Requirements.	Must do daily zero and high level calibrations	Yes.
§ 63.8(c)(6)	Continuous Monitoring System (CMS) Requirements	Must do daily zero and high level calibrations	No.
§ 63.8(c)(7)–(8)	Continuous Monitoring Systems Requirements	Out-of-control periods, including reporting	Yes.
§ 63.8(d)	Continuous Monitoring Systems Quality Control	Requirements for continuous monitoring systems quality control, including calibration, etc.; and must keep quality control plan on record for the life of the affected source. Keep old versions for 5 years after revisions.	Yes.
§ 63.8(e)	Continuous monitoring systems Performance Evaluation.	Notification, performance evaluation test plan, reports	Yes.

As stated in § 63.7565, you must comply with the applicable General Provisions according to the following:

Citation	Subject	Brief description	Applicable
§ 63.8(f)(1)–(5)	Alternative Monitoring Method	Procedures for Administrator to approve alternative monitoring.	Yes.
§ 63.8(f)(6)	Alternative to Relative Accuracy Test	Procedures for Administrator to approve alternative relative accuracy tests for continuous emissions monitoring system.	No.
§ 63.8(g)(1)–(4)	Data Reduction	Continuous opacity monitoring system 6-minute averages calculated over at least 36 evenly spaced data points; and continuous emissions monitoring system 1-hour averages computed over at least 4 equally spaced data points.	Yes.
§ 63.8(g)(5)	Data Reduction	Data that cannot be used in computing averages for continuous emissions monitoring system and continuous opacity monitoring system.	No.
§ 63.9(a)	Notification Requirements	Applicability and State Delegation	Yes.
§ 63.9(b)(1)–(5)	Initial Notifications	Submit notification 120 days after effective date; and Notification of intent to construct/reconstruct; and Notification of commencement of construct/reconstruct; Notification of startup; and Contents of each.	Yes.
§ 63.9(c)	Request for Compliance Extension	Can request if cannot comply by date or if installed BACT/LAER.	Yes.
§ 63.9(d)	Notification of Special Compliance Requirements for New Source.	For sources that commence construction between proposal and promulgation and want to comply 3 years after effective date.	Yes.
§ 63.9(e)	Notification of Performance Test	Notify Administrator 60 days prior	No.
§ 63.9(f)	Notification of VE/Opacity Test	Notify Administrator 30 days prior	No.
§ 63.9(g)	Additional Notifications When Using Continuous Monitoring Systems.	Notification of performance evaluation; and notification using continuous opacity monitoring system data; and notification that exceeded criterion for relative accuracy.	Yes.
§ 63.9(h)(1)–(6)	Notification of Compliance Status	Contents; and due 60 days after end of performance test or other compliance demonstration, and when to submit to Federal vs. State authority.	Yes.
§ 63.9(i)	Adjustment of Submittal Deadlines	Procedures for Administrator to approve change in when notifications must be submitted.	Yes.
§ 63.9(j)	Change in Previous Information	Must submit within 15 days after the change	Yes.
§ 63.10(a)	Recordkeeping/Reporting	Applies to all, unless compliance extension; and when to submit to Federal vs. State authority; and procedures for owners of more than 1 source.	Yes.
§ 63.10(b)(1)	Recordkeeping/Reporting	General Requirements; and keep all records readily available and keep for 5 years.	Yes.
§ 63.10(b)(2)(i)–(v)	Records related to Startup, Shutdown, and Malfunction	Occurrence of each of operation (process, equipment); and occurrence of each malfunction of air pollution equipment; and maintenance of air pollution control equipment; and actions during startup, shutdown, and malfunction.	Yes.

§ 63.10(b)(2)(vi) and (x–xi)	Continuous monitoring systems Records	Malfunctions, inoperative, out-of-control; and calibration checks; and adjustments, maintenance.	Yes.
§ 63.10(b)(2)(vii)–(ix)	Records	Measurements to demonstrate compliance with emission limitations; and performance test, performance evaluation, and visible emission observation results; and measurements to determine conditions of performance tests and performance evaluations.	Yes.
§ 63.10(b)(2)(xii)	Records	Records when under waiver	Yes.
§ 63.10(b)(2)(xiii)	Records	Records when using alternative to relative accuracy test.	No.
§ 63.10(b)(2)(xiv)	Records	All documentation supporting Initial Notification and Notification of Compliance Status.	Yes.
§ 63.10(b)(3)	Records	Applicability Determinations	Yes.
§ 63.10(c)(1),(5)–(8),(10)–(15)	Records	Additional Records for continuous monitoring systems	Yes.
§ 63.10(c)(7)–(8)	Records	Records of excess emissions and parameter monitoring exceedances for continuous monitoring systems.	No.
§ 63.10(d)(1)	General Reporting Requirements	Requirement to report	Yes.
§ 63.10(d)(2)	Report of Performance Test Results	When to submit to Federal or State authority	Yes.
§ 63.10(d)(3)	Reporting Opacity or VE Observations	What to report and when	Yes.
§ 63.10(d)(4)	Progress Reports	Must submit progress reports on schedule if under compliance extension.	Yes.
§ 63.10(d)(5)	Startup, Shutdown, and Malfunction Reports	Contents and submission	Yes.
§ 63.10(e)(1)(2)	Additional continuous monitoring systems Reports	Must report results for each CEM on a unit; and written copy of performance evaluation; and 3 copies of continuous opacity monitoring system performance evaluation.	Yes.
§ 63.10(e)(3)	Reports	Excess Emission Reports	No.
§ 63.10(e)(3)(i–iii)	Reports	Schedule for reporting excess emissions and parameter monitor exceedance (now defined as deviations).	No.
§ 63.10(e)(3)(iv–v)	Excess Emissions Reports	Requirement to revert to quarterly submission if there is an excess emissions and parameter monitor exceedance (now defined as deviations); and provision to request semiannual reporting after compliance for one year; and submit report by 30th day following end of quarter or calendar half; and if there has not been an exceedance or excess emission (now defined as deviations), report contents is a statement that there have been no deviations.	No.
§ 63.10(e)(3)(iv–v)	Excess Emissions Reports	Must submit report containing all of the information in § 63.10(c)(5–13), § 63.8(c)(7–8).	No.
§ 63.10(e)(3)(vi–viii)	Excess Emissions Report and Summary Report	Requirements for reporting excess emissions for continuous monitoring systems (now called deviations); Requires all of the information in § 63.10(c)(5–13), § 63.8(c)(7–8).	No.
§ 63.10(e)(4)	Reporting continuous opacity monitoring system data	Must submit continuous opacity monitoring system data with performance test data.	Yes.
§ 63.10(f)	Waiver for Recordkeeping/Reporting	Procedures for Administrator to waive	Yes.
§ 63.11	Flares	Requirements for flares	No.

As stated in § 63.7565, you must comply with the applicable General Provisions according to the following:

Citation	Subject	Brief description	Applicable
§ 63.12	Delegation	State authority to enforce standards	Yes.
§ 63.13	Addresses	Addresses where reports, notifications, and requests are sent.	Yes.
§ 63.14	Incorporation by Reference	Test methods incorporated by reference	Yes.
§ 63.15	Availability of Information	Public and confidential Information	Yes.

[69 FR 55253, Sept. 13, 2004, as amended at 71 FR 20468, Apr. 20, 2006]

APPENDIX A TO SUBPART DDDDD—METHODOLOGY AND CRITERIA FOR DEMONSTRATING ELIGIBILITY FOR THE HEALTH-BASED COMPLIANCE ALTERNATIVES

1. PURPOSE/INTRODUCTION

This appendix provides the methodology and criteria for demonstrating that your affected source is eligible for the compliance alternative for the HCl emission limit and/or the total selected metals (TSM) emission limit. This appendix specifies emissions testing methods that you must use to determine HCl, chlorine, and manganese emissions from the affected units and what parts of the affected source facility must be included in the eligibility demonstration. You must demonstrate that your affected source is eligible for the health-based compliance alternatives using either a look-up table analysis (based on the look-up tables included in this appendix) or a site-specific compliance demonstration performed according to the criteria specified in this appendix. This appendix also specifies how and when you file any eligibility demonstrations for your affected source and how to show that your affected source remains eligible for the health-based compliance alternatives in the future.

2. WHO IS ELIGIBLE TO DEMONSTRATE THAT THEY QUALIFY FOR THE HEALTH-BASED COMPLIANCE ALTERNATIVES?

Each new, reconstructed, or existing affected source may demonstrate that they are eligible for the health-based compliance alternatives. Section 63.7490 of subpart DDDDD defines the affected source and explains which affected sources are new, existing, or reconstructed.

3. WHAT PARTS OF MY FACILITY HAVE TO BE INCLUDED IN THE HEALTH-BASED ELIGIBILITY DEMONSTRATION?

If you are attempting to determine your eligibility for the compliance alternative for HCl, you must include every emission point subject to subpart DDDDD that emits either HCl or Cl_2 in the eligibility demonstration.

If you are attempting to determine your eligibility for the compliance alternative for TSM, you must include every emission point subject to subpart DDDDD that emits manganese in the eligibility demonstration.

4. HOW DO I DETERMINE HAP EMISSIONS FROM MY AFFECTED SOURCE?

(a) You must conduct HAP emissions tests or fuel analysis for every emission point covered under subpart DDDDD within the affected source facility according to the requirements in paragraphs (b) through (f) of this section and the methods specified in Table 1 of this appendix.

(1) If you are attempting to determine your eligibility for the compliance alternative for HCl, you must test the subpart DDDDD units at your facility for both HCl and Cl_2. When conducting fuel analysis, you must assume any chlorine detected will be emitted as Cl_2.

(2) If you are attempting to determine your eligibility for the compliance alternative for TSM, you must test the subpart DDDDD units at your facility for manganese.

(b) *Periods when emissions tests must be conducted.* (1) You must not conduct emissions tests during periods of startup, shutdown, or malfunction, as specified in §63.7(e)(1).

(2) You must test under worst-case operating conditions as defined in this appendix. You must describe your worst-case operating conditions in your performance test report for the process and control systems (if applicable) and explain why the conditions are worst-case.

(c) *Number of test runs.* You must conduct three separate test runs for each test required in this section, as specified in §63.7(e)(3). Each test run must last at least 1 hour.

(d) *Sampling locations.* Sampling sites must be located at the outlet of the control device and prior to any releases to the atmosphere.

(e) *Collection of monitoring data for HAP control devices.* During the emissions test, you must collect operating parameter monitoring system data at least every 15 minutes during the entire emissions test and establish the site-specific operating requirements in Tables 3 or 4, as appropriate, of subpart DDDDD using data from the monitoring system and the procedures specified in §63.7530 of subpart DDDDD.

(f) *Nondetect data.* You may treat emissions of an individual HAP as zero if all of the test runs result in a nondetect measurement and the condition in paragraph (f)(1) of this section is met for the manganese test method. Otherwise, nondetect data for individual HAP must be treated as one-half of the method detection limit.

(1) For manganese measured using Method 29 in appendix A to 40 CFR part 60, you analyze samples using atomic absorption spectroscopy (AAS).

(g) You must determine the maximum hourly emission rate for each appropriate emission point according to Equation 1 of this appendix. An appropriate emission point is any emission point emitting HCl, Cl_2, or Manganese from a subpart DDDDD emission unit.

$$E_{i,s} = \sum_{j=1}^{t} \left(R_{i,j} \times I_j \right) \qquad \text{(Eq. 1)}$$

Where:

$E_{i,s}$ = maximum hourly emission rate for HAP i at each emission point s associated with a subpart DDDDD emission unit j, lbs/hr

i = applicable HAP, where i = (HCl, Cl_2, or Manganese) s = individual emission point

j = each subpart DDDDD emission unit associated with an emission point, s

t = total number of subpart DDDDD emission units associated with an emission point s

$R_{i,j}$ = emission rate (the 3-run average as determined according to table 1 of this appendix or the pollutant concentration in the fuel samples analyzed according to §63.7521) for HAP i at subpart DDDDD emission unit j associated with emission point s, lb per million Btu.

I_j = Maximum rated heat input capacity of each subpart DDDDD unit j emitting HAP i associated with emission point s, million Btu per hour.

5. WHAT ARE THE CRITERIA FOR DETERMINING IF MY FACILITY IS ELIGIBLE FOR THE HEALTH-BASED COMPLIANCE ALTERNATIVES?

(a) Determine the HAP emissions from each appropriate emission point within the affected source facility using the procedures specified in section 4 of this appendix.

(b) Demonstrate that your facility is eligible for either of the health-based compliance alternatives using either the methods described in section 6 of this appendix (look-up table analysis) or section 7 of this appendix (site-specific compliance demonstration).

(c) Your facility is eligible for the health-based compliance alternative for HCl if one of the following two statements is true:

(1) The calculated HCl-equivalent emission rate is below the appropriate value in the look-up table;

(2) Your site-specific compliance demonstration indicates that none of your HI values for HCl and CL_2 are greater than 1.0 at locations where people live or congregate (e.g., schools, daycare centers, etc.);

(d) Your facility is eligible for the health-based compliance alternative for TSM if one of the following two statements is true:

(1) The manganese emission rate for all your subpart DDDDD sources is below the appropriate value in the look-up table;

(2) Your site-specific compliance demonstration indicates that none of your HQ values for manganese are greater than 1.0 at locations where people live or congregate (e.g., schools, daycare centers, etc.).

6. HOW DO I CONDUCT A LOOK-UP TABLE ANALYSIS?

You may use look-up tables to demonstrate that your facility is eligible for either the compliance alternative for HCl emissions limit or the compliance alternative for the TSM emissions limit, unless your permitting authority determines that the look-up table analysis in this section is not applicable to your facility on technical grounds due to site-specific variations that are not accounted for in the look-up table analysis (e.g. presence of complex terrain, rain caps, or building downwash effects).

(a) *HCl compliance alternative.* (1) Using the emission rates for HCl and Cl_2 determined according to section 4 of this appendix, calculate, using equation 2 of this appendix, the toxicity-weighted emission rate (expressed in HCl-equivalents) for each emission point that emits HCl or Cl_2 from any subpart DDDDD sources. Then, calculate the weighted average stack height using equation 3 of this appendix.

$$TW_s = E_{HCl,s} + E_{Cl_2,s} \left(\frac{RV_{HCl}}{RV_{Cl_2}} \right) \qquad \text{(Eq. 2)}$$

Where:

TW_s = the toxicity-weighted emission rate (in HCl-equivalent) for each emission point s, lb/hr.

s = individual emission points

$E_{HCl,s}$ = the maximum hourly emission rate for HCl at emission point s, lb/hr

$E_{Cl2,s}$ = the maximum hourly emission rate for Cl_2 at emission point s, lb/hr

RV_{Cl2} = the reference value for Cl_2

RV_{HCl} = the reference value for HCl

(reference values for HCl and Cl_2 can be found at *http://www.epa.gov/ttn/atw/toxsource/summary.html*).

$$H_{HCl} = \frac{\sum_{s=1}^{n}(TW_s \times H_s)}{TW_T} \qquad \text{(Eq. 3)}$$

Where:

H_{HCl} = weighted average stack height for determining the maximum allowable HCl-equivalent emission rate (in Table 2 to this appendix), m.

s = individual emission points

n = total number of emission points

TW_s = toxicity-weighted HCl-equivalent emission rate from each emission point (from equation 2), lb/hr.

H_s = height of each individual stack, m

TW_T = total toxicity-weighted HCl-equivalent emission rate from the source (summed for all emission points), lb/hr.

(2) Calculate the total toxicity-weighted emission rate for your affected source by summing the toxicity-weighted emission rate for each appropriate subpart DDDDD emission point.

(3) Using the weighted average stack height and the minimum distance between any appropriate subpart DDDDD emission point at the source and the property boundary, identify the appropriate maximum allowable toxicity weighted emission rate for your affected source, expressed in HCl-equivalents, from table 2 of this appendix. Appropriate emission points are those that emit HCl or Cl_2, or both, from subpart DDDDD units. If one or both of these values does not match the exact values in the look-up tables, then use the next lowest table value. (NOTE: If your weighted average stack height is less than 5 meters (m), you must use the 5 meter row.) Your affected source is eligible to comply with the health-based alternative for HCl emissions if the value calculated in paragraph (a)(2) of this section, determined using the methods specified in this appendix, does not exceed the appropriate value in table 2 of this appendix.

(b) *TSM Compliance Alternative.* Using the emission rates for manganese determined according to section 4 of this appendix, calculate the total manganese emission rate for your affected source by summing the maximum hourly manganese emission rates for all your subpart DDDDD units. Identify the appropriate allowable emission rate in table 3 of this appendix for your affected source using the weighted average stack height value and the minimum distance between any appropriate subpart DDDDD emission point at the facility and the property boundary. Appropriate emission points are those that emit manganese from subpart DDDDD units. If one or both of these values does not match the exact values in the look-up tables, then use the next lowest table value. (NOTE: If your weighted average stack height is less than 5 meters, you must use the 5 meter row.) Your affected source is eligible to comply with the health-based alternative for manganese emissions and may exclude manganese when demonstrating compliance with the TSM emission limit if the total manganese emission rate, determined using the methods specified in this appendix, does not exceed the appropriate value specified in table 3 of this appendix.

$$H_{Mn} = \frac{\sum_{s=1}^{n}(E_{Mn,s} \times H_s)}{E_{Mn,T}} \qquad \text{(Eq. 4)}$$

Where:

H_{Mn} = weighted average stack height for determining the maximum allowable emission rate for manganese (in table 3 to this appendix), m.

s = individual emission points

n = total number of emission points

$E_{Mn,s}$= maximum hourly manganese emissions from emission point s, lbs/hr.

H_s = height of each individual stack s

$E_{Mn,T}$ = total maximum hourly manganese emissions from affected source (sum emission rates from all emission points), lb/hr

7. HOW DO I CONDUCT A SITE-SPECIFIC COMPLIANCE DEMONSTRATION?

If you fail to demonstrate that your facility is able to comply with one or both of the alternative health-based emission standards using the look-up table approach, you may choose to perform a site-specific compliance

demonstration for your facility. You may use any scientifically-accepted peer-reviewed risk assessment methodology for your site-specific compliance demonstration. An example of one approach for performing a site-specific compliance demonstration for air toxics can be found in the EPA's ''Air Toxics Risk Assessment Reference Library, Volume 2, Site-Specific Risk Assessment Technical Resource Document'', which may be obtained through the EPA's Air Toxics Web site at *http://www.epa.gov/ttn/fera/risk_atoxic.html*.

(a) Your facility is eligible for the HCl alternative compliance option if your site-specific compliance demonstration shows that the maximum HI for HCl and Cl_2 from your subpart DDDDD sources is less than or equal to 1.0.

(b) Your facility is eligible for the TSM alternative compliance option if your site-specific compliance demonstration shows that the maximum HQ for manganese from your subpart DDDDD sources is less than or equal to 1.0.

(c) At a minimum, your site-specific compliance demonstration must:

(1) Estimate long-term inhalation exposures through the estimation of annual or multi-year average ambient concentrations;

(2) Estimate the inhalation exposure for the individual most exposed to the facility's emissions;

(3) Use site-specific, quality-assured data wherever possible;

(4) Use health-protective default assumptions wherever site-specific data are not available, and;

(5) Contain adequate documentation of the data and methods used for the assessment so that it is transparent and can be reproduced by an experienced risk assessor and emissions measurement expert.

(d) Your site-specific compliance demonstration need not:

(1) Assume any attenuation of exposure concentrations due to the penetration of outdoor pollutants into indoor exposure areas;

(2) Assume any reaction or deposition of the emitted pollutants during transport from the emission point to the point of exposure.

8. What Must My Health-Based Eligibility Demonstration Contain?

(a) Your health-based eligibility demonstration must contain, at a minimum, the information specified in paragraphs (a)(1) through (6) of this section.

(1) Identification of each appropriate emission point at the affected source facility, including the maximum rated capacity of each appropriate emission point.

(2) Stack parameters for each appropriate emission point including, but not limited to, the parameters listed in paragraphs (a)(2)(i) through (iv) below:

(i) Emission release type.

(ii) Stack height, stack area, stack gas temperature, and stack gas exit velocity.

(iii) Plot plan showing all emission points, nearby residences, and fenceline.

(iv) Identification of any control devices used to reduce emissions from each appropriate emission point.

(3) Emission test reports for each pollutant and appropriate emission point which has been tested using the test methods specified in Table 1 of this appendix, including a description of the process parameters identified as being worst case. Fuel analyses for each fuel and emission point which has been conducted including collection and analytical methods used.

(4) Identification of the RfC values used in your look-up table analysis or site-specific compliance demonstration.

(5) Calculations used to determine the HCl-equivalent or manganese emission rates according to sections 6(a) or (b) of this appendix.

(6) Identification of the controlling process factors (including, but not limited to, fuel type, heat input rate, type of control devices, process parameters reflecting the emissions rates used for your eligibility demonstration) that will become Federally enforceable permit conditions used to show that your facility remains eligible for the health-based compliance alternatives.

(b) If you use the look-up table analysis in section 6 of this appendix to demonstrate that your facility is eligible for either health-based compliance alternative, your eligibility demonstration must contain, at a minimum, the information in paragraphs (a) and (b)(1) through (3) of this section.

(1) Calculations used to determine the weighted average stack height of the subpart DDDDD emission points that emit manganese, HCl, or Cl_2.

(2) Identification of the subpart DDDDD emission point, that emits either manganese or HCl and Cl_2, with the minimum distance to the property boundary of the facility.

(3) Comparison of the values in the look-up tables (Tables 2 and 3 of this appendix) to your maximum HCl-equivalent or manganese emission rates.

(c) If you use a site-specific compliance demonstration as described in section 7 of this appendix to demonstrate that your facility is eligible, your eligibility demonstration must contain, at a minimum, the information in paragraphs (a) and (c)(1) through (7) of this section:

(1) Identification of the risk assessment methodology used.

(2) Documentation of the fate and transport model used.

(3) Documentation of the fate and transport model inputs, including the information described in paragraphs (a)(1) through (5) of this section converted to the dimensions required for the model and all of the following

that apply: meteorological data; building, land use, and terrain data; receptor locations and population data; and other facility-specific parameters input into the model.

(4) Documentation of the fate and transport model outputs.

(5) Documentation of any exposure assessment and risk characterization calculations.

(6) Comparison of the HQ HI to the limit of 1.0.

(d) To be eligible for either health-based compliance alternative, the parameters that defined your affected source as eligible for the health-based compliance alternatives must be submitted to your permitting authority for incorporation into your title V permit, as federally enforceable limits, at the same time you submit your health-based eligibility demonstration. These parameters include, but are not limited to, fuel type, fuel mix (annual average), emission rate, type of control devices, process parameters (e.g., maximum heat input), and non-process parameters (e.g., stack height).

9. WHEN DO I HAVE TO COMPLETE AND SUBMIT MY HEALTH-BASED ELIGIBILITY DEMONSTRATION?

(a) If you have an existing affected source, you must complete and submit your eligibility demonstration to your permitting authority, along with a signed certification that the demonstration is an accurate depiction of your facility, no later than the date one year prior to the compliance date of subpart DDDDD. A separate copy of the eligibility demonstration must be submitted to: U.S. EPA, Risk and Exposure Assessment Group, Emission Standards Division (C404–01), Attn: Group Leader, Research Triangle Park, North Carolina 27711, electronic mail address *REAG@epa.gov*.

(b) If you have a new or reconstructed affected source that starts up before the effective date of subpart DDDDD, or an affected source that is an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP before the effective date of subpart DDDDD, then you may submit an eligibility demonstration at any time after September 13, 2004 but you must comply with the emissions limits in table 1 to this subpart and all other requirements of subpart DDDDD until your eligibility demonstration is submitted to your permitting authority in accordance with the requirements of section 10 of this appendix.

(c) If you have a new or reconstructed affected source that starts up after the effective date of subpart DDDDD, or an affected source that is an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP after the effective date for subpart DDDDD, then you must follow the schedule in paragraphs (c)(1) and (2) of this section.

(1) You must complete and submit a preliminary eligibility demonstration based on the information (e.g., equipment types, estimated emission rates, process and non-process parameters, reference values, etc.) that will be used to apply for your title V permit. This preliminary eligibility demonstration must be submitted with your application for approval of construction or reconstruction. You must base your preliminary eligibility demonstration on the maximum emissions allowed under your title V permit. If the preliminary eligibility demonstration indicates that your affected source facility is eligible for either compliance alternative, then you may start up your new affected source and your new affected source will be considered in compliance with the alternative standard and subject to the compliance requirements in this appendix.

(2) You must conduct the emission tests or analyses specified in section 4 of this appendix upon initial startup and use the results of these emissions tests to complete and submit your eligibility demonstration within 180 days following your initial startup date.

10. WHEN DO I BECOME ELIGIBLE FOR THE HEALTH-BASED COMPLIANCE ALTERNATIVES?

(a) For existing sources, new sources, or reconstructed sources that start up before the effective date of subpart DDDDD, or an affected source that is an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP before the effective date of subpart DDDDD, you are eligible to comply with a health-based compliance alternative upon submission of a complete demonstration meeting all the requirements of paragraph 8 for the applicable alternative. However, your eligibility demonstration may be reviewed by the permitting authority or by EPA to verify that the demonstration meets the requirements of appendix A to this subpart and is technically sound (i.e. use of the look-up tables is appropriate or the site-specific assessment is technically valid). If you are notified by the permitting authority or by EPA of any deficiencies in your submission, then you are not eligible for the health-based compliance alternative until the permitting authority or EPA verifies that the deficiencies are corrected.

(b) For new or reconstructed sources that start up after the effective date of subpart DDDDD, you are eligible to comply with a the health-based compliance alternatives upon submission of a complete preliminary eligibility determination in accordance with paragraph (c)(1) of section 9 that demonstrates your affected source is eligible for the applicable alternative. You may then start up your source and conduct the necessary testing in accordance with paragraph

(c)(2) of section 9. The eligibility demonstration submitted in accordance with paragraph (c)(2) of section 9 may be reviewed by the permitting authority or by EPA to verify that the demonstration meets the requirements of appendix A to this subpart and is technically sound (i.e. use of the look-up tables is appropriate or the site-specific assessment is technically valid). If you are notified in writing by the permitting authority of any deficiencies in your submission, then you have 30 days to correct the deficiencies unless the permitting authority agrees to extend this time to a period not to exceed 90 days. If the deficiencies are not corrected within the applicable time period, you will not be eligible for the health-based compliance alternative until the permitting authority verifies that the deficiencies are corrected.

(c) If the title V permit conditions requested in accordance with paragraph (d) of section 8 are disapproved by the permitting authority, then your affected source must comply with the applicable emission limits, operating limits, and work practice standards in subpart DDDDD by the compliance dates specified in §63.7495. Until the requested conditions (or alternative conditions meeting the requirements of paragraph (d) of section 8) are incorporated into the permit, compliance with the proposed conditions shall be considered compliance with the health-based alternative.

11. How Do I Ensure That My Facility Remains Eligible for the Health-Based Compliance Alternatives?

(a) You must update your eligibility demonstration and resubmit it each time that any of the parameters that defined your affected source as eligible for the health-based compliance alternatives changes in a way that could result in increased HAP emissions or increased risk from exposure to emissions. These parameters include, but are not limited to, fuel type, fuel mix (annual average), type of control devices, HAP emission rate, stack height, process parameters (e.g., heat input capacity), relevant reference values, and locations where people live).

(b) If you are updating your eligibility demonstration to account for an action in paragraph (a) of this section that is under your control (e.g. change in heat input capacity of your boiler), you must submit your revised eligibility demonstration to the permitting authority prior to making the change and revise your permit to incorporate the change. If your affected source is no longer eligible for the health-based compliance alternatives, then you must comply with the applicable emission limits, operating limits, and compliance requirements in subpart DDDDD prior to making the process change and revising your permit. If you are updating your eligibility demonstration to account for an action in paragraph (a) of this section that is outside of your control (e.g. change in a reference value), and that change causes your source to no longer be able to meet the criteria for the health-based compliance alternatives, your source must comply with the applicable emission limits, operating limits, and compliance requirements in subpart DDDDD within 3 years.

(c) Your revised eligibility demonstration may be reviewed by the permitting authority or EPA to verify that the demonstration meets the requirements of appendix A to this subpart and is technically sound (i.e. use of the look-up tables is appropriate or the site-specific assessment is technically valid). If you are notified by the permitting authority or EPA of any deficiencies in your submission, you will not remain eligible for the health-based compliance alternatives until the permitting authority or EPA verifies that the deficiencies are corrected.

12. What Records Must I Keep?

You must keep records of the information used in developing the eligibility demonstration for your affected source, including all of the information specified in section 8 of this appendix.

13. Definitions

The definitions in §63.7575 of subpart DDDDD apply to this appendix. Additional definitions applicable for this appendix are as follows:

Hazard Index (HI) means the sum of more than one hazard quotient for multiple substances and/or multiple exposure pathways.

Hazard Quotient (HQ) means the ratio of the predicted media concentration of a pollutant to the media concentration at which no adverse effects are expected. For inhalation exposures, the HQ is calculated as the air concentration divided by the RfC.

Look-up table analysis means a risk screening analysis based on comparing the HAP or HAP-equivalent emission rate from the affected source to the appropriate maximum allowable HAP or HAP-equivalent emission rates specified in Tables 2 and 3 of this appendix.

Reference Concentration (RfC) means an estimate (with uncertainty spanning perhaps an order of magnitude) of a continuous inhalation exposure to the human population (including sensitive subgroups) that is likely to be without an appreciable risk of deleterious effects during a lifetime. It can be derived from various types of human or animal data, with uncertainty factors generally applied to reflect limitations of the data used.

Worst-case operating conditions means operation of an affected unit during emissions testing under the conditions that result in the highest HAP emissions or that result in

the emissions stream composition (including HAP and non-HAP) that is most challenging for the control device if a control device is used. For example, worst-case conditions could include operation of an affected unit firing solid fuel likely to produce the most HAP.

TABLE 1 TO APPENDIX B OF SUBPART DDDDD—EMISSION TEST METHODS

For . . .	You must . . .	Using . . .
(1) Each subpart DDDDD emission point for which you choose to use a compliance alternative.	Select sampling ports' location and the number of traverse points.	Method 1 of 40 CFR part 60, appendix A.
(2) Each subpart DDDDD emission point for which you choose to use a compliance alternative.	Determine velocity and volumetric flow rate;.	Method 2, 2F, or 2G in appendix A to 40 CFR part 60.
(3) Each subpart DDDDD emission point for which you choose to use a compliance alternative.	Conduct gas molecular weight analysis ..	Method 3A or 3B in appendix A to 40 CFR part 60.
(4) Each subpart DDDDD emission point for which you choose to use a compliance alternative.	Measure moisture content of the stack gas.	Method 4 in appendix A to 40 CFR part 60.
(5) Each subpart DDDDD emission point for which you choose to use the HCl compliance alternative.	Measure the hydrogen chloride and chlorine emission concentrations.	Method 26 or 26A in appendix A to 40 CFR part 60.
(6) Each subpart DDDDD emission point for which you choose to use the TSM compliance alternative.	Measure the manganese emission concentration.	Method 29 in appendix A to 40 CFR part 60.
(7) Each subpart DDDDD emission point for which you choose to use a compliance alternative.	Convert emissions concentration to lb per MMBtu emission rates.	Method 19 F-factor methodology in appendix A to part 60 of this chapter.

TABLE 2 TO APPENDIX A OF SUBPART DDDDD—ALLOWABLE TOXICITY-WEIGHTED EMISSION RATE EXPRESSED IN HCl EQUIVALENTS (lbs/hr)

Stack ht. (m)	Distance to property boundary (m)											
	0	50	100	150	200	250	500	1000	1500	2000	3000	5000
5	114.9	114.9	114.9	114.9	114.9	114.9	144.3	287.3	373.0	373.0	373.0	373.0
10	188.5	188.5	188.5	188.5	188.5	188.5	195.3	328.0	432.5	432.5	432.5	432.5
20	386.1	386.1	386.1	386.1	386.1	386.1	386.1	425.4	580.0	602.7	602.7	602.7
30	396.1	396.1	396.1	396.1	396.1	396.1	396.1	436.3	596.2	690.6	807.8	816.5
40	408.1	408.1	408.1	408.1	408.1	408.1	408.1	448.2	613.3	715.5	832.2	966.0
50	421.4	421.4	421.4	421.4	421.4	421.4	421.4	460.6	631.0	746.3	858.2	1002.8
60	435.5	435.5	435.5	435.5	435.5	435.5	435.5	473.4	649.0	778.6	885.0	1043.4
70	450.2	450.2	450.2	450.2	450.2	450.2	450.2	486.6	667.4	813.8	912.4	1087.4
80	465.5	465.5	465.5	465.5	465.5	465.5	465.5	500.0	685.9	849.8	940.9	1134.8
100	497.5	497.5	497.5	497.5	497.5	497.5	497.5	527.4	723.6	917.1	1001.2	1241.3
200	677.3	677.3	677.3	677.3	677.3	677.3	677.3	682.3	919.8	1167.1	1390.4	1924.6

TABLE 3 TO APPENDIX A OF SUBPART DDDDD—ALLOWABLE MANGANESE EMISSION RATE (lbs/hr)

Stack ht. (m)	Distance to property boundary (m)											
	0	50	100	150	200	250	500	1000	1500	2000	3000	5000
5	0.29	0.29	0.29	0.29	0.29	0.29	0.36	0.72	0.93	0.93	0.93	0.94
10	0.47	0.47	0.47	0.47	0.47	0.47	0.49	0.82	1.08	1.08	1.08	1.08
20	0.97	0.97	0.97	0.97	0.97	0.97	0.97	1.06	1.45	1.51	1.51	1.51
30	0.99	0.99	0.99	0.99	0.99	0.99	0.99	1.09	1.49	1.72	2.02	2.04
40	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.12	1.53	1.79	2.08	2.42
50	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.15	1.58	1.87	2.15	2.51
60	1.09	1.09	1.09	1.09	1.09	1.09	1.09	1.18	1.62	1.95	2.21	2.61
70	1.13	1.13	1.13	1.13	1.13	1.13	1.13	1.22	1.67	2.03	2.28	2.72
80	1.16	1.16	1.16	1.16	1.16	1.16	1.16	1.25	1.71	2.12	2.35	2.84
100	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.32	1.81	2.29	2.50	3.10
200	1.69	1.69	1.69	1.69	1.69	1.69	1.69	1.71	2.30	2.92	3.48	4.81

[69 FR 55253, Sept. 13, 2004, as amended at 70 FR 76933, Dec. 28, 2005]

Subpart EEEEE—National Emission Standards for Hazardous Air Pollutants for Iron and Steel Foundries

SOURCE: 69 FR 21923, Apr. 22, 2004, unless otherwise noted.

WHAT THIS SUBPART COVERS

§63.7680 What is the purpose of this subpart?

This subpart establishes national emission standards for hazardous air pollutants (NESHAP) for iron and steel foundries. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emissions limitations, work practice standards, and operation and maintenance requirements in this subpart.

§63.7681 Am I subject to this subpart?

You are subject to this subpart if you own or operate an iron and steel foundry that is (or is part of) a major source of hazardous air pollutant (HAP) emissions. Your iron and steel foundry is a major source of HAP for purposes of this subpart if it emits or has the potential to emit any single HAP at a rate of 10 tons or more per year or any combination of HAP at a rate of 25 tons or more per year or if it is located at a facility that emits or has the potential to emit any single HAP at a rate of 10 tons or more per year or any combination of HAP at a rate of 25 tons or more per year.

§63.7682 What parts of my foundry does this subpart cover?

(a) The affected source is each new or existing iron and steel foundry.

(b) This subpart covers emissions from metal melting furnaces, scrap preheaters, pouring areas, pouring stations, automated conveyor and pallet cooling lines, automated shakeout lines, and mold and core making lines. This subpart also covers fugitive emissions from foundry operations.

(c) An affected source is existing if you commenced construction or reconstruction of the affected source before December 23, 2002.

(d) An affected source is new if you commenced construction or reconstruction of the affected source on or after December 23, 2002. An affected source is reconstructed if it meets the definition of ''reconstruction'' in §63.2.

§63.7683 When do I have to comply with this subpart?

(a) Except as specified in paragraph (b) of this section, if you have an existing affected source, you must comply with each emissions limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you no later than April 23, 2007. Major source status for existing affected sources must be determined no later than April 23, 2007.

(b) If you have an existing affected source, you must comply with the work practice standards in §63.7700(b) or (c), as applicable, no later than April 22, 2005.

(c) If you have a new affected source for which the initial startup date is on or before April 22, 2004, you must comply with each emissions limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you by April 22, 2004.

(d) If you have a new affected source for which the initial startup date is after April 22, 2004, you must comply with each emissions limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you upon initial startup.

(e) If your iron and steel foundry is an area source that becomes a major source of HAP, you must meet the requirements of §63.6(c)(5).

(f) You must meet the notification and schedule requirements in §63.7750. Note that several of these notifications must be submitted before the compliance date for your affected source.

EMISSIONS LIMITATIONS

§63.7690 What emissions limitations must I meet?

(a) You must meet each emissions limit or standard in paragraphs (a)(1) through (11) of this section that applies to you.

(1) For each electric arc metal melting furnace, electric induction metal melting furnace, or scrap preheater at an existing iron and steel foundry, you must not discharge emissions through a conveyance to the atmosphere that exceed either the limit for particulate matter (PM) in paragraph (a)(1)(i) of this section or, alternatively the limit for total metal HAP in paragraph (a)(1)(ii) of this section:

(i) 0.005 grains of PM per dry standard cubic foot (gr/dscf), or

(ii) 0.0004 gr/dscf of total metal HAP.

(2) For each cupola metal melting furnace at an existing iron and steel foundry, you must not discharge emissions through a conveyance to the atmosphere that exceed either the limit for PM in paragraph (a)(2)(i) of this section or, alternatively the limit for total metal HAP in paragraph (a)(2)(ii) of this section:

(i) 0.006 gr/dscf of PM, or

(ii) 0.0005 gr/dscf of total metal HAP.

(3) For each cupola metal melting furnace or electric arc metal melting furnace at a new iron and steel foundry, you must not discharge emissions through a conveyance to the atmosphere that exceed either the limit for PM in paragraph (a)(3)(i) of this section or, alternatively the limit for total metal HAP in paragraph (a)(3)(ii) of this section:

(i) 0.002 gr/dscf of PM, or

(ii) 0.0002 gr/dscf of total metal HAP.

(4) For each electric induction metal melting furnace or scrap preheater at a new iron and steel foundry, you must not discharge emissions through a conveyance to the atmosphere that exceed either the limit for PM in paragraph (a)(4)(i) of this section or, alternatively the limit for total metal HAP in paragraph (a)(4)(ii) of this section:

(i) 0.001 gr/dscf of PM, or

(ii) 0.00008 gr/dscf of total metal HAP.

(5) For each pouring station at an existing iron and steel foundry, you must not discharge emissions through a conveyance to the atmosphere that exceed either the limit for PM in paragraph (a)(5)(i) of this section or, alternatively the limit for total metal HAP in paragraph (a)(5)(ii) of this section:

(i) 0.010 gr/dscf of PM, or

(ii) 0.0008 gr/dscf of total metal HAP.

(6) For each pouring area or pouring station at a new iron and steel foundry, you must not discharge emissions through a conveyance to the atmosphere that exceed either the limit for PM in paragraph (a)(6)(i) of this section or, alternatively the limit for total metal HAP in paragraph (a)(6)(ii) of this section:

(i) 0.002 gr/dscf of PM, or

(ii) 0.0002 gr/dscf of total metal HAP.

(7) For each building or structure housing any emissions source at the iron and steel foundry, you must not discharge any fugitive emissions to the atmosphere that exhibit opacity greater than 20 percent (6-minute average), except for one 6-minute average per hour that does not exceed 27 percent opacity.

(8) For each cupola metal melting furnace at a new or existing iron and steel foundry, you must not discharge emissions of volatile organic hazardous air pollutants (VOHAP) through a conveyance to the atmosphere that exceed 20 parts per million by volume (ppmv) corrected to 10 percent oxygen.

(9) As an alternative to the work practice standard in §63.7700(e) for a scrap preheater at an existing iron and steel foundry or in §63.7700(f) for a scrap preheater at a new iron and steel foundry, you must not discharge emissions of VOHAP through a conveyance to the atmosphere that exceed 20 ppmv.

(10) For one or more automated conveyor and pallet cooling lines that use a sand mold system or automated shakeout lines that use a sand mold system at a new iron and steel foundry, you must not discharge emissions of VOHAP through a conveyance to the atmosphere that exceed a flow-weighted average of 20 ppmv.

(11) For each triethylamine (TEA) cold box mold or core making line at a new or existing iron and steel foundry, you must meet either the emissions limit in paragraph (a)(11)(i) of this section or, alternatively the emissions standard in paragraph (a)(11)(ii) of this section:

(i) You must not discharge emissions of TEA through a conveyance to the atmosphere that exceed 1 ppmv, as determined when scrubbing with fresh acid solution; or

(ii) You must reduce emissions of TEA from each TEA cold box mold or core making line by at least 99 percent, as determined when scrubbing with fresh acid solution.

(b) You must meet each operating limit in paragraphs (b)(1) through (5) of this section that applies to you.

(1) You must install, operate, and maintain a capture and collection system for all emissions sources subject to an emissions limit or standard for VOHAP or TEA in paragraphs (a)(8) through (11) of this section.

(i) Each capture and collection system must meet accepted engineering standards, such as those published by the American Conference of Governmental Industrial Hygienists.

(ii) You must operate each capture system at or above the lowest value or settings established as operating limits in your operation and maintenance plan.

(2) You must operate each wet scrubber applied to emissions from a metal melting furnace, scrap preheater, pouring area, or pouring station subject to an emissions limit for PM or total metal HAP in paragraphs (a)(1) through (6) of this section such that the 3-hour average pressure drop and scrubber water flow rate does not fall below the minimum levels established during the initial or subsequent performance test.

(3) You must operate each combustion device applied to emissions from a cupola metal melting furnace subject to the emissions limit for VOHAP in paragraph (a)(8) of this section, such that the 15-minute average combustion zone temperature does not fall below 1,300 degrees Fahrenheit (°F). Periods when the cupola is off blast and for 15 minutes after going on blast from an off blast condition are not included in the 15-minute average.

(4) You must operate each combustion device applied to emissions from a scrap preheater subject to the emissions limit for VOHAP in paragraph (a)(9) of this section or from a TEA cold box mold or core making line subject to the emissions limit for TEA in paragraph (a)(11) of this section, such that the 3-hour average combustion zone temperature does not fall below the minimum level established during the initial or subsequent performance test.

(5) You must operate each wet acid scrubber applied to emissions from a TEA cold box mold or core making line subject to the emissions limit for TEA in paragraph (a)(11) of this section such that:

(i) The 3-hour average scrubbing liquid flow rate does not fall below the minimum level established during the initial or subsequent performance test; and

(ii) The 3-hour average pH of the scrubber blowdown, as measured by a continuous parameter monitoring system (CPMS), does not exceed 4.5 or the pH of the scrubber blowdown, as measured once every 8 hours during process operations, does not exceed 4.5.

(c) If you use a control device other than a baghouse, wet scrubber, wet acid scrubber, or combustion device, you must prepare and submit a monitoring plan containing the information listed in paragraphs (c)(1) through (5) of this section. The monitoring plan is subject to approval by the Administrator.

(1) A description of the device;

(2) Test results collected in accordance with §63.7732 verifying the performance of the device for reducing emissions of PM, total metal HAP, VOHAP, or TEA to the levels required by this subpart;

(3) A copy of the operation and maintenance plan required by §63.7710(b);

(4) A list of appropriate operating parameters that will be monitored to maintain continuous compliance with the applicable emissions limitation(s); and

(5) Operating parameter limits based on monitoring data collected during the performance test.

WORK PRACTICE STANDARDS

§63.7700 What work practice standards must I meet?

(a) For each segregated scrap storage area, bin or pile, you must either comply with the certification requirements in paragraph (b) of this section, or prepare and implement a plan for the selection and inspection of scrap according to the requirements in paragraph

(c) of this section. You may have certain scrap subject to paragraph (b) of this section and other scrap subject to paragraph (c) of this section at your facility provided the scrap remains segregated until charge make-up.

(b) You must prepare and operate at all times according to a written certification that the foundry purchases and uses only metal ingots, pig iron, slitter, or other materials that do not include post-consumer automotive body scrap, post-consumer engine blocks, post-consumer oil filters, oily turnings, lead components, mercury switches, plastics, or free organic liquids. For the purpose of this paragraph (b), ''free organic liquids'' is defined as material that fails the paint filter test by EPA Method 9095A, ''Paint Filter Liquids Test'' (Revision 1, December 1996), as published in EPA Publication SW–846 ''Test Methods for Evaluating Solid Waste, Physical/Chemical Methods'' (incorporated by reference—see § 63.14). Any post-consumer engine blocks, post-consumer oil filters, or oily turnings that are processed and/or cleaned to the extent practicable such that the materials do not include lead components, mercury switches, plastics, or free organic liquids can be included in this certification.

(c) You must prepare and operate at all times according to a written plan for the selection and inspection of iron and steel scrap to minimize, to the extent practicable, the amount of organics and HAP metals in the charge materials used by the iron and steel foundry. This scrap selection and inspection plan is subject to approval by the Administrator. You must keep a copy of the plan onsite and readily available to all plant personnel with materials acquisition or inspection duties. You must provide a copy of the material specifications to each of your scrap vendors. Each plan must include the information specified in paragraphs (c)(1) through (3) of this section.

(1) A materials acquisition program to limit organic contaminants according to the requirements in paragraph (c)(1)(i) or (ii) of this section, as applicable.

(i) For scrap charged to a scrap preheater, electric arc metal melting furnace, or electric induction metal melting furnaces, specifications for scrap materials to be depleted (to the extent practicable) of the presence of used oil filters, plastic parts, organic liquids, and a program to ensure the scrap materials are drained of free liquids; or

(ii) For scrap charged to a cupola metal melting furnace, specifications for scrap materials to be depleted (to the extent practicable) of the presence of plastic, and a program to ensure the scrap materials are drained of free liquids.

(2) A materials acquisition program specifying that the scrap supplier remove accessible mercury switches from the trunks and hoods of any automotive bodies contained in the scrap and remove accessible lead components such as batteries and wheel weights. You must obtain and maintain onsite a copy of the procedures used by the scrap supplier for either removing accessible mercury switches or for purchasing automobile bodies that have had mercury switches removed, as applicable.

(3) Procedures for visual inspection of a representative portion, but not less than 10 percent, of all incoming scrap shipments to ensure the materials meet the specifications.

(i) The inspection procedures must identify the location(s) where inspections are to be performed for each type of shipment. Inspections may be performed at the scrap supplier's facility. The selected location(s) must provide a reasonable vantage point, considering worker safety, for visual inspection.

(ii) The inspection procedures must include recordkeeping requirements that document each visual inspection and the results.

(iii) The inspection procedures must include provisions for rejecting or returning entire or partial scrap shipments that do not meet specifications and limiting purchases from vendors whose shipments fail to meet specifications for more than three inspections in one calender year.

(iv) If the inspections are performed at the scrap supplier's facility, the inspection procedures must include an explanation of how the periodic inspections ensure that not less than 10 percent of scrap purchased from each supplier is subject to inspection.

(d) For each furan warm box mold or core making line in a new or existing iron and steel foundry, you must use a binder chemical formulation that does not contain methanol as a specific ingredient of the catalyst formulation as determined by the Material Safety Data Sheet. This requirement does not apply to the resin portion of the binder system.

(e) For each scrap preheater at an existing iron and steel foundry, you must meet either the requirement in paragraph (e)(1) or (2) of this section. As an alternative to the requirement in paragraph (e)(1) or (2) of this section, you must meet the VOHAP emissions limit in §63.7690(a)(9).

(1) You must install, operate, and maintain a gas-fired preheater where the flame directly contacts the scrap charged; or

(2) You must charge only material that is subject to and in compliance with the scrap certification requirement in paragraph (b) of this section.

(f) For each scrap preheater at a new iron and steel foundry, you must charge only material that is subject to and in compliance with the scrap certification requirement in paragraph (b) of this section. As an alternative to this requirement, you must meet the VOHAP emissions limit in §63.7690(a)(9).

[69 FR 21923, Apr. 22, 2004, as amended at 70 FR 29404, May 20, 2005]

OPERATION AND MAINTENANCE REQUIREMENTS

§63.7710 What are my operation and maintenance requirements?

(a) As required by §63.6(e)(1)(i), you must always operate and maintain your iron and steel foundry, including air pollution control and monitoring equipment, in a manner consistent with good air pollution control practices for minimizing emissions at least to the levels required by this subpart.

(b) You must prepare and operate at all times according to a written operation and maintenance plan for each capture and collection system and control device for an emissions source subject to an emissions limit in §63.7690(a). Your operation and maintenance plan also must include procedures for igniting gases from mold vents in pouring areas and pouring stations that use a sand mold system. This operation and maintenance plan is subject to approval by the Administrator. Each plan must contain the elements described in paragraphs (b)(1) through (6) of this section.

(1) Monthly inspections of the equipment that is important to the performance of the total capture system (*i.e.*, pressure sensors, dampers, and damper switches). This inspection must include observations of the physical appearance of the equipment (*e.g.*, presence of holes in the ductwork or hoods, flow constrictions caused by dents or accumulated dust in the ductwork, and fan erosion). The operation and maintenance plan must also include requirements to repair the defect or deficiency as soon as practicable.

(2) Operating limits for each capture system for an emissions source subject to an emissions limit or standard for VOHAP or TEA in §63.7690(a)(8) through (11). You must establish the operating according to the requirements in paragraphs (b)(2)(i) through (iii) of this section.

(i) Select operating limit parameters appropriate for the capture system design that are representative and reliable indicators of the performance of the capture system. At a minimum, you must use appropriate operating limit parameters that indicate the level of the ventilation draft and damper position settings for the capture system when operating to collect emissions, including revised settings for seasonal variations. Appropriate operating limit parameters for ventilation draft include, but are not limited to: volumetric flow rate through each separately ducted hood, total volumetric flow rate at the inlet to the control device to which the capture system is vented, fan motor amperage, or static pressure. Any parameter for damper position setting may be used that indicates the duct damper position related to the fully open setting.

(ii) For each operating limit parameter selected in paragraph (b)(2)(i) of this section, designate the value or setting for the parameter at which the capture system operates during the

process operation. If your operation allows for more than one process to be operating simultaneously, designate the value or setting for the parameter at which the capture system operates during each possible configuration that you may operate (*i.e.*, the operating limits with one furnace melting, two melting, as applicable to your plant).

(iii) Include documentation in your plan to support your selection of the operating limits established for your capture system. This documentation must include a description of the capture system design, a description of the capture system operating during production, a description of each selected operating limit parameter, a rationale for why you chose the parameter, a description of the method used to monitor the parameter according to the requirements of § 63.7740(a), and the data used to set the value or setting for the parameter for each of your process configurations.

(3) Preventative maintenance plan for each control device, including a preventative maintenance schedule that is consistent with the manufacturer's instructions for routine and long-term maintenance.

(4) A site-specific monitoring plan for each bag leak detection system. For each bag leak detection system that operates on the triboelectric effect, the monitoring plan must be consistent with the recommendations contained in the U.S. Environmental Protection Agency guidance document ''Fabric Filter Bag Leak Detection Guidance'' (EPA–454/R–98–015). This baghouse monitoring plan is subject to approval by the Administrator. The owner or operator shall operate and maintain the bag leak detection system according to the site-specific monitoring plan at all times. The plan must address all of the items identified in paragraphs (b)(4)(i) through (v) of this section.

(i) Installation of the bag leak detection system.

(ii) Initial and periodic adjustment of the bag leak detection system including how the alarm set-point will be established.

(iii) Operation of the bag leak detection system including quality assurance procedures.

(iv) How the bag leak detection system will be maintained including a routine maintenance schedule and spare parts inventory list.

(v) How the bag leak detection system output will be recorded and stored.

(5) Corrective action plan for each baghouse. The plan must include the requirement that, in the event a bag leak detection system alarm is triggered, you must initiate corrective action to determine the cause of the alarm within 1 hour of the alarm, initiate corrective action to correct the cause of the problem within 24 hours of the alarm, and complete the corrective action as soon as practicable. Corrective actions taken may include, but are not limited to:

(i) Inspecting the baghouse for air leaks, torn or broken bags or filter media, or any other condition that may cause an increase in emissions.

(ii) Sealing off defective bags or filter media.

(iii) Replacing defective bags or filter media or otherwise repairing the control device.

(iv) Sealing off a defective baghouse compartment.

(v) Cleaning the bag leak detection system probe or otherwise repairing the bag leak detection system.

(vi) Making process changes.

(vii) Shutting down the process producing the PM emissions.

(6) Procedures for providing an ignition source to mold vents of sand mold systems in each pouring area and pouring station unless you determine the mold vent gases either are not ignitable, ignite automatically, or cannot be ignited due to accessibility or safety issues. You must document and maintain records of this determination. The determination of ignitability, accessibility, and safety may encompass multiple casting patterns provided the castings utilize similar sand-to-metal ratios, binder formulations, and coating materials. The determination of ignitability must be based on observations of the mold vents within 5 minutes of pouring, and the flame must be present for at least 15 seconds for the mold vent to be considered ignited. For the purpose of this determination:

(i) Mold vents that ignite more than 75 percent of the time without the presence of an auxiliary ignition source are considered to ignite automatically; and

(ii) Mold vents that do not ignite automatically and cannot be ignited in the presence of an auxiliary ignition source more than 25 percent of the time are considered to be not ignitable.

GENERAL COMPLIANCE REQUIREMENTS

§63.7720 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emissions limitations, work practice standards, and operation and maintenance requirements in this subpart at all times, except during periods of startup, shutdown, or malfunction.

(b) During the period between the compliance date specified for your iron and steel foundry in §63.7683 and the date when applicable operating limits have been established during the initial performance test, you must maintain a log detailing the operation and maintenance of the process and emissions control equipment.

(c) You must develop a written startup, shutdown, and malfunction plan according to the provisions in §63.6(e)(3). The startup, shutdown, and malfunction plan also must specify what constitutes a shutdown of a cupola and how to determine that operating conditions are normal following startup of a cupola.

[69 FR 21923, Apr. 22, 2004, as amended at 71 FR 20468, Apr. 20, 2006]

INITIAL COMPLIANCE REQUIREMENTS

§63.7730 By what date must I conduct performance tests or other initial compliance demonstrations?

(a) As required by §63.7(a)(2), you must conduct a performance test no later than 180 calendar days after the compliance date that is specified in §63.7683 for your iron and steel foundry to demonstrate initial compliance with each emissions limitation in §63.7690 that applies to you.

(b) For each work practice standard in §63.7700 and each operation and maintenance requirement in §63.7710 that applies to you where initial compliance is not demonstrated using a performance test, you must demonstrate initial compliance no later than 30 calendar days after the compliance date that is specified for your iron and steel foundry in §63.7683.

(c) If you commenced construction or reconstruction between December 23, 2002 and April 22, 2004, you must demonstrate initial compliance with either the proposed emissions limit or the promulgated emissions limit no later than October 19, 2004 or no later than 180 calendar days after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

(d) If you commenced construction or reconstruction between December 23, 2002 and April 22, 2004, and you chose to comply with the proposed emissions limit when demonstrating initial compliance, you must conduct a second performance test to demonstrate compliance with the promulgated emissions limit by October 19, 2007 or after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

§63.7731 When must I conduct subsequent performance tests?

(a) You must conduct subsequent performance tests to demonstrate compliance with all applicable PM or total metal HAP, VOHAP, and TEA emissions limitations in §63.7690 for your iron and steel foundry no less frequently than every 5 years. The requirement to conduct performance tests every 5 years does not apply to an emissions source for which a continuous emissions monitoring system (CEMS) is used to demonstrate continuous compliance.

(b) You must conduct subsequent performance tests to demonstrate compliance with the opacity limit in §63.7690(a)(7) for your iron and steel foundry no less frequently than once every 6 months.

§63.7732 What test methods and other procedures must I use to demonstrate initial compliance with the emissions limitations?

(a) You must conduct each performance test that applies to your iron and steel foundry according to the requirements in §63.7(e)(1) and the conditions specified in paragraphs (b) through (h) of this section.

(b) To determine compliance with the applicable emissions limit for PM in §63.7690(a)(1) through (6) for a metal melting furnace, scrap preheater, pouring station, or pouring area, follow the test methods and procedures in paragraphs (b)(1) through (5) of this section.

(1) Determine the concentration of PM according to the test methods in 40 CFR part 60, appendix A that are specified in paragraphs (b)(1)(i) through (v) of this section.

(i) Method 1 or 1A to select sampling port locations and the number of traverse points in each stack or duct. Sampling sites must be located at the outlet of the control device (or at the outlet of the emissions source if no control device is present) prior to any releases to the atmosphere.

(ii) Method 2, 2A, 2C, 2D, 2F, or 2G to determine the volumetric flow rate of the stack gas.

(iii) Method 3, 3A, or 3B to determine the dry molecular weight of the stack gas.

(iv) Method 4 to determine the moisture content of the stack gas.

(v) Method 5, 5B, 5D, 5F, or 5I, as applicable, to determine the PM concentration. The PM concentration is determined using only the front-half (probe rinse and filter) of the PM catch.

(2) Collect a minimum sample volume of 60 dscf of gas during each PM sampling run. A minimum of three valid test runs are needed to comprise a performance test.

(3) For cupola metal melting furnaces, sample only during times when the cupola is on blast.

(4) For electric arc and electric induction metal melting furnaces, sample only when metal is being melted.

(5) For scrap preheaters, sample only when scrap is being preheated.

(c) To determine compliance with the applicable emissions limit for total metal HAP in §63.7690(a)(1) through (6) for a metal melting furnace, scrap preheater, pouring station, or pouring area, follow the test methods and procedures in paragraphs (c)(1) through (5) of this section.

(1) Determine the concentration of total metal HAP according to the test methods in 40 CFR part 60, appendix A that are specified in paragraphs (c)(1)(i) through (v) of this section.

(i) Method 1 or 1A to select sampling port locations and the number of traverse points in each stack or duct. Sampling sites must be located at the outlet of the control device (or at the outlet of the emissions source if no control device is present) prior to any releases to the atmosphere.

(ii) Method 2, 2A, 2C, 2D, 2F, or 2G to determine the volumetric flow rate of the stack gas.

(iii) Method 3, 3A, or 3B to determine the dry molecular weight of the stack gas.

(iv) Method 4 to determine the moisture content of the stack gas.

(v) Method 29 to determine the total metal HAP concentration.

(2) Collect a minimum sample volume of 60 dscf of gas during each total metal HAP sampling run. A minimum of three valid test runs are needed to comprise a performance test.

(3) For cupola metal melting furnaces, sample only during times when the cupola is on blast.

(4) For electric arc and electric induction metal melting furnaces, sample only when metal is being melted.

(5) For scrap preheaters, sample only when scrap is being preheated.

(d) To determine compliance with the opacity limit in §63.7690(a)(7) for fugitive emissions from buildings or structures housing any emissions source at the iron and steel foundry, follow the procedures in paragraphs (d)(1) and (2) of this section.

(1) Using a certified observer, conduct each opacity test according to the requirements in EPA Method 9 (40 CFR part 60, appendix A) and §63.6(h)(5).

(2) Conduct each test such that the opacity observations overlap with the PM performance tests.

(e) To determine compliance with the applicable VOHAP emissions limit in §63.7690(a)(8) for a cupola metal melting furnace or in §63.7690(a)(9) for a scrap preheater, follow the test methods and procedures in paragraphs (e)(1) through (4) of this section.

(1) Determine the VOHAP concentration for each test run according to the test methods in 40 CFR part 60, appendix A that are specified in paragraphs (b)(1)(i) through (v) of this section.

(i) Method 1 or 1A to select sampling port locations and the number of traverse points in each stack or duct. Sampling sites must be located at the outlet of the control device (or at the outlet of the emissions source if no control device is present) prior to any releases to the atmosphere.

(ii) Method 2, 2A, 2C, 2D, 2F, or 2G to determine the volumetric flow rate of the stack gas.

(iii) Method 3, 3A, or 3B to determine the dry molecular weight of the stack gas.

(iv) Method 4 to determine the moisture content of the stack gas.

(v) Method 18 to determine the VOHAP concentration. Alternatively, you may use Method 25 to determine the concentration of total gaseous nonmethane organics (TGNMO) or Method 25A to determine the concentration of total organic compounds (TOC), using hexane as the calibration gas.

(2) Determine the average VOHAP, TGNMO, or TOC concentration using a minimum of three valid test runs. Each test run must include a minimum of 60 continuous operating minutes.

(3) For a cupola metal melting furnace, correct the measured concentration of VOHAP, TGNMO, or TOC for oxygen content in the gas stream using Equation 1 of this section:

$$C_{VOHAP,\ 10\%O_2} = C_{VOHAP}\left(\frac{10.9\%}{20.9\% - \%O_2}\right) \qquad \text{(Eq. 1)}$$

Where:

C_{VOHAP} = Concentration of VOHAP in ppmv as measured by Method 18 in 40 CFR part 60, appendix A or the concentration of TGNMO or TOC in ppmv as hexane as measured by Method 25 or 25A in 40 CFR part 60, appendix A; and

$\%O_2$ = Oxygen concentration in gas stream, percent by volume (dry basis).

(4) For a cupola metal melting furnace, measure the combustion zone temperature of the combustion device with the CPMS required in §63.7740(d) during each sampling run in 15-minute intervals. Determine and record the 15-minute average of the three runs.

(f) Follow the applicable procedures in paragraphs (f)(1) through (3) of this section to determine compliance with the VOHAP emissions limit in §63.7690(a)(10) for automated pallet cooling lines or automated shakeout lines.

(1) Follow these procedures to demonstrate compliance by direct measurement of total hydrocarbons (a surrogate for VOHAP) using a volatile organic compound (VOC) CEMS.

(i) Using the VOC CEMS required in §63.7740(g), measure and record the concentration of total hydrocarbons (as hexane) for 180 continuous operating minutes. You must measure emissions at the outlet of the control device (or at the outlet of the emissions source if no control device is present) prior to any releases to the atmosphere.

(ii) Reduce the monitoring data to hourly averages as specified in §63.8(g)(2).

(iii) Compute and record the 3-hour average of the monitoring data.

(2) As an alternative to the procedures in paragraph (f)(1) of this section, you may demonstrate compliance with the VOHAP emissions limit in §63.7690(a)(10) by establishing a site-specific TOC emissions limit that is correlated to the VOHAP emissions limit according to the procedures in paragraph (f)(2)(i) through (ix) of this section.

(i) Determine the VOHAP concentration for each test run according to the test methods in 40 CFR part 60, appendix A that are specified in paragraph (f)(2)(ii) through (vi) of this section.

(ii) Method 1 or 1A to select sampling port locations and the number of traverse points in each stack or duct. Sampling sites must be located at the outlet of the control device (or at the outlet of the emissions source if no control device is present) prior to any releases to the atmosphere.

(iii) Method 2, 2A, 2C, 2D, 2F, or 2G to determine the volumetric flow rate of the stack gas.

(iv) Method 3, 3A, or 3B to determine the dry molecular weight of the stack gas.

(v) Method 4 to determine the moisture content of the stack gas.

(vi) Method 18 to determine the VOHAP concentration. Alternatively, you may use Method 25 to determine the concentration of TGNMO using hexane as the calibration gas.

(vii) Using the CEMS required in § 63.7740(g), measure and record the concentration of total hydrocarbons (as hexane) during each of the Method 18 (or Method 25) sampling runs. You must measure emissions at the outlet of the control device (or at the outlet of the emissions source if no control device is present) prior to any releases to the atmosphere.

(viii) Calculate the average VOHAP (or TGNMO) concentration for the source test as the arithmetic average of the concentrations measured for the individual test runs, and determine the average concentration of total hydrocarbon (as hexane) as measured by the CEMS during all test runs.

(ix) Calculate the site-specific VOC emissions limit using Equation 2 of this section:

$$VOC_{limit} = 20 \times \frac{C_{VOHAP,\ avg}}{C_{CEM}} \qquad \text{(Eq. 2)}$$

Where:

$C_{VOHAP,avg}$ = Average concentration of VOHAP for the source test in ppmv as measured by Method 18 in 40 CFR part 60, appendix A or the average concentration of TGNMO for the source test in ppmv as hexane as measured by Method 25 in 40 CFR part 60, appendix A; and

C_{CEM} = Average concentration of total hydrocarbons in ppmv as hexane as measured using the CEMS during the source test.

(3) For two or more exhaust streams from one or more automated conveyor and pallet cooling lines or automated shakeout lines, compute the flow-weighted average concentration of VOHAP emissions for each combination of exhaust streams using Equation 3 of this section:

$$C_W = \frac{\sum_{i=1}^{n} C_i\, Q_i}{\sum_{i=1}^{n} Q_i} \qquad \text{(Eq. 3)}$$

Where:

C_w = Flow-weighted concentration of VOHAP or VOC, ppmv (as hexane);

C_i = Concentration of VOHAP or VOC from exhaust stream ''i'', ppmv (as hexane);

n = Number of exhaust streams sampled; and

Q_i = Volumetric flow rate of effluent gas from exhaust stream ''i,'' in dry standard cubic feet per minute (dscfm).

(g) To determine compliance with the emissions limit or standard in § 63.7690(a)(11) for a TEA cold box mold or core making line, follow the test methods in 40 CFR part 60, appendix A, specified in paragraphs (g)(1) through (4) of this section.

(1) Determine the TEA concentration for each test run according to the test methods in 40 CFR part 60, appendix A that are specified in paragraphs (g)(1)(i) through (v) of this section.

(i) Method 1 or 1A to select sampling port locations and the number of traverse points in each stack or duct. If you elect to meet the 99 percent reduction standard, sampling sites must be located both at the inlet to the control device and at the outlet of the control device prior to any releases to the atmosphere. If you elect to meet the concentration limit, the sampling site must be located at the outlet of the control device (or at the outlet of the emissions source if no control device is present) prior to any releases to the atmosphere.

(ii) Method 2, 2A, 2C, 2D, 2F, or 2G to determine the volumetric flow rate of the stack gas.

(iii) Method 3, 3A, or 3B to determine the dry molecular weight of the stack gas.

(iv) Method 4 to determine the moisture content of the stack gas.

(v) Method 18 to determine the TEA concentration. The Method 18 sampling option and time must be sufficiently long such that either the TEA concentration in the field sample is at least 5 times the limit of detection for the analytical method or the test results calculated using the laboratory's

reported analytical detection limit for the specific field samples are less than ⅕ of the applicable emissions limit. The adsorbent tube approach, as described in Method 18, may be required to achieve the necessary analytical detection limits. The sampling time must be at least 1 hour in all cases.

(2) Conduct the test as soon as practicable after adding fresh acid solution and the system has reached normal operating conditions.

(3) If you use a wet acid scrubber that is subject to the operating limit in §63.7690(b)(5)(ii) for pH level, determine the pH of the scrubber blowdown using the procedures in paragraph (g)(3)(i) or (ii) of this section.

(i) Measure the pH of the scrubber blowdown with the CPMS required in §63.7740(f)(2) during each TEA sampling run in intervals of no more than 15 minutes. Determine and record the 3-hour average; or

(ii) Measure and record the pH level using the probe and meter required in §63.7740(f)(2) once each sampling run. Determine and record the average pH level for the three runs.

(4) If you are subject to the 99 percent reduction standard, calculate the mass emissions reduction using Equation 4 of this section:

$$\%\ \text{reduction} = \frac{E_i - E_o}{E_i} \times 100\% \qquad \text{(Eq. 4)}$$

Where:

E_i = Mass emissions rate of TEA at control device inlet, kg/hr; and

E_o = Mass emissions rate of TEA at control device outlet, kg/hr.

(h) To determine compliance with the PM or total metal HAP emissions limits in §63.7690(a)(1) through (6) when one or more regulated emissions sources are combined with either another regulated emissions source subject to a different emissions limit or other non-regulated emissions sources, you may demonstrate compliance using one of the procedures in paragraphs (h)(1) through (3) of this section.

(1) Meet the most stringent applicable emissions limit for the regulated emissions sources included in the combined emissions stream for the combined emissions stream.

(2) Use the procedures in paragraphs (h)(2)(i) through (iii) of this section.

(i) Determine the volumetric flow rate of the individual regulated streams for which emissions limits apply.

(ii) Calculate the flow-weighted average emissions limit, considering only the regulated streams, using Equation 3 of this section, except C_w is the flow-weighted average emissions limit for PM or total metal HAP in the exhaust stream, gr/dscf; and C_i is the concentration of PM or total metal HAP in exhaust stream ''i'', gr/dscf.

(iii) Meet the calculated flow-weighted average emissions limit for the regulated emissions sources included in the combined emissions stream for the combined emissions stream.

(3) Use the procedures in paragraphs (h)(3)(i) through (iii) of this section.

(i) Determine the PM or total metal HAP concentration of each of the regulated streams prior to the combination with other exhaust streams or control device.

(ii) Measure the flow rate and PM or total metal HAP concentration of the combined exhaust stream both before and after the control device and calculate the mass removal efficiency of the control device using Equation 4 of this section, except E_i is the mass emissions rate of PM or total metal HAP at the control device inlet, lb/hr and E_o is the mass emissions rate of PM or total metal HAP at the control device outlet, lb/hr

(iii) Meet the applicable emissions limit based on the calculated PM or total metal HAP concentration for the regulated emissions source using Equation 5 of this section:

$$C_{released} = C_i \times \left(1 - \frac{\%\ \text{reduction}}{100}\right) \qquad \text{(Eq. 5)}$$

Where:

$C_{released}$ = Calculated concentration of PM (or total metal HAP) predicted to be released to the atmosphere from the regulated emissions source, in gr/dscf; and

C_i = Concentration of PM (or total metal HAP) in the uncontrolled regulated exhaust stream, in gr/dscf.

§ 63.7733 What procedures must I use to establish operating limits?

(a) For each capture system subject to operating limits in § 63.7690(b)(1)(ii), you must establish site-specific operating limits in your operation and maintenance plan according to the procedures in paragraphs (a)(1) through (3) of this section.

(1) Concurrent with applicable emissions and opacity tests, measure and record values for each of the operating limit parameters in your capture system operation and maintenance plan according to the monitoring requirements in § 63.7740(a).

(2) For any dampers that are manually set and remain at the same position at all times the capture system is operating, the damper position must be visually checked and recorded at the beginning and end of each run.

(3) Review and record the monitoring data. Identify and explain any times the capture system operated outside the applicable operating limits.

(b) For each wet scrubber subject to the operating limits in § 63.7690(b)(2) for pressure drop and scrubber water flow rate, you must establish site-specific operating limits according to the procedures specified in paragraphs (b)(1) and (2) of this section.

(1) Using the CPMS required in § 63.7740(c), measure and record the pressure drop and scrubber water flow rate in intervals of no more than 15 minutes during each PM test run.

(2) Compute and record the 3-hour average pressure drop and average scrubber water flow rate for each sampling run in which the applicable emissions limit is met.

(c) For each combustion device applied to emissions from a scrap preheater or TEA cold box mold or core making line subject to the operating limit in § 63.7690(b)(4) for combustion zone temperature, you must establish a site-specific operating limit according to the procedures specified in paragraphs (c)(1) and (2) of this section.

(1) Using the CPMS required in § 63.7740(e), measure and record the combustion zone temperature during each sampling run in intervals of no more than 15 minutes.

(2) Compute and record the 3-hour average combustion zone temperature for each sampling run in which the applicable emissions limit is met.

(d) For each acid wet scrubber subject to the operating limit in § 63.7690(b)(5), you must establish a site-specific operating limit for scrubbing liquid flow rate according to the procedures specified in paragraphs (d)(1) and (2) of this section.

(1) Using the CPMS required in § 63.7740(f), measure and record the scrubbing liquid flow rate during each TEA sampling run in intervals of no more than 15 minutes.

(2) Compute and record the 3-hour average scrubbing liquid flow rate for each sampling run in which the applicable emissions limit is met.

(e) You may change the operating limits for a capture system, wet scrubber, acid wet scrubber, or combustion device if you meet the requirements in paragraphs (e)(1) through (3) of this section.

(1) Submit a written notification to the Administrator of your request to conduct a new performance test to revise the operating limit.

(2) Conduct a performance test to demonstrate compliance with the applicable emissions limitation in § 63.7690.

(3) Establish revised operating limits according to the applicable procedures in paragraphs (a) through (d) of this section.

(f) You may use a previous performance test (conducted since December 22, 2002) to establish an operating limit provided the test meets the requirements of this subpart.

§ 63.7734 How do I demonstrate initial compliance with the emissions limitations that apply to me?

(a) You have demonstrated initial compliance with the emissions limits in § 63.7690(a) if:

(1) For each electric arc metal melting furnace, electric induction metal

melting furnace, or scrap preheater at an existing iron and steel foundry,

(i) The average PM concentration in the exhaust stream, determined according to the performance test procedures in §63.7732(b), did not exceed 0.005 gr/dscf; or

(ii) The average total metal HAP concentration in the exhaust stream, determined according to the performance test procedures in §63.7732(c), did not exceed 0.0004 gr/dscf.

(2) For each cupola metal melting furnace at an existing iron and steel foundry,

(i) The average PM concentration in the exhaust stream, determined according to the performance test procedures in §63.7732(b), did not exceed 0.006 gr/dscf; or

(ii) The average total metal HAP concentration in the exhaust stream, determined according to the performance test procedures in §63.7732(c), did not exceed 0.0005 gr/dscf.

(3) For each cupola metal melting furnace or electric arc metal melting furnace at a new iron and steel foundry,

(i) The average PM concentration in the exhaust stream, determined according to the performance test procedures in §63.7732(b), did not exceed 0.002 gr/dscf; or

(ii) The average total metal HAP concentration in the exhaust stream, determined according to the performance test procedures in §63.7732(c), did not exceed 0.0002 gr/dscf.

(4) For each electric induction metal melting furnace or scrap preheater at a new iron and steel foundry,

(i) The average PM concentration in the exhaust stream, determined according to the performance test procedures in §63.7732(b), did not exceed 0.001 gr/dscf; or

(ii) The average total metal HAP concentration in the exhaust stream, determined according to the performance test procedures in §63.7732(c), did not exceed 0.00008 gr/dscf.

(5) For each pouring station at an existing iron and steel foundry,

(i) The average PM concentration in the exhaust stream, measured according to the performance test procedures in §63.7732(b), did not exceed 0.010 gr/dscf; or

(ii) The average total metal HAP concentration in the exhaust stream, determined according to the performance test procedures in §63.7732(c), did not exceed 0.0008 gr/dscf.

(6) For each pouring area or pouring station at a new iron and steel foundry,

(i) The average PM concentration in the exhaust stream, measured according to the performance test procedures in §63.7732(b), did not exceed 0.002 gr/dscf; or

(ii) The average total metal HAP concentration in the exhaust stream, determined according to the performance test procedures in §63.7732(c), did not exceed 0.0002 gr/dscf.

(7) For each building or structure housing any emissions source at the iron and steel foundry, the opacity of fugitive emissions discharged to the atmosphere, determined according to the performance test procedures in §63.7732(d), did not exceed 20 percent (6-minute average), except for one 6-minute average per hour that did not exceed 27 percent opacity.

(8) For each cupola metal melting furnace at a new or existing iron and steel foundry, the average VOHAP concentration, determined according to the performance test procedures in §63.7732(e), did not exceed 20 ppmv corrected to 10 percent oxygen.

(9) For each scrap preheater at an existing iron and steel foundry that does not meet the work practice standards in §63.7700(e)(1) or (2) and for each scrap preheater at a new iron and steel foundry that does not meet the work practice standard in §63.7700(f), the average VOHAP concentration determined according to the performance test procedures in §63.7732(e), did not exceed 20 ppmv.

(10) For one or more automated conveyor and pallet cooling lines that use a sand mold system or automated shakeout lines that use a sand mold system at a new foundry,

(i) You have reduced the data from the CEMS to 3-hour averages according to the performance test procedures in §63.7732(f)(1) or (2); and

(ii) The 3-hour flow-weighted average VOHAP concentration, measured according to the performance test procedures in §63.7332(f)(1) or (2), did not exceed 20 ppmv.

(11) For each TEA cold box mold or core making line in a new or existing iron and steel foundry, the average TEA concentration, determined according to the performance test procedures in § 63.7732(g) did not exceed 1 ppmv or was reduced by 99 percent.

(b) You have demonstrated initial compliance with the operating limits in § 63.7690(b) if:

(1) For each capture system subject to the operating limit in § 63.7690(b)(1)(ii),

(i) You have established appropriate site-specific operating limits in your operation and maintenance plan according to the requirements in § 63.7710(b); and

(ii) You have a record of the operating parameter data measured during the performance test in accordance with § 63.7733(a); and

(2) For each wet scrubber subject to the operating limits in § 63.7690(b)(2) for pressure drop and scrubber water flow rate, you have established appropriate site-specific operating limits and have a record of the pressure drop and scrubber water flow rate measured during the performance test in accordance with § 63.7733(b).

(3) For each combustion device subject to the operating limit in § 63.7690(b)(3) for combustion zone temperature, you have a record of the combustion zone temperature measured during the performance test in accordance with § 63.7732(e)(4).

(4) For each combustion device subject to the operating limit in § 63.7690(b)(4) for combustion zone temperature, you have established appropriate site-specific operating limits and have a record of the combustion zone temperature measured during the performance test in accordance with § 63.7733(c).

(5) For each acid wet scrubber subject to the operating limits in § 63.7690(b)(5) for scrubbing liquid flow rate and scrubber blowdown pH,

(i) You have established appropriate site-specific operating limits for the scrubbing liquid flow rate and have a record of the scrubbing liquid flow rate measured during the performance test in accordance with § 63.7733(d); and

(ii) You have a record of the pH of the scrubbing liquid blowdown measured during the performance test in accordance with § 63.7732(g)(3).

§ 63.7735 How do I demonstrate initial compliance with the work practice standards that apply to me?

(a) For each iron and steel foundry subject to the certification requirement in § 63.7700(b), you have demonstrated initial compliance if you have certified in your notification of compliance status that: ''At all times, your foundry will purchase and use only metal ingots, pig iron, slitter, or other materials that do not include post-consumer automotive body scrap, post-consumer engine blocks, post-consumer oil filters, oily turnings, lead components, mercury switches, plastics, or free organic liquids.''

(b) For each iron and steel foundry subject to the requirements in § 63.7700(c) for a scrap inspection and selection plan, you have demonstrated initial compliance if you have certified in your notification of compliance status that:

(1) You have submitted a written plan to the Administrator for approval according to the requirements in § 63.7700(c); and

(2) You will operate at all times according to the plan requirements.

(c) For each furan warm box mold or core making line in a new or existing foundry subject to the work practice standard in § 63.7700(d), you have demonstrated initial compliance if you have certified in your notification of compliance status that:

(1) You will meet the no methanol requirement for the catalyst portion of each binder chemical formulation; and

(2) You have records documenting your certification of compliance, such as a material safety data sheet (provided that it contains appropriate information), a certified product data sheet, or a manufacturer's hazardous air pollutant data sheet, onsite and available for inspection.

(d) For each scrap preheater at an existing iron and steel foundry subject to the work practice standard in § 63.7700(e)(1) or (2), you have demonstrated initial compliance if you have certified in your notification of compliance status that:

(1) You have installed a gas-fired preheater where the flame directly contacts the scrap charged, you will operate and maintain each gas-fired scrap preheater such that the flame directly contacts the scrap charged, and you have records documenting your certification of compliance that are onsite and available for inspection; or

(2) You will charge only material that is subject to and in compliance with the scrap certification requirements in §63.7700(b) and you have records documenting your certification of compliance that are onsite and available for inspection.

(e) For each scrap preheater at a new iron and steel foundry subject to the work practice standard in §63.7700(f), you have demonstrated initial compliance if you have certified in your notification of compliance status that you will charge only material that is subject to and in compliance with the scrap certification requirements in §63.7700(b) and you have records documenting your certification of compliance that are onsite and available for inspection.

[69 FR 21923, Apr. 22, 2004, as amended at 70 FR 29404, May 20, 2005]

§63.7736 How do I demonstrate initial compliance with the operation and maintenance requirements that apply to me?

(a) For each capture system subject to an operating limit in §63.7690(b), you have demonstrated initial compliance if you have met the conditions in paragraphs (a)(1) and (2) of this section.

(1) You have certified in your notification of compliance status that:

(i) You have submitted the capture system operation and maintenance plan to the Administrator for approval according to the requirements of §63.7710(b); and

(ii) You will inspect, operate, and maintain each capture system according to the procedures in the plan.

(2) You have certified in your performance test report that the system operated during the test at the operating limits established in your operation and maintenance plan.

(b) For each control device subject to an operating limit in §63.7690(b), you have demonstrated initial compliance if you have certified in your notification of compliance status that:

(1) You have submitted the control device operation and maintenance plan to the Administrator for approval according to the requirements of §63.7710(b); and

(2) You will inspect, operate, and maintain each control device according to the procedures in the plan.

(c) For each bag leak detection system, you have demonstrated initial compliance if you have certified in your notification of compliance status that:

(1) You have submitted the bag leak detection system monitoring plan to the Administrator for approval according to the requirements of §63.7710(b);

(2) You will inspect, operate, and maintain each bag leak detection system according to the procedures in the plan; and

(3) You will follow the corrective action procedures for bag leak detection system alarms according to the requirements in the plan.

(d) For each pouring area and pouring station in a new or existing foundry, you have demonstrated initial compliance if you have certified in your notification of compliance status report that:

(1) You have submitted the mold vent ignition plan to the Administrator for approval according to the requirements in §63.7710(b); and

(2) You will follow the procedures for igniting mold vent gases according to the requirements in the plan.

CONTINUOUS COMPLIANCE REQUIREMENTS

§63.7740 What are my monitoring requirements?

(a) For each capture system subject to an operating limit in §63.7690(b)(1), you must install, operate, and maintain a CPMS according to the requirements in §63.7741(a) and the requirements in paragraphs (a)(1) and (2) of this section.

(1) If you use a flow measurement device to monitor the operating limit parameter, you must at all times monitor the hourly average rate (*e.g.*, the hourly average actual volumetric flow rate through each separately ducted hood or the average hourly total volumetric

flow rate at the inlet to the control device).

(2) Dampers that are manually set and remain in the same position are exempt from the requirement to install and operate a CPMS. If dampers are not manually set and remain in the same position, you must make a visual check at least once every 24 hours to verify that each damper for the capture system is in the same position as during the initial performance test.

(b) For each negative pressure baghouse or positive pressure baghouse equipped with a stack that is applied to meet any PM or total metal HAP emissions limitation in this subpart, you must at all times monitor the relative change in PM loadings using a bag leak detection system according to the requirements in § 63.7741(b) and conduct inspections at their specified frequencies according to the requirements specified in paragraphs (b)(1) through (8) of this section.

(1) Monitor the pressure drop across each baghouse cell each day to ensure pressure drop is within the normal operating range identified in the manual.

(2) Confirm that dust is being removed from hoppers through weekly visual inspections or other means of ensuring the proper functioning of removal mechanisms.

(3) Check the compressed air supply for pulse-jet baghouses each day.

(4) Monitor cleaning cycles to ensure proper operation using an appropriate methodology.

(5) Check bag cleaning mechanisms for proper functioning through monthly visual inspection or equivalent means.

(6) Make monthly visual checks of bag tension on reverse air and shaker-type baghouses to ensure that bags are not kinked (kneed or bent) or lying on their sides. You do not have to make this check for shaker-type baghouses using self-tensioning (spring-loaded) devices.

(7) Confirm the physical integrity of the baghouse through quarterly visual inspections of the baghouse interior for air leaks.

(8) Inspect fans for wear, material buildup, and corrosion through quarterly visual inspections, vibration detectors, or equivalent means.

(c) For each wet scrubber subject to the operating limits in § 63.7690(b)(2), you must at all times monitor the 3-hour average pressure drop and scrubber water flow rate using CPMS according to the requirements in § 63.7741(c).

(d) For each combustion device subject to the operating limit in § 63.7690(b)(3), you must at all times monitor the 15-minute average combustion zone temperature using a CPMS according to the requirements of § 63.7741(d).

(e) For each combustion device subject to the operating limit in § 63.7690(b)(4), you must at all times monitor the 3-hour average combustion zone temperature using CPMS according to the requirements in § 63.7741(d).

(f) For each wet acid scrubber subject to the operating limits in § 63.7690(b)(5),

(1) You must at all times monitor the 3-hour average scrubbing liquid flow rate using CPMS according to the requirements of § 63.7741(e)(1); and

(2) You must at all times monitor the 3-hour average pH of the scrubber blowdown using CPMS according to the requirements in § 63.7741(e)(2) or measure and record the pH of the scrubber blowdown once per production cycle using a pH probe and meter according to the requirements in § 63.7741(e)(3).

(g) For one or more automated conveyor and pallet cooling lines and automated shakeout lines at a new iron and steel foundry subject to the VOHAP emissions limit in § 63.7690(a)(10), you must at all times monitor the 3-hour average VOHAP concentration using a CEMS according to the requirements of § 63.7741(g).

§ 63.7741 What are the installation, operation, and maintenance requirements for my monitors?

(a) For each capture system subject to an operating limit in § 63.7690(b)(1), you must install, operate, and maintain each CPMS according to the requirements in paragraphs (a)(1) through (3) of this section.

(1) If you use a flow measurement device to monitor an operating limit parameter for a capture system, you must meet the requirements in paragraphs (a)(1)(i) through (iv) of this section.

(i) Locate the flow sensor and other necessary equipment such as straightening vanes in a position that provides a representative flow and that reduces swirling flow or abnormal velocity distributions due to upstream and downstream disturbances.

(ii) Use a flow sensor with a minimum measurement sensitivity of 2 percent of the flow rate.

(iii) Conduct a flow sensor calibration check at least semiannually.

(iv) At least monthly, inspect all components for integrity, all electrical connections for continuity, and all mechanical connections for leakage.

(2) If you use a pressure measurement device to monitor the operating limit parameter for a capture system, you must meet the requirements in paragraphs (a)(2)(i) through (vi) of this section.

(i) Locate the pressure sensor(s) in or as close to a position that provides a representative measurement of the pressure and that minimizes or eliminates pulsating pressure, vibration, and internal and external corrosion.

(ii) Use a gauge with a minimum measurement sensitivity of 0.5 inch of water or a transducer with a minimum measurement sensitivity of 1 percent of the pressure range.

(iii) Check the pressure tap for pluggage daily.

(iv) Using a manometer, check gauge calibration quarterly and transducer calibration monthly.

(v) Conduct calibration checks any time the sensor exceeds the manufacturer's specified maximum operating pressure range, or install a new pressure sensor.

(vi) At least monthly, inspect all components for integrity, all electrical connections for continuity, and all mechanical connections for leakage.

(3) Record the results of each inspection, calibration, and validation check.

(b) You must install, operate, and maintain a bag leak detection system according to the requirements in paragraphs (b)(1) through (7) of this section.

(1) The system must be certified by the manufacturer to be capable of detecting emissions of particulate matter at concentrations of 10 milligrams per actual cubic meter (0.0044 grains per actual cubic foot) or less.

(2) The bag leak detection system sensor must provide output of relative particulate matter loadings and the owner or operator shall continuously record the output from the bag leak detection system using electronic or other means (*e.g.*, using a strip chart recorder or a data logger).

(3) The system must be equipped with an alarm that will sound when an increase in relative particulate loadings is detected over the alarm set point established in the operation and maintenance plan, and the alarm must be located such that it can be heard by the appropriate plant personnel.

(4) The initial adjustment of the system must, at minimum, consist of establishing the baseline output by adjusting the sensitivity (range) and the averaging period of the device, and establishing the alarm set points and the alarm delay time (if applicable).

(5) Following the initial adjustment, do not adjust the sensitivity or range, averaging period, alarm set point, or alarm delay time without approval from the Administrator. Except, once per quarter, you may adjust the sensitivity of the bag leak detection system to account for seasonable effects including temperature and humidity according to the procedures in the operation and maintenance plan required by §63.7710(b).

(6) For negative pressure, induced air baghouses, and positive pressure baghouses that are discharged to the atmosphere through a stack, the bag leak detector sensor must be installed downstream of the baghouse and upstream of any wet scrubber.

(7) Where multiple detectors are required, the system's instrumentation and alarm may be shared among detectors.

(c) For each wet scrubber subject to the operating limits in §63.7690(b)(2), you must install and maintain CPMS to measure and record the pressure drop and scrubber water flow rate according to the requirements in paragraphs (c)(1) and (2) of this section.

(1) For each CPMS for pressure drop you must:

(i) Locate the pressure sensor in or as close as possible to a position that provides a representative measurement of the pressure drop and that minimizes

or eliminates pulsating pressure, vibration, and internal and external corrosion.

(ii) Use a gauge with a minimum measurement sensitivity of 0.5 inch of water or a transducer with a minimum measurement sensitivity of 1 percent of the pressure range.

(iii) Check the pressure tap for pluggage daily.

(iv) Using a manometer, check gauge calibration quarterly and transducer calibration monthly.

(v) Conduct calibration checks any time the sensor exceeds the manufacturer's specified maximum operating pressure range, or install a new pressure sensor.

(vi) At least monthly, inspect all components for integrity, all electrical connections for continuity, and all mechanical connections for leakage.

(2) For each CPMS for scrubber liquid flow rate, you must:

(i) Locate the flow sensor and other necessary equipment in a position that provides a representative flow and that reduces swirling flow or abnormal velocity distributions due to upstream and downstream disturbances.

(ii) Use a flow sensor with a minimum measurement sensitivity of 2 percent of the flow rate.

(iii) Conduct a flow sensor calibration check at least semiannually according to the manufacturer's instructions.

(iv) At least monthly, inspect all components for integrity, all electrical connections for continuity, and all mechanical connections for leakage.

(d) For each combustion device subject to the operating limit in § 63.7690(b)(3) or (4), you must install and maintain a CPMS to measure and record the combustion zone temperature according to the requirements in paragraphs (d)(1) through (8) of this section.

(1) Locate the temperature sensor in a position that provides a representative temperature.

(2) For a noncryogenic temperature range, use a temperature sensor with a minimum tolerance of 2.2 °C or 0.75 percent of the temperature value, whichever is larger.

(3) For a cryogenic temperature range, use a temperature sensor with a minimum tolerance of 2.2 °C or 2 percent of the temperature value, whichever is larger.

(4) Shield the temperature sensor system from electromagnetic interference and chemical contaminants.

(5) If you use a chart recorder, it must have a sensitivity in the minor division of at least 20 °F.

(6) Perform an electronic calibration at least semiannually according to the procedures in the manufacturer's owners manual. Following the electronic calibration, conduct a temperature sensor validation check, in which a second or redundant temperature sensor placed nearby the process temperature sensor must yield a reading within 16.7 °C of the process temperature sensor's reading.

(7) Conduct calibration and validation checks any time the sensor exceeds the manufacturer's specified maximum operating temperature range, or install a new temperature sensor.

(8) At least monthly, inspect all components for integrity and all electrical connections for continuity, oxidation, and galvanic corrosion.

(e) For each wet acid scrubber subject to the operating limits in § 63.7690(b)(5), you must:

(1) Install and maintain CPMS to measure and record the scrubbing liquid flow rate according to the requirements in paragraph (c)(2) of this section; and

(2) Install and maintain CPMS to measure and record the pH of the scrubber blowdown according to the requirements in paragraph (e)(2)(i) through (iv) of this section.

(i) Locate the pH sensor in a position that provides a representative measurement of the pH and that minimizes or eliminates internal and external corrosion.

(ii) Use a gauge with a minimum measurement sensitivity of 0.1 pH or a transducer with a minimum measurement sensitivity of 5 percent of the pH range.

(iii) Check gauge calibration quarterly and transducer calibration monthly using a manual pH gauge.

(iv) At least monthly, inspect all components for integrity, all electrical

connections for continuity, and all mechanical connections for leakage.

(3) As an alternative to the CPMS required in paragraph (e)(2) of this section, you may use a pH probe to extract a sample for analysis by a pH meter that meets the requirements in paragraphs (e)(3)(i) through (iii) of this section.

(i) The pH meter must have a range of at least 1 to 5 or more;

(ii) The pH meter must have an accuracy of ±0.1; and

(iii) The pH meter must have a resolution of at least 0.1 pH.

(f) You must operate each CPMS used to meet the requirements of this subpart according to the requirements specified in paragraphs (f)(1) through (3) of this section.

(1) Each CPMS must complete a minimum of one cycle of operation for each successive 15-minute period. You must have a minimum of three of the required four data points to constitute a valid hour of data.

(2) Each CPMS must have valid hourly data for 100 percent of every averaging period.

(3) Each CPMS must determine and record the hourly average of all recorded readings and the 3-hour average of all recorded readings.

(g) For each automated conveyor and pallet cooling line and automated shakeout line at a new iron and steel foundry subject to the VOHAP emissions limit in §63.7690(a)(10), you must install, operate, and maintain a CEMS to measure and record the concentration of VOHAP emissions according to the requirements in paragraphs (g)(1) through (3) of this section.

(1) You must install, operate, and maintain each CEMS according to Performance Specification 8 in 40 CFR part 60, appendix B.

(2) You must conduct a performance evaluation of each CEMS according to the requirements of §63.8 and Performance Specification 8 in 40 CFR part 60, appendix B.

(3) You must operate each CEMS according to the requirements specified in paragraph (g)(3)(i) through (iv) of this section.

(i) As specified in §63.8(c)(4)(ii), each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

(ii) You must reduce CEMS data as specified in §63.8(g)(2).

(iii) Each CEMS must determine and record the 3-hour average emissions using all the hourly averages collected for periods during which the CEMS is not out-of-control.

(iv) Record the results of each inspection, calibration, and validation check.

§63.7742 How do I monitor and collect data to demonstrate continuous compliance?

(a) Except for monitoring malfunctions, associated repairs, and required quality assurance or control activities (including as applicable, calibration checks and required zero and span adjustments), you must monitor continuously (or collect data at all required intervals) any time a source of emissions is operating.

(b) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emissions or operating levels or to fulfill a minimum data availability requirement, if applicable. You must use all the data collected during all other periods in assessing compliance.

(c) A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring system to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

§63.7743 How do I demonstrate continuous compliance with the emissions limitations that apply to me?

(a) You must demonstrate continuous compliance by meeting the applicable conditions in paragraphs (a)(1) through (12) of this section:

(1) For each electric arc metal melting furnace, electric induction metal melting furnace, or scrap preheater at an existing iron and steel foundry,

(i) Maintaining the average PM concentration in the exhaust stream at or below 0.005 gr/dscf; or

(ii) Maintaining the average total metal HAP concentration in the exhaust stream at or below 0.0004 gr/dscf.

(2) For each cupola metal melting furnace at an existing iron and steel foundry,

(i) Maintaining the average PM concentration in the exhaust stream at or below 0.006 gr/dscf; or

(ii) Maintaining the average total metal HAP concentration in the exhaust stream at or below 0.0005 gr/dscf.

(3) For each cupola metal melting furnace or electric arc metal melting furnace at new iron and steel foundry,

(i) Maintaining the average PM concentration in the exhaust stream at or below 0.002 gr/dscf; or

(ii) Maintaining the average total metal HAP concentration in the exhaust stream at or below 0.0002 gr/dscf.

(4) For each electric induction metal melting furnace or scrap preheater at a new iron and steel foundry,

(i) Maintaining the average PM concentration in the exhaust stream at or below 0.001 gr/dscf; or

(ii) Maintaining the average total metal HAP concentration in the exhaust stream at or below 0.00008 gr/dscf.

(5) For each pouring station at an existing iron and steel foundry,

(i) Maintaining the average PM concentration in the exhaust stream at or below 0.010 gr/dscf; or

(ii) Maintaining the average total metal HAP concentration in the exhaust stream at or below 0.0008 gr/dscf.

(6) For each pouring area or pouring station at a new iron and steel foundry,

(i) Maintaining the average PM concentration in the exhaust stream at or below 0.002 gr/dscf; or

(ii) Maintaining the average total metal HAP concentration in the exhaust stream at or below 0.0002 gr/dscf.

(7) For each building or structure housing any emissions source at the iron and steel foundry, maintaining the opacity of any fugitive emissions discharged to the atmosphere at or below 20 percent opacity (6-minute average), except for one 6-minute average per hour that does not exceed 27 percent opacity.

(8) For each cupola metal melting furnace at a new or existing iron and steel foundry, maintaining the average VOHAP concentration in the exhaust stream at or below 20 ppmv corrected to 10 percent oxygen.

(9) For each scrap preheater at an existing new iron and steel foundry that does not comply with the work practice standard in §63.7700(e)(1) or (2) and for each scrap preheater at a new iron and steel foundry that does not comply with the work practice standard in §63.7700(f), maintaining the average VOHAP concentration in the exhaust stream at or below 20 ppmv.

(10) For one or more automated conveyor and pallet cooling lines or automated shakeout lines that use a sand mold system at a new iron and steel foundry,

(i) Maintaining the 3-hour flow-weighted average VOHAP concentration in the exhaust stream at or below 20 ppmv;

(ii) Inspecting and maintaining each CEMS according to the requirements of §63.7741(g) and recording all information needed to document conformance with these requirements; and

(iii) Collecting and reducing monitoring data for according to the requirements of §63.7741(g) and recording all information needed to document conformance with these requirements.

(11) For each TEA cold box mold or core making line at a new or existing iron and steel foundry, maintaining a 99 percent reduction in the VOHAP concentration in the exhaust stream or maintaining the average VOHAP concentration in the exhaust stream at or below 1 ppmv.

(12) Conducting subsequent performance tests at least every 5 years for each emissions source subject to an emissions limit for PM, total metal HAP, VOHAP, or TEA in §63.7690(a) and subsequent performance tests at least every 6 months for each building or structure subject to the opacity limit in §63.7690(a)(7).

(b) You must demonstrate continuous compliance for each capture system subject to an operating limit in §63.7690(b)(1) by meeting the requirements in paragraphs (b)(1) and (2) of this section.

(1) Operating the capture system at or above the lowest values or settings established for the operating limits in your operation and maintenance plan; and

(2) Monitoring the capture system according to the requirements in

§63.7740(a) and collecting, reducing, and recording the monitoring data for each of the operating limit parameters according to the applicable requirements in this subpart.

(c) For each baghouse equipped with a bag leak detection system,

(1) Maintaining records of the times the bag leak detection system alarm sounded, and for each valid alarm, the time you initiated corrective action, the corrective action taken, and the date on which corrective action was completed; and

(2) Inspecting and maintaining each baghouse according to the requirements of §63.7740(b)(1) through (8) and recording all information needed to document conformance with these requirements.

(d) For each wet scrubber that is subject to the operating limits in §63.7690(b)(2), you must demonstrate continuous compliance by:

(1) Maintaining the 3-hour average pressure drop and 3-hour average scrubber water flow rate at levels no lower than those established during the initial or subsequent performance test;

(2) Inspecting and maintaining each CPMS according to the requirements of §63.7741(c) and recording all information needed to document conformance with these requirements; and

(3) Collecting and reducing monitoring data for pressure drop and scrubber water flow rate according to the requirements of §63.7741(f) and recording all information needed to document conformance with these requirements.

(e) For each combustion device that is subject to the operating limit in §63.7690(b)(3), you must demonstrate continuous compliance by:

(1) Maintaining the 15-minute average combustion zone temperature at a level no lower than 1,300 °F;

(2) Inspecting and maintaining each CPMS according to the requirements of §63.7741(d) and recording all information needed to document conformance with these requirements; and

(3) Collecting and reducing monitoring data for combustion zone temperature according to the requirements of §63.7741(f) and recording all information needed to document conformance with these requirements.

(f) For each combustion device that is subject to the operating limit in §63.7690(b)(4), you must demonstrate continuous compliance by:

(1) Maintaining the 3-hour average combustion zone temperature at a level no lower that established during the initial or subsequent performance test;

(2) Inspecting and maintaining each CPMS according to the requirements of §63.7741(d) and recording all information needed to document conformance with these requirements; and

(3) Collecting and reducing monitoring data for combustion zone temperature according to the requirements of §63.7741(f) and recording all information needed to document conformance with these requirements.

(g) For each acid wet scrubber subject to the operating limits in §63.7690(b)(5), you must demonstrate continuous compliance by:

(1) Maintaining the 3-hour average scrubbing liquid flow rate at a level no lower than the level established during the initial or subsequent performance test;

(2) Maintaining the 3-hour average pH of the scrubber blowdown at a level no higher than 4.5 (if measured by a CPMS) or maintaining the pH level of the scrubber blowdown during each production shift no higher than 4.5;

(3) Inspecting and maintaining each CPMS according to the requirements of §63.7741(e) and recording all information needed to document conformance with these requirements; and

(4) Collecting and reducing monitoring data for scrubbing liquid flow rate and scrubber blowdown pH according to the requirements of §63.7741(f) and recording all information needed to document conformance with these requirements. If the pH level of the scrubber blowdown is measured by a probe and meter, you must demonstrate continuous compliance by maintaining records that document the date, time, and results of each sample taken for each production shift.

§63.7744 How do I demonstrate continuous compliance with the work practice standards that apply to me?

(a) You must maintain records that document continuous compliance with

the certification requirements in § 63.7700(b) or with the procedures in your scrap selection and inspection plan required in § 63.7700(c). Your records documenting compliance with the scrap selection and inspection plan must include a copy (kept onsite) of the procedures used by the scrap supplier for either removing accessible mercury switches or for purchasing automobile bodies that have had mercury switches removed, as applicable.

(b) You must keep records of the chemical composition of all catalyst binder formulations applied in each furan warm box mold or core making line at a new or existing iron and steel foundry to demonstrate continuous compliance with the requirements in § 63.7700(d).

(c) For a scrap preheater at an existing iron and steel foundry, you must operate and maintain each gas-fired preheater such that the flame directly contacts the scrap charged to demonstrate continuous compliance with the requirement § 63.7700(e)(1). If you choose to meet the work practice standard in § 63.7700(e)(2), you must keep records to document that the scrap preheater charges only material that is subject to and in compliance with the scrap certification requirements in § 63.7700(b).

(d) For a scrap preheater at a new iron and steel foundry, you must keep records to document that each scrap preheater charges only material that is subject to and in compliance with the scrap certification requirements in § 63.7700(b) to demonstrate continuous compliance with the requirement in § 63.7700(f).

§ 63.7745 How do I demonstrate continuous compliance with the operation and maintenance requirements that apply to me?

(a) For each capture system and control device for an emissions source subject to an emissions limit in § 63.7690(a), you must demonstrate continuous compliance with the operation and maintenance requirements of § 63.7710 by:

(1) Making monthly inspections of capture systems and initiating corrective action according to § 63.7710(b)(1) and recording all information needed to document conformance with these requirements;

(2) Performing preventative maintenance for each control device according to the preventive maintenance plan required by § 63.7710(b)(3) and recording all information needed to document conformance with these requirements;

(3) Operating and maintaining each bag leak detection system according to the site-specific monitoring plan required by § 63.7710(b)(4) and recording all information needed to demonstrate conformance with these requirements;

(4) Initiating and completing corrective action for a bag leak detection system alarm according to the corrective action plan required by § 63.7710(b)(5) and recording all information needed to document conformance with these requirements; and

(5) Igniting gases from mold vents according to the procedures in the plan required by § 63.7710(b)(6). (Any instance where you fail to follow the procedures is a deviation that must be included in your semiannual compliance report.)

(b) You must maintain a current copy of the operation and maintenance plans required by § 63.7710(b) onsite and available for inspection upon request. You must keep the plans for the life of the iron and steel foundry or until the iron and steel foundry is no longer subject to the requirements of this subpart.

§ 63.7746 What other requirements must I meet to demonstrate continuous compliance?

(a) *Deviations.* You must report each instance in which you did not meet each emissions limitation in § 63.7690 (including each operating limit) that applies to you. This requirement includes periods of startup, shutdown, and malfunction. You also must report each instance in which you did not meet each work practice standard in § 63.7700 and each operation and maintenance requirement of § 63.7710 that applies to you. These instances are deviations from the emissions limitations, work practice standards, and operation and maintenance requirements in this subpart. These deviations must be reported according to the requirements of § 63.7751.

(b) *Startups, shutdowns, and malfunctions.* (1) Consistent with the requirements of §§63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with §63.6(e)(1).

(2) The Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations according to the provisions in §63.6(e).

[69 FR 21923, Apr. 22, 2004, as amended at 71 FR 20468, Apr. 20, 2006]

§63.7747 How do I apply for alternative monitoring requirements for a continuous emissions monitoring system?

(a) You may request an alternative monitoring method to demonstrate compliance with the VOHAP emissions limits in §63.7690(a)(10) for automated pallet cooling lines or automated shakeout lines at a new iron and steel foundry according to the procedures in this section.

(b) You can request approval to use an alternative monitoring method in the notification of construction or reconstruction for new sources, or at any time.

(c) You must submit a monitoring plan that includes a description of the control technique or pollution prevention technique, a description of the continuous monitoring system or method including appropriate operating parameters that will be monitored, test results demonstrating compliance with the emissions limit, operating limit(s) (if applicable) determined according to the test results, and the frequency of measuring and recording to establish continuous compliance. If applicable, you must also include operation and maintenance requirements for the monitors.

(d) The monitoring plan is subject to approval by the Administrator. Use of the alternative monitoring method must not begin until approval is granted by the Administrator.

NOTIFICATIONS, REPORTS, AND RECORDS

§63.7750 What notifications must I submit and when?

(a) You must submit all of the notifications required by §§63.6(h)(4) and (5), 63.7(b) and (c); 63.8(e); 63.8(f)(4) and (6); 63.9(b) through (h) that apply to you by the specified dates.

(b) As specified in §63.9(b)(2), if you start up your iron and steel foundry before April 22, 2004, you must submit your initial notification no later than August 20, 2004.

(c) If you start up your new iron and steel foundry on or after April 22, 2004, you must submit your initial notification no later than 120 calendar days after you become subject to this subpart.

(d) If you are required to conduct a performance test, you must submit a notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin as required by §63.7(b)(1).

(e) If you are required to conduct a performance test or other initial compliance demonstration, you must submit a notification of compliance status according to the requirements of §63.9(h)(2)(ii).

(1) For each initial compliance demonstration that does not include a performance test, you must submit the notification of compliance status before the close of business on the 30th calendar day following completion of the initial compliance demonstration.

(2) For each initial compliance demonstration that does include a performance test, you must submit the notification of compliance status, including the performance test results, before the close of business on the 60th calendar day following the completion of the performance test according to the requirement specified in §63.10(d)(2).

§63.7751 What reports must I submit and when?

(a) Compliance report due dates. Unless the Administrator has approved a different schedule, you must submit a semiannual compliance report to your permitting authority according to the requirements specified in paragraphs (a)(1) through (5) of this section.

(1) The first compliance report must cover the period beginning on the compliance date that is specified for your iron and steel foundry by § 63.7683 and ending on June 30 or December 31, whichever date comes first after the compliance date that is specified for your iron and steel foundry.

(2) The first compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date comes first after your first compliance report is due.

(3) Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date comes first after the end of the semiannual reporting period.

(5) For each iron and steel foundry that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of the dates specified in paragraphs (a)(1) through (4) of this section.

(b) Compliance report contents. Each compliance report must include the information specified in paragraphs (b)(1) through (3) of this section and, as applicable, paragraphs (b)(4) through (8) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a startup, shutdown, or malfunction during the reporting period and you took action consistent with your startup, shutdown, and malfunction plan, the compliance report must include the information in § 63.10(d)(5)(i).

(5) If there were no deviations from any emissions limitations (including operating limit), work practice standards, or operation and maintenance requirements, a statement that there were no deviations from the emissions limitations, work practice standards, or operation and maintenance requirements during the reporting period.

(6) If there were no periods during which a continuous monitoring system (including a CPMS or CEMS) was out-of-control as specified by § 63.8(c)(7), a statement that there were no periods during which the CPMS was out-of-control during the reporting period.

(7) For each deviation from an emissions limitation (including an operating limit) that occurs at an iron and steel foundry for which you are not using a continuous monitoring system (including a CPMS or CEMS) to comply with an emissions limitation or work practice standard required in this subpart, the compliance report must contain the information specified in paragraphs (b)(1) through (4) and (b)(7)(i) and (ii) of this section. This requirement includes periods of startup, shutdown, and malfunction.

(i) The total operating time of each emissions source during the reporting period.

(ii) Information on the number, duration, and cause of deviations (including unknown cause) as applicable and the corrective action taken.

(8) For each deviation from an emissions limitation (including an operating limit) or work practice standard occurring at an iron and steel foundry where you are using a continuous monitoring system (including a CPMS or CEMS) to comply with the emissions limitation or work practice standard in this subpart, you must include the information specified in paragraphs (b)(1) through (4) and (b)(8)(i) through (xi) of this section. This requirement includes periods of startup, shutdown, and malfunction.

(i) The date and time that each malfunction started and stopped.

(ii) The date and time that each continuous monitoring system was inoperative, except for zero (low-level) and high-level checks.

(iii) The date, time, and duration that each continuous monitoring system was out-of-control, including the information in §63.8(c)(8).

(iv) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(v) A summary of the total duration of the deviations during the reporting period and the total duration as a percent of the total source operating time during that reporting period.

(vi) A breakdown of the total duration of the deviations during the reporting period into those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and unknown causes.

(vii) A summary of the total duration of continuous monitoring system downtime during the reporting period and the total duration of continuous monitoring system downtime as a percent of the total source operating time during the reporting period.

(viii) A brief description of the process units.

(ix) A brief description of the continuous monitoring system.

(x) The date of the latest continuous monitoring system certification or audit.

(xi) A description of any changes in continuous monitoring systems, processes, or controls since the last reporting period.

(c) Immediate startup, shutdown, and malfunction report. If you had a startup, shutdown, or malfunction during the semiannual reporting period that was not consistent with your startup, shutdown, and malfunction plan, you must submit an immediate startup, shutdown, and malfunction report according to the requirements of §63.10(d)(5)(ii).

(d) Part 70 monitoring report. If you have obtained a title V operating permit for an iron and steel foundry pursuant to 40 CFR part 70 or 40 CFR part 71, you must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If you submit a compliance report for an iron and steel foundry along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all the required information concerning deviations from any emissions limitation or operation and maintenance requirement in this subpart, submission of the compliance report satisfies any obligation to report the same deviations in the semiannual monitoring report. However, submission of a compliance report does not otherwise affect any obligation you may have to report deviations from permit requirements for an iron and steel foundry to your permitting authority.

§63.7752 What records must I keep?

(a) You must keep the records specified in paragraphs (a)(1) through (4) of this section:

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any initial notification or notification of compliance status that you submitted, according to the requirements of §63.10(b)(2)(xiv).

(2) The records specified in §63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.

(3) Records of performance tests and performance evaluations as required by §63.10(b)(2)(viii).

(4) Records of the annual quantity of each chemical binder or coating material used to make molds and cores, the Material Data Safety Sheet or other documentation that provides the chemical composition of each component, and the annual quantity of HAP used at the foundry.

(b) You must keep the following records for each CEMS.

(1) Records described in §63.10(b)(2)(vi) through (xi).

(2) Previous (*i.e.*, superseded) versions of the performance evaluation plan as required in §63.8(d)(3).

(3) Request for alternatives to relative accuracy tests for CEMS as required in §63.8(f)(6)(i).

(4) Records of the date and time that each deviation started and stopped, and whether the deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(c) You must keep the records required by §§ 63.7743, 63.7744, and 63.7745 to show continuous compliance with each emissions limitation, work practice standard, and operation and maintenance requirement that applies to you.

§ 63.7753 In what form and for how long must I keep my records?

(a) You must keep your records in a form suitable and readily available for expeditious review, according to the requirements of § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record onsite for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record according to the requirements in § 63.10(b)(1). You can keep the records for the previous 3 years offsite.

OTHER REQUIREMENTS AND INFORMATION

§ 63.7760 What parts of the General Provisions apply to me?

Table 1 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you.

§ 63.7761 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the U.S. Environmental Protection Agency (EPA), or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency, in addition to the U.S. EPA, has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out if implementation and enforcement of this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that cannot be delegated to State, local, or tribal agencies are specified in paragraphs (c)(1) through (4) of this section.

(1) Approval of alternatives to non-opacity emissions limitations in § 63.7690 and work practice standards in § 63.7700 under § 63.6(g).

(2) Approval of major alternatives to test methods under § 63.7(e)(2)(ii) and (f) and as defined in § 63.90.

(3) Approval of major alternatives to monitoring under § 63.8(f) and as defined in § 63.90.

(4) Approval of major alternatives to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.

DEFINITIONS

§ 63.7765 What definitions apply to this subpart?

Terms used in this subpart are defined in the Clean Air Act (CAA), in § 63.2, and in this section.

Automated conveyor and pallet cooling line means any dedicated conveyor line or area used for cooling molds received from pouring stations.

Automated shakeout line means any mechanical process unit designed for and dedicated to separating a casting from a mold. These mechanical processes include, but are not limited to, shaker decks, rotary separators, and high-frequency vibration units. Automated shakeout lines do not include manual processes for separating a casting from a mold, such as personnel using a hammer, chisel, pick ax, sledge hammer, or jackhammer.

Bag leak detection system means a system that is capable of continuously monitoring relative particulate matter (dust) loadings in the exhaust of a baghouse to detect bag leaks and other upset conditions. A bag leak detection system includes, but is not limited to, an instrument that operates on triboelectric, electrodynamic, light scattering, light transmittance, or other effect to continuously monitor relative particulate matter loadings.

Binder chemical means a component of a system of chemicals used to bind

sand together into molds, mold sections, and cores through chemical reaction as opposed to pressure.

Capture system means the collection of components used to capture gases and fumes released from one or more emissions points and then convey the captured gas stream to a control device or to the atmosphere. A capture system may include, but is not limited to, the following components as applicable to a given capture system design: duct intake devices, hoods, enclosures, ductwork, dampers, manifolds, plenums, and fans.

Cold box mold or core making line means a mold or core making line in which the formed aggregate is hardened by catalysis with a gas.

Combustion device means an afterburner, thermal incinerator, or scrap preheater.

Conveyance means the system of equipment that is designed to capture pollutants at the source, convey them through ductwork, and exhaust them using forced ventilation. A conveyance may, but does not necessarily include, control equipment designed to reduce emissions of the pollutants. Emissions that are released through windows, vents, or other general building ventilation or exhaust systems are not considered to be discharged through a conveyance.

Cooling means the process of molten metal solidification within the mold and subsequent temperature reduction prior to shakeout.

Cupola means a vertical cylindrical shaft furnace that uses coke and forms of iron and steel such as scrap and foundry returns as the primary charge components and melts the iron and steel through combustion of the coke by a forced upward flow of heated air.

Deviation means any instance in which an affected source or an owner or operator of such an affected source:

(1) Fails to meet any requirement or obligation established by this subpart including, but not limited to, any emissions limitation (including operating limits), work practice standard, or operation and maintenance requirement;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any iron and steel foundry required to obtain such a permit; or

(3) Fails to meet any emissions limitation (including operating limits) or work practice standard in this subpart during startup, shutdown, or malfunction, regardless of whether or not such failure is permitted by this subpart.

Electric arc furnace means a vessel in which forms of iron and steel such as scrap and foundry returns are melted through resistance heating by an electric current flowing through the arcs formed between the electrodes and the surface of the metal and also flowing through the metal between the arc paths.

Electric induction furnace means a vessel in which forms of iron and steel such as scrap and foundry returns are melted though resistance heating by an electric current that is induced in the metal by passing an alternating current through a coil surrounding the metal charge or surrounding a pool of molten metal at the bottom of the vessel.

Emissions limitation means any emissions limit or operating limit.

Exhaust stream means gases emitted from a process through a conveyance as defined in this subpart.

Free organic liquids means material that fails the paint filter test by EPA Method 9095A (incorporated by reference—see §63.14). That is, if any portion of the material passes through and drops from the filter within the 5-minute test period, the material contains free liquids.

Fresh acid solution means a sulfuric acid solution used for the control of triethylamine emissions that has a pH of 2.0 or less.

Fugitive emissions means any pollutant released to the atmosphere that is not discharged through a *conveyance* as defined in this subpart.

Furan warm box mold or core making line means a mold or core making line in which the binder chemical system used is that system commonly designated as a furan warm box system by the foundry industry.

Hazardous air pollutant means any substance on the list originally established in 112(b)(1) of the CAA and subsequently amended as published in the *Code of Federal Regulations.*

Iron and steel foundry means a facility or portion of a facility that melts scrap, ingot, and/or other forms of iron and/or steel and pours the resulting molten metal into molds to produce final or near final shape products for introduction into commerce. Research and development facilities and operations that only produce non-commercial castings are not included in this definition.

Metal melting furnace means a cupola, electric arc furnace, or electric induction furnace that converts scrap, foundry returns, and/or other solid forms of iron and/or steel to a liquid state. This definition does not include a holding furnace, an argon oxygen decarburization vessel, or ladle that receives molten metal from a metal melting furnace, to which metal ingots or other material may be added to adjust the metal chemistry.

Mold or core making line means the collection of equipment that is used to mix an aggregate of sand and binder chemicals, form the aggregate into final shape, and harden the formed aggregate. This definition does not include a line for making green sand molds or cores.

Mold vent means an intentional opening in a mold through which gases containing pyrolysis products of organic mold and core constituents produced by contact with or proximity to molten metal normally escape the mold during and after metal pouring.

Pouring area means an area, generally associated with floor and pit molding operations, in which molten metal is brought to each individual mold. Pouring areas include all pouring operations that do not meet the definition of a pouring station.

Pouring station means the fixed location to which molds are brought in a continuous or semicontinuous manner to receive molten metal, after which the molds are moved to a cooling area.

Responsible official means responsible official as defined in § 63.2.

Scrap preheater means a vessel or other piece of equipment in which metal scrap that is to be used as melting furnace feed is heated to a temperature high enough to eliminate moisture and other volatile impurities or tramp materials by direct flame heating or similar means of heating.

Scrubber blowdown means liquor or slurry discharged from a wet scrubber that is either removed as a waste stream or processed to remove impurities or adjust its composition or pH before being returned to the scrubber.

Work practice standard means any design, equipment, work practice, or operational standard, or combination thereof, that is promulgated pursuant to section 112(h) of the CAA.

[69 FR 21923, Apr. 22, 2004, as amended at 70 FR 29404, May 20, 2005]

TABLE 1 TO SUBPART EEEEE OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART EEEEE

[As stated in § 63.7760, you must meet each requirement in the following table that applies to you.]

Citation	Subject	Applies to Subpart EEEEE?	Explanation
63.1	Applicability	Yes.	
63.2	Definitions	Yes.	
63.3	Units and abbreviations	Yes.	
63.4	Prohibited activities	Yes.	
63.5	Construction/reconstruction	Yes.	
63.6(a)–(g)	Compliance with standards and maintenance requirements.	Yes.	
63.6(h)	Opacity and visible emissions standards.	Yes.	
63.6(i)–(j)	Compliance extension and Presidential compliance exemption.	Yes.	
63.7(a)(1)–(a)(2)	Applicability and performance test dates.	No	Subpart EEEEE specifies applicability and performance test dates.
63.7(a)(3), (b)–(h)	Performance testing requirements.	Yes.	
63.8(a)(1)–(a)(3), (b), (c)(1)–(c)(3), (c)(6)–(c)(8), (d), (e), (f)(1)–(f)(6), (g)(1)–(g)(4).	Monitoring requirements	Yes	Subpart EEEEE specifies requirements for alternative monitoring systems.

[As stated in § 63.7760, you must meet each requirement in the following table that applies to you.]

Citation	Subject	Applies to Subpart EEEEE?	Explanation
63.8(a)(4)	Additional monitoring requirements for control devices in § 63.11.	No	Subpart EEEEE does not require flares.
63.8(c)(4)	Continuous monitoring system (CMS) requirements.	No	Subpart EEEEE specifies requirements for operation of CMS and CEMS.
63.8(c)(5)	Continuous opacity monitoring system (COMS) Minimum Procedures.	No	Subpart EEEEE does not require COMS.
63.8(g)(5)	Data reduction	No	Subpart EEEEE specifies data reduction requirements.
63.9	Notification requirements	Yes.	
63.10(a)–(b), (c)(1)–(6), (c)(9)–(15), (d)(1)–(2), (e)(1)–(2), (f).	Recordkeeping and reporting requirements.	Yes	Additional records for CMS in § 63.10(c)(1)–(6), (9)–(15) apply only to CEMS.
63.10(c)(7)–(8)	Records of excess emissions and parameter monitoring exceedances for CMS.	No	Subpart EEEEE specifies records requirements.
63.10(d)(3)	Reporting opacity or visible emissions observations.	Yes.	
63.10(e)(3)	Excess emissions reports	No	Subpart EEEEE specifies reporting requirements.
63.10(e)(4)	Reporting COMS data	No	Subpart EEEEE data does not require COMS.
63.11	Control device requirements	No	Subpart EEEEE does not require flares.
63.12	State authority and delegations.	Yes.	
63.13–63.15	Addresses of State air pollution control agencies and EPA regional offices. Incorporation by reference. Availability of information and confidentiality.	Yes.	

Subpart FFFFF—National Emission Standards for Hazardous Air Pollutants for Integrated Iron and Steel Manufacturing Facilities

SOURCE: 68 FR 27663, May 20, 2003, unless otherwise noted.

WHAT THIS SUBPART COVERS

§ 63.7780 What is the purpose of this subpart?

This subpart establishes national emission standards for hazardous air pollutants (NESHAP) for integrated iron and steel manufacturing facilities. This subpart also establishes requirements to demonstrate initial and continuous compliance with all applicable emission limitations and operation and maintenance requirements in this subpart.

§ 63.7781 Am I subject to this subpart?

You are subject to this subpart if you own or operate an integrated iron and steel manufacturing facility that is (or is part of) a major source of hazardous air pollutants (HAP) emissions. Your integrated iron and steel manufacturing facility is a major source of HAP if it emits or has the potential to emit any single HAP at a rate of 10 tons or more per year or any combination of HAP at a rate of 25 tons or more per year.

§ 63.7782 What parts of my plant does this subpart cover?

(a) This subpart applies to each new and existing affected source at your integrated iron and steel manufacturing facility.

(b) The affected sources are each new or existing sinter plant, blast furnace, and basic oxygen process furnace (BOPF) shop at your integrated iron and steel manufacturing facility.

(c) This subpart covers emissions from the sinter plant windbox exhaust, discharge end, and sinter cooler; the blast furnace casthouse; and the BOPF shop including each individual BOPF and shop ancillary operations (hot metal transfer, hot metal desulfurization, slag skimming, and ladle metallurgy).

(d) A sinter plant, blast furnace, or BOPF shop at your integrated iron and steel manufacturing facility is existing if you commenced construction or reconstruction of the affected source before July 13, 2001.

(e) A sinter plant, blast furnace, or BOPF shop at your integrated iron and steel manufacturing facility is new if you commence construction or reconstruction of the affected source on or after July 13, 2001. An affected source is reconstructed if it meets the definition of reconstruction in § 63.2.

§ 63.7783 When do I have to comply with this subpart?

(a) If you have an existing affected source, you must comply with each emission limitation and operation and maintenance requirement in this subpart that applies to you no later than May 22, 2006.

(b) If you have a new affected source and its initial startup date is on or before May 20, 2003, then you must comply with each emission limitation and operation and maintenance requirement in this subpart that applies to you by May 20, 2003.

(c) If you have a new affected source and its initial startup date is after May 20, 2003, you must comply with each emission limitation and operation and maintenance requirement in this subpart that applies to you upon initial startup.

(d) If your integrated iron and steel manufacturing facility is not a major source and becomes a major source of HAP, the following compliance dates apply to you.

(1) Any portion of the existing integrated iron and steel manufacturing facility that becomes a new affected source or a new reconstructed source must be in compliance with this subpart upon startup.

(2) All other parts of the integrated iron and steel manufacturing facility must be in compliance with this subpart no later than 2 years after it becomes a major source.

(e) You must meet the notification and schedule requirements in § 63.7840. Several of these notifications must be submitted before the compliance date for your affected source.

EMISSION LIMITATIONS

§ 63.7790 What emission limitations must I meet?

(a) You must meet each emission limit and opacity limit in Table 1 to this subpart that applies to you.

(b) You must meet each operating limit for capture systems and control devices in paragraphs (b)(1) through (3) of this section that applies to you.

(1) You must operate each capture system applied to emissions from a sinter plant discharge end or blast furnace casthouse or to secondary emissions from a BOPF at or above the lowest value or settings established for the operating limits in your operation and maintenance plan;

(2) For each venturi scrubber applied to meet any particulate emission limit in Table 1 to this subpart, you must maintain the hourly average pressure drop and scrubber water flow rate at or above the minimum levels established during the initial performance test.

(3) For each electrostatic precipitator applied to emissions from a BOPF, you must maintain the average opacity of emissions for each 6-minute period at or below the site-specific opacity value corresponding to the 99 percent upper confidence limit on the mean of a normal distribution of average opacity values established during the initial performance test.

(c) An owner or operator who uses an air pollution control device other than a baghouse, venturi scrubber, or electrostatic precipitator must submit a description of the device; test results collected in accordance with § 63.7822 verifying the performance of the device for reducing emissions of particulate matter to the atmosphere to the levels required by this subpart; a copy of the operation and maintenance plan required in § 63.7800(b); and appropriate

operating parameters that will be monitored to maintain continuous compliance with the applicable emission limitation(s). The monitoring plan identifying the operating parameters to be monitored is subject to approval by the Administrator.

(d) For each sinter plant, you must either:

(1) Maintain the 30-day rolling average oil content of the feedstock at or below 0.02 percent; or

(2) Maintain the 30-day rolling average of volatile organic compound emissions from the windbox exhaust stream at or below 0.2 lb/ton of sinter.

OPERATION AND MAINTENANCE REQUIREMENTS

§63.7800 What are my operation and maintenance requirements?

(a) As required by §63.6(e)(1)(i), you must always operate and maintain your affected source, including air pollution control and monitoring equipment, in a manner consistent with good air pollution control practices for minimizing emissions at least to the levels required by this subpart.

(b) You must prepare and operate at all times according to a written operation and maintenance plan for each capture system or control device subject to an operating limit in §63.7790(b). Each plan must address the elements in paragraphs (b)(1) through (5) of this section.

(1) Monthly inspections of the equipment that is important to the performance of the total capture system (*e.g.*, pressure sensors, dampers, and damper switches). This inspection must include observations of the physical appearance of the equipment (*e.g.*, presence of holes in ductwork or hoods, flow constrictions caused by dents or accumulated dust in the ductwork, and fan erosion). The operation and maintenance plan also must include requirements to repair any defect or deficiency in the capture system before the next scheduled inspection.

(2) Preventative maintenance for each control device, including a preventative maintenance schedule that is consistent with the manufacturer's instructions for routine and long-term maintenance.

(3) Operating limits for each capture system applied to emissions from a sinter plant discharge end or blast furnace casthouse, or to secondary emissions from a BOPF. You must establish the operating limits according to the requirements in paragraphs (b)(3)(i) through (iii) of this section.

(i) Select operating limit parameters appropriate for the capture system design that are representative and reliable indicators of the performance of the capture system. At a minimum, you must use appropriate operating limit parameters that indicate the level of the ventilation draft and the damper position settings for the capture system when operating to collect emissions, including revised settings for seasonal variations. Appropriate operating limit parameters for ventilation draft include, but are not limited to, volumetric flow rate through each separately ducted hood, total volumetric flow rate at the inlet to the control device to which the capture system is vented, fan motor amperage, or static pressure.

(ii) For each operating limit parameter selected in paragraph (b)(3)(i) of this section, designate the value or setting for the parameter at which the capture system operates during the process operation. If your operation allows for more than one process to be operating simultaneously, designate the value or setting for the parameter at which the capture system operates during each possible configuration that you may operate.

(iii) Include documentation in your plan to support your selection of the operating limits established for the capture system. This documentation must include a description of the capture system design, a description of the capture system operating during production, a description of each selected operating limit parameter, a rationale for why you chose the parameter, a description of the method used to monitor the parameter according to the requirements of §63.7830(a), and the data used to set the value or setting for the parameter for each of your process configurations.

(4) Corrective action procedures for bag leak detection systems. In the event a bag leak detection system

alarm is triggered, you must initiate corrective action to determine the cause of the alarm within 1 hour of the alarm, initiate corrective action to correct the cause of the problem within 24 hours of the alarm, and complete the corrective action as soon as practicable. Corrective actions may include, but are not limited to:

(i) Inspecting the baghouse for air leaks, torn or broken bags or filter media, or any other condition that may cause an increase in emissions.

(ii) Sealing off defective bags or filter media.

(iii) Replacing defective bags or filter media or otherwise repairing the control device.

(iv) Sealing off a defective baghouse compartment.

(v) Cleaning the bag leak detection system probe, or otherwise repair the bag leak detection system.

(vi) Shutting down the process producing the particulate emissions; and

(5) Procedures for determining and recording the daily sinter plant production rate in tons per hour.

GENERAL COMPLIANCE REQUIREMENTS

§ 63.7810 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limitations and operation and maintenance requirements in this subpart at all times, except during periods of startup, shutdown, and malfunction as defined in § 63.2.

(b) During the period between the compliance date specified for your affected source in § 63.7783 and the date upon which continuous monitoring systems have been installed and certified and any applicable operating limits have been set, you must maintain a log detailing the operation and maintenance of the process and emissions control equipment.

(c) You must develop a written startup, shutdown, and malfunction plan according to the provisions in § 63.6(e)(3).

[68 FR 27663, May 20, 2003, as amended at 71 FR 20468, Apr. 20, 2006]

INITIAL COMPLIANCE REQUIREMENTS

§ 63.7820 By what date must I conduct performance tests or other initial compliance demonstrations?

(a) You must conduct a performance test to demonstrate initial compliance with each emission and opacity limit in Table 1 to this subpart that applies to you. You must also conduct a performance test to demonstrate initial compliance with the 30-day rolling average operating limit for the oil content of the sinter plant feedstock in § 63.7790(d)(1) or alternative limit for volatile organic compound emissions from the sinter plant windbox exhaust stream in § 63.7790(d)(2). You must conduct the performance tests within 180 calendar days after the compliance date that is specified in § 63.7783 for your affected source and report the results in your notification of compliance status.

(b) For each operation and maintenance requirement that applies to you where initial compliance is not demonstrated using a performance test or opacity observation, you must demonstrate initial compliance within 30 calendar days after the compliance date that is specified for your affected source in § 63.7783.

(c) If you commenced construction or reconstruction between July 13, 2001 and May 20, 2003, you must demonstrate initial compliance with either the proposed emission limit or the promulgated emission limit no later than November 17, 2003 or no later than 180 days after startup of the source, whichever is later, according to § 63.7(a)(2)(ix).

(d) If you commenced construction or reconstruction between July 13, 2001 and May 20, 2003, and you chose to comply with the proposed emission limit when demonstrating initial compliance, you must conduct a second performance test to demonstrate compliance with the promulgated emission limit by November 17, 2006, or no later than 180 days after startup of the source, whichever is later, according to § 63.7(a)(2)(ix).

§63.7821 When must I conduct subsequent performance tests?

You must conduct subsequent performance tests to demonstrate compliance with all applicable PM and opacity limits in Table 1 to this subpart no less frequently than twice (at mid-term and renewal) during each term of your title V operating permit. For sources without a title V operating permit, you must conduct subsequent performance tests every 2.5 years.

§63.7822 What test methods and other procedures must I use to demonstrate initial compliance with the emission limits for particulate matter?

(a) You must conduct each performance test that applies to your affected source according to the requirements in §63.7(e)(1) and the conditions detailed in paragraphs (b) through (i) of this section.

(b) To determine compliance with the applicable emission limit for particulate matter in Table 1 to this subpart, follow the test methods and procedures in paragraphs (b)(1) and (2) of this section.

(1) Determine the concentration of particulate matter according to the following test methods in appendix A to part 60 of this chapter:

(i) Method 1 to select sampling port locations and the number of traverse points. Sampling ports must be located at the outlet of the control device and prior to any releases to the atmosphere.

(ii) Method 2, 2F, or 2G to determine the volumetric flow rate of the stack gas.

(iii) Method 3, 3A, or 3B to determine the dry molecular weight of the stack gas.

(iv) Method 4 to determine the moisture content of the stack gas.

(v) Method 5, 5D, or 17, as applicable, to determine the concentration of particulate matter (front half filterable catch only).

(2) Collect a minimum sample volume of 60 dry standard cubic feet (dscf) of gas during each particulate matter test run. Three valid test runs are needed to comprise a performance test.

(c) For each sinter plant windbox exhaust stream, you must complete the requirements of paragraphs (c)(1) and (2) of this section:

(1) Follow the procedures in your operation and maintenance plan for measuring and recording the sinter production rate for each test run in tons per hour; and

(2) Compute the process-weighted mass emissions (E_p) for each test run using Equation 1 of this section as follows:

$$E_p = \frac{C \times Q}{P \times K} \qquad \text{(Eq. 1)}$$

Where:

E_p = Process-weighted mass emissions of particulate matter, lb/ton;

C = Concentration of particulate matter, grains per dry standard cubic foot (gr/dscf);

Q = Volumetric flow rate of stack gas, dry standard cubic foot per hour (dscf/hr);

P = Production rate of sinter during the test run, tons/hr; and

K = Conversion factor, 7,000 grains per pound (gr/lb).

(d) If you apply two or more control devices in parallel to emissions from a sinter plant discharge end or a BOPF, compute the average flow-weighted concentration for each test run using Equation 2 of this section as follows:

$$C_W = \frac{\sum_{i=1}^{n} C_i Q_i}{\sum_{i=1}^{n} Q_i} \qquad \text{(Eq. 2)}$$

Where:

C_w = Flow-weighted concentration, gr/dscf;

C_i = Concentration of particulate matter from exhaust stream ''i'', gr/dscf; and

Q_i = Volumetric flow rate of effluent gas from exhaust stream ''i'', dry standard cubic foot per minute (dscfm).

(e) For a control device applied to emissions from a blast furnace casthouse, sample for an integral number of furnace tapping operations sufficient to obtain at least 1 hour of sampling for each test run.

(f) For a primary emission control device applied to emissions from a BOPF with a closed hood system, sample only during the primary oxygen blow and do not sample during any subsequent reblows. Continue sampling for each run for an integral number of primary oxygen blows.

(g) For a primary emission control system applied to emissions from a BOPF with an open hood system and for a control device applied solely to secondary emissions from a BOPF, you must complete the requirements of paragraphs (g)(1) and (2) of this section:

(1) Sample only during the steel production cycle. Conduct sampling under conditions that are representative of normal operation. Record the start and end time of each steel production cycle and each period of abnormal operation; and

(2) Sample for an integral number of steel production cycles. The steel production cycle begins when the scrap is charged to the furnace and ends 3 minutes after the slag is emptied from the vessel into the slag pot.

(h) For a control device applied to emissions from BOPF shop ancillary operations (hot metal transfer, skimming, desulfurization, or ladle metallurgy), sample only when the operation(s) is being conducted.

(i) Subject to approval by the permitting authority, you may conduct representative sampling of stacks when there are more than three stacks associated with a process.

§ 63.7823 What test methods and other procedures must I use to demonstrate initial compliance with the opacity limits?

(a) You must conduct each performance test that applies to your affected source according to the requirements in §63.7(h)(5) and the conditions detailed in paragraphs (b) through (d) of this section.

(b) You must conduct each visible emissions performance test such that the opacity observations overlap with the performance test for particulate matter.

(c) To determine compliance with the applicable opacity limit in Table 1 to this subpart for a sinter plant discharge end or a blast furnace casthouse:

(1) Using a certified observer, determine the opacity of emissions according to Method 9 in appendix A to part 60 of this chapter.

(2) Obtain a minimum of 30 6-minute block averages. For a blast furnace casthouse, make observations during tapping of the furnace. Tapping begins when the furnace is opened, usually by creating a hole near the bottom of the furnace, and ends when the hole is plugged.

(d) To determine compliance with the applicable opacity limit in Table 1 to this subpart for BOPF shops:

(1) For an existing BOPF shop:

(i) Using a certified observer, determine the opacity of emissions according to Method 9 in appendix A to part 60 of this chapter except as specified in paragraphs (d)(1)(ii) and (iii) of this section.

(ii) Instead of procedures in section 2.4 of Method 9 in appendix A to part 60 of this chapter, record observations to the nearest 5 percent at 15-second intervals for at least three steel production cycles.

(iii) Instead of procedures in section 2.5 of Method 9 in appendix A to part 60 of this chapter, determine the 3-minute block average opacity from the average of 12 consecutive observations recorded at 15-second intervals.

(2) For a new BOPF shop housing a bottom-blown BOPF:

(i) Using a certified observer, determine the opacity of emissions according to Method 9 in appendix A to part 60 of this chapter.

(ii) Determine the highest and second highest sets of 6-minute block average opacities for each steel production cycle.

(3) For a new BOPF shop housing a top-blown BOPF:

(i) Determine the opacity of emissions according to the requirements for an existing BOPF shop in paragraphs (d)(1)(i) through (iii) of this section.

(ii) Determine the highest and second highest sets of 3-minute block average opacities for each steel production cycle.

(4) Opacity observations must cover the entire steel production cycle and must be made for at least three cycles. The steel production cycle begins when the scrap is charged to the furnace and ends 3 minutes after the slag is emptied from the vessel into the slag pot.

(5) Determine and record the starting and stopping times of the steel production cycle.

§63.7824 What test methods and other procedures must I use to establish and demonstrate initial compliance with operating limits?

(a) For each capture system subject to an operating limit in §63.7790(b)(1), you must certify that the system operated during the performance test at the site-specific operating limits established in your operation and maintenance plan using the procedures in paragraphs (a)(1) through (4) of this section.

(1) Concurrent with all opacity observations, measure and record values for each of the operating limit parameters in your capture system operation and maintenance plan according to the monitoring requirements specified in §63.7830(a).

(2) For any dampers that are manually set and remain at the same position at all times the capture system is operating, the damper position must be visually checked and recorded at the beginning and end of each opacity observation period segment.

(3) Review and record the monitoring data. Identify and explain any times the capture system operated outside the applicable operating limits.

(4) Certify in your performance test report that during all observation period segments, the capture system was operating at the values or settings established in your capture system operation and maintenance plan.

(b) For a venturi scrubber subject to operating limits for pressure drop and scrubber water flow rate in §63.7790(b)(2), you must establish site-specific operating limits according to the procedures in paragraphs (b)(1) and (2) of this section.

(1) Using the continuous parameter monitoring system (CPMS) required in §63.7830(c), measure and record the pressure drop and scrubber water flow rate during each run of the particulate matter performance test.

(2) Compute and record the hourly average pressure drop and scrubber water flow rate for each individual test run. Your operating limits are the lowest average pressure drop and scrubber water flow rate value in any of the three runs that meet the applicable emission limit.

(c) For an electrostatic precipitator subject to the operating limit in §63.7790(b)(3) for opacity, you must establish a site-specific operating limit according to the procedures in paragraphs (c)(1) through (3) of this section.

(1) Using the continuous opacity monitoring system (COMS) required in §63.7830(d), measure and record the opacity of emissions from each control device stack during each run of the particulate matter performance test.

(2) Compute and record the 6-minute block average opacity from 36 or more data points equally spaced over each 6-minute period during the test runs.

(3) Determine, based on the 6-minute block averages, the opacity value corresponding to the 99 percent upper confidence limit on the mean of a normal distribution of average opacity values.

(d) You may change the operating limits for a capture system, venturi scrubber, or electrostatic precipitator if you meet the requirements in paragraphs (d)(1) through (3) of this section.

(1) Submit a written notification to the Administrator of your request to conduct a new performance test to revise the operating limit.

(2) Conduct a performance test to demonstrate compliance with the applicable emission limitation in Table 1 to this subpart.

(3) Establish revised operating limits according to the applicable procedures in paragraphs (a) through (c) of this section for a control device or capture system.

(e) For each sinter plant subject to the operating limit for the oil content of the sinter plant feedstock in §63.7790(d)(1), you must demonstrate initial compliance according to the procedures in paragraphs (e)(1) through (3) of this section.

(1) Sample the feedstock at least three times a day (once every 8 hours), composite the three samples each day, and analyze the composited samples using Method 9071B, ''n-Hexane Extractable Material(HEM) for Sludge, Sediment, and Solid Samples,'' (Revision 2, April 1998). Method 9071B is incorporated by reference (see §63.14) and is published in EPA Publication SW–846 ''Test Methods for Evaluating Solid Waste, Physical/Chemical Methods.'' Record the sampling date and time, oil

content values, and sinter produced (tons/day).

(2) Continue the sampling and analysis procedure for 30 consecutive days.

(3) Each day, compute and record the 30-day rolling average using that day's value and the 29 previous daily values.

(f) To demonstrate initial compliance with the alternative operating limit for volatile organic compound emissions from the sinter plant windbox exhaust stream in § 63.7790(d)(2), follow the test methods and procedures in paragraphs (f)(1) through (5) of this section.

(1) Determine the volatile organic compound emissions according to the following test methods in appendix A to part 60 of this chapter:

(i) Method 1 to select sampling port locations and the number of traverse points. Sampling ports must be located at the outlet of the control device and prior to any releases to the atmosphere.

(ii) Method 2, 2F, or 2G to determine the volumetric flow rate of the stack gas.

(iii) Method 3, 3A, or 3B to determine the dry molecular weight of the stack gas.

(iv) Method 4 to determine the moisture content of the stack gas.

(v) Method 25 to determine the mass concentration of volatile organic compound emissions (total gaseous nonmethane organics as carbon) from the sinter plant windbox exhaust stream stack.

(2) Determine volatile organic compound (VOC) emissions every 24 hours (from at least three samples taken at 8-hour intervals) using Method 25 in 40 CFR part 60, appendix A. Record the sampling date and time, sampling results, and sinter produced (tons/day).

(3) Compute the process-weighted mass emissions (E_v) each day using Equation 1 of this section as follows:

$$E_v = \frac{M_C \times Q}{35.31 \times 454{,}000 \times K} \qquad \text{(Eq. 1)}$$

Where:

E_v = Process-weighted mass emissions of volatile organic compounds, lb/ton;

M_c = Average concentration of total gaseous nonmethane organics as carbon by Method 25 (40 CFR part 60, appendix A), milligrams per dry standard cubic meters (mg/dscm) for each day;

Q = Volumetric flow rate of stack gas, dscf/hr;

35.31 = Conversion factor (dscf/dscm);

454,000 = Conversion factor (mg/lb); and

K = Daily production rate of sinter, tons/hr.

(4) Continue the sampling and analysis procedure in paragraphs (f)(1) through (3) of this section for 30 consecutive days.

(5) Compute and record the 30-day rolling average of VOC emissions for each operating day.

(g) You may use an alternative test method to determine the oil content of the sinter plant feedstock or the volatile organic compound emissions from the sinter plant windbox exhaust stack if you have already demonstrated the equivalency of the alternative method for a specific plant and have received previous approval from the applicable permitting authority.

§ 63.7825 How do I demonstrate initial compliance with the emission limitations that apply to me?

(a) For each affected source subject to an emission or opacity limit in Table 1 to this subpart, you have demonstrated initial compliance if:

(1) You meet the conditions in Table 2 to this subpart; and

(2) For each capture system subject to the operating limit in § 63.7790(b)(1), you have established appropriate site-specific operating limit(s) and have a record of the operating parameter data measured during the performance test in accordance with § 63.7824(a)(1).

(3) For each venturi scrubber subject to the operating limits for pressure drop and scrubber water flow rate in § 63.7790(b)(2), you have established appropriate site-specific operating limits and have a record of the pressure drop and scrubber water flow rate measured during the performance test in accordance with § 63.7824(b); and

(4) For each electrostatic precipitator subject to the opacity operating limit in § 63.7790(b)(3), you have established an appropriate site-specific operating limit and have a record of the opacity measurements made during the performance test in accordance with § 63.7824(c).

(b) For each existing or new sinter plant subject to the operating limit in § 63.7790(d)(1), you have demonstrated initial compliance if the 30-day rolling

average of the oil content of the feedstock, measured during the initial performance test in accordance with §63.7824(e) is no more than 0.02 percent or the volatile organic compound emissions from the sinter plant windbox exhaust stream, measured during the initial performance test in accordance with §63.7824(f), is no more than 0.2 lb/ton of sinter produced.

(c) For each emission limitation that applies to you, you must submit a notification of compliance status according to §63.7840(e).

§63.7826 How do I demonstrate initial compliance with the operation and maintenance requirements that apply to me?

(a) For a capture system applied to emissions from a sinter plant discharge end or blast furnace casthouse or to secondary emissions from a BOPF, you have demonstrated initial compliance if you meet all of the conditions in paragraphs (a)(1) through (4) of this section.

(1) Prepared the capture system operation and maintenance plan according to the requirements of §63.7800(b), including monthly inspection procedures and detailed descriptions of the operating parameter(s) selected to monitor the capture system;

(2) Certified in your performance test report that the system operated during the test at the operating limits established in your operation and maintenance plan;

(3) Submitted a notification of compliance status according to the requirements in §63.7840(e), including a copy of the capture system operation and maintenance plan and your certification that you will operate the capture system at the values or settings established for the operating limits in that plan; and

(4) Prepared a site-specific monitoring plan according to the requirements in §63.7831(a).

(b) For each control device subject to operating limits in §63.7790(b)(2) or (3), you have demonstrated initial compliance if you meet all the conditions in paragraphs (b)(1) through (3) of this section.

(1) Prepared the control device operation and maintenance plan according to the requirements of §63.7800(b), including a preventative maintenance schedule and, if applicable, detailed descriptions of the procedures you use for corrective action for baghouses;

(2) Submitted a notification of compliance status according to the requirements in §63.7840(e), including a copy of the operation and maintenance plan; and

(3) Prepared a site-specific monitoring plan according to the requirements in §63.7831(a).

CONTINUOUS COMPLIANCE REQUIREMENTS

§63.7830 What are my monitoring requirements?

(a) For each capture system subject to an operating limit in §63.7790(b)(1) established in your capture system operation and maintenance plan, you must install, operate, and maintain a CPMS according to the requirements in §63.7831(e) and the requirements in paragraphs (a)(1) through (3) of this section.

(1) Dampers that are manually set and remain in the same position are exempt from the requirement to install and operate a CPMS. If dampers are not manually set and remain in the same position, you must make a visual check at least once every 24 hours to verify that each damper for the capture system is in the same position as during the initial performance test.

(2) If you use a flow measurement device to monitor the operating limit parameter for a sinter plant discharge end or blast furnace casthouse, you must monitor the hourly average rate (*e.g.,* the hourly average actual volumetric flow rate through each separately ducted hood, the average hourly total volumetric flow rate at the inlet to the control device) according to the requirements in §63.7832.

(3) If you use a flow measurement device to monitor the operating limit parameter for a capture system applied to secondary emissions from a BOPF, you must monitor the average rate for each steel production cycle (*e.g.,* the average actual volumetric flow rate through each separately ducted hood for each steel production cycle, the average total volumetric flow rate at the inlet to the control device for each

steel production cycle) according to the requirements in § 63.7832.

(b) For each baghouse applied to meet any particulate emission limit in Table 1 of this subpart, you must install, operate, and maintain a bag leak detection system according to § 63.7831(f), monitor the relative change in particulate matter loadings according to the requirements in § 63.7832, and conduct inspections at their specified frequencies according to the requirements in paragraphs (b)(1) through (8) of this section.

(1) Monitor the pressure drop across each baghouse cell each day to ensure pressure drop is within the normal operating range identified in the manual.

(2) Confirm that dust is being removed from hoppers through weekly visual inspections or other means of ensuring the proper functioning of removal mechanisms.

(3) Check the compressed air supply for pulse-jet baghouses each day.

(4) Monitor cleaning cycles to ensure proper operation using an appropriate methodology.

(5) Check bag cleaning mechanisms for proper functioning through monthly visual inspection or equivalent means.

(6) Make monthly visual checks of bag tension on reverse air and shaker-type baghouses to ensure that bags are not kinked (kneed or bent) or laying on their sides. You do not have to make this check for shaker-type baghouses using self-tensioning (spring-loaded) devices.

(7) Confirm the physical integrity of the baghouse through quarterly visual inspections of the baghouse interior for air leaks.

(8) Inspect fans for wear, material buildup, and corrosion through quarterly visual inspections, vibration detectors, or equivalent means.

(c) For each venturi scrubber subject to the operating limits for pressure drop and scrubber water flow rate in § 63.7790(b)(2), you must install, operate, and maintain CPMS according to the requirements in § 63.7831(g) and monitor the hourly average pressure drop and water flow rate according to the requirements in § 63.7832.

(d) For each electrostatic precipitator subject to the opacity operating limit in § 63.7790(b)(3), you must install, operate, and maintain a COMS according to the requirements in § 63.7831(h) and monitor the 6-minute average opacity of emissions exiting each control device stack according to the requirements in § 63.7832.

(e) For each sinter plant subject to the operating limit in § 63.7790(d), you must either:

(1) Compute and record the 30-day rolling average of the oil content of the feedstock for each operating day using the procedures in § 63.7824(e); or

(2) Compute and record the 30-day rolling average of volatile organic compound emissions (lbs/ton of sinter) for each operating day using the procedures in § 63.7824(f).

§ 63.7831 What are the installation, operation, and maintenance requirements for my monitors?

(a) For each CPMS required in § 63.7830, you must develop and make available for inspection upon request by the permitting authority a site-specific monitoring plan that addresses the requirements in paragraphs (a)(1) through (6) of this section.

(1) Installation of the CPMS sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the exhaust emissions (*e.g.*, on or downstream of the last control device);

(2) Performance and equipment specifications for the sample interface, the parametric signal analyzer, and the data collection and reduction system;

(3) Performance evaluation procedures and acceptance criteria (*e.g.*, calibrations);

(4) Ongoing operation and maintenance procedures in accordance with the general requirements of §§ 63.8(c)(1), (c)(3), (c)(4)(ii), (c)(7), and (c)(8);

(5) Ongoing data quality assurance procedures in accordance with the general requirements of § 63.8(d); and

(6) Ongoing recordkeeping and reporting procedures in accordance the general requirements of §§ 63.10(c), (e)(1), and (e)(2)(i).

(b) Unless otherwise specified, each CPMS must:

(1) Complete a minimum of one cycle of operation for each successive 15-minute period and collect a minimum of three of the required four data points to constitute a valid hour of data;

(2) Provide valid hourly data for at least 95 percent of every averaging period; and

(3) Determine and record the hourly average of all recorded readings.

(c) You must conduct a performance evaluation of each CPMS in accordance with your site-specific monitoring plan.

(d) You must operate and maintain the CPMS in continuous operation according to the site-specific monitoring plan.

(e) For each capture system subject to an operating limit in §63.7790(b)(1), you must install, operate, and maintain each CPMS according to the requirements in paragraphs (a) through (d) of this section.

(f) For each baghouse applied to meet any particulate emission limit in Table 1 of this subpart, you must install, operate, and maintain a bag leak detection system according to the requirements in paragraphs (f)(1) through (7) of this section.

(1) The system must be certified by the manufacturer to be capable of detecting emissions of particulate matter at concentrations of 10 milligrams per actual cubic meter (0.0044 grains per actual cubic foot) or less.

(2) The system must provide output of relative changes in particulate matter loadings.

(3) The system must be equipped with an alarm that will sound when an increase in relative particulate loadings is detected over a preset level. The alarm must be located such that it can be heard by the appropriate plant personnel.

(4) Each system that works based on the triboelectric effect must be installed, operated, and maintained in a manner consistent with the guidance document, ''Fabric Filter Bag Leak Detection Guidance,'' EPA–454/R–98–015, September 1997. You may install, operate, and maintain other types of bag leak detection systems in a manner consistent with the manufacturer's written specifications and recommendations.

(5) To make the initial adjustment of the system, establish the baseline output by adjusting the sensitivity (range) and the averaging period of the device. Then, establish the alarm set points and the alarm delay time.

(6) Following the initial adjustment, do not adjust the sensitivity or range, averaging period, alarm set points, or alarm delay time, except as detailed in your operation and maintenance plan. Do not increase the sensitivity by more than 100 percent or decrease the sensitivity by more than 50 percent over a 365-day period unless a responsible official certifies, in writing, that the baghouse has been inspected and found to be in good operating condition.

(7) Where multiple detectors are required, the system's instrumentation and alarm may be shared among detectors.

(g) For each venturi scrubber subject to operating limits in §63.7790(b)(2) for pressure drop and scrubber water flow rate, you must install, operate, and maintain each CPMS according to the requirements in paragraphs (a) through (d) of this section.

(h) For each electrostatic precipitator subject to the opacity operating limit in §63.7790(b)(3), you must install, operate, and maintain each COMS according to the requirements in paragraphs (h)(1) through (4) of this section.

(1) You must install, operate, and maintain each COMS according to Performance Specification 1 in 40 CFR part 60, appendix B.

(2) You must conduct a performance evaluation of each COMS according to §63.8 and Performance Specification 1 in appendix B to 40 CFR part 60.

(3) Each COMS must complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

(4) COMS data must be reduced as specified in §63.8(g)(2).

§63.7832 How do I monitor and collect data to demonstrate continuous compliance?

(a) Except for monitoring malfunctions, out-of-control periods as specified in §63.8(c)(7), associated repairs,

and required quality assurance or control activities (including as applicable, calibration checks and required zero and span adjustments), you must monitor continuously (or collect data at all required intervals) at all times an affected source is operating.

(b) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels or to fulfill a minimum data availability requirement, if applicable. You must use all the data collected during all other periods in assessing compliance.

(c) A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

§ 63.7833 How do I demonstrate continuous compliance with the emission limitations that apply to me?

(a) You must demonstrate continuous compliance for each affected source subject to an emission or opacity limit in § 63.7790(a) by meeting the requirements in Table 3 to this subpart.

(b) You must demonstrate continuous compliance for each capture system subject to an operating limit in § 63.7790(b)(1) by meeting the requirements in paragraphs (b)(1) and (2) of this section.

(1) Operate the capture system at or above the lowest values or settings established for the operating limits in your operation and maintenance plan; and

(2) Monitor the capture system according to the requirements in § 63.7830(a) and collect, reduce, and record the monitoring data for each of the operating limit parameters according to the applicable requirements of this subpart;

(c) For each baghouse applied to meet any particulate emission limit in Table 1 to this subpart, you must demonstrate continuous compliance by completing the requirements in paragraphs (c)(1) and (2) of this section:

(1) Maintaining records of the time you initiated corrective action in the event of a bag leak detection system alarm, the corrective action(s) taken, and the date on which corrective action was completed.

(2) Inspecting and maintaining each baghouse according to the requirements in § 63.7831(f) and recording all information needed to document conformance with these requirements. If you increase or decrease the sensitivity of the bag leak detection system beyond the limits specified in § 63.7831(f)(6), you must include a copy of the required written certification by a responsible official in the next semi-annual compliance report.

(d) For each venturi scrubber subject to the operating limits for pressure drop and scrubber water flow rate in § 63.7790(b)(2), you must demonstrate continuous compliance by completing the requirements of paragraphs (d)(1) through (3) of this section:

(1) Maintaining the hourly average pressure drop and scrubber water flow rate at levels no lower than those established during the initial or subsequent performance test;

(2) Operating and maintaining each venturi scrubber CPMS according to § 63.7831(g) and recording all information needed to document conformance with these requirements; and

(3) Collecting and reducing monitoring data for pressure drop and scrubber water flow rate according to § 63.7831(b) and recording all information needed to document conformance with these requirements.

(e) For each electrostatic precipitator subject to the site-specific opacity operating limit in § 63.7790(b)(3), you must demonstrate continuous compliance by completing the requirements of paragraphs (e)(1) and (2) of this section:

(1) Maintaining the average opacity of emissions for each 6-minute period no higher than the site-specific limit established during the initial or subsequent performance test; and

(2) Operating and maintaining each COMS and reducing the COMS data according to § 63.7831(h).

(f) For each new or existing sinter plant subject to the operating limit in

§63.7790(d), you must demonstrate continuous compliance by either:

(1) For the sinter plant feedstock oil content operating limit in §63.7790(d)(1),

(i) Computing and recording the 30-day rolling average of the percent oil content for each operating day according to the performance test procedures in §63.7824(e);

(ii) Recording the sampling date and time, oil content values, and sinter produced (tons/day); and

(iii) Maintaining the 30-day rolling average oil content of the feedstock no higher than 0.02 percent.

(2) For the volatile organic compound operating limit in §63.7790(d)(2),

(i) Computing and recording the 30-day rolling average of volatile organic compound emissions for each operating day according to the performance test procedures in §63.7824(f);

(ii) Recording the sampling date and time, sampling values, and sinter produced (tons/day); and

(iii) Maintaining the 30-day rolling average of volatile organic compound emissions no higher than 0.2 lb/ton of sinter produced.

§63.7834 How do I demonstrate continuous compliance with the operation and maintenance requirements that apply to me?

(a) For each capture system and control device subject to an operating limit in §63.7790(b), you must demonstrate continuous compliance with the operation and maintenance requirements in §63.7800(b) by meeting the requirements of paragraphs (a)(1) through (3) of this section:

(1) Making monthly inspections of capture systems and initiating corrective action according to §63.7800(b)(1) and recording all information needed to document conformance with these requirements;

(2) Performing preventative maintenance according to §63.7800(b)(2) and recording all information needed to document conformance with these requirements; and

(3) Initiating and completing corrective action for a bag leak detection system alarm according to §63.7800(b)(4) and recording all information needed to document conformance with these requirements.

(b) You must maintain a current copy of the operation and maintenance plan required in §63.7800(b) onsite and available for inspection upon request. You must keep the plans for the life of the affected source or until the affected source is no longer subject to the requirements of this subpart.

§63.7835 What other requirements must I meet to demonstrate continuous compliance?

(a) *Deviations.* You must report each instance in which you did not meet each emission limitation in §63.7790 that applies to you. This includes periods of startup, shutdown, and malfunction. You also must report each instance in which you did not meet each operation and maintenance requirement in §63.7800 that applies to you. These instances are deviations from the emission limitations and operation and maintenance requirements in this subpart. These deviations must be reported according to the requirements in §63.7841.

(b) *Startups, shutdowns, and malfunctions.* (1) Consistent with §§63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with §63.6(e)(1).

(2) The Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in §63.6(e).

[68 FR 27663, May 20, 2003, as amended at 71 FR 20468, Apr. 20, 2006]

NOTIFICATIONS, REPORTS, AND RECORDS

§63.7840 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.6(h)(4) and (5), 63.7(b) and (c), 63.8(e) and (f)(4), and 63.9(b) through (h) that apply to you by the specified dates.

(b) As specified in §63.9(b)(2), if you startup your affected source before May 20, 2003, you must submit your initial notification no later than September 17, 2003.

(c) As specified in §63.9(b)(3), if you start your new affected source on or

after May 20, 2003, you must submit your initial notification no later than 120 calendar days after you become subject to this subpart.

(d) If you are required to conduct a performance test, you must submit a notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin as required in § 63.7(b)(1).

(e) If you are required to conduct a performance test, opacity observation, or other initial compliance demonstration, you must submit a notification of compliance status according to § 63.9(h)(2)(ii).

(1) For each initial compliance demonstration that does not include a performance test, you must submit the notification of compliance status before the close of business on the 30th calendar day following completion of the initial compliance demonstration.

(2) For each initial compliance demonstration that does include a performance test, you must submit the notification of compliance status, including the performance test results, before the close of business on the 60th calendar day following the completion of the performance test according to § 63.10(d)(2).

§ 63.7841 What reports must I submit and when?

(a) *Compliance report due dates.* Unless the Administrator has approved a different schedule, you must submit a semiannual compliance report to your permitting authority according to the requirements in paragraphs (a)(1) through (5) of this section.

(1) The first compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.7783 and ending on June 30 or December 31, whichever date comes first after the compliance date that is specified for your source in § 63.7783.

(2) The first compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date comes first after your first compliance report is due.

(3) Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date comes first after the end of the semiannual reporting period.

(5) For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (a)(1) through (4) of this section.

(b) *Compliance report contents.* Each compliance report must include the information in paragraphs (b)(1) through (3) of this section and, as applicable, paragraphs (b)(4) through (8) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a startup, shutdown, or malfunction during the reporting period and you took actions consistent with your startup, shutdown, and malfunction plan, the compliance report must include the information in § 63.10(d)(5)(i).

(5) If there were no deviations from the continuous compliance requirements in §§ 63.7833 and 63.7834 that apply to you, a statement that there were no deviations from the emission limitations or operation and maintenance requirements during the reporting period.

(6) If there were no periods during which a continuous monitoring system (including a CPMS, COMS, or continuous emission monitoring system (CEMS) was out-of-control as specified in § 63.8(c)(7), a statement that there were no periods during which the CPMS was out-of-control during the reporting period.

(7) For each deviation from an emission limitation in §63.7790 that occurs at an affected source where you are not using a continuous monitoring system (including a CPMS, COMS, or CEMS) to comply with an emission limitation in this subpart, the compliance report must contain the information in paragraphs (b)(1) through (4) of this section and the information in paragraphs (b)(7)(i) and (ii) of this section. This includes periods of startup, shutdown, and malfunction.

(i) The total operating time of each affected source during the reporting period.

(ii) Information on the number, duration, and cause of deviations (including unknown cause, if applicable) as applicable and the corrective action taken.

(8) For each deviation from an emission limitation occurring at an affected source where you are using a continuous monitoring system (including a CPMS or COMS) to comply with the emission limitation in this subpart, you must include the information in paragraphs (b)(1) through (4) of this section and the information in paragraphs (b)(8)(i) through (xi) of this section. This includes periods of startup, shutdown, and malfunction.

(i) The date and time that each malfunction started and stopped.

(ii) The date and time that each continuous monitoring was inoperative, except for zero (low-level) and high-level checks.

(iii) The date, time, and duration that each continuous monitoring system was out-of-control as specified in §63.8(c)(7), including the information in §63.8(c)(8).

(iv) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(v) A summary of the total duration of the deviation during the reporting period and the total duration as a percent of the total source operating time during that reporting period.

(vi) A breakdown of the total duration of the deviations during the reporting period including those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and other unknown causes.

(vii) A summary of the total duration of continuous monitoring system downtime during the reporting period and the total duration of continuous monitoring system downtime as a percent of the total source operating time during the reporting period.

(viii) A brief description of the process units.

(ix) A brief description of the continuous monitoring system.

(x) The date of the latest continuous monitoring system certification or audit.

(xi) A description of any changes in continuous monitoring systems, processes, or controls since the last reporting period.

(c) *Immediate startup, shutdown, and malfunction report.* If you had a startup, shutdown, or malfunction during the semiannual reporting period that was not consistent with your startup, shutdown, and malfunction plan, you must submit an immediate startup, shutdown, and malfunction report according to the requirements in §63.10(d)(5)(ii).

(d) *Part 70 monitoring report.* If you have obtained a title V operating permit for an affected source pursuant to 40 CFR part 70 or 71, you must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If you submit a compliance report for an affected source along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all the required information concerning deviations from any emission limitation or operation and maintenance requirement in this subpart, submission of the compliance report satisfies any obligation to report the same deviations in the semiannual monitoring report. However, submission of a compliance report does not otherwise affect any obligation you may have to report deviations from permit requirements for an affected source to your permitting authority.

§ 63.7842 What records must I keep?

(a) You must keep the following records:

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any initial notification or notification of compliance status that you submitted, according to the requirements in § 63.10(b)(2)(xiv).

(2) The records in § 63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.

(3) Records of performance tests, performance evaluations, and opacity observations as required in § 63.10(b)(2)(viii).

(b) For each COMS, you must keep the records specified in paragraphs (b)(1) through (4) of this section.

(1) Records described in § 63.10(b)(2)(vi) through (xi).

(2) Monitoring data for a performance evaluation as required in § 63.6(h)(7)(i) and (ii).

(3) Previous (that is, superceded) versions of the performance evaluation plan as required in § 63.8(d)(3).

(4) Records of the date and time that each deviation started and stopped, and whether the deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(c) You must keep the records required in § 63.6(h)(6) for visual observations.

(d) You must keep the records required in §§ 63.7833 and 63.7834 to show continuous compliance with each emission limitation and operation and maintenance requirement that applies to you.

§ 63.7843 In what form and how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review, according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record on site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record according to § 63.10(b)(1). You can keep the records offsite for the remaining 3 years.

Other Requirements and Information

§ 63.7850 What parts of the General Provisions apply to me?

Table 4 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you.

§ 63.7851 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the United States Environmental Protection Agency (U.S. EPA), or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out if this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under subpart E of this part, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are specified in paragraphs (c)(1) through (4) of this section.

(1) Approval of alternative opacity emission limits in Table 1 to this subpart under § 63.6(h)(9).

(2) Approval of major alternatives to test methods under § 63.7(e)(2)(ii) and (f) and as defined in § 63.90, except for approval of an alternative method for the oil content of the sinter plant feedstock or volatile organic compound measurements for the sinter plant windbox exhaust stream stack as provided in § 63.7824(g).

(3) Approval of major alternatives to monitoring under § 63.8(f) and as defined in § 63.90.

(4) Approval of major alternatives to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.

§63.7852 What definitions apply to this subpart?

Terms used in this subpart are defined in the Clean Air Act, in §63.2, and in this section as follows.

Bag leak detection system means a system that is capable of continuously monitoring relative particulate matter (dust) loadings in the exhaust of a baghouse to detect bag leaks and other upset conditions. A bag leak detection system includes, but is not limited to, an instrument that operates on tribroelectric, light scattering, light transmittance, or other effect to continuously monitor relative particulate matter loadings.

Basic oxygen process furnace means any refractory-lined vessel in which high-purity oxygen is blown under pressure through a bath of molten iron, scrap metal, and fluxes to produce steel. This definition includes both top and bottom blown furnaces, but does not include argon oxygen decarburization furnaces.

Basic oxygen process furnace shop means the place where steelmaking operations that begin with the transfer of molten iron (hot metal) from the torpedo car and end prior to casting the molten steel, including hot metal transfer, desulfurization, slag skimming, refining in a basic oxygen process furnace, and ladle metallurgy occur.

Basic oxygen process furnace shop ancillary operations means the processes where hot metal transfer, hot metal desulfurization, slag skimming, and ladle metallurgy occur.

Blast furnace means a furnace used for the production of molten iron from iron ore and other iron bearing materials.

Bottom-blown furnace means any basic oxygen process furnace in which oxygen and other combustion gases are introduced into the bath of molten iron through tuyeres in the bottom of the vessel or through tuyeres in the bottom and sides of the vessel.

Casthouse means the building or structure that encloses the bottom portion of a blast furnace where the hot metal and slag are tapped from the furnace.

Certified observer means a visible emission observer certified to perform EPA Method 9 opacity observations.

Desulfurization means the process in which reagents such as magnesium, soda ash, and lime are injected into the hot metal, usually with dry air or nitrogen, to remove sulfur.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emission limitation (including operating limits) or operation and maintenance requirement;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or

(3) Fails to meet any emission limitation in this subpart during startup, shutdown, or malfunction, regardless of whether or not such failure is permitted by this subpart.

Discharge end means the place where those operations conducted within the sinter plant starting at the discharge of the sintering machine's traveling grate including (but not limited to) hot sinter crushing, screening, and transfer operations occur.

Emission limitation means any emission limit, opacity limit, or operating limit.

Hot metal transfer station means the location in a basic oxygen process furnace shop where molten iron (hot metal) is transferred from a torpedo car or hot metal car used to transport hot metal from the blast furnace casthouse to a holding vessel or ladle in the basic oxygen process furnace shop. This location also is known as the reladling station or ladle transfer station.

Integrated iron and steel manufacturing facility means an establishment engaged in the production of steel from iron ore.

Ladle metallurgy means a secondary steelmaking process that is performed typically in a ladle after initial refining in a basic oxygen process furnace

to adjust or amend the chemical and/or mechanical properties of steel.

Primary emissions means particulate matter emissions from the basic oxygen process furnace generated during the steel production cycle which are captured and treated in the furnace's primary emission control system.

Primary emission control system means the combination of equipment used for the capture and collection of primary emissions (*e.g.*, an open hood capture system used in conjunction with an electrostatic precipitator or a closed hood system used in conjunction with a scrubber).

Primary oxygen blow means the period in the steel production cycle of a basic oxygen process furnace during which oxygen is blown through the molten iron bath by means of a lance inserted from the top of the vessel (top-blown) or through tuyeres in the bottom and/or sides of the vessel (bottom-blown).

Responsible official means responsible official as defined in §63.2.

Secondary emissions means particulate matter emissions that are not controlled by a primary emission control system, including emissions that escape from open and closed hoods, lance hole openings, and gaps or tears in ductwork to the primary emission control system.

Secondary emission control system means the combination of equipment used for the capture and collection of secondary emissions from a basic oxygen process furnace.

Sinter cooler means the apparatus used to cool the hot sinter product that is transferred from the discharge end through contact with large volumes of induced or forced draft air.

Sinter plant means the machine used to produce a fused clinker-like aggregate or sinter of fine iron-bearing materials suited for use in a blast furnace. The machine is composed of a continuous traveling grate that conveys a bed of ore fines and other finely divided iron-bearing material and fuel (typically coke breeze), a burner at the feed end of the grate for ignition, and a series of downdraft windboxes along the length of the strand to support downdraft combustion and heat sufficient to produce a fused sinter product.

Skimming station means the locations inside a basic oxygen process furnace shop where slag is removed from the top of the molten metal bath.

Steel production cycle means the operations conducted within the basic oxygen process furnace shop that are required to produce each batch of steel. The following operations are included: scrap charging, preheating (when done), hot metal charging, primary oxygen blowing, sampling, (vessel turndown and turnup), additional oxygen blowing (when done), tapping, and deslagging. The steel production cycle begins when the scrap is charged to the furnace and ends after the slag is emptied from the vessel into the slag pot.

Top-blown furnace means any basic oxygen process furnace in which oxygen is introduced into the bath of molten iron by means of an oxygen lance inserted from the top of the vessel.

Windboxes means the compartments that provide for a controlled distribution of downdraft combustion air as it is drawn through the sinter bed of a sinter plant to make the fused sinter product.

TABLE 1 TO SUBPART FFFFF OF PART 63—EMISSION AND OPACITY LIMITS

As required in §63.7790(a), you must comply with each applicable emission and opacity limit in the following table:

For . . .	You must comply with each of the following . . .
1. Each windbox exhaust stream at an existing sinter plant	You must not cause to be discharged to the atmosphere any gases that contain particulate matter in excess of 0.4 lb/ton of product sinter.
2. Each windbox exhaust stream at a new sinter plant	You must not cause to be discharged to the atmosphere any gases that contain particulate matter in excess of 0.3 lb/ton of product sinter.

For . . .	You must comply with each of the following . . .
3. Each discharge end at an existing sinter plant	a. You must not cause to be discharged to the atmosphere any gases that exit from one or more control devices that contain, on a flow-weighted basis, particulate matter in excess of 0.02 gr/dscf [1]; and b. You must not cause to be discharged to the atmosphere any secondary emissions that exit any opening in the building or structure housing the discharge end that exhibit opacity greater than 20 percent (6-minute average).
4. Each discharge end at a new sinter plant	a. You must not cause to be discharged to the atmosphere any gases that exit from one or more control devices that contain, on a flow weighted basis, particulate matter in excess of 0.01 gr/dscf; and b. You must not cause to be discharged to the atmosphere any secondary emissions that exit any opening in the building or structure housing the discharge end that exhibit opacity greater than 10 percent (6-minute average).
5. Each sinter cooler stack at an existing sinter plant	You must not cause to be discharged to the atmosphere any gases that contain particulate matter in excess of 0.03 gr/dscf.
6. Each sinter cooler stack at a new sinter plant	You must not cause to be discharged to the atmosphere any gases that contain particulate matter in excess of 0.01 gr/dscf.
7. Each casthouse at an existing blast furnace	a. You must not cause to be discharged to the atmosphere any gases that exit from a control device that contain particulate matter in excess of 0.01 gr/dscf; and b. You must not cause to be discharged to the atmosphere any secondary emissions that exit any opening in the casthouse or structure housing the blast furnace that exhibit opacity greater than 20 percent (6-minute average).
8. Each casthouse at a new blast furnace	a. You must not cause to be discharged to the atmosphere any gases that exit from a control device that contain particulate matter in excess of 0.003 gr/dscf; and b. You must not cause to be discharged to the atmosphere any secondary emissions that exit any opening in the casthouse or structure housing the blast furnace that exhibit opacity greater than 15 percent (6-minute average).
9. Each BOPF at a new or existing shop	a. You must not cause to be discharged to the atmosphere any gases that exit from a primary emission control system for a BOPF with a closed hood system at a new or existing BOPF shop that contain, on a flow-weighted basis, particulate matter in excess of 0.03 gr/dscf during the primary oxygen blow [2]; b. You must not cause to be discharged to the atmosphere any gases that exit from a primary emission control system for a BOPF with an open hood system that contain, on a flow-weighted basis, particulate matter in excess of 0.02 gr/dscf during the steel production cycle for an existing BOPF shop or 0.01 gr/dscf during the steel production cycle for a new BOPF shop [2]; and c. You must not cause to be discharged to the atmosphere any gases that exit from a control device used solely for the collection of secondary emissions from the BOPF that contain particulate matter in excess of 0.01 gr/dscf for an existing BOPF shop or 0.0052 gr/dscf for a new BOPF shop.
10. Each hot metal transfer, skimming, and desulfurization operation at a new or existing BOPF shop.	You must not cause to be discharged to the atmosphere any gases that exit from a control device that contain particulate matter in excess of 0.01 gr/dscf for an existing BOPF shop or 0.003 gr/dscf for a new BOPF shop.
11. Each ladle metallurgy operation at a new or existing BOPF shop.	You must not cause to be discharged to the atmosphere any gases that exit from a control device that contain particulate matter in excess of 0.01 gr/dscf for an existing BOPF shop or 0.004 gr/dscf for a new BOPF shop.
12. Each roof monitoring at an existing BOPF shop	You must not cause to be discharged to the atmosphere any secondary emissions that exit any opening in the BOPF shop or any other building housing the BOPF or BOPF shop operation that exhibit opacity greater than 20 percent (3-minute average).

For . . .	You must comply with each of the following . . .
13. Each roof monitor at a new BOPF shop	a. You must not cause to be discharged to the atmosphere any secondary emissions that exit any opening in the BOPF shop or other building housing a bottom-blown BOPF or BOPF shop operations that exhibit opacity (for any set of 6-minute averages) greater than 10 percent, except that one 6-minute period not to exceed 20 percent may occur once per steel production cycle; or b. You must not cause to be discharged to the atmosphere any secondary emissions that exit any opening in the BOPF shop or other building housing a top-blown BOPF or BOPF shop operations that exhibit opacity (for any set of 3-minute averages) greater than 10 percent, except that one 3-minute period greater than 10 percent but less than 20 percent may occur once per steel production cycle.

[1] This limit applies if the cooler is vented to the same control device as the discharge end.
[2] This limit applies to control devices operated in parallel for a single BOPF during the oxygen blow.

TABLE 2 TO SUBPART FFFFF OF PART 63—INITIAL COMPLIANCE WITH EMISSION AND OPACITY LIMITS

As required in §63.7825(a)(1), you must demonstrate initial compliance with the emission and opacity limits according to the following table:

For . . .	You have demonstrated initial compliance if . . .
1. Each windbox exhaust stream at an existing sinter plant	The process-weighted mass rate of particulate matter from a windbox exhaust stream, measured according to the performance test procedures in §63.7822(c), did not exceed 0.4 lb/ton of product sinter.
2. Each windbox exhaust stream at a new sinter plant	The process-weighted mass rate of particulate matter from a windbox exhaust stream, measured according to the performance test procedures in §63.7822(c), did not exceed 0.3 lb/ton of product sinter.
3. Each discharge end at an existing sinter plant	a. The flow-weighted average concentration of particulate matter from one or more control devices applied to emissions from a discharge end, measured according to the performance test procedures in §63.7822(d), did not exceed 0.02 gr/dscf; and b. The opacity of secondary emissions from each discharge end, determined according to the performance test procedures in §63.7823(c), did not exceed 20 percent (6-minute average).
4. Each discharge end at a new sinter plant	a. The flow-weighted average concentration of particulate matter from one or more control devices applied to emissions from a discharge end, measured according to the performance test procedures in §63.7822(d), did not exceed 0.01 gr/dscf; and b. The opacity of secondary emissions from each discharge end, determined according to the performance test procedures in §63.7823(c), did not exceed 10 percent (6-minute average).
5. Each sinter cooler stack at an existing sinter plant	The average concentration of particulate matter from a sinter cooler stack, measured according to the performance test procedures in §63.7822(b), did not exceed 0.03 gr/dscf.
6. Each sinter cooler stack at a new sinter plant	The average concentration of particulate matter from a sinter cooler stack, measured according to the performance test procedures in §63.7822(b), did not exceed 0.01 gr/dscf.
7. Each casthouse at an existing blast furnace	a. The average concentration of particulate matter from a control device applied to emissions from a casthouse, measured according to the performance test procedures in §63.7822(e), did not exceed 0.01 gr/dscf; and b. The opacity of secondary emissions from each casthouse, determined according to the performance test procedures in §63.7823(c), did not exceed 20 percent (6-minute average).
8. Each casthouse at a new blast furnace	a. The average concentration of particulate matter from a control device applied to emissions from a casthouse, measured according to the performance test procedures in §63.7822(e), did not exceed 0.003 gr/dscf; and

For . . .	You have demonstrated initial compliance if . . .
	b. The opacity of secondary emissions from each casthouse, determined according to the performance test procedures in §63.7823(c), did not exceed 15 percent (6-minute average).
9. Each BOPF at a new or existing BOPF shop	a. The average concentration of particulate matter from a primary emission control system applied to emissions from a BOPF with a closed hood system, measured according to the performance test procedures in §63.7822(f), did not exceed 0.03 gr/dscf for a new or existing BOPF shop;
	b. The average concentration of particulate matter from a primary emission control system applied to emissions from a BOPF with an open hood system, measured according to the performance test procedures in §63.7822(g), did not exceed 0.02 gr/dscf for an existing BOPF shop or 0.01 gr/dscf for a new BOPF shop; and
	c. The average concentration of particulate matter from a control device applied solely to secondary emissions from a BOPF, measured according to the performance test procedures in §63.7822(g), did not exceed 0.01 gr/dscf for an existing BOPF shop or 0.0052 gr/dscf for a new BOPF shop.
10. Each hot metal transfer skimming, and desulfurization at a new or existing BOPF shop.	The average concentration of particulate matter from a control device applied to emissions from hot metal transfer, skimming, or desulfurization, measured according to the performance test procedures in §63.7822(h), did not exceed 0.01 gr/dscf for an existing BOPF shop or 0.003 gr/dscf for a new BOPF shop.
11. Each ladle metallurgy operation at a new or existing BOPF shop.	The average concentration of particulate matter from a control device applied to emissions from a ladle metallurgy operation, measured according to the performance test procedures in §63.7822(h), did not exceed 0.01 gr/dscf for an existing BOPF shop or 0.004 gr/dscf for a new BOPF shop.
12. Each roof monitor at an existing BOPF shop	The opacity of secondary emissions from each BOPF shop, determined according to the performance test procedures in §63.7823(d), did not exceed 20 percent (3-minute average).
13. Each roof monitor at a new BOPF shop	a. The opacity of the highest set of 6-minute averages from each BOPF shop housing a bottom-blown BOPF, determined according to the performance test procedures in §63.7823(d), did not exceed 20 percent and the second highest set of 6-minute averages did not exceed 10 percent; or
	b. The opacity of the highest set of 3-minute averages from each BOPF shop housing a top-blown BOPF, determined according to the performance test procedures in §63.7823(d), did not exceed 20 percent and the second highest set of 3-minute averages did not exceed 10 percent.

TABLE 3 TO SUBPART FFFFF OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION AND OPACITY LIMITS

As required in §63.7833(a), you must demonstrate continuous compliance with the emission and opacity limits according to the following table:

For . . .	You must demonstrate continuous compliance by . . .
1. Each windbox exhaust stream at an existing sinter plant	a. Maintaining emissions of particulate matter at or below 0.4 lb/ton of product sinter; and
	b. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at mid-term and renewal).
2. Each windbox exhaust stream at a new sinter plant	a. Maintaining emissions of particulate matter at or below 0.3 lb/ton of product sinter; and
	b. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at mid-term and renewal).
3. Each discharge end at an existing sinter plant	a. Maintaining emissions of particulate matter from one or more control devices at or below 0.02 gr/dscf; and

For . . .	You must demonstrate continuous compliance by . . .
	b. Maintaining the opacity of secondary emissions that exit any opening in the building or structure housing the discharge end at or below 20 percent (6-minute average); and c. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at midterm and renewal).
4. Each discharge end at a new sinter plant	a. Maintaining emissions of particulate matter from one or more control devices at or below 0.01 gr/dscf; b. Maintaining the opacity of secondary emissions that exit any opening in the building or structure housing the discharge end at or below 10 percent (6-minute average); and c. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at midterm and renewal).
5. Each sinter cooler stack at an existing sinter plant	a. Maintaining emissions of particulate matter at or below 0.03 gr/dscf; and b. Conducting subsequent performance sinter plant tests at least twice during each term of your title V operating permit (at midterm and renewal).
6. Each sinter cooler stack at a new sinter plant	a. Maintaining emissions of particulate matter at or below 0.01 gr/dscf; and b. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at midterm and renewal).
7. Each casthouse at an existing blast furnace	a. Maintaining emissions of particulate matter from a control device at or below 0.01 gr/dscf; b. Maintaining the opacity of secondary emissions that exit any opening in the casthouse or structure housing the blast furnace at or below 20 percent (6-minute average); and c. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at midterm and renewal).
8. Each casthouse at a new blast furnace	a. Maintaining emissions of particulate matter from a control device at or below 0.003 gr/dscf; b. Maintaining the opacity of secondary emissions that exit any opening in the casthouse or building housing the casthouse at or below 15 percent (6-minute average); and c. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at midterm and renewal).
9. Each BOPF at a new or existing BOPF shop	a. Maintaining emissions of particulate matter from the primary emission control system for a BOPF with a closed hood system at or below 0.03 gr/dscf; b. Maintaining emissions of particulate matter from the primary emission control system for a BOPF with an open hood system at or below 0.02 gr/dscf for an existing BOPF shop or 0.01 gr/dscf for a new BOPF shop; c. Maintaining emissions of particulate matter from a control device applied solely to secondary emissions from a BOPF at or below 0.01 gr/dscf for an existing BOPF shop or 0.0052 gr/dscf for a new BOPF shop; and d. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at midterm and renewal).
10. Each hot metal transfer, skimming, and desulfurization operation at a new or existing BOPF shop.	a. Maintaining emissions of particulate matter from a control device at or below 0.01 gr/dscf at an existing BOPF or 0.003 gr/dscf for a new BOPF; and b. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at midterm and renewal).
11. Each ladle metallurgy operation at a new or existing BOPF shop.	a. Maintaining emissions of particulate matter from a control device at or below 0.01 gr/dscf at an existing BOPF shop or 0.004 gr/dscf for a new BOPF shop; and b. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at midterm and renewal).
12. Each roof monitor at an existing BOPF shop	a. Maintaining the opacity of secondary emissions that exit any opening in the BOPF shop or other building housing the BOPF or shop operation at or below 20 percent (3-minute average); and

For . . .	You must demonstrate continuous compliance by . . .
	b. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at mid-term and renewal).
13. Each roof monitor at a new BOPF shop	a. Maintaining the opacity (for any set of 6-minute averages) of secondary emissions that exit any opening in the BOPF shop or other building housing a bottom-blown BOPF or shop operation at or below 10 percent, except that one 6-minute period greater than 10 percent but no more than 20 percent may occur once per steel production cycle; b. Maintaining the opacity (for any set of 3-minute averages) of secondary emissions that exit any opening in the BOPF shop or other building housing a top-blown BOPF or shop operation at or below 10 percent, except that one 3-minute period greater than 10 percent but less than 20 percent may occur once per steel production cycle; and c. Conducting subsequent performance tests at least twice during each term of your title V operating permit (at mid-term and renewal).

TABLE 4 TO SUBPART FFFFF OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART FFFFF

As required in §63.7850, you must comply with the requirements of the NESHAP General Provisions (40 CFR part 63, subpart A) shown in the following table:

Citation	Subject	Applies to Subpart FFFFF	Explanation
§63.1	Applicability	Yes.	
§63.2	Definitions	Yes.	
§63.3	Units and Abbreviations	Yes.	
§63.4	Prohibited Activities	Yes.	
§63.5	Construction/Reconstruction	Yes.	
§63.6(a), (b), (c), (d), (e), (f), (g), (h)(2)(ii)–(h)(9).	Compliance with Standards and Maintenance Requirements.	Yes.	
§63.6(h)(2)(i)	Determining Compliance with Opacity and VE Standards.	No	Subpart FFFFF specifies Method 9 in appendix A to part 60 of this chapter to comply with roof monitor opacity limits.
§63.7(a)(1)–(2)	Applicability and Performance Test Dates.	No	Subpart FFFFF and specifies performance test applicability and dates.
§63.7(a)(3), (b), (c)–(h)	Performance Testing Requirements.	Yes.	
§63.8(a)(1)–(a)(3), (b), (c)(1)–(3), (c)(4)(i)–(e), (c)(7)–(8), (f)(1)–(5), (g)(1)–(4).	Monitoring Requirements	Yes	CMS requirements in §63.8(c)(4)(i)–(ii), (c)(5) and (6), (d), and (e) apply only to COMS for electrostatic precipitators.
§63.8(a)(4)	Additional Monitoring Requirements for Control Devices in §63.11.	No	Subpart FFFFF does not require flares.
§63.8(c)(4)	Continuous Monitoring System Requirements.	No	Subpart FFFFF specifies requirements for operation of CMS.
§63.8(f)(6)	RATA Alternative	No.	
§63.9	Notification Requirements	Yes	Additional notifications for CMS in §63.9(g) apply to COMS for electrostatic precipitators.
§63.9(g)(5)	DATA Reduction	No	Subpart FFFFF specifies data reduction requirements.
§63.10(a), (b)(1)–(2)(xii), (b)(2)(xiv), (b)(3), (c)(1)–(6), (c)(9)–(15), (d), (e)(1)–(2), (e)(4), (f).	Recordkeeping and Reporting Requirements.	Yes	Additional records for CMS in §63.10(c) (1)–(6), (9)–(15), and reports in §63.10(d)(1)–(2) apply only to COMS for electrostatic precipitators.
§63.10(b)(2)(xiii)	CMS Records for RATA Alternative.	No.	
§63.10(c)(7)–(8)	Records of Excess Emissions and Parameter Monitoring Exceedances for CMS.	No	Subpart FFFFF specifies record requirements.
§63.11	Control Device Requirements	No	Subpart FFFFF does not require flares.

Citation	Subject	Applies to Subpart FFFFF	Explanation
§ 63.12	State Authority and Delegations	Yes.	
§ 63.13–§ 63.15	Addresses, Incorporation by Reference, Availability of Information.	Yes.	

Subpart GGGGG—National Emission Standards for Hazardous Air Pollutants: Site Remediation

SOURCE: 68 FR 58190, Oct. 8, 2003, unless otherwise noted.

WHAT THIS SUBPART COVERS

§ 63.7880 What is the purpose of this subpart?

This subpart establishes national emissions limitations and work practice standards for hazardous air pollutants (HAP) emitted from site remediation activities. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emissions limitations and work practice standards.

§ 63.7881 Am I subject to this subpart?

(a) This subpart applies to you if you own or operate a facility at which you conduct a site remediation, as defined in § 63.7957; and this site remediation, unless exempted under paragraph (b) or (c) of this section, meets all three of the following conditions specified in paragraphs (a)(1) through (3) of this section.

(1) Your site remediation cleans up a remediation material, as defined in § 63.7957.

(2) Your site remediation is co-located at your facility with one or more other stationary sources that emit HAP and meet an affected source definition specified for a source category that is regulated by another subpart under 40 CFR part 63. This condition applies regardless whether or not the affected stationary source(s) at your facility is subject to the standards under the applicable subpart(s).

(3) Your facility is a major source of HAP as defined in § 63.2. A major source emits or has the potential to emit any single HAP at the rate of 10 tons (9.07 megagrams) or more per year of any HAP or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year. All emissions of HAP from every source at your facility (i.e., both the site remediation activity and all other facility activities) must be considered in making this calculation.

(b) You are not subject to this subpart if your site remediation qualifies for any of one of the exemptions listed in paragraphs (b)(1) through (6) of this section.

(1) Your site remediation is not subject to this subpart if the site remediation only cleans up material that does not contain any of the HAP listed in Table 1 of this subpart.

(2) Your site remediation is not subject to this subpart if the site remediation will be performed under the authority of the Comprehensive Environmental Response and Compensation Liability Act (CERCLA) as a remedial action or a non time-critical removal action.

(3) Your site remediation is not subject to this subpart if the site remediation will be performed under a Resource Conservation and Recovery Act (RCRA) corrective action conducted at a treatment, storage and disposal facility (TSDF) that is either required by your permit issued by either the U.S. Environmental Protection Agency (EPA) or a State program authorized by the EPA under RCRA section 3006; required by orders authorized under RCRA; or required by orders authorized under RCRA section 7003.

(4) Your site remediation is not subject to this subpart if the site remediation is conducted at a gasoline service station to clean up remediation material from a leaking underground storage tank.

(5) Your site remediation is not subject to this subpart if the site remediation is conducted at a farm or residential site.

(6) Your site remediation is not subject to this subpart if the site remediation is conducted at a research and development facility that meets the requirements under Clean Air Act (CAA) section 112(c)(7).

(c) Your site remediation is not subject to this subpart, except for the recordkeeping requirements specified in this paragraph, if the site remediation meets the all of the conditions in paragraphs (c)(1) through (3) of this section.

(1) Before beginning the site remediation, you determine for the remediation material that you will excavate, extract, pump, or otherwise remove during your site remediation that the total quantity of the HAP listed in Table 1 of this subpart which is contained in the material is less than 1 megagram per year (Mg/yr).

(2) You prepare and maintain at your facility written documentation to support your determination of the total HAP quantity used to demonstrate compliance with paragraph (c)(1) of this section. This documentation must include a description of your methodology and data you used for determining the total HAP content of the material.

(3) This exemption may be applied to more than one site remediation at your facility provided that the total quantity of the HAP listed in Table 1 of this subpart for all of your site remediations exempted under this provision is less than 1 Mg/yr.

(d) Your site remediation is not subject to the requirements of this subpart if all remediation activities at your facility subject to this subpart are completed and you have notified the Administrator in writing that all remediation activities subject to this subpart are completed. You must maintain records of compliance, in accordance with §63.7953, for each remediation activity that was subject to this subpart. All future remediation activity meeting the applicability criteria in this section must comply with the requirements of this subpart.

§63.7882 What site remediation sources at my facility does this subpart affect?

(a) This subpart applies to each new, reconstructed, or existing affected source for your site remediation as designated by paragraphs (a)(1) through (3) of this section.

(1) *Process vents.* The affected source is the entire group of process vents associated with the in-situ and ex-situ remediation processes used at your site to remove, destroy, degrade, transform, or immobilize hazardous substances in the remediation material subject to remediation. Examples of such in-situ remediation processes include, but are not limited to, soil vapor extraction and bioremediation processes. Examples of such ex-situ remediation processes include but are not limited to, thermal desorption, bioremediation, and air stripping processes.

(2) *Remediation material management units.* Remediation material management unit means a tank, surface impoundment, container, oil-water separator, organic-water separator, or transfer system, as defined in §63.7957, and is used at your site to manage remediation material. The affected source is the entire group of remediation material management units used for the site remediations at your site. For the purpose of this subpart, a tank or container that is also equipped with a vent that serves as a process vent, as defined in §63.7957, is not a remediation material management unit, but instead this unit is considered to be a process vent affected source under paragraph (a)(1) of this section.

(3) *Equipment leaks.* The affected source is the entire group of equipment components (pumps, valves, etc.) used to manage remediation materials and meeting both of the conditions specified in paragraphs (a)(3)(i) and (ii) of this section. If either of these conditions do not apply to an equipment component, then that component is not part of the affected source for equipment leaks.

(i) The equipment component contains or contacts remediation material having a concentration of total HAP listed in Table 1 of this subpart equal to or greater than 10 percent by weight.

(ii) The equipment component is intended to operate for 300 hours or more during a calendar year in remediation material service, as defined in §63.7957.

(b) Each affected source for your site is existing if you commenced construction or reconstruction of the affected source before July 30, 2002.

(c) Each affected source for your site is new if you commenced construction or reconstruction of the affected source on or after July 30, 2002. An affected source is reconstructed if it meets the definition of reconstruction in § 63.2.

§ 63.7883 When do I have to comply with this subpart?

(a) If you have an existing affected source, you must comply with each emission limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you no later than October 9, 2006.

(b) If you have a new affected source that manages remediation material other than a radioactive mixed waste as defined in § 63.7957, then you must meet the compliance date specified in paragraph (b)(1) or (2) of this section, as applicable to your affected source.

(1) If the affected source's initial startup date is on or before October 8, 2003, you must comply with each emission limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you by October 8, 2003.

(2) If the affected source's initial startup date is after October 8, 2003, you must comply with each emission limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you upon initial startup.

(c) If you have a new affected source that manages remediation material that is a radioactive mixed waste as defined in § 63.7957, then you must meet the compliance date specified in paragraph (c)(1) or (2) of this section, as applicable to your affected source.

(1) If the affected source's initial startup date is on or before October 8, 2003, you must comply with each emission limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you no later than October 9, 2006.

(2) If the affected source's initial startup date is after October 8, 2003, you must comply with each emission limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you upon initial startup.

(d) If your facility is an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP as defined in § 63.2, then you must meet the compliance dates specified in paragraphs (d)(1) and (2) of this section.

(1) For each source at your facility that is a new affected source subject to this subpart, you must comply with each emission limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you upon initial startup.

(2) For all other affected sources subject to this subpart, you must comply with each emission limitation, work practice standard, and operation and maintenance requirement in this subpart that applies to you no later than 3 years after your facility becomes a major source.

(e) You must meet the notification requirements, according to the schedule applicable to your facility, as specified in § 63.7950 and in 40 CFR part 63, subpart A. Some of the notifications must be submitted before you are required to comply with the emissions limitations and work practice standards in this subpart.

GENERAL STANDARDS

§ 63.7884 What are the general standards I must meet for each site remediation with affected sources?

(a) For each site remediation with affected sources designated under § 63.7882, you must meet the standards specified in §§ 63.7885 through 63.7953, as applicable to your affected sources, unless your site remediation meets the requirements for an exemption under paragraph (b) of this section.

(b) A site remediation that is completed within 30 consecutive calendar days according to the conditions in paragraphs (b)(1) and (2) of this section is not subject to the standards under paragraph (a) of this section. This exemption cannot be used for a site remediation involving the staged or intermittent cleanup of remediation material whereby the remediation activities at the site are started, stopped, and

then re-started in a series of intervals with durations less than 30-days per interval for which the total time of all of the intervals required to complete the site remediation exceeds a total of 30 days.

(1) The 30-day period for a site remediation is determined from the first day that any action is initiated that removes, destroys, degrades, transforms, immobilizes, or otherwise manages the remediation materials. The end of a site remediation is determined by the last day on which treatment or disposal of the remediation materials from the cleanup is completed. The following activities, when completed before beginning this initial action, are not counted as part of the 30-day period: activities to characterize the type and extent of the contamination by collecting and analyzing samples, activities to obtain permits from Federal, State, or local authorities to conduct the site remediation, activities to schedule workers and necessary equipment, and activities to arrange for contractor or third party assistance in performing the site remediation.

(2) You must prepare and maintain at your facility written documentation describing the exempted site remediation, and listing the initiation and completion dates for the site remediation.

§63.7885 What are the general standards I must meet for my affected process vents?

(a) For the process vents that comprise the affected source designated under §63.7882, you must select and meet the requirements under one of the options specified in paragraph (b) of this section.

(b) For each affected process vent, except as exempted under paragraph (c) of this section, you must meet one of the options in paragraphs (b)(1) through (3) of this section.

(1) You control HAP emissions from the affected process vents according to the standards specified in §§63.7890 through 63.7893.

(2) You determine for the remediation material treated or managed by the process vented through the affected process vents that the average total volatile organic hazardous air pollutant (VOHAP) concentration, as defined in §63.7957, of this material is less than 10 parts per million by weight (ppmw). Determination of the VOHAP concentration is made using the procedures specified in §63.7943.

(3) If the process vent is also subject to another subpart under 40 CFR part 61 or 40 CFR part 63, you control emissions of the HAP listed in Table 1 of this subpart from the affected process vent in compliance with the standards specified in the applicable subpart. This means you are complying with all applicable emissions limitations and work practice standards under the other subpart (*e.g.*, you install and operate the required air pollution controls or have implemented the required work practice to reduce HAP emissions to levels specified by the applicable subpart). This provision does not apply to any exemption of the affected source from the emissions limitations and work practice standards allowed by the other applicable subpart.

(c) A process vent that meets the exemption requirements in paragraphs (c)(1) and (2) of this section is exempted from the requirements in paragraph (b) of this section.

(1) The process vent stream exiting the process vent meets the conditions in either paragraph (c)(1)(i) or (ii) of this section.

(i) The process vent stream flow rate is less than 0.005 cubic meters per minute (m^3/min) at standard conditions (as defined in 40 CFR 63.2); or

(ii) The process vent stream flow rate is less than 6.0 m^3/min at standard conditions (as defined in 40 CFR 63.2) and the total concentration of HAP listed in Table 1 of this subpart is less than 20 parts per million by volume (ppmv).

(2) You must demonstrate that the process vent stream meets the applicable exemption conditions in paragraph (c)(1) of this section using the procedures specified in §63.694(m). You must prepare and maintain documentation at your facility to support your determination of the process vent stream flow rate. This documentation must include identification of each process vent exempted under this paragraph and the test results used to determine the process vent stream flow rate and total HAP concentration, as applicable

to the exemption conditions for your process vent. You must perform a new determination of the process vent stream flow rate and total HAP concentration, as applicable to the exemption conditions for your process vent, whenever changes to operation of the unit on which the process vent is used could cause the process vent stream conditions to exceed the maximum limits of the exemption.

§ 63.7886 What are the general standards I must meet for my affected remediation material management units?

(a) For each remediation material management unit that is part of an affected source designated by § 63.7882, you must select and meet the requirements under one of the options specified in paragraph (b) of this section except for those remediation material management units exempted under paragraph (c) or (d) of this section.

(b) For each affected remediation material management unit, you must meet one of the options in paragraphs (b)(1) through (4) of this section.

(1) You control HAP emissions from the affected remediation material management unit according to the standards specified in paragraphs (b)(1)(i) through (v) of this section, as applicable to the unit.

(i) If the remediation material management unit is a tank, then you control HAP emissions according to the standards specified in §§ 63.7895 through 63.7898.

(ii) If the remediation material management unit is a container, then you control HAP emissions according to the standards specified in §§ 63.7900 through 63.7903.

(iii) If the remediation material management unit is a surface impoundment, then you control HAP emissions according to the standards specified in §§ 63.7905 through 63.7908.

(iv) If the remediation material management unit is an oil-water or organic-water separator, then you control HAP emissions according to the standards specified in §§ 63.7910 through 63.7913.

(v) If the remediation material management unit is a transfer system, then you control HAP emissions according to the standards specified in §§ 63.7915 through 63.7918.

(2) You determine for the remediation material placed in the remediation material management unit that the average total VOHAP concentration, as defined in § 63.7957, of this material is less than 500 ppmw. Determination of the total VOHAP concentration is made based on the remediation material composition at the point-of-extraction, as defined in § 63.7957, using the procedures specified in § 63.7943.

(3) If the remediation material management unit is also subject to another subpart under 40 CFR part 61 or 40 CFR part 63, you control emissions of the HAP listed in Table 1 of this subpart from the affected remediation material management unit in compliance with the standards specified in the applicable subpart. This means you are complying with all applicable emissions limitations and work practice standards under the other subpart (*e.g.,* you install and operate the required air pollution controls or have implemented the required work practice to reduce HAP emissions to levels specified by the applicable subpart). This provision does not apply to any exemption of the affected source from the emissions limitations and work practice standards allowed by the other applicable subpart.

(4) If the remediation material management unit is an open tank or surface impoundment used for a biological treatment process, you meet the requirements as specified in paragraphs (b)(4)(i) and (ii) of this section.

(i) You demonstrate that the biological treatment process conducted in the open tank or surface impoundment meets the performance levels specified in either § 63.684(b)(4)(i) or (ii).

(ii) You monitor the biological treatment process conducted in the open tank or surface impoundment according to the requirements in § 63.684(e)(4).

(c) A remediation material management unit is exempted from the requirements in paragraph (b) of this section if this unit is used for cleanup of radioactive mixed waste, as defined in § 63.7957, that is subject to applicable regulations, directives, and other requirements under the Atomic Energy

Act, the Nuclear Waste Policy Act, or the Waste Isolation Pilot Plant Land Withdrawal Act.

(d) One or a combination of remediation material management units may be exempted at your discretion from the requirements in paragraph (b) of this section provided that the total annual quantity of HAP listed in Table 1 of this subpart contained in the remediation material placed in all of the remediation material management units exempted under this paragraph is less than 1 Mg/yr. For each remediation material management unit you select to be exempted under this provision, you must meet the requirements in paragraphs (d)(1) and (2) of this section.

(1) You must designate each of the remediation material management units you are selecting to be exempted under this paragraph by either submitting to the Administrator a written notification identifying the exempt units or permanently marking the exempt units at the faculty site. If you choose to prepare and submit a written notification, this notification must include a site plan, process diagram, or other appropriate documentation identifying each of the exempt units. If you choose to permanently mark the exempt units, each exempt unit must be marked in such a manner that it can be readily identified as an exempt unit from the other remediation material management units located at the site.

(2) You must prepare an initial determination of the total annual HAP quantity in the remediation material placed in the units exempted under this paragraph. This determination is based on the total quantity of the HAP listed in Table 1 of this subpart as determined at the point where the remediation material is placed in each exempted unit. You must perform a new determination whenever the extent of changes to the quantity or composition of the remediation material placed in the exempted units could cause the total annual HAP content in the remediation material to exceed 1 Mg/yr. You must maintain documentation to support the most recent determination of the total annual HAP quantity. This documentation must include the basis and data used for determining the organic HAP content of the remediation material.

§63.7887 What are the general standards I must meet for my affected equipment leak sources?

You must control HAP emissions from equipment leaks from each equipment component that is part of the affected source specified in §63.7882 by implementing leak detection and control measures according to the standards specified in §§63.7920 through 63.7922.

§63.7888 How do I implement this rule at my facility using the cross-referenced requirements in other subparts?

(a) For the purposes of this subpart, when you read the term ''HAP listed in Table 1 of this subpart'' in a cross-referenced section under 40 CFR part 63, subpart DD—National Emission Standards for Hazardous Air Pollutants from Off-Site Waste and Recovery Operations, you should refer to Table 1 of this subpart.

(b) For the purposes of this subpart, when you read the term off-site material in a cross-referenced section under 40 CFR part 63, subpart DD—National Emission Standards for Hazardous Air Pollutants from Off-Site Waste and Recovery Operations you should substitute the term remediation material, as defined in §63.7957.

(c) For the purposes of this subpart, when you read the term regulated material in a cross-referenced section under 40 CFR part 63, subparts OO, PP, QQ, RR, TT, UU, WW, and VV you should substitute the term remediation material, as defined in §63.7957.

PROCESS VENTS

§63.7890 What emissions limitations and work practice standards must I meet for process vents?

(a) You must control HAP emissions from each new and existing process vent subject to §63.7885(b)(1) according to emissions limitations and work practice standards in this section that apply to your affected process vents.

(b) For your affected process vents, you must meet one of the facility-wide emission limit options specified in paragraphs (b)(1) through (4) of this

section. If you have multiple affected process vent streams, you may comply with this paragraph using a combination of controlled and uncontrolled process vent streams that achieve the facility-wide emission limit that applies to you.

(1) Reduce from all affected process vents the total emissions of the HAP listed in Table 1 of this subpart to a level less than 1.4 kilograms per hour (kg/hr) and 2.8 Mg/yr (3.0 pounds per hour (lb/hr) and 3.1 tpy); or

(2) Reduce from all affected process vents the emissions of total organic carbon (TOC) (minus methane and ethane) to a level below 1.4 kg/hr and 2.8 Mg/yr (3.0 lb/hr and 3.1 tpy); or

(3) Reduce from all affected process vents the total emissions of the HAP listed in Table 1 of this subpart by 95 percent by weight or more; or

(4) Reduce from all affected process vents the emissions of TOC (minus methane and ethane) by 95 percent by weight or more.

(c) For each closed vent system and control device you use to comply with paragraph (b) of this section, you must meet the operating limit requirements and work practice standards in §63.7925(c) through (j) that apply to your closed vent system and control device.

§63.7891 How do I demonstrate initial compliance with the emissions limitations and work practice standards for process vents?

(a) You must demonstrate initial compliance with the emissions limitations and work practice standards in §63.7890(b) applicable to your affected process vents by meeting the requirements in paragraphs (b) through (d) of this section.

(b) You have measured or determined using the procedures for performance tests and design evaluations in §63.7941 that emission levels from all of your affected process vents meet the facility-wide emission limits in §63.7890(b) that apply to you, as follows in paragraphs (b)(1) through (4) of this section.

(1) If you elect to meet §63.7890(b)(1), you demonstrate that the total emissions of the HAP listed in Table 1 of this subpart from all affected process vents at your facility are less than 1.4 kg/hr and 2.8 Mg/yr (3.0 lb/hr and 3.1 tpy).

(2) If you elect to meet §63.7890(b)(2), you demonstrate that emissions of TOC (minus methane and ethane) from all affected process vents at your facility are less than 1.4 kg/hr and 2.8 Mg/yr (3.0 lb/hr and 3.1 tpy).

(3) If you elect to meet §63.7890(b)(3), you demonstrate that the total emissions of the HAP listed in Table 1 of this subpart from all affected process vents are reduced by 95 percent by weight or more.

(4) If you elect to meet §63.7890(b)(4), you demonstrate that the emissions of TOC (minus methane and ethane) from all affected process vents are reduced by 95 percent by weight or more.

(c) For each closed vent system and control device you use to comply with §63.7890(b), you have met each requirement for demonstrating initial compliance with the emission limitations and work practice standards for a closed vent system and control device in §63.7926.

(d) You have submitted a notification of compliance status according to the requirements in §63.7950.

§63.7892 What are my inspection and monitoring requirements for process vents?

For each closed vent system and control device you use to comply with §63.7890(b), you must monitor and inspect the closed vent system and control device according to the requirements in §63.7927 that apply to you.

§63.7893 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for process vents?

(a) You must demonstrate continuous compliance with the emissions limitations and work practice standards in §63.7890 applicable to your affected process vents by meeting the requirements in paragraphs (b) through (d) of this section.

(b) You must maintain emission levels from all of your affected process vents to meet the facility-wide emission limits in §63.7890(b) that apply to you, as specified in the following paragraph (b)(1) through (4) of this section.

(1) If you elect to meet §63.7890(b)(1), you maintain the total emissions of

the HAP listed in Table 1 of this subpart from all affected process vents at your facility are less than 1.4 kg/hr and 2.8 Mg/yr (3.0 lb/hr and 3.1 tpy).

(2) If you elect to meet §63.7890(b)(2), you maintain emissions of TOC (minus methane and ethane) from all affected process vents at your facility are less than 1.4 kg/hr and 2.8 Mg/yr (3.0 lb/hr and 3.1 tpy).

(3) If you elect to meet §63.7890(b)(3), you maintain the total emissions of the HAP listed in Table 1 of this subpart from all affected process vents are reduced by 95 percent by weight or more.

(4) If you elect to meet §63.7890(b)(4), you maintain that the emissions of TOC (minus methane and ethane) from all affected process vents are reduced by 95 percent by weight or more.

(c) For each closed vent system and control device you use to comply with §63.7890(b), you have met each requirement for demonstrating continuous compliance with the emission limitations and work practice standards for a closed vent system and control device in §63.7928.

(d) Keeping records to document continuous compliance with the requirements of this subpart according to the requirements in §63.7952.

TANKS

§63.7895 What emissions limitations and work practice standards must I meet for tanks?

(a) You must control HAP emissions from each new and existing tank subject to §63.7886(b)(1)(i) according to emissions limitations and work practice standards in this section that apply to your affected tanks.

(b) For each affected tank, you must install and operate air pollution controls that meet the requirements in paragraphs (b)(1) through (4) of this section that apply to your tank.

(1) Unless your tank is used for a waste stabilization process, as defined in §63.7957, you must determine the maximum HAP vapor pressure (expressed in kilopascals (kPa)) of the remediation material placed in your tank using the procedures specified in §63.7944.

(2) If the maximum HAP vapor pressure of the remediation material you place in your tank is less than 76.6 kPa, then you must determine which tank level controls (*i.e.*, Tank Level 1 or Tank Level 2) apply to your tank as shown in Table 2 of this subpart, and based on your tank's design capacity (expressed in cubic meters (m^3)) and the maximum HAP vapor pressure of the remediation material you place in this tank. If your tank is required by Table 2 of this subpart to use Tank Level 1 controls, then you must meet the requirements in paragraph (c) of this section. If your tank is required by Table 2 of this subpart to use Tank Level 2 controls, then you must meet the requirements in paragraph (d) of this section

(3) If maximum HAP vapor pressure of the remediation material you place in your tank is 76.6 kPa or greater, then the tank must use one of the Tank Level 2 controls specified in paragraphs (d)(3) through (5) of this section. Use of floating roofs under paragraph (d)(1) or (2) of this section is not allowed for tanks managing these remediation materials.

(4) A tank used for a waste stabilization process, as defined in §63.7957, must use one of Tank Level 2 controls, as specified in paragraph (d) of this section, that is appropriate for your waste stabilization process.

(c) If you use Tank Level 1 controls, you must install and operate a fixed roof according to the requirements in §63.902. As an alternative to using this fixed roof, you may choose to use one of Tank Level 2 controls in paragraph (d) of this section.

(d) If you use Tank Level 2 controls, you must meet the requirements of one of the options in paragraphs (d)(1) through (5) of this section.

(1) Install and operate a fixed roof with an internal floating roof according to the requirements in §63.1063(a)(1)(i), (a)(2), and (b); or

(2) Install and operate an external floating roof according to the requirements in §63.1063(a)(1)(ii), (a)(2), and (b); or

(3) Install and operate a fixed roof vented through a closed vent system to a control device according to the requirements in §63.685(g). You must meet the emissions limitations and work practice standards in §63.7925

that apply to your closed vent system and control device; or

(4) Install and operate a pressure tank according to the requirements in § 63.685(h); or

(5) Locate the tank inside a permanent total enclosure and vent emissions from the enclosure through a closed vent system to a control device that is an enclosed combustion device according to the requirements in § 63.685(i). You must meet the emissions limitations and work practice standards in § 63.7925 that apply to your closed vent system and control device.

(e) As provided in § 63.6(g), you may request approval from the EPA to use an alternative to the work practice standards in this section that apply to your tanks. If you request for permission to use an alternative to the work practice standards, you must submit the information described in § 63.6(g)(2).

§ 63.7896 How do I demonstrate initial compliance with the emissions limitations and work practice standards for tanks?

(a) You must demonstrate initial compliance with the emissions limitations and work practice standards in § 63.7895 that apply to your affected tanks by meeting the requirements in paragraphs (b) through (h) of this section, as applicable to your containers.

(b) You have submitted as part of your notification of compliance status, specified in § 63.7950, a signed statement that you have met the requirements in paragraphs (b)(1) and (2) of this section.

(1) You have determined the applicable tank control levels specified in § 63.7895(b) for the tanks to be used for your site remediation.

(2) You have determined, according to the procedures § 63.7944, and recorded the maximum HAP vapor pressure of the remediation material placed in each affected tank subject to § 63.7886(b)(1)(i) that does not use Tank Level 2 controls.

(c) You must demonstrate initial compliance of each tank determined under paragraph (b) of this section to require Tank Level 1 controls if you have submitted as part of your notification of compliance status, specified in § 63.7950, a signed statement that you have met the requirements in paragraphs (c)(1) through (3) of this section.

(1) Each tank using Tank Level 1 controls is equipped with a fixed roof and closure devices according to the requirements in § 63.902(b) and (c) and you have records documenting the design.

(2) You have performed an initial visual inspection of the fixed roof and closure devices for defects according to the requirements in § 63.906(a) and you have records documenting the inspection results.

(3) You will operate the fixed roof and closure devices according to the requirements in § 63.902.

(d) You must demonstrate initial compliance of each tank determined under paragraph (b) of this section to require Tank Level 2 controls and using a fixed roof with an internal floating roof according to § 63.7895(d)(1) if you have submitted as part of your notification of compliance status, specified in § 63.7950, a signed statement that you have met the requirements in paragraphs (d)(1) through (3) of this section.

(1) Each tank is equipped with an internal floating roof that meets the requirements in § 63.1063(a) and you have records documenting the design.

(2) You will operate the internal floating roof according to the requirements in § 63.1063(b).

(3) You have performed an initial visual inspection according to the requirements in § 63.1063(d)(1) and you have a record of the inspection results.

(e) You must demonstrate initial compliance of each tank determined under paragraph (b) of this section to require Tank Level 2 controls and using an external floating roof according to § 63.7895(d)(2) if you have submitted as part of your notification of compliance status, specified in § 63.7950, a signed statement that you have met the requirements in paragraphs (e)(1) through (3) of this section.

(1) Each tank is equipped with an external floating roof that meets the requirements in § 63.1063(a) and you have records documenting the design.

(2) You will operate the external floating roof according to the requirements in § 63.1063(b).

(3) You have performed an initial seal gap measurement inspection according

to the requirements in §63.1063(d)(3) and you have records of the measurement results.

(f) You must demonstrate initial compliance of each tank determined under paragraph (b) of this section to require Tank Level 2 controls and using a fixed roof vented to a control device according to §63.7895(d)(3) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (f)(1) through (4) of this section.

(1) Each tank is equipped with a fixed roof and closure devices according to the requirements in §63.902(b) and (c) and you have records documenting the design.

(2) You have performed an initial visual inspection of fixed roof and closure devices for defects according to the requirements in §63.695(b)(3) and you have records documenting the inspection results.

(3) You will operate the fixed roof and closure devices according to the requirements in §63.685(g).

(4) You have met each applicable requirement for demonstrating initial compliance with the emission limitations and work practice standards for a closed vent system and control device in §63.7926.

(g) You must demonstrate initial compliance of each tank determined under paragraph (b) of this section to require Tank Level 2 controls and operates as a pressure tank according to §63.7895(d)(4) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (g)(1) and (2) of this section.

(1) Each tank is designed to operate as a pressure tank according to the requirements in §63.685(h), and you have records documenting the design.

(2) You will operate the pressure tank and according to the requirements in §63.685(h).

(h) You must demonstrate initial compliance of each tank determined under paragraph (b) of this section to require Tank Level 2 controls and using a permanent total enclosure vented to an enclosed combustion device according to §63.7895(d)(5) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (h)(1) and (2) of this section.

(1) You have submitted as part of your notification of compliance status a signed statement that you have performed the verification procedure according to the requirements in §63.685(i), and you have records of the supporting calculations and measurements.

(2) You have met each applicable requirement for demonstrating initial compliance with the emission limitations and work practice standards for a closed vent system and control device in §63.7926.

§63.7897 What are my inspection and monitoring requirements for tanks?

(a) You must visually inspect each of your tanks using Tank Level 1 controls for defects at least annually according to the requirements in §63.906(a).

(b) You must inspect and monitor each of your tanks using Tank Level 2 controls according to the requirements in paragraphs (b)(1) through (5), as applicable to your tanks.

(1) If you use a fixed roof with an internal floating roof according to §63.7895(d)(1), you must visually inspect the fixed roof and internal floating roof according to the requirements in §63.1063(d)(1) and (2).

(2) If you use an external floating roof according to §63.7895(d)(2), you must visually inspect the external floating roof according to the requirements in §63.1063(d)(1) and inspect the seals according to the requirements in §63.1063(d)(2) and (3).

(3) If you use a fixed roof vented to a control device according to §63.7895(d)(3), you must meet requirements in paragraphs (b)(3)(i) and (ii) of this section.

(i) You must visually inspect the fixed roof and closure devices for defects according to the requirements in §63.695(b)(3).

(ii) You must monitor and inspect the closed vent system and control device according to the requirements in §63.7927 that apply to you.

(4) If you use a pressure tank according to §63.7895(d)(4), you must visually

inspect the tank and its closure devices for defects at least annually to ensure they are operating according to the design requirements in § 63.685(h).

(5) If you use a permanent total enclosure vented to an enclosed combustion device according to § 63.7895(d)(5), you must meet requirements in paragraphs (b)(5)(i) and (ii) of this section.

(i) You must perform the verification procedure for the permanent total enclosure at least annually according to the requirements in § 63.685(i).

(ii) You must monitor and inspect the closed vent system and control device according to the requirements in § 63.7927 that apply to you.

§ 63.7898 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for tanks?

(a) You must demonstrate continuous compliance with the emissions limitations and work practice standards in § 63.7895 applicable to your affected tanks by meeting the requirements in paragraphs (b) through (d) of this section.

(b) You must demonstrate continuous compliance with the requirement to determine the applicable tank control level specified in § 63.7895(b) for each affected tank by meeting the requirements in paragraphs (b)(1) through (3) of this section.

(1) Keeping records of the tank design capacity according to the requirements in § 63.1065(a).

(2) For tanks subject to § 63.7886(b)(1)(ii) and not using Tank Level 2 controls, meeting the requirements in paragraphs (b)(2)(i) and (ii) of this section.

(i) Keeping records of the maximum HAP vapor pressure determined according to the procedures in § 63.7944 for the remediation material placed in each affected tank.

(ii) Performing a new determination of the maximum HAP vapor pressure whenever changes to the remediation material managed in the tank could potentially cause the maximum HAP vapor pressure to increase to a level that is equal to or greater than the maximum HAP vapor pressure for the tank design capacity specified in Table 2. You must keep records of each determination.

(3) Keeping records to document compliance with the requirements of this subpart according to the requirements in § 63.7952.

(c) You must demonstrate continuous compliance for each tank determined to require Tank Level 1 controls by meeting the requirements in paragraphs (c)(1) through (5) of this section.

(1) Operating and maintaining the fixed roof and closure devices according to the requirements in § 63.902(c).

(2) Visually inspecting the fixed roof and closure devices for defects at least annually according to the requirements in § 63.906(a).

(3) Repairing defects according to the requirements in § 63.63.906(b).

(4) Recording the information specified in § 63.907(a)(3) and (b).

(5) Keeping records to document compliance with the requirements of this subpart according to the requirements in § 63.7952.

(d) You must demonstrate continuous compliance for each tank determined to require Tank Level 2 controls and using a fixed roof with an internal floating roof according to § 63.7895(d)(1) by meeting the requirements in paragraphs (d)(1) through (5) of this section.

(1) Operating and maintaining the internal floating roof according to the requirements in § 63.1063(b).

(2) Visually inspecting the internal floating roof according to the requirements in § 63.1063(d)(1) and (2).

(3) Repairing defects according to the requirements in § 63.1063(e).

(4) Recording the information specified in § 63.1065(b) through (d).

(5) Keeping records to document compliance with the requirements of this subpart according to the requirements in § 63.7952.

(e) You must demonstrate continuous compliance for each tank determined to require Tank Level 2 controls and using an external floating roof according to § 63.7895(d)(2) by meeting the requirements in paragraphs (e)(1) through (5) of this section.

(1) Operating and maintaining the external floating roof according to the requirements in § 63.1063(b).

(2) Visually inspecting the external floating roof according to the requirements in §63.1063(d)(1) and inspecting the seals according the requirements in §63.1063(d)(2) and (3).

(3) Repairing defects according to the requirements in §63.1063(e).

(4) Recording the information specified in §63.1065(b) through (d).

(5) Keeping records to document compliance with the requirements of this subpart according to the requirements in §63.7952.

(f) You must demonstrate continuous compliance for each tank determined to require Tank Level 2 controls and using a fixed roof vented to a control device according to §63.7895(d)(3) by meeting the requirements in paragraphs (f)(1) through (6) of this section.

(1) Operating and maintaining the fixed roof and closure devices according to the requirements in §63.685(g).

(2) Visually inspecting the fixed roof and closure devices for defects at least annually according to the requirements in §63.695(b)(3)(i).

(3) Repairing defects according to the requirements in §63.695(b)(4).

(4) Recording the information specified in §63.696(e).

(5) Meeting each applicable requirement for demonstrating continuous compliance with the emission limitations and work practice standards for a closed vent system and control device in §63.7928.

(6) Keeping records to document compliance with the requirements of this subpart according to the requirements in §63.7952.

(g) You must demonstrate continuous compliance for each tank determined to require Tank Level 2 controls and operated as a pressure tank according to §63.7895(d)(4) by meeting the requirements in paragraphs (g)(1) through (3) of this section.

(1) Operating and maintaining the pressure tank and closure devices according to the requirements in §63.685(h).

(2) Visually inspecting each pressurized tank and closure devices for defects at least annually to ensure they are operating according to the design requirements in §63.685(h), and recording the results of each inspection.

(3) Keeping records to document compliance with the requirements of this subpart according to the requirements in §63.7952.

(h) You must demonstrate continuous compliance for each tank determined to require Tank Level 2 controls and using a permanent total enclosure vented to an enclosed combustion device according to §63.7895(d)(5) by meeting the requirements in paragraphs (h)(1) through (4) of this section.

(1) Performing the verification procedure for the enclosure annually according to the requirements in §63.685(i).

(2) Recording the information specified in §63.696(f).

(3) Meeting each applicable requirement for demonstrating continuous compliance with the emissions limitations and work practice standards for a closed vent system and control device in §63.7928.

(4) Keeping records to document compliance with the requirements of this subpart according to the requirements in §63.7952.

CONTAINERS

§63.7900 What emissions limitations and work practice standards must I meet for containers?

(a) You must control HAP emissions from each new and existing container subject to §63.7886(b)(1)(ii) according to emissions limitations and work practice standards in this section that apply to your affected containers.

(b) For each container having a design capacity greater than 0.1 m^3 you must meet the requirements in paragraph (b)(1) or (2) of this section that apply to your container except at the times the container is used for treatment of remediation material by a waste stabilization process, as defined in §63.7957. As an alternative for any container subject to this paragraph, you may choose to meet the requirements in paragraph (d) of this section.

(1) If the design capacity of your container is less than or equal to 0.46 m^3, then you must use controls according to the standards for Container Level 1 controls as specified in §63.922. As an alternative, you may choose to use controls according to either of the standards for Container Level 2 controls as specified in §63.923.

(2) If the design capacity of your container is greater than 0.46 m^3, then you must use controls according to the standards for Container Level 2 controls as specified in § 63.923 except as provided for in paragraph (b)(3) of this section.

(3) As an alternative to meeting the standards in paragraph (b)(2) of this section for containers with a capacity greater than 0.46 m^3, if you determine that either of the conditions in paragraphs (b)(3)(i) or (ii) apply to the remediation material placed in your container, then you may use controls according to the standards for Container Level 1 controls as specified in § 63.922.

(i) Vapor pressure of every organic constituent in the remediation material placed in your container is less than 0.3 kPa at 20 °C; or

(ii) Total concentration of the pure organic constituents having a vapor pressure greater than 0.3 kPa at 20 °C in the remediation material placed in your container is less than 20 percent by weight.

(c) At times when a container having a design capacity greater than 0.1 m^3 is used for treatment of a remediation material by a waste stabilization process as defined in § 63.7957, you must control air emissions from the container during the process whenever the remediation material in the container is exposed to the atmosphere according to the standards for Container Level 3 controls as specified in § 63.924. You must meet the emissions limitations and work practice standards in § 63.7925 that apply to your closed vent system and control device.

(d) As an alternative to meeting the requirements in paragraph (b) of this section, you may choose to use controls on your container according to the standards for Container Level 3 controls as specified in § 63.924. You must meet the emissions limitations and work practice standards in § 63.7925 that apply to your closed vent system and control device.

(e) As provided in § 63.6(g), you may request approval from the EPA to use an alternative to the work practice standards in this section that apply to your containers. If you request for permission to use an alternative to the work practice standards, you must submit the information described in § 63.6(g)(2).

§ 63.7901 How do I demonstrate initial compliance with the emissions limitations and work practice standards for containers?

(a) You must demonstrate initial compliance with the emissions limitations and work practice standards in § 63.7990 that apply to your affected containers by meeting the requirements in paragraphs (b) through (e) of this section, as applicable to your containers.

(b) You have submitted as part of your notification of compliance status, specified in § 63.7950, a signed statement that you have met the requirements in paragraphs (b)(1) and (2) of this section.

(1) You have determined the applicable container control levels specified in § 63.7990 for the containers to be used for your site remediation.

(2) You have determined and recorded the maximum vapor pressure or total organic concentration for the remediation material placed in containers with a design capacity greater than 0.46 m^3, and do not use Container Level 2 or Level 3 controls.

(c) You must demonstrate initial compliance of each container determined under paragraph (b) of this section to require Container Level 1 controls if you have submitted as part of your notification of compliance status, specified in § 63.7950, a signed statement that you have met the requirements in paragraphs (c)(1) and (2) of this section.

(1) Each container using Container Level 1 controls will be one of the containers specified in § 63.922(b).

(2) You will operate each container cover and closure device according to the requirements in § 63.922(d).

(d) You must demonstrate initial compliance of each container determined under paragraph (b) of this section to require Container Level 2 controls if you have submitted as part of your notification of compliance status, specified in § 63.7950, a signed statement that you have met the requirements in paragraphs (d)(1) through (4) of this section.

(1) Each container using Container Level 2 controls will be one of the containers specified in § 63.923(b).

(2) You will transfer remediation materials into and out of each container according to the procedures in §63.923(d).

(3) You will operate and maintain the container covers and closure devices according to the requirements in §63.923(d).

(4) You have records that the container meets the applicable U.S. Department of Transportation regulations, or you have conducted an initial test of each container for no detectable organic emissions using the procedures in §63.925(a), and have records documenting the test results, or you have demonstrated within the last 12 months that each container is vapor-tight according to the procedures in §63.925(a) and have records documenting the test results.

(e) You must demonstrate initial compliance of each container determined under paragraph (b) of this section to require Container Level 3 controls if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (e)(1) and (2) of this section.

(1) For each permanent total enclosure you use to comply with §63.7900, you have performed the verification procedure according to the requirements in §63.924(c)(1), and prepare records of the supporting calculations and measurements.

(2) You have met each applicable requirement for demonstrating initial compliance with the emission limitations and work practice standards for a closed vent system and control device in §63.7926.

§63.7902 What are my inspection and monitoring requirements for containers?

(a) You must inspect each container using Container Level 1 or Container Level 2 controls according to the requirements in §63.926(a).

(b) If you use Container Level 3 controls, you must meet requirements in paragraphs (b)(1) and (2) of this section, as applicable to your site remediation.

(1) You must perform the verification procedure for each permanent total enclosure annually according to the requirements in §63.924(c)(1).

(2) You must monitor and inspect each closed vent system and control device according to the requirements in §63.7927 that apply to you.

§63.7903 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for containers?

(a) You must demonstrate continuous compliance with the emissions limitations and work practice standards in §63.7990 applicable to your affected containers by meeting the requirements in paragraphs (b) through (e) of this section.

(b) You must demonstrate continuous compliance with the requirement to determine the applicable container control level specified in §63.7990(b) for each affected tank by meeting the requirements in paragraphs (b)(1) through (3) of this section.

(1) Keeping records of the quantity and design capacity for each type of container used for your site remediation and subject to §63.7886(b)(1)(ii).

(2) For containers subject to §63.7886(b)(1)(ii) with a design capacity greater than 0.46 m^3 and not using Container Level 2 or Container Level 3 controls, meeting the requirements in paragraphs (b)(2)(i) and (ii) of this section.

(i) Keeping records of the maximum vapor pressure or total organic concentration for the remediation material placed in the containers, as applicable to the conditions in §63.7900(b)(3)(i) or (ii) for which your containers qualify to use Container Level 1 controls.

(ii) Performing a new determination whenever changes to the remediation material placed in the containers could potentially cause the maximum vapor pressure or total organic concentration to increase to a level that is equal to or greater than the conditions specified in §63.7900(b)(3)(i) or (ii), as applicable to your containers. You must keep records of each determination.

(3) Keeping records to document compliance with the requirements according to the requirements in §63.7952.

(c) You must demonstrate continuous compliance for each container determined to require Container Level 1 controls by meeting the requirements

in paragraphs (c)(1) through (5) of this section.

(1) Operating and maintaining covers for each container according to the requirements in § 63.922(d) .

(2) Inspecting each container annually according to the requirements in § 63.926(a)(2).

(3) Emptying or repairing each container according to the requirements in § 63.926(a)(3).

(4) Keeping records of an inspection that includes the information in paragraphs (a)(4)(i) and (ii) of this section.

(i) Date of each inspection; and

(ii) If a defect is detected during an inspection, the location of the defect, a description of the defect, the date of detection, the corrective action taken to repair the defect, and if repair is delayed, the reason for any delay and the date completion of the repair is expected.

(5) Keeping records to document compliance with the requirements according to the requirements in § 63.7952.

(d) You must demonstrate continuous compliance for each container determined to require Container Level 2 controls by meeting the requirements in paragraphs (d)(1) through (6) of this section.

(1) Transferring remediation material in and out of the container according to the requirements in § 63.923(c).

(2) Operating and maintaining container covers according to the requirements in § 63.923(d).

(3) Inspecting each container annually according to the requirements in § 63.926(a)(2).

(4) Emptying or repairing containers according to the requirements in § 63.926(a)(3).

(5) Keeping records of each inspection that include the information in paragraphs (d)(5)(i) and (ii) of this section.

(i) Date of each inspection; and

(ii) If a defect is detected during an inspection, the location of the defect, a description of the defect, the date of detection, the corrective action taken to repair the defect, and if repair is delayed, the reason for any delay and the date completion of the repair is expected.

(6) Keeping records to document compliance with the requirements of this subpart according to the requirements in § 63.7952.

(e) You must demonstrate continuous compliance for each container determined to require Container Level 3 controls by meeting the requirements in paragraphs (e)(1) through (4) of this section.

(1) Performing the verification procedure for the enclosure annually according to the requirements in § 63.685(i).

(2) Recording the information specified in § 63.696(f).

(3) Meeting each applicable requirement for demonstrating continuous compliance with the emissions limitations and work practice standards for a closed vent system and control device in § 63.7928.

(4) Keeping records to document compliance with the requirements of this subpart according to the requirements in § 63.7952.

SURFACE IMPOUNDMENTS

§ 63.7905 What emissions limitations or work practice standards must I meet for surface impoundments?

(a) You must control HAP emissions from each new and existing surface impoundment subject to § 63.7886(b)(1)(iii) according to emissions limitations and work practice standards in this section that apply to your affected surface impoundments.

(b) For each affected surface impoundment, you must install and operate air pollution controls that meet either of the options in paragraphs (b)(1) or (2) of this section.

(1) Install and operate a floating membrane cover according to the requirements in § 63.942; or

(2) Install and operate a cover vented through a closed vent system to a control device according to the requirements in § 63.943. You must meet the emissions limitations and work practice standards in § 63.7925 that apply to your closed vent system and control device.

(c) As provided in § 63.6(g), you may request approval from the EPA to use an alternative to the work practice standards in this section that apply to your surface impoundments. If you request for permission to use an alternative to the work practice standards,

you must submit the information described in §63.6(g)(2).

§63.7906 How do I demonstrate initial compliance with the emissions limitations or work practice standards for surface impoundments?

(a) You must demonstrate initial compliance with the emissions limitations and work practice standards in §63.7905 that apply to your affected surface impoundments by meeting the requirements in paragraphs (b) and (c) of this section, as applicable to your surface impoundments.

(b) You must demonstrate initial compliance of each surface impoundment using a floating membrane cover according to §63.7905(b)(1) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (b)(1) through (3) of this section.

(1) You have installed a floating membrane cover and closure devices that meet the requirements in §63.942(b), and you have records documenting the design and installation.

(2) You will operate the cover and closure devices according to the requirements in §63.942(c).

(3) You have performed an initial visual inspection of each surface impoundment and closure devices according to the requirements in §63.946(a), and you have records documenting the inspection results.

(c) You must demonstrate initial compliance of each surface impoundment using a cover vented to a control device according to §63.7905(b)(2) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (c)(1) through (4) of this section.

(1) You have installed a cover and closure devices that meet the requirements in §63.943(b), and have records documenting the design and installation.

(2) You will operate the cover and closure devices according to the requirements in §63.943(c).

(3) You have performed an initial visual inspection of each cover and closure devices according to the requirements in §63.946(b), and have records documenting the inspection results.

(4) You have met each applicable requirement for demonstrating initial compliance with the emission limitations and work practice standards for a closed vent system and control device in §63.7926.

§63.7907 What are my inspection and monitoring requirements for surface impoundments?

(a) If you use a floating membrane cover according to §63.7905(b)(1), you must visually inspect the floating membrane cover and its closure devices at least annually according to the requirements in §63.946(a).

(b) If you use a cover vented to a control device according to §63.7905(b)(2), you must meet requirements in paragraphs (b)(1) and (2) of this section.

(1) You must visually inspect the cover and its closure devices for defects according to the requirements in §63.946(b).

(2) You must monitor and inspect the closed vent system and control device according to the requirements in §63.7927 that apply to you.

§63.7908 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for surface impoundments?

(a) You must demonstrate continuous compliance with the emissions limitations and work practice standards in §63.7905 applicable to your affected surface impoundments by meeting the requirements in paragraphs (b) and (c) of this section as applicable to your surface impoundments.

(b) You must demonstrate continuous compliance for each surface impoundment using a floating membrane cover according to §63.7905(b)(1) by meeting the requirements in paragraphs (b)(1) through (5) of this section.

(1) Operating and maintaining the floating membrane cover and closure devices according to the requirements in §63.942(c).

(2) Visually inspecting the floating membrane cover and closure devices for defects at least annually according to the requirements in §63.946(a).

(3) Repairing defects according to the requirements in §63.946(c).

(4) Recording the information specified in § 63.947(a)(2) and (a)(3).

(5) Keeping records to document compliance with the requirements according to the requirements in § 63.7952.

(c) You must demonstrate continuous compliance for each surface impoundment using a cover vented to a control device according to § 63.7905(b)(2) by meeting the requirements in paragraphs (c)(1) through (6) of this section.

(1) Operating and maintaining the cover and its closure devices according to the requirements in § 63.943(c).

(2) Visually inspecting the cover and its closure devices for defects at least annually according to the requirements in § 63.946(b).

(3) Repairing defects according to the requirements in § 63.946(c).

(4) Recording the information specified in § 63.947(a)(2) and (a)(3).

(5) Meeting each applicable requirement for demonstrating continuous compliance with the emission limitations and work practice standards for a closed vent system and control device in § 63.7928.

(6) Keeping records to document compliance with the requirements according to the requirements in § 63.7952.

SEPARATORS

§ 63.7910 What emissions limitations and work practice standards must I meet for separators?

(a) You must control HAP emissions from each new and existing oil-water separator and organic-water separator subject to § 63.7886(b)(1)(iv) according to emissions limitations and work practice standards in this section that apply to your affected separators.

(b) For each affected separator, you must install and operate air pollution controls that meet one of the options in paragraphs (b)(1) through (3) of this section.

(1) Install and operate a floating roof according to the requirements in § 63.1043. For portions of the separator where it is infeasible to install and operate a floating roof, such as over a weir mechanism, you must comply with the requirements specified in paragraph (b)(2) of this section.

(2) Install and operate a fixed roof vented through a closed vent system to a control device according to the requirements in § 63.1044. You must meet the emissions limitations and work practice standards in § 63.7925 that apply to your closed vent system and control device.

(3) Install and operate a pressurized separator according to the requirements in § 63.1045.

(c) As provided in § 63.6(g), you may request approval from the EPA to use an alternative to the work practice standards in this section that apply to your separators. If you request for permission to use an alternative to the work practice standards, you must submit the information described in § 63.6(g)(2).

§ 63.7911 How do I demonstrate initial compliance with the emissions limitations and work practice standards for separators?

(a) You must demonstrate initial compliance with the emissions limitations and work practice standards in § 63.7910 that apply to your affected separators by meeting the requirements in paragraphs (b) through (d) of this section, as applicable to your separators.

(b) You must demonstrate initial compliance of each separator using a floating roof according to § 63.7910(b)(1) if you have submitted as part of your notification of compliance status, specified in § 63.7950, a signed statement that you have met the requirements in paragraphs (b)(1) through (4) of this section.

(1) You have installed a floating roof and closure devices that meet the requirements in § 63.1043(b), and you have records documenting the design and installation.

(2) You will operate the floating roof and closure devices according to the requirements in § 63.1043(c).

(3) You have performed an initial seal gap measurement inspection using the procedures in § 63.1046(b), and you have records documenting the measurement results.

(4) You have performed an initial visual inspection of the floating roof and closure devices for defects according to the requirements in § 63.1047(b)(2), and you have records documenting the inspection results.

(5) For any portions of the separator using a fixed roof vented to a control

device according to §63.7910(b)(1), you have met the requirements in paragraphs (c)(1) through (4) of this section.

(c) You must demonstrate initial compliance of each separator using a fixed roof vented to a control device according to §63.7910(b)(2) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (c)(1) through (4) of this section.

(1) You have installed a fixed roof and closure devices that meet the requirements in §63.1042(b), and you have records documenting the design and installation.

(2) You will operate the fixed roof and its closure devices according to the requirements in §63.1042(c).

(3) You have performed an initial visual inspection of the fixed roof and closure devices for defects according to the requirements in §63.1047(a).

(4) You have met each applicable requirement for demonstrating initial compliance with the emission limitations and work practice standards for a closed vent system and control device in §63.7926.

(d) You must demonstrate initial compliance of each pressurized separator that operates as a closed system according to §63.7910(b)(3) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (d)(1) and (2) of this section.

(1) You have installed a pressurized separator that operates as a closed system according to the requirements in §63.1045(b)(1) and (b)(2), and you have records of the design and installation.

(2) You will operate the pressurized separator as a closed system according to the requirements in §63.1045(b)(3).

§63.7912 What are my inspection and monitoring requirements for separators?

(a) If you use a floating roof according to §63.7910(b)(1), you must meet requirements in paragraphs (a)(1) and (2) of this section.

(1) Measure the seal gaps at least annually according to the requirements in §63.1047(b)(1).

(2) Visually inspect the floating roof at least annually according to the requirements in §63.1047(b)(2).

(b) If you use a cover vented to a control device according to §63.7910(b)(1) or (2), you must meet requirements in paragraphs (b)(1) and (2) of this section.

(1) You must visually inspect the cover and its closure devices for defects according to the requirements in §63.1047(c).

(2) You must monitor and inspect the closed vent system and control device according to the requirements in §63.7927 that apply to you.

(c) If you use a pressurized separator that operates as a closed system according to §63.7910(b)(3), you must visually inspect each pressurized separator and closure devices for defects at least annually to ensure they are operating according to the design requirements in §63.1045(b).

§63.7913 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for separators?

(a) You must demonstrate continuous compliance with the emissions limitations and work practice standards in §63.7910 applicable to your affected separators by meeting the requirements in paragraphs (b) through (d) of this section as applicable to your surface impoundments.

(b) You must demonstrate continuous compliance for each separator using a floating roof according to §63.7910(b)(1) by meeting the requirements in paragraphs (b)(1) through (6) of this section.

(1) Operating and maintaining the floating roof according to the requirements in §63.1043(b).

(2) Performing seal gap measurement inspections at least annually according to the requirements in §63.1047(b)(1).

(3) Visually inspecting the floating roof at least annually according to the requirements in §63.1047(b)(2).

(4) Repairing defects according to the requirements in §63.1047(d).

(5) Recording the information specified in §63.1048(a) and (b).

(6) Keeping records to document compliance with the requirements according to the requirements in §63.7952.

(c) You must demonstrate continuous compliance for each separator using a

cover vented to a control device according to § 63.7905(b)(1) or (2) by meeting the requirements in paragraphs (c)(1) through (6) of this section.

(1) Operating and maintaining the fixed roof and its closure devices according to the requirements in § 63.1042.

(2) Performing visual inspections of the fixed roof and its closure devices for defects at least annually according to the requirements in § 63.1047(a).

(3) Repairing defects according to the requirements in § 63.1047(d).

(4) Recording the information specified in § 63.1048(a).

(5) Meeting each applicable requirement for demonstrating continuous compliance with the emission limitations and work practice standards for a closed vent system and control device in § 63.7928.

(6) Keeping records to document compliance with the requirements of this subpart according to the requirements in § 63.7952.

(d) You must demonstrate continuous compliance for each pressurized separator operated as a closed system according to § 63.7910(b)(3) by meeting the requirements in paragraphs (d)(1) and (2) of this section.

(1) Operating the pressurized separator at all times according to the requirements in § 63.1045.

(2) Visually inspecting each pressurized tank and closure devices for defects at least annually to ensure they are operating according to the design requirements in § 63.1045(b), and recording the results of each inspection.

TRANSFER SYSTEMS

§ 63.7915 What emissions limitations and work practice standards must I meet for transfer systems?

(a) You must control HAP emissions from each new and existing transfer system subject to § 63.7886(b)(1)(v) according to emissions limitations and work practice standards in this section that apply to your affected transfer systems.

(b) For each affected transfer system that is an individual drain system as defined in § 63.7957, you must install and operate controls according to the requirements in § 63.962.

(c) For each affected transfer system that is not an individual drain system as defined in § 63.7957, you must use one of the transfer systems specified in paragraphs (c)(1) through (3) of this section.

(1) A transfer system that uses covers according to the requirements in § 63.689(d).

(2) A transfer system that consists of continuous hard-piping. All joints or seams between the pipe sections shall be permanently or semi-permanently sealed (e.g., a welded joint between two sections of metal pipe or a bolted and gasketed flange).

(3) A transfer system that is enclosed and vented through a closed vent system to a control device according to the requirements specified in paragraphs (c)(3)(i) and (ii) of this section.

(i) The transfer system is designed and operated such that an internal pressure in the vapor headspace in the enclosure is maintained at a level less than atmospheric pressure when the control device is operating, and

(ii) The closed vent system and control device are designed and operated to meet the emissions limitations and work practice standards in § 63.7925 that apply to your closed vent system and control device.

(d) As provided in § 63.6(g), you may request approval from the EPA to use an alternative to the work practice standards in this section that apply to your transfer systems. If you request for permission to use an alternative to the work practice standards, you must submit the information described in § 63.6(g)(2).

§ 63.7916 How do I demonstrate initial compliance with the emissions limitations and work practice standards for transfer systems?

(a) You must demonstrate initial compliance with the emissions limitations and work practice standards in § 63.7915 that apply to your affected transfer systems by meeting the requirements in paragraphs (b) through (e) of this section, as applicable to your transfer systems.

(b) You must demonstrate initial compliance of each individual drain system using controls according to § 63.7915(b) if you have submitted as part of your notification of compliance status, specified in § 63.7950, a signed

statement that you have met the requirements in paragraphs (b)(1) through (3) of this section.

(1) You have installed air emission controls for each individual drain system and junction box according to the requirements in §63.962(a) and (b), and you have records documenting the installation and design.

(2) You will operate the air emission controls according to the requirements in §63.962(b)(5).

(3) You have performed an initial visual inspection of each individual drain system according to the requirements in §63.964(a), and you have records documenting the inspection results.

(c) You must demonstrate initial compliance of each transfer system using covers according to §63.7915(c)(1) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (c)(1) through (3) of this section.

(1) Each transfer system is equipped with covers and closure devices according to the requirements in §63.689(d)(1) through (4), and you have records documenting the design and installation.

(2) You have performed an initial inspection of each cover and its closure devices for defects according to the requirements in §63.695(d)(1) through (5), and you have records documenting the inspection results.

(3) You will operate each cover and its closure devices according to the requirements in §63.689(5).

(d) You must demonstrate initial compliance of each transfer system that consists of hard piping according to §63.7915(c)(2) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (d)(1) and (2) of this section.

(1) You have installed a transfer system that consists entirely of hard piping and meets the requirements in §63.7915(c)(2), and you have records documenting the design and installation.

(2) You have performed an initial inspection of the entire transfer system to verify that all joints or seams between the pipe sections are permanently or semi-permanently sealed (*e.g.*, a welded joint between two sections of metal pipe or a bolted and gasketed flange), and you have records documenting the inspection results.

(e) You must demonstrate initial compliance of each transfer system that is enclosed and vented to a control device according to §63.7915(e)(3) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (e)(1) and (2) of this section.

(1) You have installed a transfer system that is designed and operated such that an internal pressure in the vapor headspace in the enclosure is maintained at a level less than atmospheric pressure when the control device is operating, and you have records documenting the design and installation.

(2) You have met each applicable requirement for demonstrating initial compliance with the emission limitations and work practice standards for a closed vent system and control device in §63.7926.

§63.7917 What are my inspection and monitoring requirements for transfer systems?

(a) If you operate an individual drain system as a transfer system according to §63.7915(b), you must visually inspect each individual drain system at least annually according to the requirements in §63.964(a).

(b) If you operate a transfer system using covers according to §63.7915(c)(1), you must inspect each cover and its closure devices for defects according to the requirements in §63.695(d)(1) through (5).

(c) If you operate a transfer system consisting of hard piping according to §63.7915(c)(2), you must annually inspect the entire pipeline and all joints for leaks and other defects. In the event that a defect is detected, you must repair the leak or defect according to the requirements of paragraph (e) of this section.

(d) If you operate a transfer system that is enclosed and vented to a control device according to §63.7915(c)(3), you must meet requirements in paragraphs (d)(1) and (2) of this section.

(1) You must annually inspect all enclosure components (e.g., enclosure

sections, closure devices, fans) for defects that would prevent an internal pressure in the vapor headspace in the enclosure from continuously being maintained at a level less than atmospheric pressure when the control device is operating. In the event that a defect is detected, you must repair the defect according to the requirements of paragraph (e) of this section.

(2) You must monitor and inspect the closed vent system and control device according to the requirements in § 63.7927 that apply to you.

(e) If you are subject to paragraph (c) or (d) of this section, you must repair all detected defects as specified in paragraphs (e)(1) through (3) of this section.

(1) You must make first efforts at repair of the defect no later than 5 calendar days after detection and repair shall be completed as soon as possible but no later than 45 calendar days after detection except as provided in paragraph (e)(2) of this section.

(2) Repair of a defect may be delayed beyond 45 calendar days if you determine that repair of the defect requires emptying or temporary removal from service of the transfer system and no alternative transfer system is available at the site to accept the material normally handled by the system. In this case, you must repair the defect the next time the process or unit that is generating the material handled by the transfer system stops operation. Repair of the defect must be completed before the process or unit resumes operation.

(3) You must maintain a record of the defect repair according to the requirements specified in § 63.7952.

§ 63.7918 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for transfer systems?

(a) You must demonstrate continuous compliance with the emissions limitations and work practice standards in § 63.7915 applicable to your affected transfer system by meeting the requirements in paragraphs (b) through (e) of this section as applicable to your transfer systems.

(b) You must demonstrate continuous compliance for each individual drain system using controls according to § 63.7915(b) by meeting the requirements in paragraphs (b)(1) through (5) of this section.

(1) Operating and maintaining the air emission controls for individual drain systems according to the requirements in § 63.962.

(2) Visually inspecting each individual drain system at least annually according to the requirements in § 63.964(a).

(3) Repairing defects according to the requirements in § 63.964(b).

(4) Recording the information specified in § 63.965(a).

(5) Keeping records to document compliance with the requirements of this subpart according to the requirements in § 63.7952.

(c) You must demonstrate continuous compliance for each transfer system using covers according to § 63.7915(c)(1) by meeting the requirements in paragraphs (c)(1) through (4) of this section.

(1) Operating and maintaining each cover and its closure devices according to the requirements in § 63.689(d)(1) through (5).

(2) Performing inspections of each cover and its closure devices for defects at least annually according to the requirements in § 63.695(d)(1) through (5).

(3) Repairing defects according to the requirements in § 63.695(5)

(4) Keeping records to document compliance with the requirements of this subpart according to the requirements in § 63.7952.

(d) You must demonstrate continuous compliance for each transfer system that consists of hard piping according to § 63.7915(c)(2) by meeting the requirements in paragraphs (d)(1) through (4) of this section.

(1) Operating and maintaining the pipeline to ensure that all joints or seams between the pipe sections remain permanently or semi-permanently sealed (*e.g.*, a welded joint between two sections of metal pipe or a bolted and gasketed flange).

(2) Inspecting the pipeline for defects at least annually according to the requirements in § 63.7918(c).

(3) Repairing defects according to the requirements in § 63.7918(e).

(4) Keeping records to document compliance with the requirements of this

subpart according to the requirements in §63.7952.

(e) You must demonstrate continuous compliance for each transfer system that is enclosed and vented to a control device according to §63.7915(e)(3) by meeting the requirements in paragraphs (e)(1) through (5) of this section.

(1) Operating and maintaining the enclosure to ensure that the internal pressure in the vapor headspace in the enclosure is maintained continuously at a level less than atmospheric pressure when the control device is operating.

(2) Inspecting the enclosure and its closure devices for defects at least annually according to the requirements in §63.7918(d).

(3) Repairing defects according to the requirements in §63.7918(e).

(4) Meeting each applicable requirement for demonstrating continuous compliance with the emission limitations and work practice standards for a closed vent system and control device in §63.7928.

(5) Keeping records to document compliance with the requirements according to the requirements in §63.7952.

EQUIPMENT LEAKS

§63.7920 What emissions limitations and work practice standards must I meet for equipment leaks?

(a) You must control HAP emissions from each new and existing equipment subject to §63.7887 according to emissions limitations and work practice standards in this section that apply to your affected equipment.

(b) For your affected equipment, you must meet the requirements in either paragraph (b)(1) or (2) of this section.

(1) Control equipment leaks according to all applicable requirements under 40 CFR part 63, subpart TT—National Emission Standards for Equipment Leaks—Control Level 1; or

(2) Control equipment leaks according to all applicable requirements under 40 CFR part 63, subpart UU—National Emission Standards for Equipment Leaks—Control Level 2.

(c) If you use a closed vent system and control device to comply with this section, as an alternative to meeting the standards in §63.1015 or §63.1034 for closed vent systems and control devices, you may elect to meet the requirements in §§63.7925 through 63.7928 that apply to your closed vent system and control device.

(d) As provided in §63.6(g), you may request approval from the EPA to use an alternative to the work practice standards in this section that apply to your equipment. If you request for permission to use an alternative to the work practice standards, you must submit the information described in §63.6(g)(2).

§63.7921 How do I demonstrate initial compliance with the emissions limitations and work practice standards for equipment leaks?

(a) You must demonstrate initial compliance with the emissions limitations and work practice standards in §63.7920 that apply to your affected equipment by meeting the requirements in paragraphs (b) and (c) of this section, as applicable to your affected sources.

(b) If you control equipment leaks according to the requirements under §63.7920(b)(1), you must demonstrate initial compliance if you have met the requirements in paragraphs (b)(1) and (2) of this section.

(1) You include the information required in §63.1018(a)(1) in your notification of compliance status report.

(2) You have submitted as part of your notification of compliance status a signed statement that:

(i) You will meet the requirements in §§63.1002 through 63.1016 that apply to your affected equipment.

(ii) You have identified the equipment subject to control according to the requirements in §63.1003, including equipment designated as unsafe to monitor, and have records supporting the determinations with a written plan for monitoring the equipment according to the requirements in §63.1003(c)(4).

(c) If you control equipment leaks according to the requirements under §63.7920(b)(2), you must demonstrate initial compliance if you have met the requirements in paragraphs (c)(1) and (2) of this section.

(1) You have included the information required in §63.1039(a) in your notification of compliance status report.

(2) You have submitted as part of your notification of compliance status a signed statement that:

(i) You will meet the requirements in §§ 63.1021 through 63.1037 that apply to your affected equipment.

(ii) You have identified the equipment subject to control according to the requirements in § 63.1022, including equipment designated as unsafe to monitor, and have records supporting the determinations with a written plan for monitoring the equipment according to the requirements in § 63.1022(c)(4).

§ 63.7922 How do I demonstrate continuous compliance with the work practice standards for equipment leaks?

(a) You must demonstrate continuous compliance with the emissions limitations and work practice standards in § 63.7920 applicable to your affected equipment by meeting the requirements in paragraphs (b) through (d) of this section that apply to you.

(b) If you control equipment leaks according to the requirements under § 63.7920(b)(1), you must demonstrate continuous compliance by inspecting, monitoring, repairing, and maintaining records according to the requirements in §§ 63.1002 through 63.1018 that apply to your affected equipment.

(c) If you control equipment leaks according to the requirements under § 63.7920(b)(2), you must demonstrate continuous compliance by inspecting, monitoring, repairing, and maintaining records according to the requirements in §§ 63.1021 through 63.1039 that apply to your affected equipment.

(d) You must keep records to demonstrate compliance with the requirements according to the requirements in § 63.7952.

CLOSED VENT SYSTEMS AND CONTROL DEVICES

§ 63.7925 What emissions limitations and work practice standards must I meet for closed vent systems and control devices?

(a) For each closed-vent system and control device you use to comply with requirements in §§ 63.7890 through 63.7922, as applicable to your affected sources, you must meet the emissions limitations and work practice standards in this section.

(b) Whenever gases or vapors containing HAP are vented through the closed-vent system to the control device, the control device must be operating except at those times listed in either paragraph (b)(1) or (2) of this section.

(1) The control device may be bypassed for the purpose of performing planned routine maintenance of the closed-vent system or control device in situations when the routine maintenance cannot be performed during periods that the emission point vented to the control device is shutdown. On an annual basis, the total time that the closed-vent system or control device is bypassed to perform routine maintenance must not exceed 240 hours per each calendar year.

(2) The control device may be bypassed for the purpose of correcting a malfunction of the closed-vent system or control device. You must perform the adjustments or repairs necessary to correct the malfunction as soon as practicable after the malfunction is detected.

(c) For each closed vent system, you must meet the work practice standards in § 63.693(c).

(d) For each control device other than a flare or a control device used to comply with the facility-wide process vent emission limits in § 63.7890(b), you must control HAP emissions to meet either of the emissions limits in paragraphs (d)(1) or (2) of this section except as provided for in paragraph (f) of this section.

(1) Reduce emissions of total HAP listed in Table 1 of this subpart or TOC (minus methane and ethane) from each control device by 95 percent by weight; or

(2) Limit the concentration of total HAP listed in Table 1 of this subpart or TOC (minus methane and ethane) from each combustion control device (a thermal incinerator, catalytic incinerator, boiler, or process heater) to 20 ppmv or less on a dry basis corrected to 3 percent oxygen.

(e) If you use a flare for your control device, then you must meet the requirements for flares in § 63.11(b).

(f) If you use a process heater or boiler for your control device, then as alternative to meeting the emissions limits in paragraph (d) of this section you may choose to comply with one of the work practice standards in paragraphs (f)(1) through (3) of this section.

(1) Introduce the vent stream into the flame zone of the boiler or process heater and maintain the conditions in the combustion chamber at a residence time of 0.5 seconds or longer and at a temperature of 760 °C or higher; or

(2) Introduce the vent stream with the fuel that provides the predominate heat input to the boiler or process heater (*i.e.*, the primary fuel); or

(3) Introduce the vent stream to a boiler or process heater for which you either have been issued a final permit under 40 CFR part 270 and complies with the requirements of 40 CFR part 266, subpart H—Hazardous Waste Burned in Boilers and Industrial Furnaces; or has certified compliance with the interim status requirements of 40 CFR part 266, subpart H.

(g) For each control device other than a flare, you must meet each operating limit in paragraphs (g)(1) through (6) of this section that applies to your control device.

(1) If you use a regenerable carbon adsorption system, you must:

(i) Maintain the hourly average total regeneration stream mass flow during the adsorption bed regeneration cycle greater than or equal to the stream mass flow established in the design evaluation or performance test.

(ii) Maintain the hourly average temperature of the adsorption bed during regeneration (except during the cooling cycle) greater than or equal to the temperature established during the design evaluation or performance test.

(iii) Maintain the hourly average temperature of the adsorption bed after regeneration (and within 15 minutes after completing any cooling cycle) less than or equal to the temperature established during the design evaluation.

(iv) Maintain the frequency of regeneration greater than or equal to the frequency established during the design evaluation.

(2) If you use a nonregenerable carbon adsorption system, you must maintain the hourly average temperature of the adsorption bed less than or equal to the temperature established during the design evaluation or performance test.

(3) If you use a condenser, you must maintain the daily average condenser exit temperature less than or equal to the temperature established during the design evaluation or performance test.

(4) If you use a thermal incinerator, you must maintain the daily average firebox temperature greater than or equal to the temperature established in the design evaluation or during the performance test.

(5) If you use a catalytic incinerator, you must maintain the daily average temperature difference across the catalyst bed greater than or equal to the minimum temperature difference established during the performance test or design evaluation.

(6) If you use a boiler or process heater to comply with an emission limit in paragraph (d) of this section, you must maintain the daily average firebox temperature within the operating level established during the design evaluation or performance test.

(h) If you use a carbon adsorption system as your control, you must meet each work practice standard in paragraphs (h)(1) through (3) of this section that applies to your control device.

(1) If you use a regenerable carbon adsorption system, you must:

(i) Replace the existing adsorbent in each segment of the bed with an adsorbent that meets the replacement specifications established during the design evaluation before the age of the adsorbent exceeds the maximum allowable age established during the design evaluation.

(ii) Follow the disposal requirements for spent carbon in §63.693(d)(4).

(2) If you use a nonregenerable carbon adsorption system, you must:

(i) Replace the existing adsorbent in each segment of the bed with an adsorbent that meets the replacement specifications established during the design evaluation before the age of the adsorbent exceeds the maximum allowable age established during the design evaluation.

(ii) Meet the disposal requirements for spent carbon in §63.693(d)(4)(ii).

(3) If you use a nonregenerative carbon adsorption system, you may choose to comply with the requirements in paragraphs (h)(3)(i) and (ii) of this section as an alternative to the requirements in paragraph (h)(2) of this section. You must:

(i) Immediately replace the carbon canister or carbon in the control device when the monitoring device indicates breakthrough has occurred according to the requirements in §63.693(d)(4)(iii)(A), or replace the carbon canister or carbon in the control device at regular intervals according to the requirements in §63.693(d)(4)(iii)(B).

(ii) Follow the disposal requirements for spent carbon in §63.693(d)(4)(ii).

(i) If you use a catalytic incinerator, you must replace the existing catalyst bed with a bed that meets the replacement specifications before the age of the bed exceeds the maximum allowable age established in the design evaluation or during the performance test.

(j) As provided in §63.6(g), you may request approval from the EPA to use an alternative to the work practice standards in this section that apply to your closed vent systems and control devices. If you request for permission to use an alternative to the work practice standards, you must submit the information described in §63.6(g)(2).

§63.7926 How do I demonstrate initial compliance with the emission limitations and work practice standards for closed vent systems and control devices?

(a) You must demonstrate initial compliance with the emissions limitations and work practice standards in this subpart applicable to your closed vent system and control device by meeting the requirements in paragraphs (b) through (h) of this section that apply to your closed vent system and control device.

(b) You must demonstrate initial compliance with the closed vent system work practice standards in §63.7925(c) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (b)(1) and (2) of this section.

(1) You have installed a closed vent system that meets the requirements in §63.695(c)(1) and (2), and you have records documenting the equipment design and installation.

(2) You have performed the initial inspection of the closed vent system according to the requirements in §63.695(c)(1)(i) or (ii), and you have records documenting the inspection results.

(c) You must demonstrate initial compliance of each control device subject to the emissions limits in §63.7925(d) with the applicable emissions limit in §63.7925(d) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (c)(1) and (2) of this section that apply to you.

(1) For the emissions limit in §63.7925(d)(1), the emissions of total HAP listed in Table 1 of this subpart or TOC (minus methane and ethane) from the control device, measured or determined according to the procedures for performance tests and design evaluations in §63.7941, are reduced by at least 95 percent by weight.

(2) For the emissions limit in §63.7925(d)(2), the concentration of total HAP listed in Table 1 of this subpart or TOC (minus methane and ethane) from the combustion control device, measured by a performance test or determined by a design evaluation according to the procedures in §63.7941, do not exceed 20 ppmv on a dry basis corrected to 3 percent oxygen.

(d) You must demonstrate initial compliance of each control device subject to operating limits in §63.7925(g) with the applicable limits if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (d)(1) and (2) of this section.

(1) You have established an appropriate operating limit(s) for each of the operating parameter applicable to your control device as specified in §63.7925(g)(1) through (6).

(2) You have a record of the applicable operating parameter data during the performance test or design evaluation during which the emissions met the applicable limit.

(e) You must demonstrate initial compliance with the spent carbon replacement and disposal work practice standards for carbon adsorption systems in §63.7925(h) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you will comply with each work practice standard that applies to your carbon adsorption system.

(f) You must demonstrate initial compliance with the catalyst replacement work practice standards for catalytic incinerators in §63.7925(i) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you will comply with the specified work practice standard.

(g) You must demonstrate initial compliance of each flare with the work practice standards in §63.7925(e) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (g)(1) through (3) of this section.

(1) Each flare meets the requirements in §63.11(b).

(2) You have performed a visible emissions test, determined the net heating value of gas being combusted, and determined the flare exit velocity as required in §63.693(h)(2).

(3) You will operate each flare according to the requirements in §63.11(b).

(h) You must demonstrate initial compliance of each boiler or process heater with the work practice standards in §63.7925(f) if you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (h)(1) through (3) of this section.

(1) For the work practice standards in §63.7925(f)(1), you have records documenting that the boiler or process heater is designed to operate at a residence time of 0.5 seconds or greater and maintain the combustion zone temperature at 760 °C or greater.

(2) For the work practice standard in §63.7925(f)(2), you have records documenting that the vent stream is introduced with the fuel according to the requirements in §63.693(g)(1)(iv), or that the vent stream is introduced to a boiler or process heater that meets the requirements in §63.693(g)(1)(v).

(3) For the work practice standard in §63.7925(f)(3), you have records documenting you either have been issued a final permit under 40 CFR part 270 and your boiler or process heater complies with the requirements of 40 CFR part 266, subpart H—Hazardous Waste Burned in Boilers and Industrial Furnaces; or has been certified in compliance with the interim status requirements of 40 CFR part 266, subpart H.

§63.7927 What are my inspection and monitoring requirements for closed vent systems and control devices?

(a) You must comply with the requirements in paragraphs (a)(1) and (2) of this section for each closed vent system.

(1) You must monitor and inspect each closed vent system according to the requirements in either paragraph (a)(1)(i) or (ii) of this section.

(i) You must monitor, inspect, and repair defects according to the requirements in §63.695(c)(1)(ii) through (c)(3); or

(ii) You must monitor and inspect the closed vent system according to the requirements in §63.172(f) through (j) and record the information in §63.181.

(2) If your closed vent system includes a bypass device, you must meet the requirements in either paragraph (a)(2)(i) or (ii) of this section.

(i) Use a flow indicator to determine if the presence of flow according to the requirements in §63.693(c)(2)(i); or

(ii) Use a seal or locking device and make monthly inspections as required by §63.693(c)(2)(ii).

(b) If you use a regenerable carbon adsorption system, you must meet the requirements in paragraphs (b)(1) through (3) of this section.

(1) Use a continuous parameter monitoring system (CPMS) to measure and record the hourly average total regeneration stream mass flow during each carbon adsorption cycle.

(2) Use a CPMS to measure and record the hourly average temperature of the adsorption bed during regeneration (except during the cooling cycle).

(3) Use a CPMS to measure and record the hourly average temperature of the adsorption bed after regeneration (and within 15 minutes of after completing any cooling cycle).

(c) If you use a nonregenerable carbon adsorption system, you must use a CPMS to measure and record the hourly average temperature of the adsorption bed or you must monitor the concentration of organic compounds in the exhaust vent stream according to the requirements in § 63.693(d)(4)(iii)(A).

(d) If you use a condenser, you must use a CPMS to measure and record the hourly average condenser exit temperature and determine and record the daily average condenser exit temperature.

(e) If you use a thermal incinerator, you must use a CPMS to measure and record the hourly average firebox temperature and determine and record the daily average firebox temperature.

(f) If you use a catalytic incinerator, you must use a CPMS with two temperature sensors to measure and record the hourly average temperature at the inlet of the catalyst bed, the hourly average temperature at the outlet of the catalyst bed, the hourly average temperature difference across the catalyst bed, and to determine and record the daily average temperature difference across the catalyst bed.

(g) If you use a boiler or process heater to meet an emission limitation, you must use a CPMS to measure and record the hourly average firebox temperature and determine and record the daily average firebox temperature.

(h) If you use a flare, you must monitor the operation of the flare using a heat sensing monitoring device according to the requirements in § 63.693(h)(3).

(i) If you introduce the vent stream into the flame zone of a boiler or process heater according to the requirements in § 63.7925(f)(1), you must use a CPMS to measure and record the combustion zone temperature.

§ 63.7928 How do I demonstrate continuous compliance with the emissions limitations and work practice standards for closed vent systems and control devices?

(a) You must demonstrate continuous compliance with the emissions limitations and work practice standards in this subpart applicable to your closed vent system and control device by meeting the requirements in paragraphs (b) through (j) of this section as applicable to your closed vent system and control device.

(b) You must demonstrate continuous compliance with the closed vent system work practice standards in § 63.7925(c) by meeting the requirements in paragraphs (b)(1) through (7) of this section.

(1) For a closed vent system designed to operate with no detectable organic emissions, visually inspecting the closed vent system at least annually, monitoring after a repair or replacement using the procedures in § 63.694(k), and monitoring at least annually according to the requirements in § 63.695(c)(1)(ii).

(2) For a closed vent system designed to operate below atmospheric pressure, visually inspecting the closed vent system at least annually according to the requirements in § 63.695(c)(2)(ii).

(3) Repairing defects according to the requirements in § 63.695(c)(3).

(4) Keeping records of each inspection that include the information in paragraphs (b)(4)(i) through (iii) of this section:

(i) A closed vent system identification number (or other unique identification description you select).

(ii) Date of each inspection.

(iii) If a defect is detected during an inspection, the location of the defect, a description of the defect, the date of detection, the corrective action taken to repair the defect, and if repair is delayed, the reason for any delay and the date completion of the repair is expected.

(5) If you elect to monitor the closed vent system according to the requirements in § 63.172(f) through (j), recording the information in § 63.181.

(6) If the closed vent system is equipped with a flow indicator, recording the information in § 63.693(c)(ii)(i).

(7) If the closed vent system is equipped with a seal or locking device, visually inspecting the seal or closure mechanism at least monthly according to the requirements in § 63.693(c)(ii)(i), and recording the results of each inspection.

(c) You must demonstrate continuous compliance of each control device subject to the emissions limits in §63.7925(d) with the applicable emissions limit in §63.7925(d) by meeting the requirements in paragraphs (c)(1) and (2) of this section.

(1) For the emission limit in §63.7925(d)(1), maintaining the reduction in emissions of total HAP listed in Table 1 of this subpart or TOC (minus methane and ethane) from the control device at 95 percent by weight or greater.

(2) For the emission limit in §63.7925(d)(2), maintaining the concentration of total HAP listed in Table 1 of this subpart or TOC (minus methane and ethane) from the control device at 20 ppmv or less.

(d) You must demonstrate continuous compliance of each control device subject to operating limits in §63.7925(g) with the applicable limits by meeting the requirements in paragraphs (d)(1) through (4) of this section.

(1) Maintaining each operating limit according to the requirements in §63.7925(g) as applicable to the control device.

(2) Monitoring and inspecting each control device according to the requirements in §63.7927(b) through (i) as applicable to the control device.

(3) Operating and maintaining each continuous monitoring system according to the requirements in §63.7945, and collecting and reducing data according to the requirements in §63.7946.

(4) Keeping records to document compliance with the requirements of this subpart according to the requirements in §63.7952.

(e) You must demonstrate continuous compliance with the spent carbon replacement and disposal work practice standards for regenerable carbon adsorption systems in §63.7925(h)(1) by meeting the requirements in paragraphs (e)(1) through (3) of this section.

(1) Replacing the adsorbent as required by §63.7925(h)(1)(i).

(2) Following the disposal requirements for spent carbon in §63.693(d)(4)(ii).

(3) Keeping records to document compliance with the requirements of the work practice standards.

(f) You must demonstrate continuous compliance with the spent carbon replacement and disposal work practice standards for nonregenerable carbon adsorption systems in §63.7925(h)(2) by meeting the requirements in paragraphs (f)(1) through (3) of this section.

(1) Replacing the adsorbent as required by the work practice standard in §63.7925(h)(2)(i).

(2) Following the disposal requirements for spent carbon in §63.693(d)(4)(ii).

(3) Keeping records to document compliance with the requirements of the work practice standards.

(g) You must demonstrate continuous compliance with the spent carbon replacement and disposal work practice standards for nonregenerable carbon adsorption systems in §63.7925(h)(3) by meeting the requirements in paragraphs (g)(1) through (3) of this section.

(1) Monitoring the concentration level of the organic compounds in the exhaust vent for the carbon adsorption system as required in §63.7927(c), immediately replacing the carbon canister or carbon in the control device when breakthrough is indicated by the monitoring device, and recording the date of breakthrough and carbon replacement. Or, you must replace the carbon canister or carbon in the control device at regular intervals and record the date of carbon replacement.

(2) Following the disposal requirements for spent carbon in §63.693(d)(4)(ii).

(3) Keeping records to document compliance with the requirements of the work practice standards.

(h) You must demonstrate continuous compliance with the catalyst replacement work practice standards for catalytic incinerators in §63.7925(i) by meeting the requirements in paragraphs (h)(1) and (2) of this section.

(1) Replacing the existing catalyst bed as required in §63.7925(i).

(2) Keeping records to document compliance with the requirements of the work practice standards.

(i) You must demonstrate continuous compliance of each flare with the work practice standards in §63.7925(e) by meeting the requirements in paragraphs (i)(1) through (5) of this section.

(1) Operating the flare with no visible emissions except for up to 5 minutes in any 2 consecutive hours according to the requirements in § 63.11(b)(4).

(2) Monitoring the presence of a pilot flare according to the requirements in § 63.7927(h) and maintaining a pilot flame and flare flame at all times that emissions are not vented to the flare according to the requirements in § 63.11(b)(5).

(3) Operating the flare with an exit velocity according to the requirements in § 63.11(b)(6) through (8).

(4) Operating the flare with a net heating value of the gas being combusted according to the requirements in § 63.11(b)(6)(ii).

(5) Keeping records to document compliance with the requirements of the work practice standards.

(j) You must demonstrate continuous compliance of each boiler or process heater with the work practice standards in § 63.7925(f) by meeting the requirements in paragraphs (j)(1) through (3) of this section.

(1) For the work practice standards in § 63.7925(f)(1), you must demonstrate continuous compliance by meeting the requirements in paragraphs (j)(1)(i) through (iv).

(i) Maintaining conditions in the combustion chamber at a residence time of 0.5 seconds or longer and at a combustion zone temperature at 760 °C or greater whenever the vent stream is introduced to the flame zone of the boiler or process heater.

(ii) Monitoring each boiler or process heater according to the requirements in § 63.7927(i).

(iii) Operating and maintaining each continuous monitoring system according to the requirements in § 63.7945, and collecting and reducing data according to the requirements in § 63.7946.

(iv) Keeping records to document compliance with residence time design requirement.

(2) For the work practice standards in § 63.7925(f)(2), you maintain the boiler or process heater operations such that the vent stream is introduced with the fuel according to the requirements in § 63.693(g)(1)(iv), or that the vent stream is introduced to a boiler or process heater that meets the requirements in § 63.693(g)(1)(v).

(3) For the work practice standard in § 63.7925(f)(3), you remain in compliance with all terms and conditions of the final permit under 40 CFR part 270 and your boiler or process heater complies with the requirements of 40 CFR part 266, subpart H—Hazardous Waste Burned in Boilers and Industrial Furnaces; or in compliance with the interim status requirements of 40 CFR part 266, subpart H, as applicable to your boiler or process heater.

GENERAL COMPLIANCE REQUIREMENTS

§ 63.7935 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emissions limitations (including operating limits) and the work practice standards in this subpart at all times, except during periods of startup, shutdown, and malfunction.

(b) You must always operate and maintain your affected source, including air pollution control and monitoring equipment, according to the provisions in § 63.6(e)(1)(i).

(c) You must develop a written startup, shutdown, and malfunction plan (SSMP) according to the provisions in § 63.6(e)(3).

(d) [Reserved]

(e) You must report each instance in which you did not meet each emissions limitation and each operating limit that applies to you. This includes periods of startup, shutdown, and malfunction. You must also report each instance in which you did not meet the requirements for work practice standards that apply to you. These instances are deviations from the emissions limitations and work practice standards in this subpart. These deviations must be reported according to the requirements in § 63.7951.

(f) Consistent with §§ 63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with § 63.6(e)(1). We will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in § 63.6(e).

(g) For each monitoring system required in this section, you must develop and make available for inspection by the permitting authority, upon request, a site-specific monitoring plan that addresses the following:

(1) Installation of the continuous monitoring system sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the exhaust emissions (*e.g.*, on or downstream of the last control device).

(2) Performance and equipment specifications for the sample interface, the pollutant concentration or parametric signal analyzer, and the data collection and reduction system.

(3) Performance evaluation procedures and acceptance criteria (*e.g.*, calibrations).

(h) In your site-specific monitoring plan, you must also address the following:

(1) Ongoing operation and maintenance procedures according to the general requirements of §63.8(c)(1), (3), (4)(ii), (7), and (8).

(2) Ongoing data quality assurance procedures according to the general requirements of §63.8(d).

(3) Ongoing recordkeeping and reporting procedures according to the general requirements of §63.10(c), (e)(1), and (e)(2)(i).

(i) You must operate and maintain the continuous monitoring system according to the site-specific monitoring plan.

(j) You must conduct a performance evaluation of each continuous monitoring according to your site-specific monitoring plan.

[68 FR 58190, Oct. 8, 2003, as amended at 71 FR 20468, Apr. 20, 2006]

§63.7936 What requirements must I meet if I transfer remediation material off-site to another facility?

(a) If you transfer to another facility a remediation material generated by your remediation activities and having an average total VOHAP concentration equal to or greater than 10 ppmw (as determined using the procedures specified in §63.7943), then you must transfer the remediation material to a facility that meets the requirements in paragraph (b) of this section. You must record the name, street address, and telephone number of the facility where you send this remediation material.

(b) You may elect to transfer the remediation material to one of the following facilities:

(1) A facility where your remediation material will be directly disposed in a landfill or other land disposal unit according to all applicable Federal and State requirements.

(2) A facility subject to 40 CFR part 63, subpart DD where the exemption under §63.680(b)(2)(iii) is waived and air emissions from the management of your remediation material at the facility are controlled according to all applicable requirements in the subpart for an off-site material. Prior to sending your remediation material, you must obtain a written statement from the owner or operator of the facility to which you send your remediation material acknowledging that the exemption under §63.680(b)(2)(iii) will be waived for all remediation material received at the facility from you and your material will be managed as an off-site material at the facility according to all applicable requirements. This statement must be signed by the responsible official of the receiving facility, provide the name and address of the receiving facility, and a copy sent to the appropriate EPA Regional Office at the addresses listed in 40 CFR 63.13.

(3) A facility where your remediation material will be managed according to all applicable requirements under this Subpart.

(i) You must prepare and include a notice with each shipment or transport of remediation material from your site. This notice must state that the remediation material contains organic HAP that are to be treated according to the provisions of this subpart. When the transport is continuous or ongoing (for example, discharge to a publicly owned treatment works), the notice must be submitted to the receiving facility owner or operator initially and whenever there is a change in the required treatment.

(ii) You may not transfer the remediation material unless the owner or operator of the facility receiving your remediation material has submitted to

the EPA a written certification that he or she will manage remediation material received from you according to the requirements of §§63.7885 through 63.7957. The receiving facility owner or operator may revoke the written certification by sending a written statement to the EPA and to you providing at least 90 days notice that they rescind acceptance of responsibility for compliance with the regulatory provisions listed in this section. Upon expiration of the notice period, you may not transfer your remediation material to the facility.

(iii) By providing the written certification to the EPA, the receiving facility owner or operator accepts responsibility for compliance with the regulatory provisions listed in paragraph (b)(3) of this section with respect to any shipment of remediation material covered by the written certification. Failure to abide by any of those provisions with respect to such shipments may result in enforcement action by the EPA against the certifying entity according to the enforcement provisions applicable to violations of these provisions by owners or operators of sources.

(iv) Written certifications and revocation statements to the EPA from the receiving facility owner or operator must be signed by the responsible official of the receiving facility, provide the name and address of the receiving facility, and a copy sent to the appropriate EPA Regional Office at the addresses listed in 40 CFR 63.13. Such written certifications are not transferable.

(c) Acceptance by a facility owner or operator of remediation material from a site remediation subject to this Subpart does not, by itself, require the facility owner or operator to obtain a title V permit under 40 CFR 70.3 or 40 CFR 71.3.

§ 63.7937 How do I demonstrate initial compliance with the general standards?

(a) You must demonstrate initial compliance with the general standards in §§63.7884 through 63.7887 that apply to your affected sources by meeting the requirements in paragraphs (b) through (d) of this section, as applicable to you.

(b) You must demonstrate initial compliance with the general standards in §63.7885 that apply to your affected process vents by meeting the requirements in paragraphs (b)(1) through (4) of this section, as applicable to your process vents.

(1) If HAP emissions are controlled from the affected process vents according to the emission limitations and work practice standards specified in §63.7885(b)(1), you have met the initial compliance requirements in §63.7891.

(2) If the remediation material treated or managed by the process vented through the affected process vents has an average total VOHAP less than 10 ppmw according to §63.7885(b)(2), you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have determined, according to the procedures §63.7943, and recorded the average VOHAP concentration of the remediation material placed in the affected remediation material management unit.

(3) If HAP emissions are controlled from the affected process vents to meet standards in another subpart under 40 CFR part 61 or 40 CFR part 63 according to §63.7885(b)(3), you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (b)(3)(i) and (ii) of this section.

(i) You include in your statement the citations for the specific emission limitations and work practice standards that apply to the process vents under the subpart in 40 CFR part 61 or 40 CFR part 63 that the vents are also subject.

(ii) You are complying with all applicable emissions limitations and work practice standards specified by the applicable subpart.

(4) For each process vent exempted according to §63.7885(c), you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (b)(4)(i) and (ii) of this section.

(i) You identify in your statement each process vent that qualifies for an exemption and the exemption conditions in §63.7885(c)(1)(i) or (ii) that apply to each exempted process vent.

(ii) You have performed the measurements and prepared the documentation required in §63.7885(c)(2) that demonstrates that each exempted process vent stream meets the applicable exemption conditions in §63.7885(c)(1).

(c) You must demonstrate initial compliance with the general standards in §63.7886 that apply to your affected remediation material management units by meeting the requirements in paragraphs (c)(1) through (6) of this section, as applicable to your remediation material management units.

(1) If the remediation material management unit uses air pollution controls according to the standards specified in §63.7886(b)(1), you have met the initial compliance requirements applicable to the remediation material management unit in §§63.7896, 63.7901, 63.7906, 63.7911, or 63.7816.

(2) If the remediation material managed in the affected remediation material managements has an average total VOHAP less than 500 ppmw according to §63.7886(b)(2), you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have determined, according to the procedures §63.7943, and recorded the average VOHAP concentration of the remediation material placed in the affected remediation material management unit.

(3) If HAP emissions are controlled from the affected remediation material management units to meet standards in another subpart under 40 CFR part 61 or 40 CFR part 63 according to §63.7886(b)(3), you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (c)(3)(i) and (ii) of this section.

(i) You include in your statement the citations for the specific emission limitations and work practice standards that apply to the remediation material management units under the subpart in 40 CFR part 61 or 40 CFR part 63 that the units are also subject.

(ii) You are complying with all applicable emissions limitations and work practice standards specified by the applicable subpart.

(4) If HAP emissions are controlled from the affected remediation material management unit that is an open tank or surface impoundment used for a biological treatment process according to §63.7886(b)(4), you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (c)(4)(i) and (ii) of this section.

(i) You have performed the measurements and prepared the documentation required in §63.7886(b)(4)(i) that demonstrates that each unit meets the applicable performance levels.

(ii) You will monitor the biological treatment process conducted in each unit according the requirements in §63.7886(4)(i).

(5) For each remediation material management unit used for cleanup of radioactive mixed waste and exempted according to §63.7886(c), you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (c)(5)(i) and (ii) of this section.

(i) You include in your statement the citations for the specific requirements that apply to the remediation material management units under regulations, directives, and other requirements under the Atomic Energy Act, the Nuclear Waste Policy Act, or the Waste Isolation Pilot Plant Land Withdrawal Act.

(ii) You are complying with all requirements that apply to the remediation material management units under the applicable regulations or directives.

(6) For each remediation material management unit exempted according to §63.7886(d), you have submitted as part of your notification of compliance status, specified in §63.7950, a signed statement that you have met the requirements in paragraphs (c)(6)(i) and (ii) of this section.

(i) You have designated according to the requirements in §63.7886(d)(1) each of the remediation material management units you are selecting to be exempted.

(ii) You have performed an initial determination and prepared the documentation required in §63.7886(d)(2) that demonstrates that the total annual HAP quantity (based on the HAP

listed in Table 1 of this subpart) in the remediation material placed in all of the designated exempted remediation material management units will be less than 1 Mg/yr.

(d) You must demonstrate initial compliance with the general standards in § 63.7887 that apply to your affected equipment leak sources by meeting the requirements in § 63.7921.

§ 63.7938 How do I demonstrate continuous compliance with the general standards?

(a) You must demonstrate continuous compliance with the general standards in §§ 63.7884 through 63.7887 that apply to your affected sources by meeting the requirements in paragraphs (b) through (d) of this section, as applicable to you.

(b) You have demonstrated continuous compliance with the general standards in § 63.7885 that apply to your affected process vents by meeting the requirements in paragraphs (b)(1) through (4) of this section, as applicable to your process vents.

(1) If HAP emissions are controlled from the affected process vents according to the emission limitations and work practice standards specified in § 63.7885(b)(1), you must demonstrate continuous compliance by meeting the requirements in § 63.7893.

(2) If the remediation material treated or managed by the process vented through the affected process vents has an average total VOHAP less than 10 ppmw according to § 63.7885(b)(2), you must demonstrate continuous compliance by performing a new determination and preparing new documentation as required in § 63.7886(c)(2) to show that the total VOHAP concentration of the remediation material remains less than 10 ppmw.

(3) If HAP emissions are controlled from the affected process vents to meet standards in another subpart under 40 CFR part 61 or 40 CFR part 63 according to § 63.7885(b)(3), you must demonstrate continuous compliance by complying with all applicable emissions limitations and work practice standards specified by the applicable subpart.

(4) For each process vent exempted according to § 63.7885(c), you must demonstrate continuous compliance by performing new measurements and preparing new documentation as required in § 63.7885(c)(2) that demonstrates that each exempted process vent stream meets the applicable exemption conditions in § 63.7885(c)(1).

(c) You must demonstrate continuous compliance with the general standards in § 63.7886 that apply to your affected remediation material management units by meeting the requirements in paragraphs (c)(1) through (6) of this section, as applicable to your remediation material management units.

(1) If the remediation material management unit uses air pollution controls according to the standards specified in § 63.7886(b)(1), you must demonstrate continuous compliance by meeting the requirements applicable to the remediation material management unit in §§ 63.7898, 63.7903, 63.7908, 63.7913, or 63.7818.

(2) If the remediation material managed in the affected remediation material managements has an average total VOHAP concentration less than 500 ppmw according to § 63.7886(b)(2), you must demonstrate continuous compliance by performing a new determination and preparing new documentation as required in § 63.7886(c)(2) to show that the total VOHAP concentration of the remediation material remains less than 500 ppmw.

(3) If HAP emissions are controlled from the affected remediation material management units to meet standards in another subpart under 40 CFR part 61 or 40 CFR part 63 according to § 63.7886(b)(3), you must demonstrate continuous compliance by meeting all applicable emissions limitations and work practice standards specified by the applicable subpart.

(4) If HAP emissions are controlled from the affected remediation material management unit that is an open tank or surface impoundment used for a biological treatment process according to § 63.7886(b)(4), you must demonstrate continuous compliance by meeting the requirements in paragraphs (c)(4)(i) and (ii) of this section.

(i) Performing new measurements and preparing new documentation as

required in §63.7886(4)(i) that demonstrates that each unit meets the applicable performance levels.

(ii) Monitoring the biological treatment process conducted in each unit according the requirements in §63.7886(4)(i).

(5) For each remediation material management unit used for cleanup of radioactive mixed waste and exempted according to §63.7886(c), you must demonstrate continuous compliance by meeting all requirements that apply to the remediation material management units under the applicable regulations or directives.

(6) For each remediation material management unit exempted according to §63.7886(d), you must demonstrate continuous compliance by performing new measurements and preparing new documentation as required in §63.7886(d)(2) to show that the total annual HAP quantity (based on the HAP listed in Table 1 of this subpart) in the remediation material placed in all of the designated exempted remediation material management units remains less than 1 Mg/yr.

(d) You have demonstrated continuous compliance with the general standards in §63.7887 that apply to your affected equipment leak sources by meeting the requirements in §63.7923.

PERFORMANCE TESTS

§63.7940 By what date must I conduct performance tests or other initial compliance demonstrations?

(a) You must conduct a performance test or design evaluation for each existing affected source within 180 calendar days after the compliance date that is specified in §63.7883.

(b) For each work practice standard that applies to you where initial compliance is not demonstrated using a performance test or design evaluation, you must demonstrate initial compliance within 30 calendar days after the compliance date that is specified in §63.7883 for your affected source.

(c) For new sources, you must conduct initial performance tests and other initial compliance demonstrations according to the provisions in §63.7(a)(2) (i) and (ii).

§63.7941 How do I conduct a performance test, design evaluation, or other type of initial compliance demonstration?

(a) You must conduct a performance test or design evaluation to demonstrate initial compliance for each new or existing affected source that is subject to an emission limit in this subpart. You must report the results of the performance test or design evaluation according to the requirements in §63.7950(e)(1).

(b) If you choose to conduct a performance test to demonstrate initial compliance, you must conduct the test according to the requirements in §63.7(e)(1) and paragraphs (b) (1) through (5) of this section.

(1) You must conduct three separate test runs for each performance test required in this section, as specified in §63.7(e)(3). Each test run must last at least 1 hour.

(2) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in §63.7(e)(1).

(3) You must conduct each performance test using the test methods and procedures in §63.694(l).

(4) Follow the procedures in paragraphs (b)(4)(i) through (iii) of this section to determine compliance with the facility-wide total organic mass emissions rate in §63.7890(a)(1)(i).

(i) Determine compliance with the total organic mass flow rate using Equation 1 of this section as follows:

$$E_h = \left(0.0416 \times 10^{-6}\right) Q_{sd} \sum_{i=1}^{n} \left(C_i \times MW_i\right) \qquad \text{(Eq. 1)}$$

Where:

E_h = Total organic mass flow rate, kg/h;

Q_{sd} = Volumetric flow rate of gases entering or exiting control device (or exiting the

process vent if no control device is used), as determined by Method 2 of 40 CFR part 60, appendix A, dscm/h;

n = Number of organic compounds in the vent gas;

C_i = Organic concentration in ppm, dry basis, of compound i in the vent gas, as determined by Method 18 of 40 CFR part 60, appendix A;

MW_i = Molecular weight of organic compound i in the vent gas,kg/kg-mol;

(ii) Determine compliance with the annual total organic emissions rate using Equation 2 of this section as follows:

$$E_A = E_h \times H \qquad \text{(Eq. 2)}$$

Where:

E_A = Total organic mass emissions rate, kilograms per year;

E_h = Total organic mass flow rate for the process vent, kg/h;

H = Total annual hours of operation for the affected unit, h.

(iii) Determine compliance with the total organic emissions limit from all affected process vents at the facility by summing the total hourly organic mass emissions rates (E_h as determined in Equation 1 of this section) and summing the total annual organic mass emissions rates (E_A, as determined in Equation 2 of this section) for all affected process vents at the facility.

(5) Determine compliance with the 95 percent reduction limit in § 63.7890(a)(2)(i) for the combination of all affected process vents at the facility using Equations 3 and 4 of this section to calculate control device inlet and outlet concentrations and Equation 5 of this section to calculate control device emission reductions for process vents as follows:

$$E_i = K_2\left(\sum_{j=1}^{n} C_{ij}M_{ij}\right)Q_i \qquad \text{(Eq. 3)}$$

$$E_o = K_2\left(\sum_{j=1}^{n} C_{oj}M_{oj}\right)Q_o \qquad \text{(Eq. 4)}$$

Where:

C_{ij}, C_{oj} = Concentration of sample component j of the gas stream at the inlet and outlet of the control device, dry basis, parts per million by volume. For uncontrolled vents, $C_{ij} = C_{oj}$ and equal the concentration exiting the vent;

E_i, E_o = Mass rate of total organic compounds (TOC) (minus methane and ethane) or total HAP, from Table 1 of this subpart, at the inlet and outlet of the control device, respectively, dry basis, kilogram per hour. For uncontrolled vents, $E_i = E_o$ and equal the concentration exiting the vent;

M_{ij}, M_{oj} = Molecular weight of sample component j of the gas stream at the inlet and outlet of the control device, respectively, gram/gram-mole. For uncontrolled vents, $M_{ij} = M_{oj}$ and equal the gas stream molecular weight exiting the vent;

Q_i, Q_o = Flowrate of gas stream at the inlet and outlet of the control device, respectively, dry standard cubic meters per minute (dscm/min). For uncontrolled vents, $Q_i = Q_o$ and equals the flowrate exiting the vent;

K_2 = Constant, 2.494×10^{-6} (parts per million)$^{-1}$ (gram-mole per standard cubic meter)(kilogram/gram)(minute/hour, where standard temperature (gram-mole per standard cubic meter) is 20 °C);

n = the number of components in the sample.

$$R_v = \frac{\sum_{j=1}^{n} E_i - \sum_{j=1}^{n} E_o}{\sum_{j=1}^{n} E_i} \times 100 \qquad \text{(Eq. 5)}$$

Where:

R_v = Overall emissions reduction for all affected process vents, percent

E_i = Mass rate of TOC (minus methane and ethane) or total HAP, from Table 1 of this subpart, at the inlet to the control device, or exiting the vent for uncontrolled vents, as calculated in this section, kilograms TOC per hour or kilograms HAP per hour;

E_o = Mass rate of TOC (minus methane and ethane) or total HAP, from Table 1 of this subpart, at the outlet to the control device, or exiting the vent for uncontrolled vents, as calculated in this section, kilograms TOC per hour or kilograms HAP per hour. For vents without a control device, $E_o = E_i$;

n = number of affected source process vents.

(c) If you use a carbon adsorption system, condenser, vapor incinerator, boiler, or process heater to meet an emission limit in this subpart, you may choose to perform a design evaluation to demonstrate initial compliance instead of a performance test. You must perform a design evaluation according to the general requirements in § 63.693(b)(8) and the specific requirements in § 63.694(d)(2)(ii) for a carbon

adsorption system (including establishing carbon replacement schedules and associated requirements), §63.694(e)(2)(ii) for a condenser, §63.694(f)(2)(ii) for a vapor incinerator, or §63.694(g)(2)(i)(B) for a boiler or process heater.

(d) During the performance test or design evaluation, you must collect the appropriate operating parameter monitoring system data, average the operating parameter data over each test run, and set operating limits, whether a minimum or maximum value, based on the average of values for each of the three test runs. If you use a control device design analysis to demonstrate control device performance, then the minimum or maximum operating parameter value must be established based on the control device design analysis and supplemented, as necessary, by the control device manufacturer recommendations or other applicable information.

(e) If you control air emissions from an affected source by introducing the vent stream into the flame zone of a boiler or process heater according to the requirements in §63.693(g)(1)(iii), you must conduct a performance test or design evaluation to demonstrate that the boiler or process heater meets the applicable emission limit while operating at a residence time of 0.5 seconds or greater and at a combustion zone temperature of 760 °C or higher.

(f) You must conduct a performance evaluation for each continuous monitoring system according to the requirements in §63.8(e).

(g) If you are required to conduct a visual inspection of an affected source, you must conduct the inspection according to the procedures in §63.906(a)(1) for Tank Level 1 controls, §63.1063(d) for Tank Level 2 controls, §63.946(a) for a surface impoundment equipped with a floating membrane cover, §63.946(b) for a surface impoundment equipped with a cover and vented to a control device, §63.1047(a) for a separator with a fixed roof, §63.1047(c) for a separator equipped with a fixed roof and vented to a control device, §63.695(c)(1)(i) or (c)(2)(i) for a closed vent system, and §63.964(a) for individual drain systems.

(h) If you use Container Level 1 controls, you must conduct a test to demonstrate that the container operates with no detectable organic emissions using Method 21 (40 CFR part 60, appendix A) and the procedures in §63.925(a).

(i) If you use Container Level 2 controls, you must conduct a test to demonstrate that the container operates with no detectable organic emissions or that the container is vapor-tight. You must conduct the test using Method 21 (40 CFR part 60, appendix A) and the procedures in §63.925(a) to demonstrate that the container operates with no detectable organic emissions or Method 27 (40 CFR part 60, appendix A) and the procedures in §63.925(b) to demonstrate that the container is vapor-tight.

(j) If you locate an affected source inside a permanent total enclosure that is vented to a control device, you must demonstrate that the enclosure meets the verification criteria in section 5 of Procedure T in 40 CFR 52.741, appendix B.

(k) If you use a fixed roof or a floating roof to control air emissions from a separator, you must conduct a test to demonstrate that the roof operates with no detectable organic emissions using Method 21 (40 CFR part 60, appendix A) and the procedures in §63.1046(a). If you use a floating roof, you also must measure the seal gaps according to the procedures in §63.1046(b).

(l) If you use a flare to control air emissions, you must conduct a visible emissions test using Method 22 in 40 CFR part 60, appendix A, and the procedures in §63.11(b)(4).

(m) For each initial compliance demonstration that requires a performance test or design evaluation, you must report the results in your notification of compliance status according to the requirements in §63.7950(e)(1). For each initial compliance demonstration that does not require a performance test or design evaluation, you must submit a notification of compliance status according to the requirements in §63.7950(e)(2).

§63.7942 When must I conduct subsequent performance tests?

For non-flare control devices, you must conduct performance tests at any

time the EPA requires you to according to § 63.7(3).

§ 63.7943 How do I determine the average VOHAP concentration of my remediation material?

(a) General requirements. You must determine the average total VOHAP concentration of a remediation material at the point-of-extraction using either direct measurement as specified in paragraph (b) of this section or by knowledge as specified in paragraph (c) of this section.

(b) Direct measurement. To determine the average total VOHAP concentration of a remediation material at the point-of-extraction using direct measurement, you must use the procedures in paragraphs (b)(1) through (3) of this section.

(1) Sampling. Samples of each material stream must be collected at the point-of-extraction in a manner such that volatilization of organics contained in the sample is minimized and an adequately representative sample is collected and maintained for analysis by the selected method.

(i) The averaging period to be used for determining the average total VOHAP concentration for the material stream on a mass-weighted average basis must be designated and recorded. The averaging period can represent any time interval that you determine is appropriate for the material stream but must not exceed 1 year. For streams that are combined, an averaging period representative for all streams must be selected.

(ii) No less than four samples must be collected to represent the complete range of HAP compositions and HAP quantities that occur in each material stream during the entire averaging period due to normal variations in the material stream(s). Examples of such normal variations are variation of the HAP concentration within a contamination area.

(iii) All samples must be collected and handled according to written procedures you prepare and document in a site sampling plan. This plan must describe the procedure by which representative samples of the material stream(s) are collected such that a minimum loss of organics occurs throughout the sample collection and handling process and by which sample integrity is maintained. A copy of the written sampling plan must be maintained on site in the facility operating records. An example of an acceptable sampling plan includes a plan incorporating sample collection and handling procedures according to the guidance found in ''Test Methods for Evaluating Solid Waste, Physical/Chemical Methods,'' EPA Publication No. SW–846 or Method 25D in 40 CFR part 60, appendix A.

(2) Analysis. Each collected sample must be prepared and analyzed according to either one of the methods listed in § 63.694(b)(2)(ii), or any current EPA Contracts Lab Program method (or future revisions) capable of identifying all the HAP in Table 1 of this subpart.

(3) Calculations. The average total VOHAP concentration ($\bar{C}$) on a mass-weighted basis must be calculated by using the results for all samples analyzed according to paragraph (c)(2) of this section and Equation 1 of this section as follows:

$$\bar{C} = \frac{1}{Q_T} \times \sum_{i=1}^{n} \left(Q_i \times C_i\right) \qquad \text{(Eq. 1)}$$

Where:

$\bar{C}$ = Average VOHAP concentration of the material on a mass-weighted basis, ppmw.

i = Individual sample ''i'' of the material.

n = Total number of samples of the material collected (at least 4 per stream) for the averaging period (not to exceed 1 year).

Q_i = Mass quantity of material stream represented by C_i, kilograms per hour (kg/hr).

Q_T = Total mass quantity of all material during the averaging period, kg/hr.

C_i = Measured VOHAP concentration of sample ''i'' as determined according to the requirements of paragraph (a)(3)(ii) of this section, ppmw.

(c) Knowledge of the material. To determine the average total VOHAP concentration of a remediation material at the point-of-extraction using knowledge, you must use the procedures in paragraphs (c)(1) through (3) of this section.

(1) Documentation must be prepared that presents the information used as the basis for your knowledge of the material stream's average VOHAP concentration. Examples of information that may be used as the basis for

knowledge include: material balances for the source(s) generating each material stream; species-specific chemical test data for the material stream from previous testing that are still applicable to the current material stream; test data for material from the contamination area(s) being remediated.

(2) If test data are used as the basis for knowledge, then you must document the test method, sampling protocol, and the means by which sampling variability and analytical variability are accounted for in the determination of the average VOHAP concentration. For example, you may use HAP concentration test data for the material stream that are validated according to Method 301 in 40 CFR part 63, appendix A as the basis for knowledge of the material. This information must be provided for each material stream where streams are combined.

(3) If you use species-specific chemical concentration test data as the basis for knowledge of the material, you may adjust the test data to the corresponding average VOHAP concentration value which would be obtained had the material samples been analyzed using Method 305. To adjust these data, the measured concentration for each individual HAP chemical species contained in the material is multiplied by the appropriate species-specific adjustment factor (f_{m305}) listed in Table 1 of this subpart.

(d) In the event that you and us disagree on a determination using knowledge of the average total VOHAP concentration for a remediation material, then the results from a determination of VOHAP concentration using direct measurement by Method 305 in 40 CFR part 60 appendix A, as specified in paragraph (b) of this section, will be used to determine compliance with the applicable requirements of this subpart. We may perform or request that you perform this determination using direct measurement.

§ 63.7944 How do I determine the maximum HAP vapor pressure of my remediation material?

(a) You must determine the maximum HAP vapor pressure of your remediation material using either direct measurement as specified in paragraph (b) of this section or by knowledge as specified in paragraph (c) of this section.

(b) Direct measurement to determine the maximum HAP vapor pressure.

(1) Sampling. A sufficient number of samples must be collected to be representative of the remediation material contained in the tank. All samples must be collected and handled according to written procedures prepared by you and documented in a site sampling plan. This plan must describe the procedure by which representative samples of the remediation material are collected such that a minimum loss of organics occurs throughout the sample collection and handling process and by which sample integrity is maintained. A copy of the written sampling plan must be maintained on site in the facility site operating records. An example of an acceptable sampling plan includes a plan incorporating sample collection and handling procedures according to the guidance found in ''Test Methods for Evaluating Solid Waste, Physical/Chemical Methods,'' EPA Publication No. SW–846 or Method 25D in 40 CFR part 60, appendix A.

(2) Analysis. Any one of the following methods may be used to analyze the samples and compute the maximum HAP vapor pressure of the remediation material:

(i) Method 25E in 40 CFR part 60 appendix A;

(ii) Methods described in American Petroleum Institute Bulletin 2517, ''Evaporation Loss from External Floating Roof Tanks,'';

(iii) Methods obtained from standard reference texts;

(iv) ASTM Method 2879–83; or

(v) Any other method approved by the Administrator.

(c) Use of knowledge to determine the maximum HAP vapor pressure. Documentation must be prepared and recorded that presents the information used as the basis for your knowledge that the maximum HAP vapor pressure of the remediation material is less than the maximum vapor pressure limit listed in Table 2 of this subpart for the applicable tank design capacity category.

(d) In the event that you and us disagree on a determination using knowledge of the maximum HAP vapor pressure of the remediation material, then the results from a determination of maximum HAP vapor pressure using direct measurement by Method 25E in 40 CFR part 60 appendix A, as specified in paragraph (b) of this section, will be used to determine compliance with the applicable requirements of this subpart. We may perform or request that you perform this determination using direct measurement.

CONTINUOUS MONITORING SYSTEMS

§ 63.7945 What are my monitoring installation, operation, and maintenance requirements?

(a) Each CPMS must meet the requirements in paragraphs (a)(1) through (4) of this section.

(1) Complete a minimum of one cycle of operation for each successive 15-minute period.

(2) To calculate a valid hourly value, you must have at least three of four equally spaced data values (or at least two, if that condition is included to allow for periodic calibration checks) for that hour from a CPMS that is not out of control according to the monitoring plan referenced in § 63.7935.

(3) To calculate the average emissions for each averaging period, you must have at least 75 percent of the hourly averages for that period using only block hourly average values that are based on valid data (*i.e.*, not from out-of-control periods).

(4) Unless otherwise specified, each CPMS must determine the hourly average of all recorded readings and daily average, if required.

(b) You must record the results of each inspection, calibration, and validation check.

(c) You must conduct a performance evaluation for each CPMS according to the requirements in § 63.8(e) and your site-specific monitoring plan.

§ 63.7946 How do I monitor and collect data to demonstrate continuous compliance?

(a) You must monitor and collect data according to this section and your site-specific monitoring plan required in § 63.7935.

(b) Except for monitor malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), you must monitor continuously (or collect data at all required intervals) at all times that the affected source is operating.

(c) You may not use data recorded during monitoring malfunctions, associated repairs, out of control periods and required quality assurance or control activities in data averages and calculations used to report emissions or operating levels, nor may such data be used in fulfilling a minimum data availability requirement, if applicable. You must use all the data collected during all other periods in assessing the operation of the control device and associated control system.

§ 63.7947 What are my monitoring alternatives?

(a) As an alternative to the parametric monitoring required in this subpart, you may install, calibrate, and operate a continuous emission monitoring system (CEMS) to measure the control device outlet total organic emissions or organic HAP emissions concentration.

(1) The CEMS used on combustion control devices must include a diluent gas monitoring system (for O_2 or CO_2) with the pollutant monitoring system in order to correct for dilution (*e.g.*, to 0 percent excess air).

(2) Each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. Data must be reduced as specified in § 63.8(g)(2).

(3) You must conduct a performance evaluation of the CEMS according to the requirements in § 63.8 and Performance Specification 8 (for a total organic emissions CEMS) or Performance Specification 9 (for a HAP emissions CEMS) and Performance Specification 3 (for an O_2 or CO_2 CEMS) of 40 CFR part 60, appendix B. The relative accuracy provision of Performance Specification 8, sections 2.4 and 3 need not be conducted.

(4) You must prepare a site-specific monitoring plan for operating, calibrating, and verifying the operation of your CEMS according to the requirements in §§63.8(c), (d), and (e).

(5) You must establish the emissions concentration operating limit according to paragraphs (a)(5)(i) and (ii) of this section.

(i) During the performance test, you must monitor and record the total organic or HAP emissions concentration at least once every 15 minutes during each of the three test runs.

(ii) Use the data collected during the performance test to calculate and record the average total organic or HAP emissions concentration maintained during the performance test. The average total organic or HAP emissions concentration, corrected for dilution as appropriate, is the maximum operating limit for your control device.

(b) You must maintain the daily (24-hour) average total organic or HAP emissions concentration in the exhaust vent stream of the control device outlet less than or equal to the site-specific operating limit established during the performance test.

NOTIFICATION, REPORTS, AND RECORDS

§63.7950 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.7(b) and (c), 63.8(e), 63.8(f)(4) and (6), and 63.9(b) through (h) that apply to you.

(b) As specified in §63.9(b)(2), if you start up your affected source before October 8, 2003, you must submit an Initial Notification not later than 120 calendar days after October 8, 2003.

(c) As specified in §63.9(b)(3), if you start up your new or reconstructed affected source on or after October 8, 2003, you must submit an Initial Notification no later than 120 calendar days after initial startup.

(d) If you are required to conduct a performance test, you must submit a notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin as required in §63.7(b)(1).

(e) If you are required to conduct a performance test, design evaluation, or other initial compliance demonstration, you must submit a Notification of Compliance Status according to §63.9(h)(2)(ii).

(1) For each initial compliance demonstration that includes a performance test or design evaluation, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th calendar day following the completion of the performance test according to §63.10(d)(2). You must submit the complete design evaluation and supporting documentation.

(2) For each initial compliance demonstration that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th calendar day following the completion of the initial compliance demonstration.

(f) You must provide written notification to the Administrator of the alternative standard selected under §63.1006(b)(5) or (6) before implementing either of the provisions.

§63.7951 What reports must I submit and when?

(a) Compliance report due dates. Unless the Administrator has approved a different schedule, you must submit a semiannual compliance report to your permitting authority according to the requirements specified in paragraphs (a)(1) through (5) of this section.

(1) The first compliance report must cover the period beginning on the compliance date that is specified for your affected source in §63.7883 and ending on June 30 or December 31, whichever date comes first after the compliance date that is specified for your affected source.

(2) The first compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date comes first after your first compliance report is due.

(3) Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent compliance report must be postmarked or delivered

no later than July 31 or January 31, whichever date comes first after the end of the semiannual reporting period.

(5) For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of the dates specified in paragraphs (a)(1) through (4) of this section.

(b) Compliance report contents. Each compliance report must include the information specified in paragraphs (b)(1) through (3) of this section and, as applicable, paragraphs (b)(4) through (9) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a startup, shutdown, or malfunction during the reporting period and you took action consistent with your startup, shutdown, and malfunction plan, the compliance report must include the information in § 63.10(d)(5)(i).

(5) If there were no deviations from any emissions limitations (including operating limit), work practice standards, or operation and maintenance requirements, a statement that there were no deviations from the emissions limitations, work practice standards, or operation and maintenance requirements during the reporting period.

(6) If there were no periods during which a continuous monitoring system (including a CPMS or CEMS) was out-of-control as specified by § 63.8(c)(7), a statement that there were no periods during which the CPMS was out-of-control during the reporting period.

(7) For each deviation from an emissions limitation (including an operating limit) that occurs at an affected source for which you are not using a continuous monitoring system (including a CPMS or CEMS) to comply with an emissions limitation or work practice standard required in this subpart, the compliance report must contain the information specified in paragraphs (b)(1) through (4) and (b)(7)(i) and (ii) of this section. This requirement includes periods of startup, shutdown, and malfunction.

(i) The total operating time of each affected source during the reporting period.

(ii) Information on the number, duration, and cause of deviations (including unknown cause) as applicable and the corrective action taken.

(8) For each deviation from an emissions limitation (including an operating limit) or work practice standard occurring at an affected source where you are using a continuous monitoring system (including a CPMS or CEMS) to comply with the emissions limitations or work practice standard in this subpart, you must include the information specified in paragraphs (b)(1) through (4) and (b)(8)(i) through (xi) of this section. This requirement includes periods of startup, shutdown, and malfunction.

(i) The date and time that each malfunction started and stopped.

(ii) The date and time that each continuous monitoring system was inoperative, except for zero (low-level) and high-level checks.

(iii) The date, time, and duration that each continuous monitoring system was out-of-control, including the information in § 63.8(c)(8).

(iv) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(v) A summary of the total duration of the deviations during the reporting period and the total duration as a percent of the total source operating time during that reporting period.

(vi) A breakdown of the total duration of the deviations during the reporting period into those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and unknown causes.

(vii) A summary of the total duration of continuous monitoring system downtime during the reporting period and the total duration of continuous

monitoring system downtime as a percent of the total source operating time during the reporting period.

(viii) A brief description of the process units.

(ix) A brief description of the continuous monitoring system.

(x) The date of the latest continuous monitoring system certification or audit.

(xi) A description of any changes in continuous monitoring systems, processes, or controls since the last reporting period.

(9) You must include the information on equipment leaks required in periodic reports by §63.1018(a) or §63.1039(b).

(c) Immediate startup, shutdown, and malfunction report. If you had a startup, shutdown, or malfunction during the semiannual reporting period that was not consistent with your startup, shutdown, and malfunction plan, you must submit an immediate startup, shutdown, and malfunction report according to the requirements of §63.10(d)(5)(ii) .

(d) Part 70 monitoring report. If you have obtained a title V operating permit for an affected source pursuant to 40 CFR part 70 or 40 CFR part 71, you must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If you submit a compliance report for an affected source along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all the required information concerning deviations from any emissions limitation or operation and maintenance requirement in this subpart, submission of the compliance report satisfies any obligation to report the same deviations in the semiannual monitoring report. However, submission of a compliance report does not otherwise affect any obligation you may have to report deviations from permit requirements for an affected source to your permitting authority.

§63.7952 What records must I keep?

(a) You must keep the records specified in paragraphs (a)(1) through (4) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirements in §63.10(b)(1) and (b)(2)(xiv).

(2) The records in §63.6(e)(3)(iii) through (v) related to startups, shutdowns, and malfunctions.

(3) Results of performance tests and performance evaluations as required by §63.10(b)(2)(viii).

(4) The records of initial and ongoing determinations for affected sources that are exempt from control requirements under this subpart.

(b) For each continuous monitoring system, you must keep the records as described in paragraphs (b)(1) and (2) of this section.

(1) Records described in §63.10(b)(2)(vi) through (xi) that apply to your continuous monitoring system.

(2) Performance evaluation plans, including previous (i.e., superseded) versions of the plan as required in §63.8(d)(3).

(c) You must keep the records required by this subpart to show continuous compliance with each emissions limitation, work practice standard, and operation and maintenance requirement that applies to you.

(d) You must record, on a semiannual basis, the information in §63.696(g) for planned routine maintenance of a control device for emissions from process vents.

§63.7953 In what form and how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review, according to §63.10(b)(1).

(b) As specified in §63.10(b)(1), you must keep your files of all information (including all reports and notifications) for 5 years following the date of each occurrence, measurement, maintenance, action taken to correct the cause of a deviation, report, or record.

(c) You must keep each record on site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to §63.10(b)(1). You can keep the records off-site for the remaining 3 years.

(d) If, after the remediation activity is completed, there is no other remediation activity at the facility, and you are no longer the owner of the facility, you may keep all records for the completed remediation activity at an off-site location provided you notify the Administrator in writing of the name, address and contact person for the off-site location.

OTHER REQUIREMENTS AND INFORMATION

§ 63.7955 What parts of the General Provisions apply to me?

Table 3 of this subpart shows which parts of the General Provisions in §§63.1 through 63.15 apply to you.

§ 63.7956 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the EPA, or a delegated authority such as your State, local, or tribal agency. If the EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency, in addition to the EPA, has the authority to implement and enforce this subpart. You should contact your EPA Regional Office (see list in §63.13) to find out if this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under section 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that cannot be delegated to State, local, or tribal agencies are listed in paragraphs (a)(1) through (4) of this section.

(1) Approval of alternatives to the non-opacity emissions limitations and work practice standards in this subpart under §63.6(g).

(2) Approval of major changes to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90.

(3) Approval of major changes to monitoring under §63.8(f) and as defined in §63.90.

(4) Approval of major changes to recordkeeping and reporting under §63.10(f) and as defined in §63.90.

§ 63.7957 What definitions apply to this subpart?

Terms used in this subpart are defined in the CAA, in §63.2, and in this section. If a term is defined both in this section and in another subpart cross-referenced by this subpart, then the term will have the meaning given in this section for purposes of this subpart.

Boiler means an enclosed combustion device that extracts useful energy in the form of steam and is not an incinerator or a process heater.

Closed vent system means a system that is not open to the atmosphere and is composed of hard-piping, ductwork, connections, and, if necessary, fans, blowers, or other flow-inducing device that conveys gas or vapor from an emissions point to a control device.

Closure device means a cap, hatch, lid, plug, seal, valve, or other type of fitting that prevents or reduces air pollutant emissions to the atmosphere by blocking an opening in a cover when the device is secured in the closed position. Closure devices include devices that are detachable from the cover (*e.g.*, a sampling port cap), manually operated (*e.g.*, a hinged access lid or hatch), or automatically operated (*e.g.*, a spring-loaded pressure relief valve).

Container means a portable unit used to hold material. Examples of containers include, but are not limited to drums, dumpsters, roll-off boxes, bulk cargo containers commonly known as portable tanks or totes, cargo tank trucks, dump trucks, and rail cars. For the purpose of this subpart, a front-end loader, excavator, backhoe, or other type of self-propelled excavation equipment is not a container.

Continuous record means documentation of data values measured at least once every 15 minutes and recorded at the frequency specified in this subpart.

Continuous recorder means a data recording device that either records an instantaneous data value at least once every 15 minutes or records 15-minutes or more frequent block averages.

Control device means equipment used recovering, removing, oxidizing, or destroying organic vapors. Examples of such equipment include but are not limited to carbon adsorbers, condensers, vapor incinerators, flares, boilers, and process heaters.

Cover means a device that prevents or reduces air pollutant emissions to the atmosphere by forming a continuous barrier over the remediation material managed in a unit. A cover may have openings (such as access hatches, sampling ports, gauge wells) that are necessary for operation, inspection, maintenance, and repair of the unit on which the cover is used. A cover may be a separate piece of equipment which can be detached and removed from the unit (such as a tarp) or a cover may be formed by structural features permanently integrated into the design of the unit.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emissions limitation (including any operating limit), or work practice standard;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or

(3) Fails to meet any emissions limitation,(including any operating limit), or work practice standard in this subpart during startup, shutdown, or malfunction, regardless or whether or not such failure is permitted by this subpart.

Emissions limitation means any emissions limit, opacity limit, operating limit, or visible emissions limit.

Emissions point means an individual tank, surface impoundment, container, oil-water, organic-water separator, transfer system, vent, or enclosure.

Enclosure means a structure that surrounds a tank or container, captures organic vapors emitted from the tank or container, and vents the captured vapor through a closed vent system to a control device.

Equipment means each pump, pressure relief device, sampling connection system, valve, and connector used in remediation material service at a facility.

External floating roof means a pontoon-type or double-deck type cover that rests on the liquid surface in a tank with no fixed roof.

Facility means all contiguous or adjoining property that is under common control including properties that are separated only by a road or other public right-of-way. Common control includes properties that are owned, leased, or operated by the same entity, parent entity, subsidiary, or any combination thereof. A unit or group of units within a contiguous property that are not under common control (*e.g.*, a wastewater treatment unit located at the facility but is owned by a different company) is a different facility.

Fixed roof means a cover that is mounted on a unit in a stationary position and does not move with fluctuations in the level of the liquid managed in the unit.

Flame zone means the portion of the combustion chamber in a boiler or process heater occupied by the flame envelope.

Floating roof means a cover consisting of a double deck, pontoon single deck, or internal floating cover which rests upon and is supported by the liquid being contained, and is equipped with a continuous seal.

Flow indicator means a device that indicates whether gas is flowing, or whether the valve position would allow gas to flow in a bypass line.

Hard-piping means pipe or tubing that is manufactured and properly installed according to relevant standards and good engineering practices.

Individual drain system means a stationary system used to convey wastewater streams or residuals to a remediation material management unit or to discharge or disposal. The term includes hard-piping, all drains and junction boxes, together with their associated sewer lines and other junction

boxes (*e.g.,* manholes, sumps, and lift stations) conveying wastewater streams or residuals. For the purpose of this subpart, an individual drain system is not a drain and collection system that is designed and operated for the sole purpose of collecting rainfall runoff (*e.g.,* stormwater sewer system) and is segregated from all other individual drain systems.

Internal floating roof means a cover that rests or floats on the liquid surface (but not necessarily in complete contact with it inside a tank that has a fixed roof).

Maximum HAP vapor pressure means the sum of the individual HAP equilibrium partial pressure exerted by remediation material at the temperature equal to either: the monthly average temperature as reported by the National Weather Service when the remediation material is stored or treated at ambient temperature; or the highest calendar-month average temperature of the remediation material when the remediation material is stored at temperatures above the ambient temperature or when the remediation material is stored or treated at temperatures below the ambient temperature. For the purpose of this subpart, maximum HAP vapor pressure is determined using the procedures specified in § 63.7944.

No detectable organic emissions means no escape of organics to the atmosphere as determined using the procedure specified in § 63.694(k).

Oil-water separator means a separator as defined for this subpart that is used to separate oil from water.

Operating parameter value means a minimum or maximum value established for a control device or treatment process parameter which, if achieved by itself or in combination with one or more other operating parameter values, determines that an owner or operator has complied with an applicable emissions limitation or standard.

Organic-water separator means a separator as defined for this subpart that is used to separate organics from water.

Point-of-extraction means a point above ground where you can collect samples of a remediation material before or at the first point where organic constituents in the material have the potential to volatilize and be released to the atmosphere and before placing the material in a remediation material management unit or treatment process. For the purpose this subpart, the first point where the organic constituents in the remediation material have the potential to volatilize and be released to the atmosphere is not a fugitive emissions point due to an equipment leak from any of the following equipment components: pumps, compressors, valves, connectors, instrumentation systems, or safety devices.

Process heater means an enclosed combustion device that transfers heat released by burning fuel directly to process streams or to heat transfer liquids other than water.

Process vent means any open-ended pipe, stack, duct, or other opening intended to allow the passage of gases, vapors, or fumes to the atmosphere and this passage is caused by mechanical means (such as compressors, vacuum-producing systems or fans) or by process-related means (such as volatilization produced by heating). For the purposes of this subpart, a process vent is neither a safety device (as defined in this section) nor a stack, duct or other opening used to exhaust combustion products from a boiler, furnace, heater, incinerator, or other combustion device.

Radioactive mixed waste means a material that contains both hazardous waste subject to RCRA and source, special nuclear, or by-product material subject to the Atomic Energy Act of 1954.

Remediation material means a material that contains one or more of the HAP listed in Table 1 of this subpart, and this material is one of the following:

(1) A material found in naturally occurring media such as soil, groundwater, surface water, sediments, or a mixture of such materials with liquids, sludges, or solids which is inseparable by simple mechanical removal processes and is made up primarily of media. This material does not include debris as defined in 40 CFR 268.2.

(2) A material found in intact or substantially intact containers, tanks, storage piles, or other storage units

that requires clean up because this material poses a reasonable potential threat to contaminating media. Examples of these materials include, but are not limited to, solvents, oils, paints, and other volatile or semi-volatile organic liquids found in buried drums, cans, or other containers; gasoline, fuel oil, or other fuels in leaking underground storage tanks; and solid materials containing volatile or semi-volatile organics in unused or abandoned piles. Remediation material is not a waste or residue generated by routine equipment maintenance activities performed at a facility such as, but not limited to, tank bottoms and sludges removed during tank cleanouts; sludges and sediments removed from active wastewater treatment tanks, surface impoundments, or lagoons; spent catalyst removed from process equipment; residues removed from air pollution control equipment; and debris removed during heat exchanger and pipeline cleanouts.

Remediation material management unit means a tank, container, surface impoundment, oil-water separator, organic-water separator, or transfer system used to remove, destroy, degrade, transform, immobilize, or otherwise manage remediation material.

Remediation material service means any time when a pump, compressor, agitator, pressure relief device, sampling connection system, open-ended valve or line, valve, connector, or instrumentation system contains or contacts remediation material.

Responsible official means responsible official as defined in 40 CFR 70.2.

Safety device means a closure device such as a pressure relief valve, frangible disc, fusible plug, or any other type of device which functions to prevent physical damage or permanent deformation to equipment by venting gases or vapors during unsafe conditions resulting from an unplanned, accidental, or emergency event. For the purpose of this Subpart, a safety device is not used for routine venting of gases or vapors from the vapor headspace underneath a cover such as during filling of the unit or to adjust the pressure in this vapor headspace in response to normal daily diurnal ambient temperature fluctuations. A safety device is designed to remain in a closed position during normal operations and open only when the internal pressure, or another relevant parameter, exceeds the device threshold setting applicable to the equipment as determined by the owner or operator based on manufacturer recommendations, applicable regulations, fire protection and prevention codes, standard engineering codes and practices, or other requirements for the safe handling of flammable, combustible, explosive, reactive, or hazardous materials.

Separator means a remediation material management unit, generally a tank, used to separate oil or organics from water. A separator consists of not only the separation unit but also the forebay and other separator basins, skimmers, weirs, grit chambers, sludge hoppers, and bar screens that are located directly after the individual drain system and prior to any additional treatment units such as an air flotation unit clarifier or biological treatment unit. Examples of a separator include, but are not limited to, an API separator, parallel-plate interceptor, and corrugated-plate interceptor with the associated ancillary equipment.

Site remediation means one or more activities or processes used to remove, destroy, degrade, transform, immobilize, or otherwise manage remediation material. The monitoring or measuring of contamination levels in environmental media using wells or by sampling is not considered to be a site remediation.

Sludge means sludge as defined in §260.10 of this chapter.

Soil means unconsolidated earth material composing the superficial geologic strata (material overlying bedrock), consisting of clay, silt, sand, or gravel size particles (sizes as classified by the U.S. Soil Conservation Service), or a mixture of such materials with liquids, sludges, or solids which is inseparable by simple mechanical removal processes and is made up primarily of soil.

Stabilization process means any physical or chemical process used to either reduce the mobility of contaminants in media or eliminate free liquids as determined by Test Method 9095—Paint

Filter Liquids Test in ''Test Methods for Evaluating Solid Waste, Physical/Chemical Methods,'' EPA Publication No. SW–846, Third Edition, September 1986, as amended by Update I, November 15, 1992. (As an alternative, you may use any more recent, updated version of Method 9095 approved by the EPA). A stabilization process includes mixing remediation material with binders or other materials, and curing the resulting remediation material and binder mixture. Other synonymous terms used to refer to this process are fixation or solidification. A stabilization process does not include the adding of absorbent materials to the surface of remediation material, without mixing, agitation, or subsequent curing, to absorb free liquid.

Surface impoundment means a unit that is a natural topographical depression, man-made excavation, or diked area formed primarily of earthen materials (although it may be lined with man-made materials), which is designed to hold an accumulation of liquids. Examples of surface impoundments include holding, storage, settling, and aeration pits, ponds, and lagoons.

Tank means a stationary unit that is constructed primarily of nonearthen materials (such as wood, concrete, steel, fiberglass, or plastic) which provide structural support and is designed to hold an accumulation of liquids or other materials.

Temperature monitoring device means a piece of equipment used to monitor temperature and having an accuracy of ±1 percent of the temperature being monitored expressed in degrees Celsius (°C) or ±1.2 degrees °C, whichever value is greater.

Transfer system means a stationary system for which the predominant function is to convey liquids or solid materials from one point to another point within waste management operation or recovery operation. For the purpose of this subpart, the conveyance of material using a container (as defined of this subpart) or self-propelled vehicle (*e.g.*, a front-end loader) is not a transfer system. Examples of a transfer system include but are not limited to a pipeline, an individual drain system, a gravity-operated conveyor (such as a chute), and a mechanically-powered conveyor (such as a belt or screw conveyor).

Treatment process means a process in which remediation material is physically, chemically, thermally, or biologically treated to destroy, degrade, or remove hazardous air pollutants contained in the material. A treatment process can be composed of a single unit (*e.g.*, a steam stripper) or a series of units (*e.g.*, a wastewater treatment system). A treatment process can be used to treat one or more remediation material streams at the same time.

Volatile organic hazardous air pollutant (VOHAP) concentration means the fraction by weight of the HAP listed in Table 1 of this subpart that are contained in the remediation material as measured using Method 305, 40 CFR part 63, appendix A and expressed in terms of parts per million (ppm). As an alternative to using Method 305, 40 CFR part 63, appendix A, you may determine the HAP concentration of the remediation material using any one of the other test methods specified in §63.694(b)(2)(ii). When a test method specified in §63.694(b)(2)(ii) other than Method 305 in 40 CFR part 63, appendix A is used to determine the speciated HAP concentration of the contaminated material, the individual compound concentration may be adjusted by the corresponding f_{m305} listed in Table 1 of this subpart to determine a VOHAP concentration.

Work practice standard means any design, equipment, work practice, or operational standard, or combination thereof, that is promulgated pursuant to section 112(h) of the CAA.

TABLE 1 TO SUBPART GGGGG OF PART 63—LIST OF HAZARDOUS AIR POLLUTANTS

CAS No.[a]	Compound name	f_{m305}
75070	Acetaldehyde	1.000
75058	Acetonitrile	0.989
98862	Acetophenone	0.314

CAS No.[a]	Compound name	f_{m305}
107028	Acrolein	1.000
107131	Acrylonitrile	0.999
107051	Allyl chloride	1.000
71432	Benzene (includes benzene in gasoline)	1.000
98077	Benzotrichloride (isomers and mixture)	0.958
100447	Benzyl chloride	1.000
92524	Biphenyl	0.864
542881	Bis(chloromethyl)ether[b]	0.999
75252	Bromoform	0.998
106990	1,3-Butadiene	1.000
75150	Carbon disulfide	1.000
56235	Carbon Tetrachloride	1.000
43581	Carbonyl sulfide	1.000
133904	Chloramben	0.633
108907	Chlorobenzene	1.000
67663	Chloroform	1.000
107302	Chloromethyl methyl ether[b]	1.000
126998	Chloroprene	1.000
98828	Cumene	1.000
94757	2,4-D, salts and esters	0.167
334883	Diazomethane[c]	0.999
132649	Dibenzofurans	0.967
96128	1,2-Dibromo-3-chloropropane	1.000
106467	1,4-Dichlorobenzene(p)	1.000
107062	Dichloroethane (Ethylene dichloride)	1.000
111444	Dichloroethyl ether (Bis(2-chloroethyl ether))	0.757
542756	1,3-Dichloropropene	1.000
79447	Dimethyl carbamoyl chloride[c]	0.150
57147	1,1-Dimethyl hydrazine	.....
64675	Diethyl sulfate	0.0025
77781	Dimethyl sulfate	0.086
121697	N,N-Dimethylaniline	0.0008
51285	2,4-Dinitrophenol	0.0077
121142	2,4-Dinitrotoluene	0.0848
123911	1,4-Dioxane (1,4-Diethyleneoxide)	0.869
106898	Epichlorohydrin (1-Chloro-2,3-epoxypropane)	0.939
106887	1,2-Epoxybutane	1.000
140885	Ethyl acrylate	1.000
100414	Ethyl benzene	1.000
75003	Ethyl chloride (Chloroethane)	1.000
106934	Ethylene dibromide (Dibromoethane)	0.999
107062	Ethylene dichloride (1,2-Dichloroethane)	1.000
151564	Ethylene imine (Aziridine)	0.867
75218	Ethylene oxide	1.000
75343	Ethylidene dichloride (1,1-Dichloroethane)	1.000
	Glycol ethers[d] that have a Henry's Law constant value equal to or greater than 0.1 Y/X(1.8×10^{-6} atm/gm-mole/m^3) at 25 °C.	([e])
118741	Hexachlorobenzene	0.97
87683	Hexachlorobutadiene	0.88
67721	Hexachloroethane	0.499
110543	Hexane	1.000
78591	Isophorone	0.506
58899	Lindane (all isomers)	1.000
67561	Methanol	0.855
74839	Methyl bromide (Bromomethane)	1.000
74873	Methyl chloride (Chloromethane)	1.000
71556	Methyl chloroform (1,1,1-Trichloroethane)	1.000
78933	Methyl ethyl ketone (2-Butanone)	0.990
74884	Methyl iodide (Iodomethane)	1.000
108101	Methyl isobutyl ketone (Hexone)	0.979
624839	Methyl isocyanate	1.000
80626	Methyl methacrylate	0.999
1634044	Methyl tert butyl ether	1.000
75092	Methylene chloride (Dichloromethane)	1.000
91203	Naphthalene	0.994
98953	Nitrobenzene	0.394
79469	2-Nitropropane	0.989
82688	Pentachloronitrobenzene (Quintobenzene)	0.839
87865	Pentachlorophenol	0.0898
75445	Phosgene[c]	1.000
123386	Propionaldehyde	0.999
78875	Propylene dichloride (1,2-Dichloropropane)	1.000
75569	Propylene oxide	1.000
75558	1,2-Propylenimine (2-Methyl aziridine)	0.945

CAS No.[a]	Compound name	f_{m305}
100425	Styrene	1.000
96093	Styrene oxide	0.830
79345	1,1,2,2-Tetrachloroethane	0.999
127184	Tetrachloroethylene (Perchloroethylene)	1.000
108883	Toluene	1.000
95534	o-Toluidine	0.152
120821	1,2,4-Trichlorobenzene	1.000
71556	1,1,1-Trichloroethane (Methyl chloroform)	1.000
79005	1,1,2-Trichloroethane (Vinyl trichloride)	1.000
79016	Trichloroethylene	1.000
95954	2,4,5-Trichlorophenol	0.108
88062	2,4,6-Trichlorophenol	0.132
121448	Triethylamine	1.000
540841	2,2,4-Trimethylpentane	1.000
108054	Vinyl acetate	1.000
593602	Vinyl bromide	1.000
75014	Vinyl chloride	1.000
75354	Vinylidene chloride (1,1-Dichloroethylene)	1.000
1330207	Xylenes (isomers and mixture)	1.000
95476	o-Xylenes	1.000
108383	m-Xylenes	1.000
106423	p-Xylenes	1.000

NOTES:
1. f_{m305} = Fraction measure factor in Method 305, 40 CFR part 63, appendix A.
[a] CAS numbers refer to the Chemical Abstracts Services registry number assigned to specific compounds, isomers, or mixtures of compounds.
[b] Denotes a HAP that hydrolyzes quickly in water, but the hydrolysis products are also HAP chemicals.
[c] Denotes a HAP that may react violently with water.
[d] Denotes a HAP that hydrolyzes slowly in water.
[e] The f_{m305} factors for some of the more common glycol ethers can be obtained by contacting the Waste and Chemical Processes Group, Office of Air Quality Planning and Standards, Research Triangle Park, NC 27711.

TABLE 2 TO SUBPART GGGGG OF PART 63—CONTROL LEVELS AS REQUIRED BY §63.7895(a) FOR TANKS MANAGING REMEDIATION MATERIAL WITH A MAXIMUM HAP VAPOR PRESSURE LESS THAN 76.6 kPa

If your tank design capacity is . . .	And the maximum HAP vapor pressure of the remediation material placed in your tank is . . .	Then your tank must use . . .
1. Less than 38 m^3	Less than 76.6 kPa	Tank Level 1 controls under §63.7895(b).
2. At least 38 m^3 but less than 151 m^3	Less than 13.1 kPa	Tank Level 1 controls under §63.7895(b).
3. 151 m^3 or greater	Less than 0.7 kPa	Tank Level 1 controls under §63.7895(b).
4. at least 38 m^3 but less than 151 m^3	13.1 kPa or greater	Tank Level 2 controls under §63.7895(c).
5. 151 m^3 or greater	0.7 kPa or greater	Tank Level 2 controls under §63.7895(c)

TABLE 3 TO SUBPART GGGGG OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART GGGGG

As stated in §63.7940, you must comply with the applicable General Provisions requirements according to the following table:

Citation	Subject	Brief description	Applies to subpart GGGGG
§63.1	Applicability	Initial Applicability Determination; Applicability After Standard Established; Permit Requirements; Extensions, Notifications.	Yes.
§63.2	Definitions	Definitions for part 63 standards	Yes.
§63.3	Units and Abbreviations	Units and abbreviations for part 63 standards	Yes.
§63.4	Prohibited Activities	Prohibited Activities; Compliance date; Circumvention, Severability.	Yes.
§63.5	Construction/Reconstruction	Applicability; applications; approvals	Yes.
§63.6(a)	Applicability	General Provisions (GP) apply unless compliance extension GP apply to area sources that become major.	Yes.
§63.6(b)(1)–(4)	Compliance Dates for New and Reconstructed sources	Standards apply at effective date; 3 years after effective date; upon startup; 10 years after construction or reconstruction commences for 112(f).	Yes.
§63.6(b)(5)	Notification	Must notify if commenced construction or reconstruction after proposal.	Yes.
§63.6(b)(6)	[Reserved]		
§63.6(b)(7)	Compliance Dates for New and Reconstructed Area Sources That Become Major.	Area sources that become major must comply with major source standards immediately upon becoming major, regardless of whether required to comply when they were an area source.	Yes.
§63.6(c)(1)–(2)	Compliance Dates for Existing Sources	Comply according to date in subpart, which must be no later than 3 years after effective date. For 112(f) standards, comply within 90 days of effective date unless compliance extension.	Yes.
§63.6(c)(3)–(4)	[Reserved]		
§63.6(c)(5)	Compliance Dates for Existing Area Sources That Become Major.	Area sources that become major must comply with major source standards by date indicated in subpart or by equivalent time period (for example, 3 years).	Yes.
§63.6(d)	[Reserved]		
§63.6(e)(1)–(2)	Operation & Maintenance	Operate to minimize emissions at all times. Correct malfunctions as soon as practicable. Operation and maintenance requirements independently enforceable; information Administrator will use to determine if operation and maintenance requirements were met.	Yes.
§63.6(e)(3)	Startup, Shutdown, and Malfunction Plan (SSMP)	Requirement for startup, shutdown and malfunction (SSM) and SSMP. Content of SSMP.	Yes with the exception of containers using either Level 1 or Level 2 controls.
§63.6(f)(1)	Compliance Except During SSM	You must comply with emissions standards at all times except during SSM.	Yes.
§63.6(f)(2)–(3)	Methods for Determining Compliance	Compliance based on performance test, operation and maintenance plans, records, inspection.	Yes.
§63.6(g)(1)–(3)	Alternative Standard	Procedures for getting an alternative standard	Yes.
§63.6(h)	Opacity/Visible Emissions (VE) Standards	Requirements for opacity and visible emissions limits	No. No opacity standards.

Citation	Subject	Brief description	Applies to subpart GGGGG
§ 63.6(i)(1)–(14)	Compliance Extension	Procedures and criteria for Administrator to grant compliance extension.	Yes.
§ 63.6(j)	Presidential Compliance Exemption	President may exempt source category from requirement to comply with final rule.	Yes.
§ 63.7(a)(1)–(2)	Performance Test Dates	Dates for Conducting Initial Performance Testing and Other Compliance Demonstrations. Must conduct 180 days after first subject to final rule.	Yes.
§ 63.7(a)(3)	CAA Section 114 Authority	Administrator may require a performance test under CAA section 114 at any time.	Yes.
§ 63.7(b)(1)	Notification of Performance Test	Must notify Administrator 60 days before the test	Yes.
§ 63.7(b)(2)	Notification of Rescheduling	If rescheduling a performance test is necessary, must notify Administrator 5 days before scheduled date of rescheduled date.	Yes.
§ 63.7(c)	Quality Assurance/Test Plan	Requirement to submit site-specific test plan 60 days before the test or on date Administrator agrees with: Test plan approval procedures; performance audit requirements; internal and External QA procedures for testing.	
§ 63.7(d)	Testing Facilities	Requirements for testing facilities	Yes.
§ 63.7(e)(1)	Conditions for Conducting Performance Tests	Performance tests must be conducted under representative conditions. Cannot conduct performance tests during SSM. Not a violation to exceed standard during SSM.	Yes.
§ 63.7(e)(2)	Conditions for Conducting Performance Tests	Must conduct according to rule and EPA test methods unless Administrator approves alternative.	Yes.
§ 63.7(e)(3)	Test Run Duration	Must have three test runs of at least one hour each. Compliance is based on arithmetic mean of three runs. Conditions when data from an additional test run can be used.	Yes.
§ 63.7(f)	Alternative Test Method	Procedures by which Administrator can grant approval to use an alternative test method.	Yes.
§ 63.7(g)	Performance Test Data Analysis	Must include raw data in performance test report. Must submit performance test data 60 days after end of test with the Notification of Compliance Status. Keep data for 5 years.	Yes.
§ 63.7(h)	Waiver of Tests	Procedures for Administrator to waive performance test	Yes.
§ 63.8(a)(1)	Applicability of Monitoring Requirements	Subject to all monitoring requirements in standard	Yes.
§ 63.8(a)(2)	Performance Specifications	Performance Specifications in appendix B of part 60 apply	Yes.
§ 63.8(a)(3)	[Reserved].		
§ 63.8(a)(4)	Monitoring with Flares	Unless your rule says otherwise, the requirements for flares in 63.11 apply.	Yes.
§ 63.8(b)(1)	Monitoring	Must conduct monitoring according to standard unless Administrator approves alternative.	Yes.
§ 63.8(b)(2)–(3)	Multiple Effluents and Multiple Monitoring Systems	Specific requirements for installing monitoring systems. Must install on each effluent before it is combined and before it is released to the atmosphere unless Administrator approves otherwise. If more than one monitoring system on an emissions point, must report all monitoring system results, unless one monitoring system is a backup.	Yes.
§ 63.8(c)(1)	Monitoring System Operation and Maintenance	Maintain monitoring system in a manner consistent with good air pollution control practices.	Yes.

§ 63.8(c)(1)(i)	Routine and Predictable SSM	Keep parts for routine repairs readily available; reporting requirements for SSM when action is described in SSM plan.	Yes.
§ 63.8(c)(1)(ii)	SSM not in SSMP	Reporting requirements for SSM when action is not described in SSM plan.	Yes.
§ 63.8(c)(1)(iii)	Compliance with Operation and Maintenance (O&M) Requirements.	How Administrator determines if source complying with operation and maintenance requirements. Review of source O&M procedures, records, Manufacturer's instructions, recommendations, and inspection of monitoring system.	Yes.
§ 63.8(c)(2)–(3)	Monitoring System Installation	Must install to get representative emissions and parameter measurements. Must verify operational status before or at performance test.	Yes.
§ 63.8(c)(4)	Continuous Monitoring System (CMS) Requirements	CMS must be operating except during breakdown, out-of-control, repair, maintenance, and high-level calibration drifts.	No.
§ 63.8(c)(4)(i)–(ii)	Continuous Monitoring System (CMS) Requirements	COMS must have a minimum of one cycle of sampling and analysis for each successive 10-second period and one cycle of data recording for each successive 6-minute period. CEMS must have a minimum of one cycle of operation for each successive 15-minute period.	Yes. However, COMS are not applicable. Requirements for CPMS are listed in §§ 63.7900 and 63.7913.
§ 63.8(c)(5)	COMS Minimum Procedures	COMS minimum procedures	No.
§ 63.8(c)(6)	CMS Requirements	Zero and High level calibration check requirements	Yes. However requirements for CPMS are addressed in §§ 63.7900 and 63.7913.
§ 63.8(c)(7)–(8)	CMS Requirements	Out-of-control periods, including reporting	Yes.
§ 63.8(d)	CMS Quality Control	Requirements for CMS quality control, including calibration, etc. Must keep quality control plan on record for 5 years. Keep old versions for 5 years after revisions.	Yes.
§ 63.8(e)	CMS Performance Evaluation	Notification, performance evaluation test plan, reports	Yes.
§ 63.8(f)(1)–(5)	Alternative Monitoring Method	Procedures for Administrator to approve alternative monitoring.	Yes.
§ 63.8(f)(6)	Alternative to Relative Accuracy Test	Procedures for Administrator to approve alternative relative accuracy tests for CEMS.	No.
§ 63.8(g)(1)–(4)	Data Reduction	COMS 6-minute averages calculated over at least 36 evenly spaced data points. CEMS 1-hour averages computed over at least four equally spaced data points.	Yes. However, COMS are not applicable. Requirements for CPMS are addressed in §§ 63.7900 and 63.7913.
§ 63.8(g)(5)	Data Reduction	Data that cannot be used in computing averages for CEMS and COMS.	No.
§ 63.9(a)	Notification Requirements	Applicability and State Delegation	Yes.
§ 63.9(b)(1)–(5)	Initial Notifications.	Submit notification 120 days after effective date. Notification of intent to construct/reconstruct; Notification of commencement of construct/reconstruct; Notification of startup. Contents of each.	Yes.
§ 63.9(c)	Request for Compliance Extension	Can request if cannot comply by date or if installed BACT/LAER.	Yes.
§ 63.9(d)	Notification of Special Compliance Requirements for New Source.	For sources that commence construction between proposal and promulgation and want to comply 3 years after effective date.	Yes.
§ 63.9(e)	Notification of Performance Test	Notify Administrator 60 days prior	Yes.
§ 63.9(f)	Notification of VE/Opacity Test	Notify Administrator 30 days prior	No.

Citation	Subject	Brief description	Applies to subpart GGGGG
§ 63.9(g)	Additional Notifications When Using CMS	Notification of performance evaluation. Notification using COMS data. Notification that exceeded criterion for relative accuracy.	Yes. However, there are no opacity standards.
§ 63.9(h)(1)–(6)	Notification of Compliance Status	Contents. Due 60 days after end of performance test or other compliance demonstration, except for opacity/VE, which are due 30 days after. When to submit to Federal vs. State authority.	Yes.
§ 63.9(i)	Adjustment of Submittal Deadlines	Procedures for Administrator to approve change in when notifications must be submitted.	Yes.
§ 63.9(j)	Change in Previous Information	Must submit within 15 days after the change	Yes.
§ 63.10(a)	Recordkeeping/Reporting	Applies to all, unless compliance extension. When to submit to Federal vs. State authority. Procedures for owners of more than 1 source.	Yes.
§ 63.10(b)(1)	Recordkeeping/Reporting	General Requirements. Keep all records readily available. Keep for 5 years.	Yes.
§ 63.10(b)(2)(i)–(iv)	Records related to SSM	Occurrence of each of operation (process equipment). Occurrence of each malfunction of air pollution equipment. Maintenance on air pollution control equipment. Actions during startup, shutdown, and malfunction.	Yes.
§ 63.10(b)(2)(vi) and (x–xi)	CMS Records	Malfunctions, inoperative, out-of-control. Calibration checks. Adjustments, maintenance.	Yes.
§ 63.10(b)(2)(vii)–(ix)	Records	Measurements to demonstrate compliance with emissions limitations. Performance test, performance evaluation, and visible emissions observation results. Measurements to determine conditions of performance tests and performance evaluations.	Yes.
§ 63.10(b)(2)(xii)	Records	Records when under waiver	Yes.
§ 63.10(b)(2)(xiii)	Records	Records when using alternative to relative accuracy test	No.
§ 63.10(b)(2)(xiv)	Records	All documentation supporting Initial Notification and Notification of Compliance Status.	Yes.
§ 63.10(b)(3)	Records	Applicability Determinations	Yes.
§ 63.10(c)	Records	Additional Records for CMS	No.
§ 63.10(d)(1)	General Reporting Requirements	Requirement to report	Yes.
§ 63.10(d)(2)	Report of Performance Test Results	When to submit to Federal or State authority	Yes.
§ 63.10(d)(3)	Reporting Opacity or VE Observations	What to report and when	No.
§ 63.10(d)(4)	Progress Reports	Must submit progress reports on schedule if under compliance extension.	Yes.
§ 63.10(d)(5)	Startup, Shutdown, and Malfunction Reports	Contents and submission	Yes.
§ 63.10(e)(1)–(2)	Additional CMS Reports	Must report results for each CEM on a unit Written copy of performance evaluation Three copies of COMS performance evaluation.	Yes. However, COMS are not applicable.
§ 63.10(e)(3)	Reports	Excess Emissions Reports	No.
§ 63.10(e)(3)(i–iii)	Reports	Schedule for reporting excess emissions and parameter monitor exceedance (now defined as deviations).	No.

§ 63.10(e)(3)(iv–v)	Excess Emissions Reports	Requirement to revert to quarterly submission if there is an excess emissions and parameter monitor exceedance (now defined as deviations). Provision to request semi-annual reporting after compliance for one year. Submit report by 30th day following end of quarter or calendar half. If there has not been an exceedance or excess emissions (now defined as deviations), report contents is a statement that there have been no deviations.	No.
§ 63.10(e)(3)(iv–v)	Excess Emissions Reports	Must submit report containing all of the information in §§ 63.10(c)(5–13) and 63.8(c)(7–8).	No.
§ 63.10(e)(3)(vi–viii)	Excess Emissions Report and Summary Report	Requirements for reporting excess emissions for CMSs (now called deviations). Requires all of the information in §§ 63.10(c)(5–13) and 63.8(c)(7–8).	No.
§ 63.10(e)(4)	Reporting COMS data	Must submit COMS data with performance test data	No.
§ 63.10(f)	Waiver for Recordkeeping/Reporting	Procedures for Administrator to waive	Yes.
§ 63.11	Flares	Requirements for flares	Yes.
§ 63.12	Delegation	State authority to enforce standards	Yes.
§ 63.13	Addresses	Addresses where reports, notifications, and requests are sent.	Yes.
§ 63.14	Incorporation by Reference	Test methods incorporated by reference	Yes.
§ 63.15	Availability of Information	Public and confidential information	Yes

[68 FR 58190, Oct. 8, 2003, as amended at 71 FR 20468, Apr. 20, 2006]

Subpart HHHHH—National Emission Standards for Hazardous Air Pollutants: Miscellaneous Coating Manufacturing

SOURCE: 68 FR 69185, Dec. 11, 2003, unless otherwise noted.

WHAT THIS SUBPART COVERS

§ 63.7980 What is the purpose of this subpart?

This subpart establishes national emission standards for hazardous air pollutants (NESHAP) for miscellaneous coating manufacturing. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limits, operating limits, and work practice standards.

§ 63.7985 Am I subject to the requirements in this subpart?

(a) You are subject to the requirements in this subpart if you own or operate miscellaneous coating manufacturing operations, as defined in paragraph (b) of this section, that meet the conditions specified in paragraphs (a)(1) through (4) of this section.

(1) Are located at or are part of a major source of hazardous air pollutants (HAP) emissions, as defined in section 112(a) of the Clean Air Act (CAA).

(2) Manufacture coatings as defined in § 63.8105.

(3) Process, use, or produce HAP.

(4) Are not part of an affected source under another subpart of this part 63.

(b) Miscellaneous coating manufacturing operations include the facilitywide collection of equipment described in paragraphs (b)(1) through (4) of this section that is used to manufacture coatings as defined in § 63.8105. Miscellaneous coating manufacturing operations also include cleaning operations.

(1) Process vessels.

(2) Storage tanks for feedstocks and products.

(3) Components such as pumps, compressors, agitators, pressure relief devices, sampling connection systems, open-ended valves or lines, valves, connectors, and instrumentation systems.

(4) Wastewater tanks and transfer racks.

(c) If the predominant use of a transfer rack loading arm or storage tank (including storage tanks in series) is associated with miscellaneous coating manufacturing, and the loading arm or storage tank is not part of an affected source under a subpart of this part 63, then you must assign the loading arm or storage tank to the miscellaneous coating manufacturing operations. If the predominant use cannot be determined, and the loading arm or storage tank is not part of an affected source under a subpart of this part 63, then you must assign the loading arm or storage tank to the miscellaneous coating manufacturing operations. If the use varies from year to year, then you must base the determination on the utilization that occurred during the year preceding December 11, 2003 or, if the loading arm or storage tank was not in operation during that year, you must base the use on the expected use for the first 5-year period after startup. You must include the determination in the notification of compliance status report specified in § 63.8075(d). You must redetermine the predominant use at least once every 5 years after the compliance date.

(d) The requirements for miscellaneous coatings manufacturing sources in this subpart do not apply to operations described in paragraphs (d)(1) through (4) of this section.

(1) Research and development facilities, as defined in section 112(c)(7) of the CAA.

(2) The affiliated operations located at an affected source under subparts GG (National Emission Standards for Aerospace Manufacturing and Rework Facilities), KK (National Emission Standards for the Printing and Publishing Industry), JJJJ (NESHAP: Paper and Other Web Coating), future MMMM (National Emission Standards for Miscellaneous Metal Parts and Products Surface Coating Operations) and SSSS (NESHAP: Surface Coating of Metal Coil) of 40 CFR part 63. Affiliated operations include, but are not limited to, mixing or dissolving of coating ingredients; coating mixing for

viscosity adjustment, color tint or additive blending, or pH adjustment; cleaning of coating lines and coating line parts; handling and storage of coatings and solvent; and conveyance and treatment of wastewater.

(3) Ancillary equipment such as boilers and incinerators (only those not used to comply with the emission limits in Tables 1 through 5 to this subpart), chillers and refrigeration systems, and other equipment that is not directly involved in the manufacturing of a coating (*i.e.,* it operates as a closed system, and materials are not combined with materials used to manufacture the coating).

(4) Quality assurance/quality control laboratories.

§ 63.7990 What parts of my plant does this subpart cover?

(a) This subpart applies to each miscellaneous coating manufacturing affected source as defined in § 63.7985(a).

(b) The miscellaneous coating manufacturing affected source is the miscellaneous coating manufacturing operations as defined in § 63.7985(b).

(c) An affected source is a new affected source if you commenced construction or reconstruction after April 4, 2002, and you met the applicability criteria at the time you commenced construction or reconstruction.

COMPLIANCE DATES

§ 63.7995 When do I have to comply with this subpart?

(a) If you have a new affected source, you must comply with this subpart according to the requirements in paragraphs (a)(1) and (2) of this section.

(1) If you start up your new affected source before December 11, 2003, then you must comply with the requirements for new sources in this subpart no later than December 11, 2003.

(2) If you start up your new affected source after December 11, 2003, then you must comply with the requirements for new sources in this subpart upon startup of your affected source.

(b) If you have an existing affected source on December 11, 2003, then you must comply with the requirements for existing sources in this subpart no later than December 11, 2006.

(c) [Reserved]

(d) You must meet the notification requirements in § 63.8070 according to the schedule in § 63.8070 and in 40 CFR part 63, subpart A. Some of the notifications must be submitted before you are required to comply with the emission limits, operating limits, and work practice standards in this subpart.

[68 FR 69185, Dec. 11, 2003; 68 FR 75033, Dec. 29, 2003, as amended at 70 FR 25681, May 13, 2005]

EMISSION LIMITS, WORK PRACTICE STANDARDS, AND COMPLIANCE REQUIREMENTS

§ 63.8000 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limits and work practice standards in Tables 1 through 5 to this subpart at all times, except during periods of startup, shutdown, and malfunction. You must meet the requirements specified in paragraphs (b) and (c) of this section. You must meet the requirements specified in §§ 63.8005 through 63.8025 (or the alternative means of compliance in § 63.8050), except as specified in paragraph (d) of this section. You must meet the notification, reporting, and recordkeeping requirements specified in §§ 63.8070, 63.8075, and 63.8080.

(b) *General requirements.* (1) If an emission stream contains halogen atoms, and you use a combustion-based control device (excluding a flare) to meet an organic HAP emission limit, you must determine whether the emission stream meets the definition of a halogenated stream by calculating the concentration of each organic compound that contains halogen atoms using the procedures specified in § 63.115(d)(2)(v), multiplying each concentration by the number of halogen atoms in the organic compound, and summing the resulting halogen atom concentrations for all of the organic compounds in the emission stream. Alternatively, you may elect to designate the emission stream as halogenated.

(2) Opening of a safety device, as defined in § 63.8105, is allowed at any time conditions require it to avoid unsafe conditions.

(c) *Compliance requirements for closed vent systems and control devices.*If you use a control device to comply with an emission limit in Table 1, 2, or 5 to this subpart, you must comply with the requirements in subpart SS of 40 CFR part 63 as specified in paragraphs (c)(1) through (3) of this section, except as specified in paragraph (d) of this section.

(1) If you reduce organic HAP emissions by venting emissions through a closed-vent system to any combination of control devices (except a flare), you must meet the requirements of § 63.982(c) and the requirements referenced therein.

(2) If you reduce organic HAP emissions by venting emissions through a closed-vent system to a flare, you must meet the requirements of § 63.982(b) and the requirements referenced therein. You may not use a flare to control halogenated vent streams or hydrogen halide and halogen HAP emissions.

(3) If you use a halogen reduction device to reduce hydrogen halide and halogen HAP emissions that are generated by combusting halogenated vent streams, you must meet the requirements of § 63.994 and the requirements referenced therein. If you use a halogen reduction device before a combustion device, you must determine the halogen atom emission rate prior to the combustion device according to the procedures in § 63.115(d)(2)(v).

(d) *Exceptions to the requirements specified in other subparts of this part 63*—(1) *Requirements for performance tests.* The requirements specified in paragraphs (d)(1)(i) through (v) of this section apply instead of or in addition to the requirements for performance testing of control devices as specified in subpart SS of 40 CFR part 63.

(i) Conduct gas molecular weight analysis using Method 3, 3A, or 3B in appendix A to 40 CFR part 60.

(ii) Measure moisture content of the stack gas using Method 4 in appendix A to 40 CFR part 60.

(iii) As an alternative to using Method 18, Method 25/25A, or Method 26/26A of 40 CFR part 60, appendix A, to comply with any of the emission limits specified in Tables 1 through 6 to this subpart, you may use Method 320 of 40 CFR part 60, appendix A. When using Method 320, you must follow the analyte spiking procedures of section 13 of Method 320, unless you demonstrate that the complete spiking procedure has been conducted at a similar source.

(iv) Section 63.997(c)(1) does not apply. For the purposes of this subpart, results of all initial compliance demonstrations must be included in the notification of compliance status report, which is due 150 days after the compliance date, as specified in § 63.8075(d)(1).

(v) If you do not have a closed-vent system as defined in § 63.981, you must determine capture efficiency using Method 204 of appendix M to 40 CFR part 51 for all stationary process vessels subject to requirements of Table 1 to this subpart.

(2) *Design evaluation.* To determine the percent reduction of a small control device, you may elect to conduct a design evaluation as specified in § 63.1257(a)(1) instead of a performance test as specified in subpart SS of 40 CFR part 63. You must establish the value(s) and basis for the operating limits as part of the design evaluation.

(3) *Periodic verification.* For a control device with total inlet HAP emissions less than 1 ton per year (tpy), you must establish an operating limit(s) for a parameter(s) that you will measure and record at least once per averaging period (*i.e.*, daily or block) to verify that the control device is operating properly. You may elect to measure the same parameter(s) that is required for control devices that control inlet HAP emissions equal to or greater than 1 tpy. If the parameter will not be measured continuously, you must request approval of your proposed procedure in the precompliance report. You must identify the operating limit(s) and the measurement frequency, and you must provide rationale to support how these measurements demonstrate the control device is operating properly.

(4) *Continuous emissions monitoring systems.* Each continuous emissions monitoring system (CEMS) must be installed, operated, and maintained according to the requirements in § 63.8 and paragraphs (d)(4)(i) through (iv) of this section.

(i) Each CEMS must be installed, operated, and maintained according to

the applicable Performance Specification of 40 CFR part 60, appendix B, and according to paragraph (d)(4)(ii) of this section, except as specified in paragraph (d)(4)(i)(A) of this section. For any CEMS meeting Performance Specification 8, you must also comply with appendix F, procedure 1 of 40 CFR part 60.

(A) If you wish to use a CEMS other than a Fourier Transform Infrared Spectroscopy (FTIR) meeting the requirements of Performance Specification 15 to measure hydrogen halide and halogen HAP before we promulgate a Performance Specification for such CEMS, you must prepare a monitoring plan and submit it for approval in accordance with the procedures specified in §63.8.

(B) [Reserved]

(ii) You must determine the calibration gases and reporting units for TOC CEMS in accordance with paragraph (d)(4)(ii)(A), (B), or (C) of this section.

(A) For CEMS meeting Performance Specification 9 or 15 requirements, determine the target analyte(s) for calibration using either process knowledge of the control device inlet stream or the screening procedures of Method 18 on the control device inlet stream.

(B) For CEMS meeting Performance Specification 8 used to monitor performance of a combustion device, calibrate the instrument on the predominant organic HAP and report the results as carbon (C_1), and use Method 25A or any approved alternative as the reference method for the relative accuracy tests.

(C) For CEMS meeting Performance Specification 8 used to monitor performance of a noncombustion device, determine the predominant organic HAP using either process knowledge or the screening procedures of Method 18 on the control device inlet stream, calibrate the monitor on the predominant organic HAP, and report the results as C_1. Use Method 18, ASTM D6420–99, or any approved alternative as the reference method for the relative accuracy tests, and report the results as C_1.

(iii) You must conduct a performance evaluation of each CEMS according to the requirements in 40 CFR 63.8 and according to the applicable Performance Specification of 40 CFR part 60, appendix B, except that the schedule in §63.8(e)(4) does not apply, and the results of the performance evaluation must be included in the notification of compliance status report.

(iv) The CEMS data must be reduced to operating day or operating block averages computed using valid data consistent with the data availability requirements specified in §63.999(c)(6)(i)(B) through (D), except monitoring data also are sufficient to constitute a valid hour of data if measured values are available for at least two of the 15-minute periods during an hour when calibration, quality assurance, or maintenance activities are being performed. An operating block is a period of time from the beginning to end of batch operations in the manufacturing of a coating. Operating block averages may be used only for process vessel data.

(5) *Continuous parameter monitoring.* The provisions in paragraphs (d)(5)(i) through (iii) of this section apply in addition to the requirements for continuous parameter monitoring system (CPMS) in subpart SS of 40 CFR part 63.

(i) You must record the results of each calibration check and all maintenance performed on the CPMS as specified in §63.998(c)(1)(ii)(A).

(ii) When subpart SS of 40 CFR part 63 uses the term a range or operating range of a monitored parameter, it means an operating limit for a monitored parameter for the purposes of this subpart.

(iii) As an alternative to measuring pH as specified in §63.994(c)(1)(i), you may elect to continuously monitor the caustic strength of the scrubber effluent.

(6) *Startup, shutdown, and malfunction.* Sections 63.998(b)(2)(iii) and (b)(6)(i)(A), which apply to the exclusion of monitoring data collected during periods of startup, shutdown, and malfunction (SSM) from daily averages, do not apply for the purposes of this subpart.

(7) *Reporting.* (i) When §§63.8005 through 63.8025 reference other subparts in this part 63 that use the term periodic report, it means compliance report for the purposes of this subpart.

(ii) When there are conflicts between this subpart and referenced subparts for the due dates of reports required by this subpart, reports must be submitted according to the due dates presented in this subpart.

(iii) Excused excursions, as defined in subpart SS of 40 CFR part 63, are not allowed.

[68 FR 69185, Dec. 11, 2003, as amended at 70 FR 25681, May 13, 2005]

§ 63.8005 What requirements apply to my process vessels?

(a) *General.* (1) You must meet each emission limit and work practice standard in Table 1 to this subpart that applies to you, and you must meet each applicable requirement specified in § 63.8000(b), except as specified in paragraphs (a)(1)(i) and (ii) of this section.

(i) You are not required to meet the emission limits and work practice standards in Table 1 to this subpart if you comply with § 63.8050 or § 63.8055.

(ii) You must meet the emission limits and work practice standards in Table 1 to this subpart for emissions from automatic cleaning operations. You are not required to meet the emission limits and work practice standards in Table 1 to this subpart for emissions from cleaning operations that are conducted manually.

(2) For each control device used to comply with Table 1 to this subpart, you must comply with subpart SS of this part 63 as specified in § 63.8000(c), except as specified in § 63.8000(d) and paragraphs (b) through (g) of this section.

(b) When subpart SS of this part 63 refers to process vents, it means process vessel vents for the purposes of this section.

(c) Process condensers, as defined in § 63.1251, are not considered to be control devices for process vessels.

(d) *Initial compliance.* (1) To demonstrate initial compliance with a percent reduction emission limit in Table 1 to this subpart, you must conduct the performance test or design evaluation under conditions as specified in § 63.7(e)(1), except that the performance test or design evaluation must be conducted under worst-case conditions. Also, the performance test for a control device used to control emissions from process vessels must be conducted according to § 63.1257(b)(8), including the submittal of a site-specific test plan for approval prior to testing. The requirements in § 63.997(e)(1)(i) and (iii) also do not apply for performance tests conducted to determine compliance with the emission limits for process vessels.

(2) For the initial compliance demonstration for condensers, you must determine uncontrolled emissions using the procedures specified in § 63.1257(d)(2), and you must determine controlled emissions using the procedures specified in § 63.1257(d)(3)(i)(B) and (iii).

(3) You must demonstrate that each process condenser is properly operated according to the procedures specified in § 63.1257(d)(2)(i)(C)(*4*)(*ii*) and (d)(3)(iii)(B). The reference in § 63.1257(d)(3)(iii)(B) to the alternative standard in § 63.1254(c) does not apply for the purposes of this subpart. As an alternative to measuring the exhaust gas temperature, as required by § 63.1257(d)(3)(iii)(B), you may elect to measure the liquid temperature in the receiver.

(4) You must conduct a performance test or compliance demonstration equivalent to an initial compliance demonstration within 360 hours of a change in operating conditions that are not considered to be within the previously established worst-case conditions.

(e) *Establishing operating limits.* You must establish operating limits under the conditions required for your initial compliance demonstration, except you may elect to establish operating limit(s) for conditions other than those under which a performance test was conducted as specified in paragraph (e)(1) of this section and, if applicable, paragraph (e)(2) of this section.

(1) The operating limits may be based on the results of the performance test and supplementary information such as engineering assessments and manufacturer's recommendations. These limits may be established for conditions as unique as individual emission episodes. You must provide rationale in the precompliance report for the specific level for each operating limit, including any data and calculations used to

develop the limit and a description of why the limit indicates proper operation of the control device. The procedures provided in this paragraph (e)(1) have not been approved by the Administrator and determination of the operating limit using these procedures is subject to review and approval by the Administrator.

(2) If you elect to establish separate operating limits for different emission episodes, you must maintain records as specified in §63.8085(g) of each point at which you change from one operating limit to another, even if the duration of the monitoring for an operating limit is less than 15 minutes.

(f) *Averaging periods.* If you elect to establish separate operating limits for different emission episodes, you may elect to determine operating block averages instead of the daily averages specified in §63.998(b)(3). An operating block is a period of time that is equal to the time from the beginning to end of an emission episode or sequence of emission episodes.

(g) *Flow indicators.* If flow to a control device could be intermittent, you must install, calibrate, and operate a flow indicator at the inlet or outlet of the control device to identify periods of no flow. Periods of no flow may not be used in daily or block averages, and it may not be used in fulfilling a minimum data availability requirement.

[68 FR 69185, Dec. 11, 2003, as amended at 70 FR 25681, May 13, 2005]

§63.8010 What requirements apply to my storage tanks?

(a) You must meet each emission limit in Table 2 to this subpart that applies to your storage tanks, and you must meet each applicable requirement specified in §63.8000(b). For each control device used to comply with Table 2 to this subpart, you must comply with subpart SS of this part 63 as specified in §63.8000(c), except as specified in §63.8000(d) and paragraphs (b) through (d) of this section.

(b) *Exceptions to subparts SS and WW of this part 63.* (1) If you conduct a performance test or design evaluation for a control device used to control emissions only from storage tanks, you must establish operating limits, conduct monitoring, and keep records using the same procedures as required in subpart SS of this part 63 for control devices used to reduce emissions from process vents instead of the procedures specified in §§63.985(c), 63.998(d)(2)(i), and 63.999(b)(2).

(2) When the term storage vessel is used in subparts SS and WW of this part 63, the term storage tank, as defined in §63.8105 applies for the purposes of this subpart.

(c) *Planned routine maintenance.* The emission limits in Table 2 to this subpart for control devices used to control emissions from storage tanks do not apply during periods of planned routine maintenance. Periods of planned routine maintenance of each control device, during which the control device does not meet the emission limit specified in Table 2 to this subpart, must not exceed 240 hours per year (hr/yr). You may submit an application to the Administrator requesting an extension of this time limit to a total of 360 hr/yr. The application must explain why the extension is needed, it must indicate that no material will be added to the storage tank between the time the 240 hr/yr limit is exceeded and the control device is again operational, and it must be submitted at least 60 days before the 240 hr/yr limit will be exceeded.

(d) *Vapor balancing alternative.* As an alternative to the emission limits specified in Table 2 to this subpart, you may elect to implement vapor balancing in accordance with §63.1253(f), except as specified in paragraphs (d)(1) and (2) of this section.

(1) To comply with §63.1253(f)(6)(i), the owner or operator of an offsite cleaning and reloading facility must comply with §§63.7995 through 63.8105 instead of complying with §63.1253(f)(7)(ii).

(2) You may elect to set a pressure relief device to a value less than the 2.5 psig required in §63.1253(f)(5) if you provide rationale in your notification of compliance status report explaining why the alternative value is sufficient to prevent breathing losses at all times.

§ 63.8015 What requirements apply to my equipment leaks?

(a) You must meet each requirement in Table 3 to this subpart that applies to your equipment leaks, except as specified in paragraphs (b) through (d) of this section.

(b) *Exceptions to requirements in § 63.424(a).* (1) When § 63.424(a) refers to ''a bulk gasoline terminal or pipeline breakout station subject to the provisions of this subpart,'' the phrase ''a miscellaneous coating manufacturing affected source subject to 40 CFR part 63, subpart HHHHH'' shall apply for the purposes of this subpart.

(2) When § 63.424(a) refers to ''equipment in gasoline service,'' the phrase ''equipment in organic HAP service'' shall apply for the purposes of this subpart.

(3) When § 63.424(a) specifies that ''each piece of equipment shall be inspected during loading of a gasoline cargo tank,'' the phrase ''each piece of equipment must be inspected when it is operating in organic HAP service'' shall apply for the purposes of this subpart.

(4) Equipment in service less than 300 hours per year, equipment in vacuum service, or equipment contacting nonprocess fluids is excluded from this section.

(c) When § 63.1036 refers to batch processes, any part of the miscellaneous coating manufacturing operations applies for the purposes of this subpart.

(d) For the purposes of this subpart, pressure testing for leaks in accordance with § 63.1036(b) is not required after reconfiguration of an equipment train if flexible hose connections are the only disturbed equipment.

[68 FR 69185, Dec. 11, 2003, as amended at 70 FR 25681, May 13, 2005]

§ 63.8020 What requirements apply to my wastewater streams?

(a) You must meet each requirement in Table 4 to this subpart that applies to your wastewater streams, and you must meet each applicable requirement specified in § 63.8000 and paragraphs (b) through (d) of this section.

(b) For each wastewater stream that you generate, you must either designate the wastewater stream as a Group 1 wastewater stream according to the procedures in paragraph (b)(1) of this section, or you must determine whether the wastewater stream is a Group 1 wastewater stream according to the procedures in paragraph (b)(2) of this section.

(1) You may designate any wastewater stream as a Group 1 wastewater stream. You do not have to determine the concentration for any designated Group 1 wastewater stream.

(2) For wastewater streams that you do not designate as Group 1 wastewater streams, you must use the procedures specified in § 63.144(b) to establish the concentrations, except as specified in paragraphs (b)(2)(i) and (ii) of this section.

(i) References to Table 8 compounds in § 63.144 do not apply for the purposes of this subpart.

(ii) *Alternative test methods.* (A) As an alternative to the test methods specified in § 63.144(b)(5)(i), you may use Method 8260 or 8270 as specified in § 63.1257(b)(10)(iii).

(B) As an alternative to using the methods specified in § 63.144(b)(5)(i), you may conduct wastewater analyses using Method 1666 or 1671 of 40 CFR part 136, appendix A, and comply with the sampling protocol requirements specified in § 63.144(b)(5)(ii). The validation requirements specified in § 63.144(b)(5)(iii) do not apply if you use Method 1666 or 1671 of 40 CFR part 136, appendix A.

(c) For each enhanced biological treatment unit used to comply with the requirements in Table 4 to this subpart, you must monitor total suspended solids (TSS), biological oxygen demand (BOD), and the biomass concentration. In the precompliance report you must identify and provide rationale for proposed operating limits for these parameters, methods for monitoring, the frequency of monitoring, and recordkeeping and reporting procedures that will demonstrate proper operation of the enhanced biological treatment unit. Alternatively, you may use the precompliance report to request to monitor other parameters, and you must include a description of planned reporting and recordkeeping procedures and the basis for the selected monitoring frequencies and the methods that will be used.

(d) If you transfer the wastewater offsite for enhanced biological treatment, you must obtain written certification from the offsite facility stating that the offsite facility will comply with the requirements of this subpart. The certifying entity may revoke the certification by providing 90 days notice. Upon expiration of the notice period, you may not transfer wastewater to that treatment facility.

§63.8025 What requirements apply to my transfer operations?

(a) You must comply with each emission limit and work practice standard in Table 5 to this subpart that applies to your transfer operations, and you must meet all applicable requirements specified in §63.8000(b). For each control device used to comply with Table 5 to this subpart, you must comply with subpart SS of this part 63 as specified in §63.8000(c), except as specified in §63.8000(d) and paragraph (b) of this section.

(b) If you have Group 1 transfer operations, as defined in §63.8105, then all transfer racks used for bulk loading coatings must meet the requirements for high throughput transfer racks in subpart SS of this part.

§63.8030 What requirements apply to my heat exchange systems?

(a) You must comply with the requirements specified in Table 6 to this subpart that apply to your heat exchange systems, except as specified in paragraphs (b) through (e) of this section.

(b) The phrase a chemical manufacturing process unit meeting the conditions of §63.100(b)(1) through (b)(3) of this section in §63.104(a) means the miscellaneous coating manufacturing operations defined in §63.7985(b) for the purposes of this subpart.

(c) The reference to §63.100(c) in §63.104(a) does not apply for the purposes of this subpart.

(d) The reference to §63.103(c)(1) in §63.104(f)(1) does not apply. For the purposes of this subpart, records must be retained as specified in §63.10(b)(1).

(e) The reference to the periodic report required by §63.152(c) of subpart G of this part means the compliance report required by §63.8075(e) for the purposes of this subpart.

ALTERNATIVE MEANS OF COMPLIANCE

§63.8050 How do I comply with emissions averaging for stationary process vessels at existing sources?

(a) As an alternative to complying with the requirements in Table 1 to this subpart for each individual stationary process vessel, you may elect to comply with emissions averaging for stationary process vessels greater than or equal to 250 gallons (gal) at your existing affected source as specified in paragraphs (b) through (e) of this section.

(b) *General requirements.* (1) A State may prohibit averaging of HAP emissions and require the owner or operator of an existing affected source to comply with the emission limits and work practice standards in Table 1 to this subpart.

(2) All stationary process vessels in an emissions averaging group must be equipped with a tightly-fitting vented cover.

(c) *Initial compliance.* To demonstrate initial compliance with the emissions averaging alternative, you must comply with the provisions in paragraphs (c)(1) through (4) of this section.

(1) Estimate uncontrolled emissions from each affected stationary process vessel in pounds per batch using the procedures specified in §63.1257(d)(2), except as specified in paragraphs (c)(1)(i) and (ii) of this section. For the purposes of this section, uncontrolled emissions means the emissions from the vessel if it were equipped only with a tightly-fitting vented cover. You must identify the range of typical operating parameters and perform the calculation using the values that result in the highest emissions, and you must document the operating parameters and resulting emissions calculations in the precompliance report.

(i) When you are required to calculate uncontrolled emissions from heating, you may not calculate emissions using Equation 13 of subpart GGG of this part 63.

(ii) The statement in §63.1257(d)(2)(i)(B) that ‘‘the partial pressure of HAP shall be assumed to be 25 percent of the saturated value if the

purge flow rate is greater than 100 scfm'' does not apply. For the purposes of this subpart, multiply the HAP partial pressure in Equation 12 of 40 CFR part 63, subpart GGG by a HAP-specific saturation factor determined in accordance with Equations 1 through 3 of this section. Solve equation 1 of this section iteratively beginning with saturation factors (in the right-hand side of the equation) of 1.0 for each condensable compound. Stop iterating when the calculated saturation factors for all compounds are the same to two significant figures for subsequent iterations. Note that for multi-component emission streams, saturation factors must be calculated for all condensable compounds, not just the HAP.

$$S_i = \frac{K_i A}{K_i A + V + \sum_{i=1}^{n} S_i V_i^{sat}} \qquad \text{Eq. 1}$$

$$V_i^{sat} = \frac{V P_i}{\left(P_T - \sum_{i=1}^{n} P_i\right)} \qquad \text{Eq. 2}$$

$$K_i = K_o \left(\frac{M_o}{M_i}\right)^{1/3} \qquad \text{Eq. 3}$$

where:

S_1=saturation factor for individual condensable compounds in the emission stream

P_i=partial pressure of individual condensable compounds in the emission stream calculated using Raoult's Law or other appropriate methods

P_T=pressure of the vessel vapor space

A=surface area of liquid

V=purge flow rate as used in Equation 12 of 40 CFR part 63, subpart GGG

V_i^{sat}=volumetric flowrate of condensable compounds in the emission stream

K_i=mass transfer coefficient of individual condensable compounds in the emission stream

K_o=mass transfer coefficient of a reference compound (e.g., 0.83 cm/s for water)

M_o=molecular weight of reference compound (e.g., 18.02 for water)

M_i=molecular weight of individual condensable compounds in the emission stream

n=number of condensable compounds in the emission stream

(2) Estimate controlled emissions in pounds per batch for each vessel as specified in paragraphs (c)(2)(i) through (iii) of this section.

(i) Except as specified in paragraphs (c)(2)(ii) and (iii) of this section, estimate controlled emissions as if the vessel were controlled in compliance with entry 2.b.i. in Table 1 to this subpart.

(ii) Estimate the controlled emissions using the control level achieved on November 15, 1990 if that value is greater than the applicable control level required by entry 2.b.i in Table 1 to this subpart.

(iii) Estimate the controlled emissions using the control level required to comply with a State or Federal rule other than this subpart if that level is greater than the applicable control level required by entry 2.b.i in Table 1 to this subpart and the other rule was in effect before the date when you request approval to comply with emissions averaging.

(3) Determine actual emissions in pounds per batch for each vessel in accordance with paragraph (c)(3)(i), (ii), or (iii) of this section, as applicable.

(4) Provide rationale in the precompliance report for why the sum of the actual emissions will be less than the sum of emissions from the vessels if they had been controlled in accordance with Table 1 to this subpart. The approved actual emissions calculated according to paragraph (c)(3) of this section are emission limits that must be incorporated into your operating permit.

(d) *Continuous compliance.* (1) Maintain a monthly log of the number of batches produced that can be correlated with the emissions estimates per batch developed in accordance with paragraph (c) of this section.

(2) Sum the actual emissions for all of the process vessels in the emissions averaging group every three months, with the first 3-month period beginning on the compliance date, and compare the resulting total with the total emissions for the vessels calculated in accordance with paragraph (c)(2) of this section. Compliance is demonstrated if the sum of the actual emissions is less than the emissions estimated in accordance with paragraph (c)(2) of this section.

(3) For control devices, establish operating limits and monitor as specified in §63.8000.

(e) *Recordkeeping and reporting.* Comply with §§63.8070, 63.8075, and 63.8080.

[68 FR 69185, Dec. 11, 2003, as amended at 70 FR 25682, May 13, 2005]

§63.8055 How do I comply with a weight percent HAP limit in coating products?

(a) As an alternative to complying with the requirements in Table 1 to this subpart for each individual stationary process vessel at an existing source, you may elect to comply with a 5 weight percent HAP limit for process vessels at your affected source that are used to manufacture coatings with a HAP content of less than 0.05 kg per kg product as specified in paragraph (b) of this section.

(b) You may only comply with the alternative during the production of coatings that contain less than 5 weight percent HAP, as determined using any of the procedures specified in paragraphs (b)(1) through (4) of this section.

(1) Method 311 (appendix A to 40 CFR part 63).

(2) Method 24 (appendix A to 40 CFR part 60). You may use Method 24 to determine the mass fraction of volatile matter and use that value as a substitute for the mass fraction of HAP.

(3) You may use an alternative test method for determining mass fraction of HAP if you obtain prior approval by the Administrator. You must follow the procedure in §63.7(f) to submit an alternative test method for approval.

(4) You may rely on formulation data from raw material suppliers if it represents each organic HAP that is present at 0.1 percent by mass or more for OSHA-defined carcinogens, as specified in 29 CFR 1910.1200(d)(4), and at 1.0 percent by mass or more for other compounds. If the HAP weight percent estimated based on formulation data conflicts with the results of a test conducted according to paragraphs (b)(1) through (3) of this section, then there is a rebuttal presumption that the test results are accurate unless, after consultation, you demonstrate to the satisfaction of the permitting authority that the test results are not accurate and that the formulation data are more appropriate.

[68 FR 69185, Dec. 11, 2003, as amended at 70 FR 25682, May 13, 2005; 70 FR 75927, Dec. 21, 2005]

NOTIFICATION, REPORTS, AND RECORDS

§63.8070 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.6(h)(4) and (5), 63.7(b) and (c), 63.8(e), (f)(4) and (6), 63.9(b) through (h) that apply to you by the dates specified.

(b) *Initial notification.* (1) As specified in §63.9(b)(2), if you have an existing affected source on December 11, 2003, you must submit an initial notification not later than 120 calendar days after December 11, 2003.

(2) As specified in §63.9(b)(3), if you start up your new affected source on or after December 11, 2003, you must submit an initial notification not later than 120 calendar days after you become subject to this subpart.

(c) *Notification of performance test.* If you are required to conduct a performance test, you must submit a notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin as required in §63.7(b)(1). For any performance test required as part of the initial compliance procedures for process vessels in Table 1 to this subpart, you must also submit the test plan required by §63.7(c) and the emission profile with the notification of the performance test.

§63.8075 What reports must I submit and when?

(a) You must submit each report in Table 9 to this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under §63.10(a), you must submit each report as specified in Table 9 to this subpart and paragraphs (b)(1) and (2) of this section.

(1) The compliance reports must be submitted semiannually. The first report must be submitted no later than 240 days after the applicable compliance date and shall cover the 6-month period beginning on the compliance

date. Each subsequent compliance report must cover the 6-month period following the preceding period.

(2) For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates in Table 9.

(c) *Precompliance report.* You must submit a precompliance report to request approval of any of the information in paragraphs (c)(1) through (4) of this section. We will either approve or disapprove the report within 90 days after we receive it. If we disapprove the report, you must still be in compliance with the emission limitations and work practice standards in this subpart by the compliance date.

(1) Requests for approval to set operating limits for parameters other than those specified in §§63.8005 through 63.8025, including parameters for enhanced biological treatment units. Alternatively, you may make these requests according to §63.8(f).

(2) Descriptions of daily or per batch demonstrations to verify that control devices subject to §63.8000(d)(3) are operating as designed.

(3) A description of the test conditions, data, calculations, and other information used to establish operating limits according to §63.8005(e)(1).

(4) If you comply with emissions averaging in §63.8050, the data and results of emission calculations as specified in §63.8050(c)(1) through (3), and rationale for why the sum of actual emissions will be less than the sum of emissions if the process vessels were controlled in accordance with Table 1 to this subpart as specified in §63.8050(c)(4).

(d) *Notification of compliance status report.* You must submit a notification of compliance status report according to the schedule in paragraph (d)(2) of this section, and the notification of compliance status report must include the information specified in paragraph (d)(2) of this section.

(1) You must submit the notification of compliance status report no later than 150 days after the applicable compliance date specified in §63.7995.

(2) The notification of compliance status report must include the information in paragraphs (d)(3)(i) through (vi) of this section.

(i) The results of any applicability determinations (*e.g.*, HAP content of coating products; halogenated vent stream determinations; group determinations for storage tanks, wastewater, and transfer operations; and equipment that is in organic HAP service).

(ii) The results of performance tests, engineering analyses, design evaluations, flare compliance assessments, inspections and repairs, and calculations used to demonstrate initial compliance according to §§63.8005 through 63.8025 and 63.8055. For performance tests, results must include descriptions of sampling and analysis procedures and quality assurance procedures.

(iii) Descriptions of monitoring devices, monitoring frequencies, and the operating limits established during the initial compliance demonstrations, including data and calculations to support the levels you establish.

(iv) Identification of parts of the affected source that are subject to overlapping requirements described in §63.8090 and the authority under which you will comply.

(v) Identify storage tanks for which you are complying with the vapor balancing alternative in §63.8010(e).

(vi) If you transfer Group 1 wastewater stream to an offsite facility for treatment, include the name and location of the transferee and a description of the Group 1 wastewater stream that is sent to the treatment facility. If the offsite facility provides enhanced biological treatment, also include the certification required by §63.8020(d) that the offsite facility will comply with the requirements of this subpart.

(e) *Compliance report.* The compliance report must contain the information specified in paragraphs (e)(1) through (8) of this section.

(1) Company name and address.

(2) Statement by a responsible official with that official's name, title, and signature, certifying the accuracy of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) Applicable records and information for periodic reports as specified in referenced subparts F, SS, TT, UU, and WW of this part 63.

(5) For each SSM during which excess emissions occur, the compliance report must include the information specified in paragraphs (e)(5)(i) and (ii) of this section.

(i) Records that the procedures specified in your startup, shutdown, and malfunction plan (SSMP) were followed or documentation of actions taken that are not consistent with the SSMP.

(ii) A description of each malfunction.

(6) The compliance report must contain the information on deviations, as defined in §63.8105, according to paragraphs (e)(6)(i), (ii), and (iii) of this section.

(i) If there are no deviations from any emission limit, operating limit, or work practice standard specified in this subpart, include a statement that there were no deviations from the emission limits, operating limits, or work practice standards during the reporting period.

(ii) For each deviation from an emission limit, operating limit, and work practice standard that occurs at an affected source where you are not using a continuous monitoring system (CMS) to comply with the emission limit or work practice standards in this subpart, you must include the information in paragraphs (e)(6)(ii)(A) through (C) of this section.

(A) The total operating time of each affected source during the reporting period.

(B) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(C) Operating logs for the day(s) during which the deviation occurred, except operating logs are not required for deviations of the work practice standards for equipment leaks.

(iii) For each deviation from an emission limit or operating limit occurring at an affected source where you are using a CMS to comply with the emission limit in this subpart, you must include the information in paragraphs (e)(6)(iii)(A) through (K) of this section. This includes periods of SSM.

(A) The date and time that each CMS was inoperative, except for zero (low-level) and high-level checks.

(B) The date, time, and duration that each CEMS was out-of-control, including the information in §63.8(c)(8).

(C) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(D) A summary of the total duration of the deviation during the reporting period, and the total duration as a percent of the total source operating time during that reporting period.

(E) A breakdown of the total duration of the deviations during the reporting period into those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and other unknown causes.

(F) A summary of the total duration of CMS downtime during the reporting period, and the total duration of CMS downtime as a percent of the total source operating time during that reporting period.

(G) An identification of each HAP that is known to be in the emission stream or wastewater stream, as applicable.

(H) A description of the product being produced.

(I) Identification of the CMS.

(J) The date of the latest CMS certification or audit.

(K) The operating day or operating block average values of monitored parameters for each day(s) during which the deviation occurred.

(7) If you use a CEMS, and there were no periods during which it was out-of-control as specified in §63.8(c)(7), include a statement that there were no periods during which the CEMS was out-of-control during the reporting period.

(8) *Notification of process change.* (i) Except as specified in paragraph

(e)(8)(ii) of this section, whenever you change any of the information submitted in either the notification of compliance status report or any previously reported change to the notification of compliance status report, you must document the change in your compliance report. The notification must include all of the information in paragraphs (e)(8)(i)(A) and (B) of this section.

(A) Revisions to any of the information reported in the original notification of compliance status report under paragraph (d) of this section.

(B) Information required by the notification of compliance status report under paragraph (d) of this section for changes involving the addition of processes or equipment at the affected source.

(ii) You must submit a report 60 days before the scheduled implementation date of any of the changes identified in paragraphs (e)(8)(ii)(A), (B), or (C) of this section.

(A) Any change to the information contained in either the precompliance report or any previously reported change to the precompliance report.

(B) A change in the status of a control device from small to large.

(C) A change in compliance status.

§ 63.8080 What records must I keep?

You must keep the records specified in paragraphs (a) through (g) of this section.

(a) Each applicable record required by subpart A of this part 63 and in referenced subparts SS, TT, UU, and WW of this part 63.

(b) If complying with emissions averaging, records of the monthly number of batches for each process vessel, the quarterly actual emissions for each process vessel, the quarterly estimated emissions for each process vessel if it had been controlled as specified in Table 1 to this subpart, and comparison of the sums of the quarterly actual and estimated emissions as specified in § 63.8050(d).

(c) A record of each time a safety device is opened to avoid unsafe conditions in accordance with § 63.8000(b)(2).

(d) Records of the results of each CPMS calibration check and the maintenance performed, as specified in § 63.8000(d)(5).

(e) For each CEMS, you must keep the records of the date and time that each deviation started and stopped, and whether the deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(f) In the SSMP required by § 63.6(e)(3), you are not required to include Group 2 or non-affected emission points. For equipment leaks only, the SSMP requirement is limited to control devices and is optional for other equipment.

(g) If you establish separate operating limits as allowed in § 63.8005(e), you must maintain a log of operation or a daily schedule indicating the time when you change from one operating limit to another.

OTHER REQUIREMENTS AND INFORMATION

§ 63.8090 What compliance options do I have if part of my plant is subject to both this subpart and another subpart?

(a) *Compliance with 40 CFR parts 264 and 265, subparts AA, BB, and/or CC.* (1) After the compliance dates specified in § 63.7995, if a control device that you use to comply with this subpart is also subject to monitoring, recordkeeping, and reporting requirements in 40 CFR part 264, subpart AA, BB, or CC; or the monitoring and recordkeeping requirements in 40 CFR part 265, subpart AA, BB, or CC; and you comply with the periodic reporting requirements under 40 CFR part 264, subpart AA, BB, or CC that would apply to the device if your facility had final-permitted status, you may elect to comply either with the monitoring, recordkeeping, and reporting requirements of this subpart; or with the monitoring and recordkeeping requirements in 40 CFR part 264 or 265 and the reporting requirements in 40 CFR part 264, as described in this paragraph (a), which constitute compliance with the monitoring, recordkeeping, and reporting requirements of this subpart. If you elect to comply with the monitoring, recordkeeping, and reporting requirements in 40 CFR parts 264 and/or 265, you must report the information required for the compliance report in § 63.8075(e), and you must identify in the notification of compliance

status report required by §63.8075(d) the monitoring, recordkeeping, and reporting authority under which you will comply.

(2) After the compliance dates specified in this section, if any equipment at an affected source that is subject to this subpart is also subject to 40 CFR part 264, subpart BB or to 40 CFR part 265, subpart BB, then compliance with the recordkeeping and reporting requirements of 40 CFR part 264 and/or 265 may be used to comply with the recordkeeping and reporting requirements of §63.1255, to the extent that the requirements of 40 CFR part 264 and/or 265 duplicate the requirements of this subpart. You must identify in the notification of compliance status report required by §63.8075(d) if you will comply with the recordkeeping and reporting authority under 40 CFR part 264 and/or 265.

(b) *Compliance with 40 CFR part 60, subpart Kb.* After the compliance dates specified in §63.7995, you are in compliance with this subpart for any storage tank that is assigned to miscellaneous coating manufacturing operations and that is both controlled with a floating roof and in compliance with the provisions of 40 CFR part 60, subpart Kb. You are in compliance with this subpart if you have a storage tank with a fixed roof, closed-vent system, and control device in compliance with 40 CFR part 60, subpart Kb, you must comply with the monitoring, recordkeeping, and reporting requirements in this subpart. You must also identify in your notification of compliance status report required by §63.8075(d) which storage tanks are in compliance with 40 CFR part 60, subpart Kb.

§63.8095 What parts of the General Provisions apply to me?

Table 10 to this subpart shows which parts of the General Provisions in §§63.1 through 63.15 apply to you.

§63.8100 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the U.S. Environmental Protection Agency (U.S. EPA), or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency also has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out if this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraphs (b)(1) through (4) of this section are retained by the Administrator of U.S. EPA and are not delegated to the State, local, or tribal agency.

(1) Approval of alternatives to the non-opacity emission limits and work practice standards in §63.8000(a) under §63.6(g).

(2) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90.

(3) Approval of major alternatives to monitoring under §63.8(f) and as defined in §63.90.

(4) Approval of major alternatives to recordkeeping and reporting under §63.10(f) and as defined in §63.90.

§63.8105 What definitions apply to this subpart?

(a) For an affected source complying with the requirements in subpart SS of this part 63, the terms used in this subpart and in subpart SS of this part 63 have the meaning given them in §63.981, except as specified in §§63.8000(d)(5)(ii) and (7), 63.8010(c)(2), 63.8025(b), and paragraph (g) of this section.

(b) For an affected source complying with the requirements in subpart TT of this part 63, the terms used in this subpart and in subpart TT of this part 63 have the meaning given them in §63.1001.

(c) For an affected source complying with the requirements in subpart UU of this part 63, the terms used in this subpart and in subpart UU of this part 63 have the meaning given them in §63.1020.

(d) For an affected source complying with the requirements in subpart WW of this part 63, the terms used in this subpart and subpart WW of this part 63 have the meaning given them in §63.1061, except as specified in

§§ 63.8000(d)(7), 63.8010(c)(2), and paragraph (g) of this section.

(e) For an affected source complying with requirements in §§ 63.1253, 63.1257, and 63.1258, the terms used in this subpart and in §§ 63.1253, 63.1257, and 63.1258 have the meaning given them in § 63.1251, except as specified in § 63.8000(d)(7) and paragraph (g) of this section.

(f) For an affected source complying with the requirements of § 63.104, the terms used in this subpart and in § 63.104 have the meaning given them in § 63.101, except as specified in § 63.8000(d)(7) and paragraph (g) of this section.

(g) All other terms used in this subpart are defined in the CAA, in 40 CFR 63.2, and in this paragraph (g). If a term is defined in § 63.2, § 63.981, § 63.1001, § 63.1020, § 63.1061, or § 63.1251 and in this paragraph (g), the definition in this paragraph (g) applies for the purposes of this subpart.

Bulk loading means the loading, into a tank truck or rail car, of liquid coating products that contain one or more of the organic HAP, as defined in section 112 of the CAA, from a loading rack. A loading rack is the system used to fill tank trucks and railcars at a single geographic site.

Coating means any material such as a paint, ink, or adhesive that is intended to be applied to a substrate and consists of a mixture of resins, pigments, solvents, and/or other additives. Typically, these materials are described by Standard Industry Classification (SIC) codes 285 or 289 and North American Industry Classification System (NAICS) codes 3255 and 3259.

Construction means the onsite fabrication, erection, or installation of an affected source. Addition of new equipment to an affected source does not constitute construction, but it may constitute reconstruction of the affected source if it satisfies the definition of reconstruction in § 63.2.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart including, but not limited to, any emission limit, operating limit, or work practice standard;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or

(3) Fails to meet any emission limit, operating limit, or work practice standard in this subpart during startup, shutdown, or malfunction, regardless of whether or not such failure is permitted by this subpart.

Enhanced biological treatment system means an aerated, thoroughly mixed treatment unit(s) that contains biomass suspended in water followed by a clarifier that removes biomass from the treated water and recycles recovered biomass to the aeration unit. The mixed liquor volatile suspended solids (biomass) is greater than 1 kilogram per cubic meter throughout each aeration unit. The biomass is suspended and aerated in the water of the aeration unit(s) either by submerged air flow or mechanical agitation. A thoroughly mixed treatment unit is a unit that is designed and operated to approach or achieve uniform biomass distribution and organic compound concentration throughout the aeration unit by quickly dispersing the recycled biomass and the wastewater entering the unit.

Excess emissions means emissions greater than those allowed by the emission limit.

Group 1a storage tank means a storage tank at an existing source with a capacity greater than or equal to 20,000 gal storing material that has a maximum true vapor pressure of total organic HAP greater than or equal to 1.9 pounds per square inch, absolute (psia). Group 1a storage tank also means a storage tank at a new source with either a capacity greater than or equal to 25,000 gal storing material that has a maximum true vapor pressure of total HAP greater than or equal to 0.1 psia or a capacity greater than or equal to 20,000 gal and less than 25,000 gal storing material that has a maximum true vapor pressure of total HAP greater than or equal to 1.5 psia.

Group 1b storage tank means a storage tank at a new source that has a capacity greater than or equal to 10,000 gal, stores material that has a maximum true vapor pressure of total organic HAP greater than or equal to 0.02 psia, and is not a Group 1a storage tank.

Group 2 storage tank means a storage tank that does not meet the definition of a Group 1a or Group 1b storage tank.

Group 1 transfer operations means all bulk loading of coating products if the coatings contain greater than or equal to 3.0 million gallons per year (gal/yr) of HAP with a weighted average HAP partial pressure greater than or equal to 1.5 psia.

Group 2 transfer operations means bulk loading of coating products that does not meet the definition of Group 1 transfer operations, and all loading of coating products from a loading rack to other types of containers such as cans, drums, and totes.

Group 1 wastewater stream means a wastewater stream that contains total partially soluble and soluble HAP at an annual average concentration greater than or equal to 4,000 parts per million by weight (ppmw) and load greater than or equal to 750 pounds per year (lb/yr) at an existing source or greater than or equal to 1,600 ppmw and any partially soluble and soluble HAP load at a new source.

Group 2 wastewater stream means a wastewater stream that does not meet the definition of a Group 1 wastewater stream.

Halogenated vent stream means a vent stream determined to contain halogen atoms in organic compounds at a concentration greater than or equal to 20 ppmv as determined by the procedures specified in §63.8000(b).

Hydrogen halide and halogen HAP means hydrogen chloride, chlorine, and hydrogen fluoride.

In organic HAP service means that a piece of equipment either contains or contacts a fluid (liquid or gas) that is at least 5 percent by weight of total organic HAP as determined according to the provisions of §63.180(d). The provisions of §63.180(d) also specify how to determine that a piece of equipment is not in organic HAP service.

Large control device means a control device that controls total HAP emissions of greater than or equal to 10 tpy, before control.

Maximum true vapor pressure means the equilibrium partial pressure exerted by the total organic HAP in the stored or transferred liquid at the temperature equal to the highest calendar-month average of the liquid storage or transfer temperature for liquids stored or transferred above or below the ambient temperature or at the local maximum monthly average temperature as reported by the National Weather Service for liquids stored or transferred at the ambient temperature, as determined:

(1) In accordance with methods described in American Petroleum Institute Publication 2517, Evaporative Loss From External Floating-Roof Tanks (incorporated by reference as specified in §63.14 of subpart A of this part 63); or

(2) As obtained from standard reference texts; or

(3) As determined by the American Society for Testing and Materials Method D2879–83 (incorporated by reference as specified in §63.14 of subpart A of this part); or

(4) Any other method approved by the Administrator.

Partially soluble HAP means HAP listed in Table 7 of this subpart.

Point of determination (POD) means each point where process wastewater exits the miscellaneous coating operations.

NOTE TO DEFINITION FOR POINT OF DETERMINATION: The regulation allows determination of the characteristics of a wastewater stream at the point of determination or downstream of the point of determination if corrections are made for changes in flow rate and annual average concentration of partially soluble and soluble HAP compounds as determined in §63.144. Such changes include losses by air emissions; reduction of annual average concentration or changes in flow rate by mixing with other water or wastewater streams; and reduction in flow rate or annual average concentration by treating or otherwise handling the wastewater stream to remove or destroy HAP.

Process vessel means any stationary or portable tank or other vessel with a capacity greater than or equal to 250 gal and in which mixing, blending, diluting, dissolving, temporary holding, and other processing steps occur in the manufacturing of a coating.

Process vessel vent means a vent from a process vessel or vents from multiple process vessels that are manifolded together into a common header, through which a HAP-containing gas stream is, or has the potential to be, released to the atmosphere. Emission streams that are undiluted and uncontrolled containing less than 50 ppmv HAP, as determined through process knowledge that no HAP are present in the emission stream or using an engineering assessment as discussed in §63.1257(d)(2)(ii), test data using Method 18 of 40 CFR part 60, appendix A, or any other test method that has been validated according to the procedures in Method 301 of appendix A of this part, are not considered process vessel vents. Flexible elephant trunk systems when used with closed vent systems and drawing ambient air (*i.e.,* the system is not ducted, piped, or otherwise connected to the unit operations) away from operators when vessels are opened are not process vessel vents. Process vessel vents do not include vents on storage tanks, wastewater emission sources, or pieces of equipment subject to the requirements in Table 3 of this subpart. A gas stream going to a fuel gas system is not a process vessel vent. A gas stream routed to a process for a process purpose is not a process vessel vent.

Recovery device, as used in the wastewater provisions, means an individual unit of equipment used for the purpose of recovering chemicals for fuel value (*i.e.,* net positive heating value), use, reuse, or for sale for fuel value, use, or reuse. Examples of equipment that may be recovery devices include organic removal devices such as decanters, strippers, or thin-film evaporation units. To be a recovery device, a decanter and any other equipment based on the operating principle of gravity separation must receive only multiphase liquid streams. A recovery device is considered part of the miscellaneous coating manufacturing operations.

Responsible official means responsible official as defined in 40 CFR 70.2.

Safety device means a closure device such as a pressure relief valve, frangible disc, fusible plug, or any other type of device which functions exclusively to prevent physical damage or permanent deformation to a unit or its air emission control equipment by venting gases or vapors directly to the atmosphere during unsafe conditions resulting from an unplanned, accidental, or emergency event. For the purposes of this subpart, a safety device is not used for routine venting of gases or vapors from the vapor headspace underneath a cover such as during filling of the unit or to adjust the pressure in response to normal daily diurnal ambient temperature fluctuations. A safety device is designed to remain in a closed position during normal operations and open only when the internal pressure, or another relevant parameter, exceeds the device threshold setting applicable to the air emission control equipment as determined by the owner or operator based on manufacturer recommendations, applicable regulations, fire protection and prevention codes and practices, or other requirements for the safe handling of flammable, combustible, explosive, reactive, or hazardous materials.

Shutdown means the cessation of operation of an affected source, any process vessels within an affected source, or equipment required or used to comply with this subpart if steps taken to cease operation differ from those under routine procedures for removing the vessel or equipment from service. Shutdown also applies to the emptying and degassing of storage tanks.

Small control device means a control device that controls total HAP emissions of less than 10 tpy, before control.

Soluble HAP means the HAP listed in Table 8 of this subpart.

Startup means the setting in operation of a new affected source. For new equipment added to an affected source, including equipment required or used to comply with this subpart, startup means the first time the equipment is put into operation. Startup includes the setting in operation of equipment any time the steps taken differ from routine procedures for putting the equipment into operation.

Storage tank means a tank or other vessel that is used to store organic liquids that contain one or more HAP as raw material feedstocks or products.

The following are not considered storage tanks for the purposes of this subpart:

(1) Vessels permanently attached to motor vehicles such as trucks, railcars, barges, or ships;

(2) Pressure vessels designed to operate in excess of 204.9 kilopascals and without emissions to the atmosphere;

(3) Vessels storing organic liquids that contain HAP only as impurities;

(4) Wastewater storage tanks; and

(5) Process vessels.

Total organic compounds or (TOC) means the total gaseous organic compounds (minus methane and ethane) in a vent stream.

Wastewater storage tank means a stationary structure that is designed to contain an accumulation of wastewater and is constructed primarily of nonearthen materials (*e.g.*, wood, concrete, steel, plastic) which provide structural support.

Wastewater stream means water that is discarded from miscellaneous coating manufacturing operations through a POD, and that contains an annual average concentration of total partially soluble and soluble HAP compounds of at least 1,600 ppmw at any flow rate. For the purposes of this subpart, noncontact cooling water is not considered a wastewater stream.

Work practice standard means any design, equipment, work practice, or operational standard, or combination thereof, that is promulgated pursuant to section 112(h) of the Clean Air Act.

[68 FR 69185, Dec. 11, 2003, as amended at 70 FR 25682, May 13, 2005]

TABLE 1 TO SUBPART HHHHH OF PART 63—EMISSION LIMITS AND WORK PRACTICE STANDARDS FOR PROCESS VESSELS

As required in §63.8005, you must meet each emission limit and work practice standard in the following table that applies to your process vessels.

For each . . .	You must . . .	And you must . . .
1. Portable process vessel at an existing source.	a. Equip the vessel with a cover or lid that must be in place at all times when the vessel contains a HAP, except for material additions and sampling.	Nonapplicable.
2. Stationary process vessel at an existing source.	a. Equip the vessel with a cover or lid that must be in place at all times when the vessel contains a HAP, except for material additions and sampling; or	i. Considering both capture and any combination of control (except a flare), reduce emissions of organic HAP with a vapor existing pressure ≥0.6 kPa by ≥75 percent by weight, and reduce emissions of organic HAP with a vapor pressure <0.6 kPa by ≥60 percent by weight.
	b. Equip the vessel with a tightly fitting vented cover or lid that must be closed at all times when the vessel contains HAP, except for material additions and sampling.	i. Reduce emissions of organic HAP with a vapor pressure ≥0.6 kPa by ≥75 percent by weight, and reduce emissions of organic HAP with a vapor pressure <0.6 kPa by ≥60 percent by weight, by venting emissions through a closed-vent system to any combination of control devices (except a flare); or ii. Reduce emissions of total organic HAP by venting emissions from a nonhalogenated vent stream through a closed-vent system to a flare; or iii. Reduce emissions of total organic HAP by venting emissions through a closed-vent system to a condenser that reduces the outlet gas temperature to:
		<10 °C if the process vessel contains HAP with a partial pressure <0.6 kPa, or <2 °C if the process vessel contains HAP with a partial pressure ≥0.6 kPa and <17.2 kPa, or

For each . . .	You must . . .	And you must . . .
3. Portable and stationary process vessel at a new source.	a. Equip the vessel with a tightly fitting vented cover or lid that must be closed at all times when the vessel contains HAP, except for material additions and sampling.	<−5 °C if the process vessel contains HAP with a partial pressure ≥17.2 kPa. i. Reduce emissions of total organic HAP by ≥95 percent by weight by venting emissions through a closed-vent system to any combination of control devices (except a flare); or ii. Reduce emissions of total organic HAP by venting emissions from a non-halogenated vent stream through a closed-vent system to a flare; or iii. Reduce emissions of total organic HAP by venting emissions through a closed-vent system to a condenser that reduces the outlet gas temperature to: <−4 °C if the process vessel contains HAP with a partial pressure <0.7 kPa, or
4. Halogenated vent steam from a process vessel subject to the requirements of item 2 or 3 of this table for which you use a combustion control device to control organic HAP emissions.	a. Use a halogen reduction device after the combustion control device; or	<−20 °C if the process vessel contains HAP with a partial pressure ≥0.7 kPa and <17.2 kPa, or <−30 °C if the process vessel contains HAP with a partial pressure ≥17.2 kPa. i. Reduce overall emissions of hydrogen halide and halogen HAP by ≥95 percent; or ii. Reduce overall emissions of hydrogen halide and halogen HAP to ≤0.45 kilogram per hour (kg/hr).
	b. Use a halogen reduction device before the combustion control device.	Reduce the halogen atom mass emission rate to ≤0.45 kg/hr.

[68 FR 69185, Dec. 11, 2003, as amended at 70 FR 25682, May 13, 2005]

TABLE 2 TO SUBPART HHHHH OF PART 63—EMISSION LIMITS FOR STORAGE TANKS

As required in §63.8010, you must meet each emission limit in the following table that applies to your storage tanks.

For each . . .	Then you must . . .
1. Group 1a storage tank	a. Comply with the requirements of subpart WW of this part, except as specified in §63.8010(b); or b. Reduce total organic HAP emissions from the storage tank by ≥90 percent by weight by venting emissions through a closed-vent system to any combination of control devices (excluding a flare); or c. Reduce total organic HAP emissions from the storage tank by venting emissions from a non-halogenated vent stream through a closed-vent system to a flare.
2. Group 1b storage tank	a. Comply with the requirements of subpart WW of this part, except as specified in §63.8010(b); or b. Reduce total organic HAP emissions from the storage tank by ≥80 percent by weight by venting emissions through a closed-vent system to any combination of control devices (excluding a flare); or c. Reduce total organic HAP emissions from the storage tank by venting emissions from a non-halogenated vent stream through a closed-vent system to a flare.

TABLE 3 TO SUBPART HHHHH OF PART 63—REQUIREMENTS FOR EQUIPMENT LEAKS

As required in §63.8015, you must meet each requirement in the following table that applies to your equipment leaks.

For all . . .	You must . . .
1. Equipment that is in organic HAP service at an existing source.	a. Comply with the requirements in §§63.424(a) through (d) and 63.428(e), (f), and (h)(4), except as specified in §63.8015(b); or b. Comply with the requirements of subpart TT of this part; or c. Comply with the requirements of subpart UU of this part, except as specified in §63.8015(c) and (d).

For all . . .	You must . . .
2. Equipment that is in organic HAP service at a new source.	a. Comply with the requirements of subpart TT of this part; or b. Comply with the requirements of subpart UU of this part, except as specified in § 63.8015(c) and (d).

TABLE 4 TO SUBPART HHHHH OF PART 63—EMISSION LIMITS AND WORK PRACTICE STANDARDS FOR WASTEWATER STREAMS

As required in § 63.8020, you must meet each emission limit and work practice standard in the following table that applies to your wastewater streams.

For each . . .	You must . . .
1. Wastewater tank used to store a Group 1 wastewater stream.	Maintain a fixed roof, which may have openings necessary for proper venting of the tank, such as pressure/vacuum vent or j-pipe vent.
2. Group 1 wastewater stream.	a. Convey using hard-piping and treat the wastewater as a hazardous waste in accordance with 40 CFR part 264, 265, or 266 either onsite or offsite; or b. If the wastewater contains <50 ppmw of partially soluble HAP, you may elect to treat the wastewater in an enhanced biological treatment system that is located either onsite or offsite.

TABLE 5 TO SUBPART HHHHH OF PART 63—EMISSION LIMITS AND WORK PRACTICE STANDARDS FOR TRANSFER OPERATIONS

As required in § 63.8025, you must meet each emission limit and work practice standard in the following table that applies to your transfer operations.

For each . . .	You must. . . .
1. Group 1 transfer operation vent stream.	a. Reduce emissions of total organic HAP by ≥75 percent by weight by venting emissions through a closed-vent system to any combination of control devices (except a flare); or b. Reduce emissions of total organic HAP by venting emissions from a non-halogenated vent stream through a closed-vent system to a flare; or c. Use a vapor balancing system designed and operated to collect organic HAP vapors displaced from tank trucks and railcars during loading and route the collected HAP vapors to the storage tank from which the liquid being loaded originated or to another storage tank connected by a common header.
2. Halogenated Group 1 transfer operation vent stream for which you use a combustion device to control organic HAP emissions.	a. Use a halogen reduction device after the combustion device to reduce emissions of hydrogen halide and halogen HAP by ≥95 percent by weight or to ≤0.45 kg/hr; or b. Use a halogen reduction device before the combustion device to reduce the halogen atom mass emission rate to ≤0.45 kg/hr.

TABLE 6 TO SUBPART HHHHH OF PART 63—REQUIREMENTS FOR HEAT EXCHANGE SYSTEMS

As required in § 63.8030, you must meet each requirement in the following table that applies to your heat exchange systems.

For each . . .	You must . . .
Heat exchange system, as defined in § 63.101.	Comply with the requirements in § 63.104, except as specified in § 63.8030.

TABLE 7 TO SUBPART HHHHH OF PART 63—PARTIALLY SOLUBLE HAZARDOUS AIR POLLUTANTS

As specified in § 63.8020, the partially soluble HAP in wastewater that are subject to management and treatment requirements in this subpart are listed in the following table:

Chemical name . . .	CAS No.
1. 1,1,1-Trichloroethane (methyl chloroform)	71556
2. 1,1,2,2-Tetrachloroethane	79345
3. 1,1,2-Trichloroethane	79005
4. 1,1-Dichloroethylene (vinylidene chloride)	75354
5. 1,2-Dibromoethane	106934

Chemical name . . .	CAS No.
6. 1,2-Dichloroethane (ethylene dichloride)	107062
7. 1,2-Dichloropropane	78875
8. 1,3-Dichloropropene	542756
9. 2,4,5-Trichlorophenol	95954
10. 2-Butanone (MEK)	78933
11. 1,4-Dichlorobenzene	106467
12. 2-Nitropropane	79469
13. 4-Methyl-2-pentanone (MIBK)	108101
14. Acetaldehyde	75070
15. Acrolein	107028
16. Acrylonitrile	107131
17. Allyl chloride	107051
18. Benzene	71432
19. Benzyl chloride	100447
20. Biphenyl	92524
21. Bromoform (tribromomethane)	75252
22. Bromomethane	74839
23. Butadiene	106990
24. Carbon disulfide	75150
25. Chlorobenzene	108907
26. Chloroethane (ethyl chloride)	75003
27. Chloroform	67663
28. Chloromethane	74873
29. Chloroprene	126998
30. Cumene	98828
31. Dichloroethyl ether	111444
32. Dinitrophenol	51285
33. Epichlorohydrin	106898
34. Ethyl acrylate	140885
35. Ethylbenzene	100414
36. Ethylene oxide	75218
37. Ethylidene dichloride	75343
38. Hexachlorobenzene	118741
39. Hexachlorobutadiene	87683
40. Hexachloroethane	67721
41. Methyl methacrylate	80626
42. Methyl-t-butyl ether	1634044
43. Methylene chloride	75092
44. N-hexane	110543
45. N,N-dimethylaniline	121697
46. Naphthalene	91203
47. Phosgene	75445
48. Propionaldehyde	123386
49. Propylene oxide	75569
50. Styrene	100425
51. Tetrachloroethylene (perchloroethylene)	127184
52. Tetrachloromethane (carbon tetrachloride)	56235
53. Toluene	108883
54. Trichlorobenzene (1,2,4–)	120821
55. Trichloroethylene	79016
56. Trimethylpentane	540841
57. Vinyl acetate	108054
58. Vinyl chloride	75014
59. Xylene (m)	108383
60. Xylene (o)	95476
61. Xylene (p)	106423

[68 FR 69185, Dec. 11, 2003, as amended at 70 FR 25683, May 13, 2005]

TABLE 8 TO SUBPART FFFF OF PART 63—SOLUBLE HAZARDOUS AIR POLLUTANTS

As specified in §63.8020, the soluble HAP in wastewater that are subject to management and treatment requirements of this subpart are listed in the following table:

Chemical name . . .	CAS No.
1. Acetonitrile	75058
2. Acetophenone	98862
3. Diethyl sulfate	64675
4. Dimethyl hydrazine (1,1)	57147
5. Dimethyl sulfate	77781
6. Dinitrotoluene (2,4)	121142
7. Dioxane (1,4)	123911

Chemical name . . .	CAS No.
8. Ethylene glycol dimethyl ether	110714
9. Ethylene glycol monobutyl ether acetate	112072
10. Ethylene glycol monomethyl ether acetate	110496
11. Isophorone	78591
12. Methanol	67561
13. Nitrobenzene	98953
14. Toluidine (o-)	95534
15. Triethylamine	121448

[68 FR 69185, Dec. 11, 2003, as amended at 70 FR 25683, May 13, 2005]

TABLE 9 TO SUBPART HHHHH OF PART 63—REQUIREMENTS FOR REPORTS

As required in §63.8075(a) and (b), you must submit each report that applies to you on the schedule shown in the following table:

You must submit a . . .	The report must contain . . .	You must submit the report . . .
1. Precompliance report	The information specified in §63.8075(c)	At least 6 months prior to the compliance date; or for new sources, with the application for approval of construction or reconstruction.
2. Notification of compliance status report	The information specified in §63.8075(d)	No later than 150 days after the compliance date specified in §63.7995.
3. Compliance report	The information specified in §63.8075(e)	Semiannually according to the requirements in §63.8075(b).

TABLE 10 TO SUBPART HHHHH OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART HHHHH

As specified in §63.8095, the parts of the General Provisions that apply to you are shown in the following table:

Citation	Subject	Explanation
§63.1	Applicability	Yes.
§63.2	Definitions	Yes.
§63.3	Units and Abbreviations	Yes.
§63.4	Prohibited Activities	Yes.
§63.5	Construction/Reconstruction	Yes.
§63.6(a)	Applicability	Yes.
§63.6(b)(1)–(4)	Compliance Dates for New and Reconstructed sources.	Yes.
§63.6(b)(5)	Notification	Yes.
§63.6(b)(6)	[Reserved].	
§63.6(b)(7)	Compliance Dates for New and Reconstructed Area Sources That Become Major.	Yes.
§63.6(c)(1)–(2)	Compliance Dates for Existing Sources.	Yes.
§63.6(c)(3)–(4)	[Reserved].	
§63.6(c)(5)	Compliance Dates for Existing Area Sources That Become Major.	Yes.
§63.6(d)	[Reserved].	
§63.6(e)(1)–(2)	Operation & Maintenance	Yes.
§63.6(e)(3)(i), (ii), and (v) through (viii).	SSMP	Yes, except information regarding Group 2 emission points and equipment leaks is not required in the SSMP, as specified in §63.8080(f).
§63.6(e)(3)(iii) and (iv)	Recordkeeping and Reporting During Startup, Shutdown, and Malfunction (SSM).	No, §§63.998(d)(3) and 63.998(c)(1)(ii)(D) through (G) specify the recordkeeping requirement for SSM events, and §63.8075(e)(5) specifies reporting requirements.
§63.6(e)(3)(ix)	Title V permit	Yes.
§63.6(f)(1)	Compliance Except During SSM.	Yes.
§63.6(f)(2)–(3)	Methods for Determining Compliance.	Yes.
§63.6(g)(1)–(3)	Alternative Standard	Yes.
§63.6(h)	Opacity/Visible Emission (VE) Standards.	Only for flares for which Method 22 observations are required as part of a flare compliance assessment.

Citation	Subject	Explanation
§ 63.6(i)(1)–(14)	Compliance Extension	Yes.
§ 63.6(j)	Presidential Compliance Exemption.	Yes.
§ 63.7(a)(1)–(2)	Performance Test Dates	Yes, except substitute 150 days for 180 days.
§ 63.7(a)(3)	CAA Section 114 Authority	Yes, and this paragraph also applies to flare compliance assessments as specified under § 63.997(b)(2).
§ 63.7(b)(1)	Notification of Performance Test.	Yes.
§ 63.7(b)(2)	Notification of Rescheduling	Yes.
§ 63.7(c)	Quality Assurance/Test Plan	Yes, except the test plan must be submitted with the notification of the performance test if the control device controls process vessels.
§ 63.7(d)	Testing Facilities	Yes.
§ 63.7(e)(1)	Conditions for Conducting Performance Tests.	Yes, except that performance tests for process vessels must be conducted under worst-case conditions as specified in § 63.8005.
§ 63.7(e)(2)	Conditions for Conducting Performance Tests.	Yes.
§ 63.7(e)(3)	Test Run Duration	Yes.
§ 63.7(f)	Alternative Test Method	Yes.
§ 63.7(g)	Performance Test Data Analysis.	Yes.
§ 63.7(h)	Waiver of Tests	Yes.
§ 63.8(a)(1)	Applicability of Monitoring Requirements.	Yes.
§ 63.8(a)(2)	Performance Specifications	Yes.
§ 63.8(a)(3)	[Reserved].	
§ 63.8(a)(4)	Monitoring with Flares	Yes.
§ 63.8(b)(1)	Monitoring	Yes.
§ 63.8(b)(2)–(3)	Multiple Effluents and Multiple Monitoring Systems.	Yes.
§ 63.8(c)(1)	Monitoring System Operation and Maintenance.	Yes.
§ 63.8(c)(1)(i)	Maintain and operate CMS	Yes.
§ 63.8(c)(1)(ii)	Routine repairs	Yes.
§ 63.8(c)(1)(iii)	SSMP for CMS	Yes.
§ 63.8(c)(2)–(3)	Monitoring System Installation	Yes.
§ 63.8(c)(4)	Requirements	Only for CEMS; requirements for CPMS are specified in referenced subpart SS of 40 CFR part 63. This subpart does not contain requirements for continuous opacity monitoring systems (COMS).
§ 63.8(c)(4)(i)	CMS Requirements	No. This subpart does not require COMS.
§ 63.8(c)(4)(ii)	CMS requirements	Yes.
§ 63.8(c)(5)	COMS Minimum Procedures	No. This subpart does not contain opacity or VE limits.
§ 63.8(c)(6)	CMS Requirements	Only for CEMS; requirements for CPMS are specified in referenced subpart SS of 40 CFR part 63.
§ 63.8(c)(7)–(8)	CMS Requirements	Only for CEMS. Requirements for CPMS are specified in referenced subpart SS of 40 CFR part 63.
§ 63.8(d)	CMS Quality Control	Only for CEMS; requirements for CPMS are specified in referenced subpart SS of 40 CFR part 63.
§ 63.8(e)	CMS Performance Evaluation	Section 63.8(e)(6)(ii) does not apply because this subpart does not require COMS. Other sections apply only for CEMS; requirements for CPMS are specified in referenced subpart SS of 40 CFR part 63.
§ 63.8(f)(1)–(5)	Alternative Monitoring Method	Yes, except you may also request approval using the precompliance report.
§ 63.8(f)(6)	Alternative to Relative Accuracy Test.	Only for CEMS.
§ 63.8(g)(1)–(4)	Data Reduction	Only when using CEMS, except § 63.8(g)(2) does not apply because data reduction requirements for CEMS are specified in § 63.8000(d)(4)(iv). The requirements for COMS do not apply because this subpart has no opacity or VE limits.
§ 63.8(g)(5)	Data Reduction	No. Requirements for CEMS are specified in § 63.8000(d)(4). Requirements for CPMS are specified in referenced subpart SS of 40 CFR part 63.
§ 63.9(a)	Notification Requirements	Yes.
§ 63.9(b)(1)–(5)	Initial Notifications	Yes.
§ 63.9(c)	Request for Compliance Extension.	Yes.
§ 63.9(d)	Notification of Special Compliance Requirements for New Source.	Yes.

Citation	Subject	Explanation
§63.9(e)	Notification of Performance Test.	Yes.
§63.9(f)	Notification of VE/Opacity Test	No. This subpart does not contain opacity or VE limits.
§63.9(g)	Additional Notifications When Using CMS.	Only for CEMS; requirements for CPMS are specified in referenced subpart SS of 40 CFR part 63.
§63.9(h)(1)–(6)	Notification of Compliance Status.	Yes, except this subpart has no opacity or VE limits, and §63.9(h)(2) does not apply because §63.8075(d) specifies the required contents and due date of the notification of compliance status report.
§63.9(i)	Adjustment of Submittal Deadlines.	Yes.
§63.9(j)	Change in Previous Information.	No, §63.8075(e)(8) specifies reporting requirements for process changes.
§63.10(a)	Recordkeeping/Reporting	Yes.
§63.10(b)(1)	Recordkeeping/Reporting	Yes.
§63.10(b)(2)(i)–(iv)	Records related to SSM	No, §§63.998(d)(3) and 63.998(c)(1)(ii)(D) through (G) specify recordkeeping requirements for periods of SSM.
§63.10(b)(2)(iii)	Records related to maintenance of air pollution control equipment.	Yes.
§63.10(b)(2)(vi), (x), and (xi)	CMS Records	Only for CEMS; requirements for CPMS are specified in referenced subpart SS of 40 CFR part 63.
§63.10(b)(2)(vii)–(ix)	Records	Yes.
§63.10(b)(2)(xii)	Records	Yes.
§63.10(b)(2)(xiii)	Records	Yes.
§63.10(b)(2)(xiv)	Records	Yes.
§63.10(b)(3)	Records	Yes.
§63.10(c)(1)–(6),(9)–(15)	Records	Only for CEMS; requirements for CPMS are specified in referenced subpart SS of 40 CFR part 63.
§63.10(c)(7)–(8)	Records	No. Recordkeeping requirements are specified in §63.8080.
§63.10(d)(1)	General Reporting Requirements.	Yes.
§63.10(d)(2)	Report of Performance Test Results.	Yes.
§63.10(d)(3)	Reporting Opacity or VE Observations.	No. This subpart does not contain opacity or VE limits.
§63.10(d)(4)	Progress Reports	Yes.
§63.10(d)(5)(i)	SSM Reports	No, §63.8075(e)(5) and (6) specify the SSM reporting requirements.
§63.10(d)(5)(ii)	Immediate SSM reports	No.
§63.10(e)(1)–(2)	Additional CMS Reports	Only for CEMS, but §63.10(e)(2)(ii) does not apply because this subpart does not require COMS.
§63.10(e)(3)	Reports	No. Reporting requirements are specified in §63.8075.
§63.10(e)(3)(i)–(iii)	Reports	No. Reporting requirements are specified in §63.8075.
§63.10(e)(3)(iv)–(v)	Excess Emissions Reports	No. Reporting requirements are specified in §63.8075.
§63.10(e)(3)(vi–viii)	Excess Emissions Report and Summary Report.	No. Reporting requirements are specified in §63.8075.
§63.10(e)(4)	Reporting COMS data	No. This subpart does not contain opacity or VE limits.
§63.10(f)	Waiver for Recordkeeping/Reporting.	Yes.
§63.11	Flares	Yes.
§63.12	Delegation	Yes.
§63.13	Addresses	Yes.
§63.14	Incorporation by Reference	Yes.
§63.15	Availability of Information	Yes.

[68 FR 69185, Dec. 11, 2003, as amended at 71 FR 20468, Apr. 20, 2006]

Subpart IIIII—National Emission Standards for Hazardous Air Pollutants: Mercury Emissions From Mercury Cell Chlor-Alkali Plants

SOURCE: 68 FR 70928, Dec. 19, 2003, unless otherwise noted.

WHAT THIS SUBPART COVERS

§63.8180 What is the purpose of this subpart?

This subpart establishes national emission standards for hazardous air pollutants (NESHAP) for affected sources of mercury emissions at mercury cell chlor-alkali plants. This subpart also establishes requirements to demonstrate initial and continuous

compliance with all applicable emission limitations and work practice standards in this subpart.

§ 63.8182 Am I subject to this subpart?

(a) You are subject to this subpart if you own or operate a mercury cell chlor-alkali plant.

(b) You are required to obtain a title V permit, whether your affected source is a part of a major source of hazardous air pollutant (HAP) emissions or a part of an area source of HAP emissions. A major source of HAP is a source that emits or has the potential to emit any single HAP at a rate of 10 tons or more per year or any combination of HAP at a rate of 25 tons or more per year. An area source of HAP is a source that has the potential to emit HAP but is not a major source. Nothing in this subpart revises how affected sources are aggregated for purposes of determining whether an affected source is a part of an area, nonmajor, or major source under any provisions of the Clean Air Act (CAA) or EPA's regulations. For information on aggregating affected sources to determine what is a source under title V, see the definition of major source in 40 CFR 70.2, 71.2 and 63.2.

(c) Beginning on December 19, 2006, the provisions of subpart E of 40 CFR part 61 that apply to mercury chlor-alkali plants, which are listed in paragraphs (c)(1) through (3) of this section, are no longer applicable.

(1) § 61.52(a);

(2) § 61.53(b) and (c); and

(3) § 61.55(b), (c) and (d).

§ 63.8184 What parts of my plant does this subpart cover?

(a) This subpart applies to each affected source at a plant site where chlorine and caustic are produced in mercury cells. This subpart applies to two types of affected sources: the mercury cell chlor-alkali production facility, as defined in paragraph (a)(1) of this section; and the mercury recovery facility, as defined in paragraph (a)(2) of this section.

(1) The mercury cell chlor-alkali production facility designates an affected source consisting of all cell rooms and ancillary operations used in the manufacture of product chlorine, product caustic, and by-product hydrogen at a plant site. This subpart covers mercury emissions from by-product hydrogen streams, end box ventilation system vents, and fugitive emission sources associated with cell rooms, hydrogen systems, caustic systems, and storage areas for mercury-containing wastes.

(2) The mercury recovery facility designates an affected source consisting of all processes and associated operations needed for mercury recovery from wastes at a plant site. This subpart covers mercury emissions from mercury thermal recovery unit vents and fugitive emission sources associated with storage areas for mercury-containing wastes.

(b) An affected source at your mercury cell chlor-alkali plant is existing if you commenced construction of the affected source before July 3, 2002.

(c) A mercury recovery facility is a new affected source if you commence construction or reconstruction of the affected source after July 3, 2002. An affected source is reconstructed if it meets the definition of ''reconstruction'' in § 63.2.

§ 63.8186 When do I have to comply with this subpart?

(a) If you have an existing affected source, you must comply with each emission limitation, work practice standard, and recordkeeping and reporting requirement in this subpart that applies to you no later than December 19, 2006.

(b) If you have a new or reconstructed mercury recovery facility and its initial startup date is on or before December 19, 2003, you must comply with each emission limitation, work practice standard, and recordkeeping and reporting requirement in this subpart that applies to you by December 19, 2003.

(c) If you have a new or reconstructed mercury recovery facility and its initial startup date is after December 19, 2003, you must comply with each emission limitation, work practice standard, and recordkeeping and reporting requirement in this subpart that applies to you upon initial startup.

(d) You must meet the notification and schedule requirements in § 63.8252.

Several of these notifications must be submitted before the compliance date for your affected source(s).

EMISSION LIMITATIONS AND WORK PRACTICE STANDARDS

§63.8190 What emission limitations must I meet?

(a) *Emission limits.* You must meet each emission limit in paragraphs (a)(1) through (3) of this section that applies to you.

(1) New or reconstructed mercury cell chlor-alkali production facility. Emissions of mercury are prohibited from a new or reconstructed mercury cell chlor-alkali production facility.

(2) Existing mercury cell chlor-alkali production facility. During any consecutive 52-week period, you must not discharge to the atmosphere total mercury emissions in excess of the applicable limit in paragraph (a)(2)(i) or (ii) of this section calculated using the procedures in §63.8243(a).

(i) 0.076 grams of mercury per megagram of chlorine produced (1.5×10^{-4} pounds of mercury per ton of chlorine produced) from all by-product hydrogen streams and all end box ventilation system vents when both types of emission points are present.

(ii) 0.033 grams of mercury per megagram of chlorine produced (6.59×10^{-5} pounds of mercury per ton of chlorine produced) from all by-product hydrogen streams when end box ventilation systems are not present.

(3) New, reconstructed, or existing mercury recovery facility. You must not discharge to the atmosphere mercury emissions in excess of the applicable limit in paragraph (a)(3)(i) or (ii) of this section.

(i) 23 milligrams per dry standard cubic meter from each oven type mercury thermal recovery unit vent.

(ii) 4 milligrams per dry standard cubic meter from each non-oven type mercury thermal recovery unit vent.

(b) [Reserved]

§63.8192 What work practice standards must I meet?

You must meet the work practice requirements specified in paragraphs (a) through (f) of this section. As an alternative to the requirements specified in paragraphs (a) through (d) of this section, you may choose to comply with paragraph (g) of this section.

(a) You must meet the work practice standards in Tables 1 through 4 to this subpart, except as specified in paragraph (g) of this section.

(b) You must adhere to the response intervals specified in Tables 1 through 4 to this subpart at all times. Nonadherence to the intervals in Tables 1 through 4 to this subpart constitutes a deviation and must be documented and reported in the compliance report, as required by §63.8254(b), with the date and time of the deviation, cause of the deviation, a description of the conditions, and time actual compliance was achieved.

(c) As provided in §63.6(g), you may request to use an alternative to the work practice standards in Tables 1 through 4 to this subpart.

(d) You must institute a floor-level mercury vapor measurement program to limit the amount of mercury vapor in the cell room environment through periodic measurement of mercury vapor levels and actions to be taken when a floor-level mercury concentration action level is exceeded. The program must meet the requirements listed in paragraphs (d)(1) through (4) of this section. As specified in §63.8252(e)(1)(i) to implement this program, you must prepare and submit to the Administrator a floor-level mercury vapor measurement plan which must contain the elements listed in Table 5 to this subpart.

(1) You must utilize a mercury measurement device described in of Table 6 to this subpart to measure the level of mercury vapor in the cell room at floor-level.

(2) You must conduct at least one floor-level mercury vapor measurement evaluation each half day. This evaluation must include three measurements of the mercury concentration at locations representative of the entire cell room floor area. The average of these measurements must be recorded as specified in §63.8156(c)(1). At a minimum, you must measure the level of mercury vapor above mercury-containing cell room equipment, as well as areas around the cells,

decomposers, or other mercury-containing equipment.

(3) You must establish a floor-level mercury concentration action level that is no higher than 0.05 milligrams per cubic meter (mg/m^3).

(4) If a mercury concentration greater than the action level is measured during any floor-level mercury vapor measurement evaluation, you must meet the requirements in either paragraph (d)(4)(i) or (ii) of this section.

(i) If you determine that the cause of the elevated mercury concentration is an open electrolyzer, decomposer, or other maintenance activity, you must record the information specified in paragraphs (d)(4)(i)(A) through (C) of this section.

(A) A description of the maintenance activity resulting in elevated mercury concentration;

(B) The time the maintenance activity was initiated and completed; and

(C) A detailed explanation how all the applicable requirements of Table 1 to this subpart were met during the maintenance activity.

(ii) If you determine that the cause of the elevated mercury concentration is not an open electrolyzer, decomposer, or other maintenance activity, you must follow the procedures specified in paragraphs (d)(4)(ii)(A) and (B) of this section until the floor-level mercury concentration falls below the floor-level mercury concentration action level. You must also keep all the associated records for these procedures as specified in Table 9 to this subpart.

(A) Within 1 hour of the time the floor-level mercury concentration action level was exceeded, you must conduct each inspection specified in Table 2 to this subpart in the area where the concentration higher than the floor-level mercury concentration action level was measured, with the exception of the cell room floor and the pillars and beam inspections. (B) You must also inspect all decomposers, hydrogen system piping up to the hydrogen header, and other potential locations of mercury vapor leaks in the area using a technique specified in Table 6 to this subpart. You must correct any problem identified during these inspections according to the requirements in Tables 2 and 3 to this subpart.

(e) You must prepare, submit, and operate according to a written washdown plan designed to minimize fugitive mercury emissions through routine washing of surfaces where liquid mercury could accumulate. The written plan must address the elements contained in Table 7 to this subpart.

(f) You must keep records of the mass of all virgin mercury added to cells on an annual basis.

(g) As an alternative to the work practice standards in paragraphs (a) through (d) of this section, you may institute a cell room monitoring program to continuously monitor the mercury vapor concentration in the upper portion of each cell room and to take corrective actions as quickly as possible when elevated mercury vapor levels are detected. As specified in § 63.8252(e)(1)(iv), if you choose this option, you must prepare and submit to the Administrator, a cell room monitoring plan containing the elements listed in Table 5 to this subpart and meet the requirements in paragraphs (g)(1) through (4) of this section.

(1) You must utilize mercury monitoring systems that meet the requirements of Table 8 to this subpart.

(2) You must establish an action level according to the requirements in paragraphs (g)(2)(i) through (iii) of this section.

(i) Beginning on the compliance date specified for your affected source in § 63.8186, measure and record the mercury concentration for at least 30 days using a system that meets the requirements of paragraph (g)(1) of this section.

(ii) Using the monitoring data collected according to paragraph (g)(1)(i) of this section, establish your action level at the 75th percentile of the data set.

(iii) Submit your action level as part of your Notification of Compliance Status report according to § 63.8252(e)(1).

(3) Beginning on the compliance date specified for your affected source in § 63.8186, you must continuously monitor the mercury concentration in the cell room. Failure to monitor and record the data according to § 63.8256(c)(4)(ii) for 75 percent of the time in any 6-month period constitutes a deviation.

(4) If the average mercury concentration for any 1-hour period exceeds the action level established according to paragraph (g)(2) of this section, you must meet the requirements in either paragraph (g)(4)(i) or (ii) of this section.

(i) If you determine that the cause of the elevated mercury concentration is an open electrolyzer, decomposer, or other maintenance activity, you must record the information specified in paragraphs (g)(4)(i)(A) through (C) of this section.

(A) A description of the maintenance activity resulting in elevated mercury concentration;

(B) The time the maintenance activity was initiated and completed; and

(C) A detailed explanation how all the applicable requirements of Table 1 to this subpart were met during the maintenance activity.

(ii) If you determine that the cause of the elevated mercury concentration is not an open electrolyzer, decomposer, or other maintenance activity, you must follow the procedures specified in paragraphs (g)(4)(ii)(A) and (B) of this section until the mercury concentration falls below the action level. You must also keep all the associated records for these procedures as specified in Table 9 to this subpart.

(A) Within 1 hour of the time the action level was exceeded, you must conduct each inspection specified in Table 2 to this subpart, with the exception of the cell room floor and the pillars and beam inspections. You must correct any problem identified during these inspections in accordance with the requirements in Table 2 and 3 to this subpart.

(B) If the Table 2 inspections and subsequent corrective actions do not reduce the mercury concentration below the action level, you must inspect all decomposers, hydrogen system piping up to the hydrogen header, and other potential locations of mercury vapor leaks using a technique specified in Table 6 to this subpart. If a mercury vapor leak is identified, you must take the appropriate action specified in Table 3 to this subpart.

OPERATION AND MAINTENANCE REQUIREMENTS

§63.8222 What are my operation and maintenance requirements?

As required by §63.6(e)(1)(i), you must always operate and maintain your affected source(s), including air pollution control and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions.

GENERAL COMPLIANCE REQUIREMENTS

§63.8226 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the applicable emission limitations for by-product hydrogen streams, end box ventilation system vents, and mercury thermal recovery unit vents in §63.8190 at all times, except during periods of startup, shutdown, and malfunction. You must be in compliance with the applicable work practice standards in §63.8192 at all times, except during periods of startup, shutdown, and malfunction.

(b) You must develop a written startup, shutdown, and malfunction plan (SSMP) according to the provisions in §63.6(e)(3).

[68 FR 70928, Dec. 19, 2003, as amended at 71 FR 20469, Apr. 20, 2006]

INITIAL COMPLIANCE REQUIREMENTS

§63.8230 By what date must I conduct performance tests or other initial compliance demonstrations?

(a) You must conduct a performance test no later than the compliance date that is specified in §63.8186 for your affected source to demonstrate initial compliance with the applicable emission limit in §63.8190(a)(2) for by-product hydrogen streams and end box ventilation system vents and the applicable emission limit in §63.8190(a)(3) for mercury thermal recovery unit vents.

(b) For the applicable work practice standards in §63.8192, you must demonstrate initial compliance within 30 calendar days after the compliance date that is specified for your affected source in §63.8186.

§ 63.8232 What test methods and other procedures must I use to demonstrate initial compliance with the emission limits?

You must conduct a performance test for each by-product hydrogen stream, end box ventilation system vent, and mercury thermal recovery unit vent according to the requirements in § 63.7(e)(1) and the conditions detailed in paragraphs (a) through (d) of this section.

(a) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in § 63.7(e)(1).

(b) For each performance test, you must develop a site-specific test plan in accordance with § 63.7(c)(2).

(c) You must conduct at least three test runs to comprise a performance test, as specified in § 63.7(e)(3) and in either paragraph (c)(1) or (2) of this section.

(1) The sampling time and sampling volume for each run must be at least 2 hours and 1.70 dry standard cubic meters (dscm). Mercury results below the analytical laboratory's detection limit must be reported using the reported analytical detection limit to calculate the sample concentration value and, in turn, the emission rate in the units of the standard; or

(2) The sampling time for each test run must be at least 2 hours and the mercury concentration in each field sample analyzed must be at least two times the reported analytical detection limit.

(d) You must use the test methods specified in paragraphs (d)(1) through (4) of this section and the applicable test methods in paragraphs (d)(5) through (7) of this section.

(1) Method 1 or 1A in appendix A of 40 CFR part 60 to determine the sampling port locations and the location and required number of sampling traverse points.

(2) Method 2, 2A, 2C, or 2D in appendix A of 40 CFR part 60 to determine the stack gas velocity and volumetric flow rate.

(3) Method 3, 3A, or 3B in appendix A of 40 CFR part 60 to determine the stack gas molecular weight.

(4) Method 4 in appendix A of 40 CFR part 60 to determine the stack gas moisture content.

(5) For each by-product hydrogen stream, Method 102 in appendix A of 40 CFR part 61 to measure the mercury emission rate after the last control device.

(6) For each end box ventilation system vent, Method 101 or 101A in appendix A of 40 CFR part 61 to measure the mercury emission rate after the last control device.

(7) For each mercury thermal recovery unit vent, Method 101 or 101A in appendix A of 40 CFR part 61 to measure the mercury emission rate after the last control device.

(e) During each test run for a by-product hydrogen stream and each test run for an end box ventilation system vent, you must continuously measure the electric current through the operating mercury cells and record a measurement at least once every 15 minutes.

(f) If the final control device is not a nonregenerable carbon adsorber and if you are demonstrating compliance using periodic monitoring under § 63.8240(b), you must continuously monitor the parameters listed in paragraph (f)(1) of this section and establish your maximum or minimum monitoring value (as appropriate for your control device) using the requirements in paragraph (f)(2) of this section.

(1) During the performance test specified in paragraphs (a) through (d) of this section, you must continuously monitor the control device parameters in paragraphs (f)(1)(i) through (vii) of this section and record a measurement at least once every 15 minutes.

(i) The exit gas temperature from uncontrolled streams;

(ii) The outlet temperature of the gas stream for the final (*i.e.*, the farthest downstream) cooling system when no control devices other than coolers or demisters are used;

(iii) The outlet temperature of the gas stream from the final cooling system when the cooling system is followed by a molecular sieve or regenerative carbon adsorber;

(iv) Outlet concentration of available chlorine, pH, liquid flow rate, and inlet

gas temperature of chlorinated brine scrubbers and hypochlorite scrubbers;

(v) The liquid flow rate and exit gas temperature for water scrubbers;

(vi) The inlet gas temperature of regenerative carbon adsorption systems; and

(vii) The temperature during the heating phase of the regeneration cycle for carbon adsorbers or molecular sieves.

(2) To establish a maximum monitoring value or minimum monitoring value, as appropriate for your final control device, you must average the recorded parameters in paragraphs (f)(1)(i) through (vi) of this section over the test period. If your final control device is a regenerative carbon adsorber, you must use the highest temperature reading measured in paragraph (f)(1)(vii) as the reference temperature in §63.8244(b)(2)(v).

§63.8234 What equations and procedures must I use for the initial compliance demonstration?

(a) *By-product hydrogen streams and end box ventilation system vents.* You must determine the total grams of mercury per Megagram of chlorine production (g Hg/Mg Cl_2) of chlorine produced from all by-product hydrogen streams and all end box ventilation system vents, if applicable, at a mercury cell chlor-alkali production facility, and you must follow the procedures in paragraphs (a)(1) through (6) of this section.

(1) Determine the mercury emission rate for each test run in grams per day for each by-product hydrogen stream and for each end box ventilation system vent, if applicable, from Method 101, 101A, or 102 (40 CFR part 61, appendix A).

(2) Calculate the average measured electric current through the operating mercury cells during each test run for each by-product hydrogen stream and for each end box ventilation system vent, if applicable, using Equation 1 of this section as follows:

$$CL_{avg,\ run} = \frac{\sum_{i=1}^{n} CL_{i,\ run}}{n} \qquad \text{(Eq. 1)}$$

Where:

$CL_{avg,\ run}$ = Average measured cell line current load during the test run, amperes;

$CL_{i,\ run}$ = Individual cell line current load measurement (*i.e.*, 15 minute reading) during the test run, amperes; and

n = Number of cell line current load measurements taken over the duration of the test run.

(3) Calculate the amount of chlorine produced during each test run for each by-product hydrogen stream and for each end box ventilation system vent, if applicable, using Equation 2 of this section as follows:

$$P_{Cl_2,\ run} = \left(1.3 \times 10^{-6}\right)\left(CL_{avg,\ run}\right)\left(n_{cells,\ run}\right)\left(t_{run}\right) \qquad \text{(Eq. 2)}$$

Where:

$P_{Cl_2,run}$ = Amount of chlorine produced during the test run, megagrams chlorine (Mg Cl_2);

1.3×10^{-6} = Theoretical chlorine production rate factor, Mg Cl_2 per hour per ampere per cell;

$CL_{avg,run}$ = Average measured cell line current load during test run, amperes, calculated using Equation 1 of this section;

$n_{cell,run}$ = Number of cells on-line during the test run; and

t_{run} = Duration of test run, hours.

(4) Calculate the mercury emission rate in grams of mercury per megagram of chlorine produced for each test run for each by-product hydrogen stream and for each end box ventilation system vent, if applicable, using Equation 3 of this section as follows:

$$E_{Hg,\ run} = \left[\frac{\left(R_{run}\right)\left(t_{run}\right)}{(24)\left(P_{Cl_2,\ run}\right)}\right] \qquad \text{(Eq. 3)}$$

Where:

$E_{Hg,run}$ = Mercury emission rate for the test run, g Hg/Mg Cl_2;

R_{run} = Measured mercury emission rate for the test run from paragraph (a)(1) of this section, grams Hg per day;

t_{run} = Duration of test run, hours;

24 = Conversion factor, hours per day; and

$P_{Cl_2,run}$ = Amount of chlorine produced during the test run, calculated using Equation 2 of this section, Mg Cl_2.

(5) Calculate the average mercury emission rate for each by-product hydrogen stream and for each end box ventilation system vent, if applicable, using Equation 4 of this section as follows:

$$E_{Hg,\,avg} = \frac{\sum_{i=1}^{n} E_{Hg,\,run}}{n} \qquad \text{(Eq. 4)}$$

Where:

$E_{Hg,avg}$ = Average mercury emission rate for the by-product hydrogen stream or the end box ventilation system vent, if applicable, g Hg/Mg Cl_2;

$E_{Hg,run}$ = Mercury emission rate for each test run for the by-product hydrogen stream or the end box ventilation system vent, if applicable, g Hg/Mg Cl_2, calculated using Equation 3 of this section; and

n = Number of test runs conducted for the by-product hydrogen stream or the end box ventilation system vent, if applicable.

(6) Calculate the total mercury emission rate from all by-product hydrogen streams and all end box ventilation system vents, if applicable, at the mercury cell chlor-alkali production facility using Equation 5 of this section as follows:

$$E_{Hg,\,H_2EB} = \sum_{i=1}^{n} E_{Hg,\,avg} \qquad \text{(Eq. 5)}$$

Where:

E_{Hg,H_2EB} = Total mercury emission rate from all by-product hydrogen streams and all end box ventilation system vents, if applicable, at the affected source, g Hg/Mg Cl_2;

$E_{Hg,avg}$ = Average mercury emission rate for each by-product hydrogen stream and each end box ventilation system vent, if applicable, g Hg/Mg Cl_2, determined using Equation 4 of this section; and

n = Total number of by-product hydrogen streams and end box ventilation system vents at the affected source.

(b) *Mercury thermal recovery vents.* You must determine the milligrams of mercury per dscm exhaust discharged from mercury thermal recovery unit vents, using the procedures in paragraphs (b)(1) and (2) of this section.

(1) Calculate the concentration of mercury in milligrams of mercury per dscm of exhaust for each test run for each mercury thermal recovery unit vent using Equation 6 of this section as follows:

$$C_{Hg,\,run} = \left[\frac{(m_{Hg})(10^{-3})}{(V_{m(std)})}\right] \qquad \text{(Eq. 6)}$$

Where:

$C_{Hg,run}$ = Mercury concentration for the test run, milligrams of mercury per dry standard cubic meter of exhaust;

m_{Hg} = Mass of mercury in test run sample, from Method 101, 101A, or 102, micrograms;

10-3 = Conversion factor, milligrams per microgram; and

$V_{m(std)}$ = Dry gas sample volume at standard conditions, from Method 101, 101A, or 102, dry standard cubic meters.

(2) Calculate the average concentration of mercury in each mercury thermal recovery unit vent exhaust using Equation 7 of this section as follows:

$$C_{Hg,\,avg} = \frac{\sum_{i=1}^{n} C_{Hg,\,run}}{n} \qquad \text{(Eq. 7)}$$

Where:

$C_{Hg,avg}$ = Average mercury concentration for the mercury thermal recovery unit vent, milligrams of mercury per dry standard cubic meter exhaust;

$C_{Hg,run}$ = Mercury concentration for each test run, milligrams of mercury per dry standard cubic meter of exhaust, calculated using Equation 6 of this section; and

n = Number of test runs conducted for the mercury thermal recovery unit vent.

§ 63.8236 How do I demonstrate initial compliance with the emission limitations and work practice standards?

(a) For each mercury cell chlor-alkali production facility, you have demonstrated initial compliance with the applicable emission limit for by-product hydrogen streams and end box ventilation system vents in § 63.8190(a)(2) if you comply with paragraphs (a)(1) and (2) of this section:

(1) Total mercury emission rate from all by-product hydrogen streams and all end box ventilation system vents, if applicable, at the affected source, determined according to §§ 63.8232 and 63.8234(a), did not exceed the applicable

emission limit in §63.8190(a)(2)(i) or (ii); and

(2) If you have chosen the periodic monitoring option specified in §63.8240(b) and your final control device is not a nonregenerable carbon adsorber, you have established a parameter value according to §63.8232(f)(2).

(b) For each mercury recovery facility, you have demonstrated initial compliance with the applicable emission limit for mercury thermal recovery unit vents in §63.8190(a)(3) if you comply with paragraphs (b)(1) and (2) of this section.

(1) Mercury concentration in each mercury thermal recovery unit vent exhaust, determined according to §§63.8232 and 63.8234(b), did not exceed the applicable emission limit in §63.8190(a)(3)(i) or (ii); and

(2) If you have chosen the periodic monitoring option in §63.8240(b) and have a final control device that is not a nonregenerable carbon adsorber, you have established a maximum or minimum monitoring value, as appropriate for your control device according to §63.8232(f)(2).

(c) For each affected source, you have demonstrated initial compliance with the applicable work practice standards in §63.8192 if you comply with paragraphs (c)(1) through (7) of this section.

(1) You certify in your Notification of Compliance Status that you are operating according to the work practice standards in §63.8192(a) through (d).

(2) You choose the continuous cell room monitoring program option, you certify in your Notification of Compliance Status that you are operating according to the continuous cell room monitoring program under §63.8192(g) and you have established your action level according to §63.8192(g)(2).

(3) You certify in your Notification of Compliance Status that you are operating according to your washdown plan.

(4) You have submitted your washdown plan as part of your Notification of Compliance Status.

(5) You have submitted your continuous cell room monitoring plan, if applicable, as part of your Notification of Compliance Status.

(6) You have submitted your floor-level cell room monitoring plan, if applicable, as part of your Notification of Compliance Status.

(7) You have submitted records of the mass of virgin mercury added to cells for the 5 years preceding the applicable compliance date for your affected source as a part of the Notification of Compliance Status.

(d) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in §63.8252(e).

CONTINUOUS COMPLIANCE REQUIREMENTS

§63.8240 What are my monitoring requirements?

For each by-product hydrogen stream, each end box ventilation system vent, and each mercury thermal recovery unit vent, you must monitor the mercury emissions using the procedures in paragraph (a) or (b) of this section.

(a) You must continuously monitor the mercury concentration using a mercury continuous emissions monitor according to the requirements in §§63.8242(a) and 63.8244(a); or

(b) You must periodically monitor the mercury emissions according to the requirements in §§63.8242(b) and 63.8244(b).

§63.8242 What are the installation, operation, and maintenance requirements for my continuous monitoring systems?

(a) If you choose the continuous mercury monitoring option under §63.8240(a), you must install, operate, and maintain each mercury continuous emissions monitor according to paragraphs (a)(1) through (5) of this section.

(1) Each mercury continuous emissions monitor must sample, analyze, and record the concentration of mercury at least once every 15 minutes.

(2) Each mercury continuous emissions monitor analyzer must have a detector with the capability to detect a mercury concentration at or below 0.5 times the mercury concentration level measured during the performance test conducted according to §63.8232.

(3) In lieu of a promulgated performance specification as required in

§ 63.8(a)(2), you must develop a site-specific monitoring plan that addresses the elements in paragraphs (a)(3)(i) through (vi) of this section.

(i) Installation and measurement location downstream of the final control device for each by-product hydrogen stream, end box ventilation system vent, and mercury thermal recovery unit vent.

(ii) Performance and equipment specifications for the sample interface, the pollutant concentration analyzer, and the data collection and reduction system.

(iii) Performance evaluation procedures and acceptance criteria (*i.e.*, calibrations).

(iv) Ongoing operation and maintenance procedures according to the requirements of § 63.8(c)(1), (3), and (4)(ii).

(v) Ongoing data quality assurance procedures according to the requirements of § 63.8(d).

(vi) Ongoing recordkeeping and reporting procedures in accordance with the general requirements of § 63.10(c), (e)(1), and (e)(2)(i).

(4) You must conduct a performance evaluation of each mercury continuous emissions monitor according to your site-specific monitoring plan.

(5) You must operate and maintain each mercury continuous emissions monitor in continuous operation according to the site-specific monitoring plan.

(b) If you choose the periodic monitoring option and your final control device is not a nonregenerable carbon adsorber, you must install, operate, and maintain a continuous parameter monitoring system (CPMS) for each parameter specified in § 63.8232(f)(1), according to § 63.8(c).

§ 63.8243 What equations and procedures must I use to demonstrate continuous compliance?

(a) *By-product hydrogen streams and end box ventilation system vents.* For each consecutive 52-week period, you must determine the g Hg/Mg Cl_2 produced from all by-product hydrogen streams and all end box ventilation system vents, if applicable, at a mercury cell chlor-alkali production facility using the procedures in paragraphs (a)(1) through (3) of this section. You must begin collecting data on the compliance date that is specified in § 63.8186 for your affected source and calculate your first 52-week average mercury emission rate at the end of the 52nd week after the compliance date.

(1) Each week, you must determine the weekly mercury emission rate in grams per week for each by-product hydrogen stream and for each end box ventilation system vent, if applicable, using one of the monitoring options in paragraph (a)(1)(i) or (ii) of this section.

(i) Continuous mercury monitoring according to §§ 63.8242 and 63.8244(a).

(ii) Periodic monitoring according to § 63.8244(b).

(2) Each week, you must determine the chlorine production and keep records of the production rate as required under § 63.8256(b)(6).

(3) Beginning 52 weeks after the compliance date specified in § 63.8186 for your affected source, you must calculate the 52-week average mercury emission rate from all by-product hydrogen steam and all end box ventilation system vents, if applicable, using Equation 1 of this section as follows:

$$E_{Hg} = \sum_{i=1}^{52} \left[\frac{\left(R_{week_i}\right)}{\left(P_{Cl_2,week_i}\right)} \right] \quad \text{(Eq. 1)}$$

Where:

E_{Hg} = 52-week average mercury emission rate for $week_i$, g Hg/Mg Cl_2;

$R_{week,\ i}$ = Mercury emission rate for $week_i$ from paragraph (a)(1) of this section, g Hg per week;

$P_{Cl2,\ weeki}$ = Amount of chlorine produced during $week_i$, from paragraph (a)(2) of this section, Mg Cl_2 per week.

(b) *Mercury thermal recovery units.* If you choose the continuous monitoring option in § 63.8240(a), you must demonstrate continuous compliance using paragraph (b)(1) of this section. If you choose the periodic monitoring option in § 63.8240(b), you must demonstrate continuous compliance using paragraph (b)(2) of this section.

(1) You must calculate the daily average mercury concentration using Equation 2 of this section as follows:

$$C_{Hg,\,dailyavg} = \frac{\left(\sum_{i=1}^{n} C_{Hg,\,i}\right)}{n} \quad \text{(Eq. 2)}$$

Where:

$C_{Hg,\ dailyavg}$ = Average mercury concentration for the operating day, milligrams per dry standard cubic meter;

$C_{Hg,i}$ = Concentration of mercury measured at the interval *i* (*i.e.*, 15 minute reading) using a mercury continuous emission monitor, milligrams per dry standard cubic meter; and

n = Number of concentration measurements taken during the operating day.

(2) You must calculate the daily average mercury concentration using the procedures in §63.8234(b).

§63.8244 How do I monitor and collect data to demonstrate continuous compliance?

(a) *Continuous monitoring option.* You must monitor mercury concentration according to §63.8242(a) at all times that the affected source is operating with the exception of paragraphs (a)(1) and (2) of this section.

(1) Except for monitor malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), you must monitor mercury emissions continuously (or collect data at all required intervals) at all times that the affected source is operating. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

(2) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels or to fulfill a minimum data availability requirement, if applicable. You must use all the data collected during all other periods in assessing compliance.

(b) *Periodic monitoring option.* If you choose the periodic monitoring option under §63.8240(b), you must monitor according to the procedures in paragraph (b)(1) or (2) of this section.

(1) If your final control device is a nonregenerable carbon adsorber, then you must conduct at least three test runs per week meeting the criteria specified in §63.8232(c)(1) and (2) to measure mercury emissions using the test methods specified in §63.8232(d). Alternatively, you may use any other method that has been validated using the applicable procedures in Method 301, 40 CFR part 63, appendix A.

(2) If your final control device is anything other than a nonregenerable carbon adsorber, you must monitor according to the requirements of paragraphs (b)(2)(i) through (v) of this section.

(i) You must conduct at least three test runs per week meeting the criteria specified in §63.8232(c)(1) and (2) to measure mercury emissions using the test methods specified in §63.8232(d). Alternatively, you may use any other method that has been validated using the applicable procedures in Method 301, 40 CFR part 63, appendix A.

(ii) Except as specified in paragraph (b)(2)(iii) of this section, you must continuously collect data at least once every 15 minutes using a CPMS installed and operated according to §63.8242(b) and record each 1-hour average from all measured data values during each 1-hour period for the applicable parameter identified in §63.8232(f)(1) using the methods specified in §63.8244(a).

(iii) As appropriate, you must continuously monitor the temperature specified in §63.8232(f)(1)(vii) during each heating phase of the regeneration cycle of your carbon adsorber.

(iv) If the hourly average monitoring value of any applicable parameter recorded under paragraph (b)(2)(ii) of this section is below the minimum monitoring value or above the maximum monitoring value of that same parameter established under §63.8232(f)(2) for 24 consecutive hours, your monitoring value is out of range and you must take corrective action as soon as practicable. The hourly average monitoring value must be above the minimum monitoring value or below the maximum monitoring value as appropriate for that parameter, within 48 hours of

the period that the monitoring value is out of range.

(v) If your final control device is a regenerative carbon adsorber, when the maximum hourly value of the temperature measured according to paragraph (b)(2)(iii) of this section is below the reference temperature determined according to § 63.8232(f)(2) for three consecutive regeneration cycles, your monitoring value is out of range and you must take corrective action as soon as practicable. During the first regeneration cycle following the period that your monitoring value is out of range, the maximum hourly value must be above the reference temperature recorded according to § 63.8232(f)(2).

§ 63.8246 How do I demonstrate continuous compliance with the emission limitations and work practice standards?

(a) *By-product hydrogen streams and end box ventilation system vents.* (1) For all by-product hydrogen streams and all end box ventilation system vents, if applicable, you must demonstrate continuous compliance with the applicable mercury emission limit by reducing the mercury emissions data to 52-week averages using Equation 1 of § 63.8243 and maintaining the 52-week average mercury emissions no higher than the applicable mercury emissions limit in § 63.8190(a)(2). To obtain the data to calculate these 52-week averages, you must monitor in accordance with paragraph (a)(1)(i) or (ii) of this section.

(i) *Continuous monitoring option.* You must collect mercury emissions data according to § 63.8244(a), representing at least 75 percent of the 15-minute periods in each operating day of the 52-week compliance period (with data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities not counting toward the 75 percent requirement);

(ii) *Periodic monitoring option.* You must conduct at least three test runs per week to collect mercury emissions samples according to § 63.8244(b)(1) and (2)(i) and, if your final control device is not a nonregenerable carbon adsorber, you must collect data for monitoring values according to § 63.8244(b)(2)(ii) through (v).

(2) You must maintain records of mercury emissions and 52-week average values, as required in § 63.8256(b)(3) and (4). If your final control device is not a nonregenerable carbon adsorber, you must maintain records according to § 63.8256(d).

(b) *Mercury thermal recovery unit vents.* (1) For each mercury thermal recovery unit vent, you must demonstrate continuous compliance with the applicable emission limit specified in § 63.8190(a)(3) by maintaining the outlet mercury hourly-average concentration no higher than the applicable limit. To determine the outlet mercury concentration, you must monitor according to paragraph (b)(1)(i) or (ii) of this section.

(i) *Continuous monitoring option.* You must collect mercury concentration data according to § 63.8244(a), representing at least 75 percent of the 15-minute periods in the operating day (with data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities not counting toward the 75 percent requirement).

(ii) *Periodic monitoring option.* You must conduct at least three test runs per week to collect mercury emissions samples according to § 63.8244(b)(1) and (2)(i) and, if your final control device is not a nonregenerable carbon adsorber, you must collect data for monitoring values according to § 63.8244(b)(2)(ii) through (v).

(2) You must maintain records of mercury emissions and daily average values as required in § 63.8256(b)(3). If your final control device is not a nonregenerable carbon adsorber, you must maintain records according to § 63.8256(d).

(c) You must demonstrate continuous compliance with the applicable work practice standards in § 63.8192 by maintaining records in accordance with § 63.8256(c).

§ 63.8248 What other requirements must I meet?

(a) *Deviations.* The instances specified in paragraphs (a)(1) through (4) of this

section are deviations and must be reported according to the requirements in §63.8254.

(1) You must report each instance in which you did not meet each emission limitation in §63.8190 that applies to you. This includes periods of startup, shutdown, and malfunction.

(2) You must report each instance in which you did not meet each work practice standard in §63.8192 that applies to you. This includes periods of startup, shutdown, and malfunction.

(3) You must report each instance in which the corrective actions taken according to §63.8244(b)(2)(iv) did not result in average monitoring values being within range within 48 hours of the period that the monitoring value is out of range.

(4) You must report each instance in which the corrective action taken according to §63.8244(b)(2)(v) did not result in the maximum hourly temperature being above the reference temperature during the first regeneration cycle following the period that the monitoring value was out of range.

(b) *Startups, shutdowns, and malfunctions.* (1) Consistent with §§63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with §63.6(e)(1).

(2) The Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in §63.6(e).

(3) By-passing the control device for maintenance activities is not considered a startup, shutdown, or malfunction event.

[68 FR 70928, Dec. 19, 2003, as amended at 71 FR 20469, Apr. 20, 2006]

NOTIFICATION, REPORTS, AND RECORDS

§63.8252 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.7(b) and (c), 63.8(e) and (f) and 63.9(b) through (h) that apply to you by the dates specified.

(b) As specified in §63.9(b)(2), if you start up your affected source before December 19, 2003, you must submit your initial notification not later than April 19, 2004.

(c) As specified in §63.9(b)(3), if you start up your new or reconstructed mercury recovery facility on or after December 19, 2003, you must submit your initial notification not later than 120 days after you become subject to this subpart.

(d) For each performance test that you are required to conduct for by-product hydrogen streams and end box ventilation system vents and for mercury thermal recovery unit vents, you must submit a notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin as required in §7(b)(1).

(e) You must submit a Notification of Compliance Status according to paragraphs (e)(1) and (2) of this section.

(1) For each initial compliance demonstration that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th calendar day following the completion of the initial compliance demonstration. The Notification of Compliance Status must contain the items in paragraphs (e)(1)(i) through (iv) of this section:

(i) If you choose not to implement a cell room monitoring program according to §63.8192(g), a certification that you are operating according to the applicable work practice standards in §63.8192(a) through (d) and your floor-level mercury vapor measurement plan required by §63.8192(d).

(ii) The washdown plan, and you must certify that you are operating according to the washdown plan specified in §63.8192(f).

(iii) The mass of virgin mercury added to cells for the 5 years preceding the compliance date.

(iv) If you choose to implement a cell room monitoring program according to §63.8192(g), your cell room monitoring plan.

(2) For each initial compliance demonstration that does include a performance test, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th calendar day following the completion of the

performance test according to § 63.10(d)(2). The Notification of Compliance Status must contain the information in § 63.9(h)(2)(ii)(A) through (G). The site-specific monitoring plan required in § 63.8242(a)(3) must also be submitted.

§ 63.8254 What reports must I submit and when?

(a) *Compliance report due dates.* You must submit a semiannual compliance report to your permitting authority according to the requirements in paragraphs (a)(1) through (4) of this section.

(1) The first compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.8186 and ending on June 30 or December 31, whichever date comes first after the compliance date that is specified for your affected source in § 63.8186.

(2) The first compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date comes first after your first compliance reporting period.

(3) Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date comes first after the end of the semiannual reporting period.

(b) *Compliance report contents.* Each compliance report must contain the information in paragraphs (b)(1) through (3) of this section, and as applicable, paragraphs (b)(4) through (12) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a startup, shutdown or malfunction during the reporting period and you took actions consistent with your startup, shutdown, and malfunction plan, the compliance report must include the information in § 63.10(d)(5)(i).

(5) If there were no deviations from the continuous compliance requirements in § 63.8246 that apply to you, a statement that there were no deviations from the emission limitations, work practice standards, and operation and maintenance standards during the reporting period.

(6) If there were no periods during which the mercury continuous emission monitor or CPMS (if applicable) were out-of-control as specified in § 63.8(c)(7), a statement that there were no periods during the which the mercury continuous emissions monitor or CPMS (if applicable) were out-of-control during the reporting period.

(7) For each deviation from the requirements for work practice standards in Tables 1 through 4 to this subpart that occurs at an affected source (including deviations where the response intervals were not adhered to as described in § 63.8192(b)), the compliance report must contain the information in paragraphs (b)(1) through (4) of this section and the information in paragraphs (b)(7)(i) and (ii) of this section. This includes periods of startup, shutdown, and malfunction.

(i) The total operating time of each affected source during the reporting period.

(ii) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(8) For each deviation from an emission limitation occurring at an affected source where you are using a mercury continuous emission monitor, according to the site-specific monitoring plan required in § 63.8242(a)(3), to comply with the emission limitation in this subpart, you must include the information in paragraphs (b)(1) through (4) of this section and the information in paragraphs (b)(8)(i) through (xii) of this section. This includes periods of startup, shutdown, and malfunction.

(i) The date and time that each malfunction started and stopped.

(ii) The date and time of each instance in which a continuous monitoring system was inoperative, except for zero (low-level) and high-level checks.

(iii) The date, time, and duration of each instance in which a continuous

monitoring system was out-of-control, including the information in §63.8(c)(8).

(iv) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(v) A summary of the total duration of the deviation during the reporting period and the total duration as a percent of the total source operating time during that reporting period.

(vi) A breakdown of the total duration of the deviations during the reporting period including those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and other unknown causes.

(vii) A summary of the total duration of continuous monitoring system downtime during the reporting period and the total duration of monitoring system downtime as a percent of the total source operating time during the reporting period.

(viii) An identification of each hazardous air pollutant that was monitored at the affected source.

(ix) A brief description of the process units.

(x) A brief description of the continuous monitoring system.

(xi) The date of the latest continuous monitoring system certification or audit.

(xii) A description of any changes in monitoring system, processes, or controls since the last reporting period.

(9) For each deviation from an operation and maintenance standard occurring at an affected source where you are using the periodic monitoring option specified in §63.8240(b) and your final control device is not a nonregenerable carbon adsorber, the compliance report must include the information in paragraphs (b)(1) through (4) of this section and the information in paragraphs (b)(9)(i) through (x) of this section. This includes periods of startups, shutdowns and malfunctions.

(i) The total operating time of each affected source during the reporting period.

(ii) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, whether the deviation occurred during a period of startup, shutdown, or malfunction, or other period, and the corrective action taken.

(iii) The date and time of each instance in which a CPMS was inoperative, except for zero (low-level) and high-level checks.

(iv) The date, time, and duration of each instance in which a CPMS was out-of-control, including the information specified in §63.8(c)(8).

(v) A summary of the total duration of the deviation during the reporting period and the total duration as a percent of the total source operating time during that reporting period.

(vi) A breakdown of the total duration of the deviations during the reporting period including those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and other unknown causes.

(vii) A summary of the total duration of continuous monitoring system downtime during the reporting period and the total duration of monitoring system downtime as a percent of the total source operating time during the reporting period.

(viii) A brief description of the CPMS.

(ix) The date of the latest CPMS certification or audit.

(x) A description of any changes in monitoring system, processes, or controls since the last reporting period.

(10) The compliance report must contain the mass of virgin mercury added to cells for the reporting period.

(11) The compliance report must contain each instance in which corrective actions taken under §63.8244(b)(2)(iv) did not result in average monitoring values being within range within 48 hours of the period that the monitoring value is out of range.

(12) The compliance report must contain each instance in which corrective action taken according to §63.8244(b)(2)(v) did not result in the maximum hourly temperature being above the reference temperature during the first regeneration cycle following the period that the monitoring value was out of range.

(c) *Immediate startup, shutdown, and malfunction report.* If you took an action during a startup, shutdown, or

malfunction during the semiannual reporting period that was not consistent with your startup, shutdown, and malfunction plan required in § 63.8226(b), and the source exceeded any applicable emission limitation in this subpart, you must submit an immediate startup, shutdown, and malfunction report according to the requirements in § 63.10(d)(5)(ii).

(d) *Title V monitoring report.* After your affected source has been issued a title V operating permit pursuant to 40 CFR part 70 or 40 CFR part 71, you must report all deviations from permit requirements and provide reports of any required monitoring in your semiannual monitoring report as required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If you submit a semiannual compliance report for an affected source as required by this subpart as part of the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the semiannual compliance report includes all information required by the 40 CFR part 70 or 40 CFR part 71 semiannual monitoring report for the deviations that are reported in the semiannual compliance report, submission of the semiannual compliance report satisfies your obligation to report the same deviation information in the semiannual monitoring report. However, in such situations, the semiannual monitoring report must cross-reference the semiannual compliance report, and submission of a semiannual compliance report does not otherwise affect any obligation you may have to report deviations from permit requirements for an affected source to your permitting authority under 40 CFR part 70 or 40 CFR part 71.

§ 63.8256 What records must I keep?

(a) *General records.* You must keep the records in paragraphs (a)(1) and (2) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any initial notification or Notification of Compliance Status that you submitted, according to the requirements in § 63.10(b)(2)(xiv).

(2) The records in § 63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.

(b) Records associated with the byproduct hydrogen stream and end box ventilation system vent emission limitations and the mercury thermal recovery unit vent emission limitations. You must keep the records in paragraphs (b)(1) through (5) of this section related to the emission limitations in § 63.8190(a)(2) through (3) and (b).

(1) Records of performance tests as required in § 63.10(b)(2)(viii).

(2) Records of the mercury emissions monitoring conducted during the performance tests.

(3) Records of the continuous or periodic mercury emissions monitoring data.

(4) Records of the 52-week rolling average mercury emissions.

(5) Records associated with your site-specific monitoring plan required in § 63.8242(a)(3) (*i.e.*, results of inspections, calibrations, and validation checks of each mercury concentration continuous monitoring system (CMS)).

(6) Records of chlorine production on a weekly basis.

(c) Records associated with the work practice standards.

(1) If you choose not to institute a cell room monitoring program according to § 63.8192(g) of this subpart, you must keep the records specified in paragraphs (c)(1)(i) through (v) of this section.

(i) Records specified in Table 9 to this subpart related to the work practice standards in Tables 1 through 4 of this subpart.

(ii) Your current floor-level mercury vapor measurement plan.

(iii) Records of the average value calculated from at least three measurements taken according to your floor-level mercury vapor measurement plan.

(iv) Records indicated in § 63.8192(d)(4)(i) for maintenance activities that cause the floor-level mercury concentration to exceed the action level.

(v) Records of all inspections and corrective actions taken in response to a non-maintenance related situation in

which the mercury vapor concentration exceeds the floor-level mercury concentration action level.

(2) You must maintain a copy of your current washdown plan and records of when each washdown occurs.

(3) You must maintain records of the mass of virgin mercury added to cells for each reporting period.

(4) If you choose to institute a cell room monitoring program according to §63.8192(g) of this subpart, you must keep your current cell room monitoring plan and the records specified in paragraphs (c)(4)(i) through (v) of this section.

(i) Records of the monitoring conducted in accordance with §63.8192(g)(2)(i) to establish your action level, and records demonstrating the development of this action level.

(ii) Records of the cell room mercury concentration monitoring data collected.

(iii) Instances when the action level is exceeded.

(iv) Records specified in §63.8192(g)(4)(i) for maintenance activities that cause the mercury vapor concentration to exceed the action level.

(v) Records of all inspections and corrective actions taken in response to a non-maintenance related situation in which the mercury vapor concentration exceeds the action level.

(d) Records associated with the periodic monitoring option if your final control device is not a nonregenerable carbon adsorber. You must keep the records in paragraph (d)(1) through (3) of this section.

(1) Records of the CPMS data collected during the performance test as specified in §63.8232(f)(1).

(2) Records documenting the development of the maximum monitoring value or minimum monitoring value, as appropriate, according to §63.8232(f)(2).

(3) Records of hourly average values of applicable parameters monitored as specified in §63.8244(b)(2)(ii) or (iii).

§63.8258 In what form and how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious inspection and review, according to §63.10(b)(1).

(b) As specified in §63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record on site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to §63.10(b)(1). You can keep the records offsite for the remaining 3 years.

OTHER REQUIREMENTS AND INFORMATION

§63.8262 What parts of the General Provisions apply to me?

Table 10 to this subpart shows which parts of the General Provisions in §§63.1 through 63.13 apply to you.

§63.8264 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the United States Environmental Protection Agency (U.S. EPA), or a delegated authority such as your State, local, or tribal agency. If the EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency has the authority to implement and enforce this subpart. You should contact your EPA Regional Office to find out if this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under subpart E of this part, the authorities contained in paragraph (c) of this section are retained by the EPA Administrator and are not transferred to the State, local, or tribal agency.

(c) The authorities in paragraphs (c)(1) through (4) of this section will not be delegated to State, local, or tribal agencies.

(1) Approval of alternatives under §63.6(g) to the non-opacity emission limitations in §63.8190 and work practice standards in §63.8192.

(2) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90.

(3) Approval of major alternatives to monitoring under §63.8(f) and as defined in §63.90.

(4) Approval of major alternatives to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.

§ 63.8266 What definitions apply to this subpart?

Terms used in this subpart are defined in the CAA, in § 63.2, and in this section as follows:

Aqueous liquid means a liquid mixture in which water is the predominant component.

Brine means an aqueous solution of alkali metal chloride, as sodium chloride salt solution or potassium chloride salt solution, that is used in the electrolyzer as a raw material.

By-product hydrogen stream means the hydrogen gas from each decomposer that passes through the hydrogen system and is burned as fuel, transferred to another process as raw material, or discharged directly to the atmosphere.

Caustic means an aqueous solution of alkali metal hydroxide, as sodium hydroxide or potassium hydroxide, that is produced in the decomposer.

Caustic basket means a fixture adjacent to the decomposer that contains a serrated funnel over which the caustic from the decomposer passes, breaking into droplets such that electric current is interrupted.

Caustic system means all vessels, piping, and equipment that convey caustic and remove mercury from the caustic stream. The caustic system begins at the decomposer and ends after the primary filters.

Cell room means a building or other structure in which one or more mercury cells are located.

Continuous parameter monitoring system, or CPMS, means the total equipment that may be required to meet the data acquisition and availability requirements of this subpart, used to sample, condition (if applicable), analyze, and provide a record of process of control system parameters.

Control device means a piece of equipment (such as condensers, coolers, chillers, heat exchangers, mist eliminators, absorption units, and adsorption units) that removes mercury from gaseous streams.

Decomposer means the component of a mercury cell in which mercury amalgam and water react in bed of graphite packing (within a cylindrical vessel), producing caustic and hydrogen gas and returning mercury to its elemental form for re-use in the process.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart including, but not limited to, any emission limitation (including any operating limit) or work practice standard;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the title V operating permit for any affected source required to obtain such a permit;

(3) Fails to meet any emission limitation (including any operating limit) or work practice standard in this subpart during startup, shutdown, or malfunction, regardless of whether or not such failure is allowed by this subpart; or

(4) Fails to take corrective actions within 48 hours that result in parameter monitoring values being within range.

Electrolyzer means the main component of the mercury cell that consists of an elongated, shallow steel trough that holds a layer of mercury as a flowing cathode. The electrolyzer is enclosed by side panels and a top that suspends metal anodes. In the electrolyzer, brine is fed between a flowing mercury cathode and metal anodes in the presence of electricity to produce chlorine gas and an alkali metal-mercury amalgam (mercury amalgam).

Emission limitation means any emission limit or operating limit.

End box means a component of a mercury cell for transferring materials between the electrolyzer and the decomposer. The inlet end box collects and combines raw materials at the inlet end of the cell, and the outlet end box separates and directs various materials either into the decomposer or out of the cell.

End box ventilation system means all vessels, piping, and equipment that evacuate the head space of each mercury cell end box (and possibly other

vessels and equipment) to the atmosphere. The end box ventilation system begins at the end box (and other vessel or equipment which is being evacuated) and terminates at the end box ventilation system vent. The end box ventilation system includes all control devices.

End box ventilation system vent means the discharge point of the end box ventilation system to the atmosphere after all control devices.

Hydrogen leak means hydrogen gas (containing mercury vapor) that is escaping from the decomposer or hydrogen system.

Hydrogen system means all vessels, piping, and equipment that convey a by-product hydrogen stream. The hydrogen system begins at the decomposer and ends at the point just downstream of the last control device. The hydrogen system includes all control devices.

In liquid mercury service means containing or coming in contact with liquid mercury.

Liquid mercury accumulation means one or more liquid mercury droplets, or a pool of liquid mercury, present on the floor or other surface exposed to the atmosphere.

Liquid mercury leak means the liquid mercury that is dripping or otherwise escaping from process equipment.

Liquid mercury spill means a liquid mercury accumulation resulting from a liquid mercury that leaked from process equipment or that dripped during maintenance or handling.

Mercury cell means a device consisting of an electrolyzer and decomposer, with one or more end boxes, a mercury pump, and other components linking the electrolyzer and decomposer.

Mercury cell amalgam seal pot means a compartment through which mercury amalgam passes from an outlet end box to a decomposer.

Mercury cell chlor-alkali plant means all contiguous or adjoining property that is under common control, where mercury cells are used to manufacture product chlorine, product caustic, and by-product hydrogen and where mercury may be recovered from wastes.

Mercury cell chlor-alkali production facility means an affected source consisting of all cell rooms and ancillary operations used in the manufacture of product chlorine, product caustic, and by-product hydrogen at a mercury cell chlor-alkali plant.

Mercury concentration CMS, or mercury concentration continuous monitoring system, means a CMS, as defined in §63.2, that continuously measures the concentration of mercury.

Mercury-containing wastes means waste materials containing mercury, which are typically classified under Resource Conservation and Recovery Act (RCRA) solid waste designations. K071 wastes are sludges from the brine system. K106 are wastewater treatment sludges. D009 wastes are non-specific mercury-containing wastes, further classified as either debris or nondebris (*i.e.,* cell room sludges and carbon from decomposes).

Mercury pump means a component of a mercury cell for conveying elemental mercury re-created in the decomposer to the beginning of the mercury cell. A mercury pump is typically found either as an in-line mercury pump (near a mercury suction pot or mercury seal pot) or submerged mercury pump (within a mercury pump tank or mercury pump seal).

Mercury recovery facility means an affected source consisting of all processes and associated operations needed for mercury recovery from wastes at a mercury cell chlor-alkali plant.

Mercury thermal recovery unit means the retort(s) where mercury-containing wastes are heated to volatilize mercury and the mercury recovery/control system (control devices and other equipment) where the retort off-gas is cooled, causing mercury to condense and liquid mercury to be recovered.

Mercury thermal recovery unit vent means the discharge point of the mercury thermal recovery unit to the atmosphere after all recovery/control devices. This term encompasses both oven type vents and non-oven type vents.

Mercury vacuum cleaner means a cleanup device used to draw a liquid mercury spill or accumulation (via suction pressure) into a closed compartment.

Non-oven type mercury thermal recovery unit vent means the discharge point

to the atmosphere after all recovery/control devices of a mercury thermal recovery unit in which the retort is either a rotary kiln or single hearth retort.

Open-top container means any container that does not have a tight-fitting cover that keeps its contents from being exposed to the atmosphere.

Oven type mercury thermal recovery unit vent means the discharge point to the atmosphere after all recovery/control devices of a mercury thermal recovery unit in which each retort is a batch oven retort.

Responsible official means responsible official as defined in 40 CFR 70.2.

Retort means a furnace where mercury-containing wastes are heated to drive mercury into the gas phase. The types of retorts used as part of mercury thermal recovery units at mercury cell chlor-alkali plants include batch oven retorts, rotary kilns, and single hearth retorts.

Spalling means fragmentation by chipping.

Sump means a large reservoir or pit for wastewaters (primarily washdown waters).

Trench means a narrow channel or depression built into the length of a cell room floor that leads washdown materials to a drain.

Vent hose means a connection for transporting gases from the mercury cell.

Virgin mercury means mercury that has not been processed in an onsite mercury thermal recovery unit or otherwise recovered from mercury-containing wastes onsite.

Washdown means the act of rinsing a floor or surface with a stream of aqueous liquid to cleanse it of a liquid mercury spill or accumulation, generally by driving it into a trench.

Week means any consecutive seven-day period.

Work practice standard means any design, equipment, work practice, or operational standard, or combination thereof, that is promulgated pursuant to section 112(h) of the CAA.

TABLE 1 TO SUBPART IIIII OF PART 63—WORK PRACTICE STANDARDS—DESIGN, OPERATION, AND MAINTENANCE REQUIREMENTS

As stated in §63.8192, you must meet the work practice standards in the following table:

For . . .	You must . . .
1. Cell rooms	a. For new or modified cell rooms, construct each cell room interior using materials that are resistant to absorption of mercury, resistant to corrosion, facilitate the detection of liquid mercury spills or accumulations, and are easy to clean.
	b. Limit access around and beneath mercury cells in each cell room to prevent liquid mercury from being tracked into other areas.
	c. Provide adequate lighting in each cell room to facilitate the detection of liquid mercury spills or accumulations.
	d. Minimize the number of items stored around and beneath cells in each cell room.
2. Mercury cells and electrolyzers.	a. Operate and maintain each electrolyzer, decomposer, end box, and mercury pump to minimize leakage of mercury.
	b. Prior to opening an electrolyzer for maintenance, do the following: (1) Complete work that can be done before opening the electrolyzer in order to minimize the time required to complete maintenance when the electrolyzer is open; (2) fill the electrolyzer with an aqueous liquid, when possible; (3) allow the electrolyzer to cool before opening; and (4) schedule and staff maintenance of the electrolyzer to minimize the time the electrolyzer is open.
	c. When the electrolyzer top is raised and before moving the top and anodes, thoroughly flush all visible mercury from the top and the anodes with an aqueous liquid, when possible.
	d. While an electrolyzer is open, keep the bottom covered with an aqueous liquid or maintain a continuous flow of aqueous liquid, when possible.
	e. During an electrolyzer side panel change, take measures to ensure an aqueous liquid covers or flows over the bottom, when possible.
	f. Each time an electrolyzer is opened, inspect and replace components, as appropriate.
	g. If you step into an electrolyzer bottom, either remove all visible mercury from your footwear or replace them immediately after stepping out of the electrolyzer.
	h. If an electrolyzer is disassembled for overhaul maintenance or for any other reason, chemically clean the bed plate or thoroughly flush it with an aqueous liquid.
	i. Before transporting each electrolyzer part to another work area, remove all visible mercury from the part or contain the part to prevent mercury from dripping during transport.
	j. After completing maintenance on an electrolyzer, check any mercury piping flanges that were opened for liquid mercury leaks.

For . . .	You must . . .
	k. If a liquid mercury spill occurs during any maintenance activity on an electrolyzer, clean it up in accordance with the requirements in Table 3 to this subpart.
3. Vessels in liquid mercury service.	If you replace a vessel containing mercury that is intended to trap and collect mercury after December 19, 2003, replace it with a vessel that has a cone shaped bottom with a drain valve or other design that readily facilitates mercury collection.
4. Piping and process lines in liquid mercury service.	a. To prevent mercury buildup after December 19, 2003, equip each new process line and piping system with smooth interiors and adequate low point drains or mercury knock-out pots to avoid liquid mercury buildup within the pipe and to facilitate mercury collection and recovery.
5. Cell room floors	a. Maintain a coating on cell room floors that is resistant to absorption of mercury and that facilitates the detection of liquid mercury spills or accumulations.
	b. Maintain cell room floors such that they are smooth and free of cracking and spalling.
	c. Maintain the cell room floor to prevent mercury accumulation in the corners.
	d. Maintain a layer of aqueous liquid on liquid mercury contained in trenches or drains and replenish the aqueous layer at least once per day.
	e. Keep the cell room floor clean and free of debris.
	f. If you step into a liquid mercury spill or accumulation, either remove all visible mercury from your footwear or replace your footwear immediately.
6. End boxes	a. Either equip each end box with a fixed cover that is leak tight, or route the end box head space to an end box ventilation system.
	b. For each end box ventilation system: maintain a flow of aqueous liquid over the liquid mercury in the end box and maintain the temperature of the aqueous liquid below its boiling point, maintain a negative pressure in the end box ventilation system, and maintain the end box ventilation system in good condition.
	c. Maintain each end box cover in good condition and keep the end box closed when the cell is in service and when liquid mercury is flowing down the cell, except when operation or maintenance activities require short-term access.
	d. Keep all bolts and C-clamps used to hold the covers in place when the cell is in service and when liquid mercury is flowing down the cell.
	e. Maintain each access port stopper in an end box cover in good sealing condition and keep each end box access port closed when the cell is in service and when liquid mercury is flowing down the cell.
7. Decomposers	a. Maintain each decomposer cover in good condition and keep each decomposer closed and sealed, except when maintenance activities require the cover to be removed.
	b. Maintain connections between the decomposer and the corresponding cell components, hydrogen system piping, and caustic system piping in good condition and keep the connections closed/tight, except when maintenance activities require opening/loosening these connections.
	c. Keep each mercury cell amalgam seal pot closed and sealed, except when operation or maintenance activities require short-term access.
	d. Prior to opening a decomposer, do the following: fill the decomposer with an aqueous liquid or drain the decomposer liquid mercury into a container that meets requirements in Table 1, Item 9 or 10, allow the decomposer to cool before opening, and complete work that can be done before opening the decomposer.
	e. Take precautions to avoid mercury spills when changing graphite grids or balls in horizontal decomposers or graphite packing in vertical decomposers. If a spill occurs, you must clean it up in accordance with the requirements in Table 3 to this subpart.
	f. After each maintenance activity, use an appropriate technique (Table 6 to this subpart) to check for hydrogen leaks.
	g. Before transporting any internal part from the decomposer (such as the graphite basket) to another work area, remove all visible mercury from the part or contain the part to prevent mercury from dripping during transport.
	h. Store carbon from decomposers in accordance with the requirements in 40 CFR part 265, subparts I and CC, until the carbon is treated or is disposed.
8. Submerged mercury pumps	a. Provide a vapor outlet connection from each submerged pump to an end box ventilation system. The connection must be maintained under negative pressure.
	b. Keep each mercury pump tank closed, except when maintenance or operation activities require the cover to be removed.
	c. Maintain a flow of aqueous liquid over the liquid mercury in each mercury pump tank and maintain the aqueous liquid at a temperature below its boiling point.
9. Open-top containers holding liquid mercury.	Maintain a layer of aqueous liquid over liquid mercury in each open-top container. Replenish the aqueous layer at least once per day and, when necessitated by operating procedures or observation, collect the liquid mercury from the container in accordance with the requirements in Table 4 to this subpart.
10. Closed containers used to store liquid mercury.	a. Store liquid mercury in containers with tight fitting covers.
	b. Maintain the seals on the covers in good condition.
	c. Keep each container securely closed when mercury is not being added to, or removed from, the container.
11. Caustic systems	a. Maintain the seal between each caustic basket cover and caustic basket by using gaskets and other appropriate material.
	b. Do not allow solids and liquids collected from back-flushing primary caustic filters to contact floors or run into open trenches.

For . . .	You must . . .
	c. Collect solids and liquids from back-flushing each primary caustic filter and collect these mercury-containing wastes in process vessels or in accordance with the requirements in 40 CFR part 265, subparts I and CC. d. Keep each caustic basket closed and sealed, except when operation or maintenance activities require short term access.
12. Hydrogen systems	a. Collect drips from each hydrogen seal pot and compressor seal in containers meeting the requirements in this table for open containers. These drips should not be allowed to run on the floor or in open trenches. b. Minimize purging of hydrogen from a decomposer into the cell room by either sweeping the decomposer with an inert gas or by routing the hydrogen to the hydrogen system. c. Maintain hydrogen piping gaskets in good condition. d. After any maintenance activities, use an appropriate technique (Table 6 to this subpart) to check all hydrogen piping flanges that were opened for hydrogen leaks.

TABLE 2 TO SUBPART IIIII OF PART 63—WORK PRACTICE STANDARDS—REQUIRED INSPECTIONS

As stated in §63.8192, you must meet the work practice standards in the following table:

You must inspect . . .	At least once each . . .	And if you find . . .	You must . . .
1. Each vent hose on each mercury cell.	Half day	A leaking vent hose	Take action immediately to correct the leak.
2. Each open-top container holding liquid mercury.	Half day	Liquid mercury that is not covered by an aqueous liquid.	Take action immediately to cover the liquid mercury with an aqueous liquid.
3. Each end box	Half day	a. An end box cover not securely in place.	Take action immediately to put the end box cover securely in place.
		b. An end box stopper not securely in place.	Take action immediately to put the end box stopper securely in place.
		c. Liquid mercury in an end box that is not covered by an aqueous liquid at a temperature below boiling.	Take action immediately to cover the liquid mercury with an aqueous liquid.
4. Each mercury amalgam seal pot.	Half day	A seal pot cover that is not securely in place.	Take action immediately to put the seal pot cover securely in place.
5. Each mercury seal pot	Half day	A mercury seal pot stopper not securely in place.	Take action immediately to put the mercury seal pot stopper securely in place.
6. Cell room floors	Month	Cracks, spalling, or other deficiencies that could cause liquid mercury to become trapped.	Repair the crack, spalling, or other deficiency within 1 month from the time you identify the deficiency.
7. Pillars and beams	6 months	Cracks, spalling, or other deficiencies that could cause liquid mercury to become trapped.	Repair the crack, spalling, or other deficiency within 1 month from the time you identify the deficiency.
8. Each caustic basket	Half day	A caustic basket cover that is not securely in place.	Take action immediately to put the caustic basket cover securely in place.
9. All equipment and piping in the caustic system.	Day	Equipment that is leaking caustic	Initiate repair of the leaking equipment within 72 hours from the time that you identify the caustic leak.
10. All floors and other surfaces where liquid mercury could accumulate in cell rooms and other production facilities and in mercury recovery facilities.	Half day	A liquid mercury spill or accumulation.	Take the required action specified in Table 3 to this subpart.
11. Each electrolyzer bottom, electrolyzer side panel, end box, mercury amalgam seal pot, decomposer, mercury pump, and hydrogen cooler, and all other vessels, piping, and equipment in liquid mercury service in the cell room.	Day	Equipment that is leaking liquid mercury.	Take the required action specified in Table 3 to this subpart.

You must inspect . . .	At least once each . . .	And if you find . . .	You must . . .
12. Each decomposer and all hydrogen piping up to the hydrogen header.	Half day	Equipment that is leaking hydrogen and/or mercury vapor.	Take the required action specified in Table 3 to this subpart.
13. All equipment in the hydrogen system from the start of the header to the last control device.	3 months	Equipment that is leaking hydrogen and/or mercury vapor.	Take the required action specified in Table 3 to this subpart.

TABLE 3 TO SUBPART IIIII OF PART 63—WORK PRACTICE STANDARDS—REQUIRED ACTIONS FOR LIQUID MERCURY SPILLS AND ACCUMULATIONS AND HYDROGEN AND MERCURY VAPOR LEAKS

As stated in §63.8192, you must meet the work practice standards in the following table:

During a required inspection or at any other time, If you find . . .	You must . . .
1. A liquid mercury spill or accumulation ...	a. Initiate clean up of the liquid mercury spill or accumulation as soon as possible, but no later than 1 hour from the time you detect it. b. Clean up liquid mercury using a mercury vacuum cleaner or by using an alternative method. If you use an alternative method to clean up liquid mercury, you must submit a description of the method to the Administrator in your Notification of Compliance Status report. c. If you use a mercury vacuum cleaner, the vacuum cleaner must be designed to prevent generation of airborne mercury; you must cap the ends of hoses after each use; and after vacuuming, you must wash down the area. d. Inspect all equipment in liquid mercury service in the surrounding area to identify the source of the liquid mercury within 1 hour from the time you detect the liquid mercury spill or accumulation. e. If you identify leaking equipment as the source of the spill or accumulation, contain the dripping mercury, stop the leak, and repair the leaking equipment as specified below. f. If you cannot identify the source of the liquid mercury spill or accumulation, re-inspect the area within 6 hours of the time you detected the liquid mercury spill or accumulation, or within 6 hours of the last inspection of the area.
2. Equipment that is leaking liquid mercury	a. Contain the liquid mercury dripping from the leaking equipment by placing a container under the leak within 30 minutes from the time you identify the liquid mercury leak. b. The container must meet the requirement for open-top containers in Table 1 to this subpart. c. Make a first attempt at stopping the leak within 1 hour from the time you identify the liquid mercury leak. d. Stop the leak and repair the leaking equipment within 4 hours from the time you identify the liquid mercury leak. e. You can delay repair of equipment leaking liquid mercury if you either isolate the leaking equipment from the process so that it does not remain in mercury service; or determine that you cannot repair the leaking equipment without taking the cell off line, provided that you contain the dripping mercury at all times as described above, and take the cell off line as soon as practicable, but no later than 48 hours from the time you identify the leaking equipment. You cannot place the cell back into service until the leaking equipment is repaired.
3. A decomposer or hydrogen system piping up to the hydrogen header that is leaking hydrogen and/or mercury vapor.	a. Make a first attempt at stopping the leak within 1 hour from the time you identify the hydrogen and/or mercury vapor leak. b. Stop the leak and repair the leaking equipment within 4 hours from the time you identify the hydrogen and/or mercury vapor leak. c. You can delay repair of an equipment leaking hydrogen and/or mercury vapor if you isolate the leaking equipment or take the cell off line until you repair the leaking equipment.
4. Equipment in the hydrogen system, from the start of the hydrogen header to the last control device, that is leaking hydrogen and/or mercury vapor.	a. Make a first attempt at stopping the leak within 4 hours from the time you identify the hydrogen and/or mercury vapor leak. b. Stop the leak and repair the header within 24 hours from the time you identify the hydrogen and/or mercury vapor leak. c. You can delay repair of equipment leaking hydrogen and/or mercury vapor if you isolate the leaking equipment.

TABLE 4 TO SUBPART IIIII OF PART 63—WORK PRACTICE STANDARDS—REQUIREMENTS FOR MERCURY LIQUID COLLECTION

As stated in §63.8192, you must meet the work practice standards in the following table:

You must collect liquid mercury from . . .	At the following intervals	When collecting the mercury, you must meet these requirements		
1. Open-top containers.	a. At least once each 72 hours.	i. If you spill liquid mercury during collection or transport, you must take the action specified in Table 3 to this subpart for liquid mercury spills and accumulations.	ii. From the time that you collect liquid mercury into a temporary container until the time that you store the liquid mercury, you must keep it covered by an aqueous liquid.	iii. Within 4 hours from the time you collect the liquid mercury, you must transfer it from each temporary container to a storage container that meets the specifications in Table 1 to this subpart.
2. Vessels, low point drains, mercury knockout pots, and other closed mercury collection points.	a. At least once each week.	See 1.a.i through iii above.		
3. All other equipment.	a. Whenever maintenance activities require the opening of the equipment.	See 1.a.i. through iii above.		

TABLE 5 TO SUBPART IIIII OF PART 63—REQUIRED ELEMENTS OF FLOOR-LEVEL MERCURY VAPOR MEASUREMENT AND CELL ROOM MONITORING PLANS

Your Floor-Level Mercury Vapor Measurement Plan required by §63.8192(d) and Cell Room Monitoring Plan required by §63.8192(g) must contain the elements listed in the following table:

You must specify in your plan . . .	Additional requirements
Floor-Level Mercury Vapor Measurement Plan	
1. Locations in the cell room where you will measure the level of mercury vapor.	The locations must be representative of the entire cell room floor area. At a minimum you must measure the level of mercury vapor above mercury-containing cell room equipment, as well as areas around the cells, decomposes, or other mercury-containing equipment.
2. Equipment or sampling and analytical methods that you will use to measure the level of mercury vapor.	If an instrument or other equipment is used, the plan must include manufacturer specifications and calibration procedures. The plan must also include a description of how you will ensure that the instrument will be calibrated and maintained according to manufacturer specifications.
3. Measurement frequency	Measurements must take place at least once each half day.
4. Number of measurements	At least three readings must be taken at each sample location and the average of these readings must be recorded.
5. A floor-level mercury concentration action level	The action level may not be higher than 0.05 mg/m^3.
Cell Room Monitoring Plan	
1. Details of your mercury monitoring system.	
2. How representative sampling will be conducted	Include some pre-plan measurements to demonstrate the profile of mercury concentration in the cell room and how the selected sampling locations ensure conducted representativeness.
3. Quality assurance/quality control procedures for your mercury monitoring system.	Include a description of how you will keep records or other means to demonstrate that the system is operating properly.

You must specify in your plan . . .	Additional requirements
4. Your action level	Include the background data used to establish your level.

TABLE 6 TO SUBPART IIIII OF PART 63—EXAMPLES OF TECHNIQUES FOR EQUIPMENT PROBLEM IDENTIFICATION, LEAK DETECTION AND MERCURY VAPOR

As stated in Tables 1 and 2 of Subpart IIIII, examples of techniques for equipment problem identification, leak detection and mercury vapor measurements can be found in the following table:

To detect . . .	You could use . . .	Principle of detection . . .
1. Leaking vent hoses; liquid mercury that is not covered by an aqueous liquid in open-top containers or end boxes; end box covers or stoppers, amalgam seal pot stoppers, or caustic basket covers not securely in place; cracks or spalling in cell room floors, pillars, or beams; caustic leaks; liquid mercury accumulations or spills; and equipment that is leaking liquid mercury.	Visual inspections	
2. Equipment that is leaking hydrogen and/or mercury vapor during inspections required by Table 2 to this subpart.	a. Auditory and visual inspections	
	b. Portable mercury vapor analyzer—ultraviolet light absorption detector.	A sample of gas is drawn through a detection cell where ultraviolet light at 253.7 nanometers (nm) is directed perpendicularly through the sample toward a photodetector. Elemental mercury absorbs the incident light in proportion to its concentration in the air stream.
	c. Portable mercury vapor analyzer—gold film amalgamation detector.	A sample of gas is drawn through a detection cell containing a gold film detector. Elemental mercury amalgamates with the gold film, changing the resistance of the detector in proportion to the mercury concentration in the air sample.
	d. Portable short-wave ultraviolet light, fluorescent background—visual indication.	Ultraviolet light is directed toward a fluorescent background positioned behind a suspected source of mercury emissions. Elemental mercury vapor absorbs the ultraviolet light, projecting a dark shadow image on the fluorescent background.
	e. Portable combustible gas meter.	
3. Level of mercury vapor in the cell room and other areas.	a. Portable mercury vapor analyzer—ultraviolet light absorption detector.	See Item 2.b.
	b. Portable mercury vapor analyzer—gold film amalgamation detector.	See Item 2.c.
	c. Permanganate impingement	A known volume of gas sample is absorbed in potassium permanganate solution. Elemental mercury in the solution is determined using a cold vapor adsorption analyzer, and the concentration of mercury in the gas sample is calculated.

TABLE 7 TO SUBPART IIIII OF PART 63—REQUIRED ELEMENTS OF WASHDOWN PLANS

As stated in §63.8192, your written washdown plan must address the elements contained in the following table:

For each of the following areas . . .	You must establish the following as part of your plan . . .
1. Center aisles of cell rooms	A description of the manner of washdown of the area, and the washdown frequency for the area.
2. Electrolyzers	

For each of the following areas . . .	You must establish the following as part of your plan . . .
3. End boxes and areas under end boxes 4. Decomposers and areas under decomposers 5. Caustic baskets and areas around caustic baskets 6. Hydrogen system piping 7. Basement floor of cell rooms 8. Tanks 9. Pillars and beams in cell rooms 10. Mercury cell repair areas 11. Maintenance shop areas 12. Work tables 13. Mercury thermal recovery units 14. Storage areas for mercury-containing wastes	

TABLE 8 TO SUBPART IIIII OF PART 63—REQUIREMENTS FOR CELL ROOM MONITORING PROGRAM

As stated in §63.8192(g)(1), your mercury monitoring system must meet the requirements contained in the following table:

If you utilize an . . .	Your . . .	Must . . .
1. Extractive cold vapor spectroscopy system.	a. Mercury vapor analyzer	Be capable of continuously monitoring the elemental mercury concentration with a detection level at least two times lower than the baseline mercury concentration in the cell room.
	b. Sampling system	Obtain measurements at three or more locations along the center aisle of the cell room at a height sufficient to ensure that sample is representative of the entire cell room. One sampling location must be above the midpoint of the center aisle, and the other two an equidistance between the midpoint and the end of the cells.
2. Open path differential optical absorption spectroscopy system.	a. Mercury vapor analyzer	Be capable of continuously monitoring the elemental mercury concentration with a detection level at least two times lower than the baseline mercury concentration in the cell room.
	b. Path	Be directed along the center aisle at a height sufficient to ensure that the sample is representative of the entire cell room.

TABLE 9 TO SUBPART IIIII OF PART 63—REQUIRED RECORDS FOR WORK PRACTICE STANDARDS

As stated in §63.8256(c), you must keep the records (related to the work practice standards) specified in the following table:

For each . . .	You must record the following information . . .
1. Inspection required by Table 2 to this subpart	Date and time the inspection was conducted.
2. Situation found during an inspection required by Table 2 to this subpart: leaking vent hose; open-top container where liquid mercury is not covered by an aqueous liquid; end box cover that is not securely in place; end box stopper that is not securely in place; end box where liquid mercury is not covered by an aqueous liquid at a temperature below boiling; seal pot cover that is not securely in place; open or mercury seal pot stopper that is not securely in place; crack, spalling, or other deficiency in a cell room floor, pillar, or beam that could cause liquid mercury to become trapped; or caustic basket that is not securely in place.	a. Description of the condition. b. Location of the condition. c. Date and time you identify the condition. d. Description of the corrective action taken. e. Date and time you successfully complete the corrective action.
3. Caustic leak during an inspection required by Table 2 to this subpart.	a. Location of the leak. b. Date and time you identify the leak. c. Date and time you successfully stop the leak and repair the leaking equipment.
4. Liquid mercury spill or accumulation identified during an inspection required by Table 2 to this subpart or at any other time.	a. Location of the liquid mercury spill or accumulation. b. Estimate of the weight of liquid mercury. c. Date and time you detect the liquid mercury spill or accumulation. d. Method you use to clean up the liquid mercury spill or accumulation.

For each . . .	You must record the following information . . .
5. Liquid mercury leak or hydrogen leak identified during an inspection required by Table 2 to this subpart or at any other time.	e. Date and time when you clean up the liquid mercury spill or accumulation. f. Source of the liquid mercury spill or accumulation. g. If the source of the liquid mercury spill or accumulation is not identified, the time when you reinspect the area. a. Location of the leak. b. Date and time you identify the leak. c. If the leak is a liquid mercury leak, the date and time that you successfully contain the dripping liquid mercury. d. Date and time you first attempt to stop the leak. e. Date and time you successfully stop the leak and repair the leaking equipment. f. If you take a cell off line or isolate the leaking equipment, the date and time you take the cell off line or isolate the leaking equipment, and the date and time you put the cell or isolated equipment back into service.
6. Occasion for which it is not possible to perform the design, operation and maintenance procedures required by Item 2 of Table 1 to this subpart.	a. Reason for not being able to perform each procedure determined to be not possible. b. Actions taken to reduce or prevent mercury emissions, in lieu of the requirements in Table 1 to this subpart.

TABLE 10 TO SUBPART IIIII OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART IIIII

As stated in § 63.8262, you must comply with the applicable General Provisions requirements according to the following table:

Citation	Subject	Applies to Subpart IIIII	Explanation
§ 63.1	Applicability	Yes.	
§ 63.2	Definitions	Yes.	
§ 63.3	Units and Abbreviations	Yes.	
§ 63.4	Prohibited Activities	Yes.	
§ 63.5	Construction/Reconstruction	Yes.	
§ 63.6(a)–(g), (i), (j)	Compliance with Standards and Maintenance Requirements.	Yes.	
§ 63.6(h)	Compliance with Opacity and Visible Emission Standards.	No	Subpart IIIII does not have opacity and visible emission standards.
§ 63.7(a)(1), (b)–(h)	Performance Testing Requirements.	Yes	Subpart IIIII specifies additional requirements related to site-specific test plans and the conduct of performance tests.
§ 63.7(a)(2)	Applicability and Performance Test Dates.	No	Subpart IIIII requires the performance test to be performed on the compliance date.
§ 63.8(a)(1), (a)(3); (b); (c)(1)–(4), (6)–(8); (d); (e); and (f)(1)–(5).	Monitoring Requirements	Yes.	
§ 63.8(a)(2)	Continuous Monitoring System (CMS) Requirements.	No	Subpart IIIII requires a site-specific monitoring plan in lieu of a promulgated performance specification for a mercury concentration CMS.
§ 63.8(a)(4)	Additional Monitoring Requirements for Control Devices in § 63.11.	No	Subpart IIIII does not require flares.
§ 63.8(c)(5)	COMS Minimum Procedures	No	Subpart IIIII does not have opacity and visible emission standards.
§ 63.8(f)(6)	Alternative to Relative Accuracy Test.	No	Subpart IIIII does not require CEMS.
§ 63.8(g)	Data Reduction	No	Subpart IIIII specifies mercury concentration CMS data reduction requirements.
§ 63.9(a)–(e), (g)–(j)	Notification Requirements	Yes.	
§ 63.9(f)	Notification of VE/Opacity Test.	No	Subpart IIIII does not have opacity and visible emission standards.

Citation	Subject	Applies to Subpart IIIII	Explanation
§ 63.10(a); (b)(1); (b)(2)(i)–(xii), (xiv); (b)(3); (c); (d)(1)–(2), (4)–(5); (e); (f).	Recordkeeping/Reporting	Yes.	
§ 63.10(b)(2)(xiii)	CMS Records for RATA Alternative.	No	Subpart IIIII does not require CEMS.
§ 63.10(d)(3)	Reporting Opacity or VE Observations.	No	Subpart IIIII does not have opacity and visible emission standards.
§ 63.11	Flares	No	Subpart IIIII does not require flares.
§ 63.12	Delegation	Yes.	
§ 63.13	Addresses	Yes.	
§ 63.14	Incorporation by Reference	Yes.	
§ 63.15	Availability of Information	Yes.	

Subpart JJJJJ—National Emission Standards for Hazardous Air Pollutants for Brick and Structural Clay Products Manufacturing

SOURCE: 68 FR 26722, May 16, 2003, unless otherwise note.

WHAT THIS SUBPART COVERS

§ 63.8380 What is the purpose of this subpart?

This subpart establishes national emission limitations for hazardous air pollutants (HAP) emitted from brick and structural clay products (BSCP) manufacturing facilities. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations.

§ 63.8385 Am I subject to this subpart?

You are subject to this subpart if you own or operate a BSCP manufacturing facility that is, is located at, or is part of, a major source of HAP emissions according to the criteria in paragraphs (a) and (b) of this section.

(a) A BSCP manufacturing facility is a plant site that manufactures brick (including, but not limited to, face brick, structural brick, and brick pavers); clay pipe; roof tile; extruded floor and wall tile; and/or other extruded, dimensional clay products. Brick and structural clay products manufacturing facilities typically process raw clay and shale, form the processed materials into bricks or shapes, and dry and fire the bricks or shapes.

(b) A major source of HAP emissions is any stationary source or group of stationary sources within a contiguous area under common control that emits or has the potential to emit any single HAP at a rate of 9.07 megagrams (10 tons) or more per year or any combination of HAP at a rate of 22.68 megagrams (25 tons) or more per year.

§ 63.8390 What parts of my plant does this subpart cover?

(a) This subpart applies to each existing, new, or reconstructed affected source at a BSCP manufacturing facility.

(b) The existing affected source is an existing tunnel kiln with a design capacity equal to or greater than 9.07 megagrams per hour (Mg/hr) (10 tons per hour (tph)) of fired product according to paragraphs (b)(1) through (3) of this section. For the remainder of this subpart, a tunnel kiln with a design capacity equal to or greater than 9.07 Mg/hr (10 tph) of fired product will be called a large tunnel kiln, and a tunnel kiln with a design capacity less than 9.07 Mg/hr (10 tph) of fired product will be called a small tunnel kiln.

(1) For existing tunnel kilns that do not have sawdust dryers, the kiln exhaust process stream (*i.e.,* the only process stream) is subject to the requirements of this subpart.

(2) For existing tunnel kilns that ducted exhaust to sawdust dryers prior to July 22, 2002, only the kiln exhaust process stream (*i.e.,* the process stream that exhausts directly to the atmosphere or to an air pollution control device (APCD)) is subject to the requirements of this subpart. As such, any process stream that is ducted to a sawdust dryer is not subject to these requirements.

(3) For existing tunnel kilns that first ducted exhaust to sawdust dryers on or after July 22, 2002, all of the exhaust (*i.e.*, all process streams) is subject to the requirements of this subpart.

(c) An existing small tunnel kiln whose design capacity is increased such that it is equal to or greater than 9.07 Mg/hr (10 tph) of fired product is subject to the requirements of this subpart.

(d) An existing tunnel kiln with a federally enforceable permit condition that restricts kiln operation to less than 9.07 Mg/hr (10 tph) of fired product on a 12-month rolling average basis is not subject to the requirements of this subpart.

(e) Each new or reconstructed tunnel kiln is an affected source regardless of design capacity. All process streams from each new or reconstructed tunnel kiln are subject to the requirements of this subpart.

(f) Kilns that are used exclusively for research and development (R&D) and are not used to manufacture products for commercial sale, except in a de minimis manner, are not subject to the requirements of this subpart.

(g) Kilns that are used exclusively for setting glazes on previously fired products are not subject to the requirements of this subpart.

(h) A source is a new affected source if construction of the affected source began after July 22, 2002, and you met the applicability criteria at the time you began construction.

(i) An affected source is reconstructed if you meet the criteria as defined in §63.2, except as provided in paragraphs (i)(1) and (i)(2) of this section.

(1) It is not technologically and economically feasible for an existing small tunnel kiln whose design capacity is increased such that it is equal to or greater than 9.07 Mg/hr (10 tph) of fired product to meet the relevant standards (*i.e.*, new source maximum achievable control technology (MACT)) by retrofitting with a dry lime injection fabric filter (DIFF), dry lime scrubber/fabric filter (DLS/FF), or wet scrubber (WS).

(2) It is not technologically and economically feasible for an existing large dry limestone adsorber (DLA)-controlled kiln to meet the relevant standards by retrofitting with a DIFF, DLS/FF, or WS.

(j) An affected source is existing if it is not new or reconstructed.

§63.8395 When do I have to comply with this subpart?

(a) If you have a new or reconstructed affected source, you must comply with this subpart according to paragraphs (a)(1) and (2) of this section.

(1) If the initial startup of your affected source is before May 16, 2003, then you must comply with the applicable emission limitations in Tables 1 and 2 to this subpart no later than May 16, 2003.

(2) If the initial startup of your affected source is after May 16, 2003, then you must comply with the applicable emission limitations in Tables 1 and 2 to this subpart upon initial startup of your affected source.

(b) If you have an existing affected source, you must comply with the applicable emission limitations in Tables 1 and 2 to this subpart no later than May 16, 2006.

(c) If you have an existing area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, you must be in compliance with this subpart according to paragraphs (c)(1) and (2) of this section.

(1) Any portion of the existing facility that is a new affected source or a new reconstructed source must be in compliance with this subpart upon startup.

(2) All other parts of the existing facility must be in compliance with this subpart by 3 years after the date the area source becomes a major source.

(d) If you have a new area source (*i.e.*, an area source for which construction or reconstruction commenced after July 22, 2002) that increases its emissions or its potential to emit such that it becomes a major source of HAP, you must be in compliance with this subpart upon initial startup of your affected source as a major source.

(e) You must meet the notification requirements in §63.8480 according to the schedule in §63.8480 and in 40 CFR part 63, subpart A. Some of the notifications must be submitted before you

are required to comply with the emission limitations in this subpart.

EMISSION LIMITATIONS

§ 63.8405 What emission limitations must I meet?

(a) You must meet each emission limit in Table 1 to this subpart that applies to you.

(b) You must meet each operating limit in Table 2 to this subpart that applies to you.

§ 63.8410 What are my options for meeting the emission limitations?

To meet the emission limitations in Tables 1 and 2 to this subpart, you must use one or more of the options listed in paragraphs (a) and (b) of this section.

(a) *Emissions control system.* Use an emissions capture and collection system and an APCD and demonstrate that the resulting emissions or emissions reductions meet the emission limits in Table 1 to this subpart, and that the capture and collection system and APCD meet the applicable operating limits in Table 2 to this subpart.

(b) *Process changes.* Use low-HAP raw materials or implement manufacturing process changes and demonstrate that the resulting emissions or emissions reductions meet the emission limits in Table 1 to this subpart.

GENERAL COMPLIANCE REQUIREMENTS

§ 63.8420 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limitations (including operating limits) in this subpart at all times, except during periods of startup, shutdown, and malfunction and during periods of routine control device maintenance as specified in paragraph (e) of this section.

(b) Except as specified in paragraph (e) of this section, you must always operate and maintain your affected source, including air pollution control and monitoring equipment, according to the provisions in § 63.6(e)(1)(i). During the period between the compliance date specified for your affected source in § 63.8395 and the date upon which continuous monitoring systems (CMS) (*e.g.*, continuous parameter monitoring systems) have been installed and verified and any applicable operating limits have been set, you must maintain a log detailing the operation and maintenance of the process and emissions control equipment.

(c) You must develop a written start-up, shutdown, and malfunction plan (SSMP) according to the provisions in § 63.6(e)(3).

(d) You must prepare and implement a written operation, maintenance, and monitoring (OM&M) plan according to the requirements in § 63.8425.

(e) If you own or operate an affected kiln and must perform routine maintenance on the control device for that kiln, you may bypass the kiln control device and continue operating the kiln upon approval by the Administrator provided you satisfy the conditions listed in paragraphs (e)(1) through (5) of this section.

(1) You must request a routine control device maintenance exemption from the Administrator. Your request must justify the need for the routine maintenance on the control device and the time required to accomplish the maintenance activities, describe the maintenance activities and the frequency of the maintenance activities, explain why the maintenance cannot be accomplished during kiln shutdowns, describe how you plan to minimize emissions to the greatest extent possible during the maintenance, and provide any other documentation required by the Administrator.

(2) The routine control device maintenance exemption must not exceed 4 percent of the annual operating uptime for each kiln.

(3) The request for the routine control device maintenance exemption, if approved by the Administrator, must be incorporated by reference in and attached to the affected source's title V permit.

(4) You must minimize HAP emissions during the period when the kiln is operating and the control device is offline.

(5) You must minimize the time period during which the kiln is operating and the control device is offline.

(f) You must be in compliance with the provisions of subpart A of this part,

except as noted in Table 7 to this subpart.

[68 FR 26722, May 16, 2003, as amended at 71 FR 20469, Apr. 20, 2006]

§63.8425 What do I need to know about operation, maintenance, and monitoring plans?

(a) You must prepare, implement, and revise as necessary an OM&M plan that includes the information in paragraph (b) of this section. Your OM&M plan must be available for inspection by the permitting authority upon request.

(b) Your OM&M plan must include, as a minimum, the information in paragraphs (b)(1) through (13) of this section.

(1) Each process and APCD to be monitored, the type of monitoring device that will be used, and the operating parameters that will be monitored.

(2) A monitoring schedule that specifies the frequency that the parameter values will be determined and recorded.

(3) The limits for each parameter that represent continuous compliance with the emission limitations in §63.8405. The limits must be based on values of the monitored parameters recorded during performance tests.

(4) Procedures for the proper operation and routine and long-term maintenance of each APCD, including a maintenance and inspection schedule that is consistent with the manufacturer's recommendations.

(5) Procedures for installing the CMS sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the exhaust emissions (*e.g.*, on or downstream of the last APCD).

(6) Performance and equipment specifications for the sample interface, the pollutant concentration or parametric signal analyzer, and the data collection and reduction system.

(7) Continuous monitoring system performance evaluation procedures and acceptance criteria (*e.g.*, calibrations).

(8) Procedures for the proper operation and maintenance of monitoring equipment consistent with the requirements in §§63.8450 and 63.8(c)(1), (3), (4)(ii), (7), and (8).

(9) Continuous monitoring system data quality assurance procedures consistent with the requirements in §63.8(d).

(10) Continuous monitoring system recordkeeping and reporting procedures consistent with the requirements in §63.10(c), (e)(1), and (e)(2)(i).

(11) Procedures for responding to operating parameter deviations, including the procedures in paragraphs (b)(11)(i) through (iii) of this section.

(i) Procedures for determining the cause of the operating parameter deviation.

(ii) Actions for correcting the deviation and returning the operating parameters to the allowable limits.

(iii) Procedures for recording the times that the deviation began and ended and corrective actions were initiated and completed.

(12) Procedures for keeping records to document compliance.

(13) If you operate an affected kiln and you plan to take the kiln control device out of service for routine maintenance, as specified in §63.8420(e), the procedures specified in paragraphs (b)(13)(i) and (ii) of this section.

(i) Procedures for minimizing HAP emissions from the kiln during periods of routine maintenance of the kiln control device when the kiln is operating and the control device is offline.

(ii) Procedures for minimizing the duration of any period of routine maintenance on the kiln control device when the kiln is operating and the control device is offline.

(c) Changes to the operating limits in your OM&M plan require a new performance test. If you are revising an operating limit parameter value, you must meet the requirements in paragraphs (c)(1) and (2) of this section.

(1) Submit a notification of performance test to the Administrator as specified in §63.7(b).

(2) After completing the performance tests to demonstrate that compliance with the emission limits can be achieved at the revised operating limit parameter value, you must submit the performance test results and the revised operating limits as part of the Notification of Compliance Status required under §63.9(h).

(d) If you are revising the inspection and maintenance procedures in your OM&M plan, you do not need to conduct a new performance test.

TESTING AND INITIAL COMPLIANCE REQUIREMENTS

§ 63.8435 By what date must I conduct performance tests?

You must conduct performance tests within 180 calendar days after the compliance date that is specified for your source in § 63.8395 and according to the provisions in § 63.7(a)(2).

§ 63.8440 When must I conduct subsequent performance tests?

(a) You must conduct a performance test before renewing your 40 CFR part 70 operating permit or at least every 5 years following the initial performance test.

(b) You must conduct a performance test when you want to change the parameter value for any operating limit specified in your OM&M plan.

§ 63.8445 How do I conduct performance tests and establish operating limits?

(a) You must conduct each performance test in Table 3 to this subpart that applies to you.

(b) Before conducting the performance test, you must install and calibrate all monitoring equipment.

(c) Each performance test must be conducted according to the requirements in § 63.7 and under the specific conditions in Table 3 to this subpart.

(d) You must test while operating at the maximum production level.

(e) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in § 63.7(e)(1).

(f) You must conduct at least three separate test runs for each performance test required in this section, as specified in § 63.7(e)(3). Each test run must last at least 1 hour.

(g) You must use the data gathered during the performance test and the equations in paragraphs (g)(1) and (2) of this section to determine compliance with the emission limitations.

(1) To determine compliance with the production-based hydrogen fluoride (HF), hydrogen chloride (HCl), and particulate matter (PM) emission limits in Table 1 to this subpart, you must calculate your mass emissions per unit of production for each test run using Equation 1 of this section:

$$MP = \frac{ER}{P} \qquad \text{(Eq. 1)}$$

Where:

MP=mass per unit of production, kilograms (pounds) of pollutant per megagram (ton) of fired product

ER=mass emission rate of pollutant (HF, HCl, or PM) during each performance test run, kilograms (pounds) per hour

P=production rate during each performance test run, megagrams (tons) of fired product per hour.

(2) To determine compliance with the percent reduction HF and HCl emission limits in Table 1 to this subpart, you must calculate the percent reduction for each test run using Equation 2 of this section:

$$PR = \frac{ER_i - ER_o}{ER_i}(100) \qquad \text{(Eq. 2)}$$

Where:

PR=percent reduction, percent

ER_i=mass emission rate of specific HAP (HF or HCl) entering the APCD, kilograms (pounds) per hour

ER_o=mass emission rate of specific HAP (HF or HCl) exiting the APCD, kilograms (pounds) per hour.

(h) You must establish each site-specific operating limit in Table 2 to this subpart that applies to you as specified in Table 3 to this subpart.

(i) For each affected kiln that is equipped with an APCD that is not addressed in Table 2 to this subpart or that is using process changes as a means of meeting the emission limits in Table 1 to this subpart, you must meet the requirements in § 63.8(f) and paragraphs (i)(1) and (2) of this section.

(1) Submit a request for approval of alternative monitoring procedures to the Administrator no later than the notification of intent to conduct a performance test. The request must contain the information specified in paragraphs (i)(1)(i) through (iv) of this section.

(i) A description of the alternative APCD or process changes.

(ii) The type of monitoring device or procedure that will be used.

(iii) The operating parameters that will be monitored.

(iv) The frequency that the operating parameter values will be determined and recorded to establish continuous compliance with the operating limits.

(2) Establish site-specific operating limits during the performance test based on the information included in the approved alternative monitoring procedures request and, as applicable, as specified in Table 3 to this subpart.

§ 63.8450 What are my monitoring installation, operation, and maintenance requirements?

(a) You must install, operate, and maintain each CMS according to your OM&M plan and the requirements in paragraphs (a)(1) through (5) of this section.

(1) Conduct a performance evaluation of each CMS according to your OM&M plan.

(2) The CMS must complete a minimum of one cycle of operation for each successive 15-minute period. To have a valid hour of data, you must have at least three of four equally spaced data values (or at least 75 percent if you collect more than four data values per hour) for that hour (not including startup, shutdown, malfunction, out-of-control periods, or periods of routine control device maintenance covered by a routine control device maintenance exemption as specified in § 63.8420(e)).

(3) Determine and record the 3-hour block averages of all recorded readings, calculated after every 3 hours of operation as the average of the previous 3 operating hours. To calculate the average for each 3-hour average period, you must have at least 75 percent of the recorded readings for that period (not including startup, shutdown, malfunction, out-of-control periods, or periods of routine control device maintenance covered by a routine control device maintenance exemption as specified in § 63.8420(e)).

(4) Record the results of each inspection, calibration, and validation check.

(5) At all times, maintain the monitoring equipment including, but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment.

(b) For each liquid flow measurement device, you must meet the requirements in paragraphs (a)(1) through (5) and paragraphs (b)(1) through (3) of this section.

(1) Locate the flow sensor in a position that provides a representative flowrate.

(2) Use a flow sensor with a minimum measurement sensitivity of 2 percent of the liquid flowrate.

(3) At least semiannually, conduct a flow sensor calibration check.

(c) For each pressure measurement device, you must meet the requirements in paragraphs (a)(1) through (5) and paragraphs (c)(1) through (7) of this section.

(1) Locate the pressure sensor(s) in or as close to a position that provides a representative measurement of the pressure.

(2) Minimize or eliminate pulsating pressure, vibration, and internal and external corrosion.

(3) Use a gauge with a minimum measurement sensitivity of 0.5 inch of water or a transducer with a minimum measurement sensitivity of 1 percent of the pressure range.

(4) Check the pressure tap daily to ensure that it is not plugged.

(5) Using a manometer, check gauge calibration quarterly and transducer calibration monthly.

(6) Any time the sensor exceeds the manufacturer's specified maximum operating pressure range, conduct calibration checks or install a new pressure sensor.

(7) At least monthly, inspect all components for integrity, all electrical connections for continuity, and all mechanical connections for leakage.

(d) For each pH measurement device, you must meet the requirements in paragraphs (a)(1) through (5) and paragraphs (d)(1) through (4) of this section.

(1) Locate the pH sensor in a position that provides a representative measurement of pH.

(2) Ensure the sample is properly mixed and representative of the fluid to be measured.

(3) Check the pH meter's calibration on at least two points every 8 hours of process operation.

(4) At least monthly, inspect all components for integrity and all electrical connections for continuity.

(e) For each bag leak detection system, you must meet the requirements in paragraphs (e)(1) through (11) of this section.

(1) Each triboelectric bag leak detection system must be installed, calibrated, operated, and maintained according to the ''Fabric Filter Bag Leak Detection Guidance,'' (EPA–454/R–98–015, September 1997). This document is available from the U.S. Environmental Protection Agency (U.S. EPA); Office of Air Quality Planning and Standards; Emissions, Monitoring and Analysis Division; Emission Measurement Center (MD–19), Research Triangle Park, NC 27711. This document is also available on the Technology Transfer Network (TTN) under Emission Measurement Center Continuous Emission Monitoring. Other types of bag leak detection systems must be installed, operated, calibrated, and maintained in a manner consistent with the manufacturer's written specifications and recommendations.

(2) The bag leak detection system must be certified by the manufacturer to be capable of detecting PM emissions at concentrations of 10 milligrams per actual cubic meter (0.0044 grains per actual cubic foot) or less.

(3) The bag leak detection system sensor must provide an output of relative PM loadings.

(4) The bag leak detection system must be equipped with a device to continuously record the output signal from the sensor.

(5) The bag leak detection system must be equipped with an audible alarm system that will sound automatically when an increase in relative PM emissions over a preset level is detected. The alarm must be located where it is easily heard by plant operating personnel.

(6) For positive pressure fabric filter systems, a bag leak detector must be installed in each baghouse compartment or cell.

(7) For negative pressure or induced air fabric filters, the bag leak detector must be installed downstream of the fabric filter.

(8) Where multiple detectors are required, the system's instrumentation and alarm may be shared among detectors.

(9) The baseline output must be established by adjusting the range and the averaging period of the device and establishing the alarm set points and the alarm delay time according to section 5.0 of the ''Fabric Filter Bag Leak Detection Guidance.''

(10) Following initial adjustment of the system, the sensitivity or range, averaging period, alarm set points, or alarm delay time may not be adjusted except as detailed in your OM&M plan. In no case may the sensitivity be increased by more than 100 percent or decreased more than 50 percent over a 365-day period unless such adjustment follows a complete fabric filter inspection that demonstrates that the fabric filter is in good operating condition. Record each adjustment.

(11) Record the results of each inspection, calibration, and validation check.

(f) For each lime or chemical feed rate measurement device, you must meet the requirements in paragraphs (a)(1) through (5) and paragraphs (f)(1) and (2) of this section.

(1) Locate the measurement device in a position that provides a representative feed rate measurement.

(2) At least semiannually, conduct a calibration check.

(g) For each limestone feed system on a DLA, you must meet the requirements in paragraphs (a)(1),(4), and (5) of this section and must ensure on a monthly basis that the feed system replaces limestone at least as frequently as the schedule set during the performance test.

(h) Requests for approval of alternate monitoring procedures must meet the requirements in §§ 63.8445(i) and 63.8(f).

§ 63.8455 How do I demonstrate initial compliance with the emission limitations?

(a) You must demonstrate initial compliance with each emission limitation that applies to you according to Table 4 to this subpart.

(b) You must establish each site-specific operating limit in Table 2 to this subpart that applies to you according

to the requirements in §63.8445 and Table 3 to this subpart.

(c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in §63.8480(e).

CONTINUOUS COMPLIANCE REQUIREMENTS

§63.8465 How do I monitor and collect data to demonstrate continuous compliance?

(a) You must monitor and collect data according to this section.

(b) Except for periods of monitor malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), you must monitor continuously (or collect data at all required intervals) at all times that the affected source is operating. This includes periods of startup, shutdown, malfunction, and routine control device maintenance as specified in §63.8420(e) when the affected source is operating.

(c) You may not use data recorded during monitoring malfunctions, associated repairs, out-of-control periods, or required quality assurance or control activities for purposes of calculating data averages. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring system to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions. You must use all the valid data collected during all other periods in assessing compliance. Any averaging period for which you do not have valid monitoring data and such data are required constitutes a deviation from the monitoring requirements.

§63.8470 How do I demonstrate continuous compliance with the emission limitations?

(a) You must demonstrate continuous compliance with each emission limit and operating limit in Tables 1 and 2 to this subpart that applies to you according to the methods specified in Table 5 to this subpart.

(b) For each affected kiln that is equipped with an APCD that is not addressed in Table 2 to this subpart, or that is using process changes as a means of meeting the emission limits in Table 1 to this subpart, you must demonstrate continuous compliance with each emission limit in Table 1 to this subpart, and each operating limit established as required in §63.8445(i)(2) according to the methods specified in your approved alternative monitoring procedures request, as described in §§63.8445(i)(1) and 63.8(f).

(c) You must report each instance in which you did not meet each emission limit and each operating limit in this subpart that applies to you. This includes periods of startup, shutdown, malfunction, and routine control device maintenance. These instances are deviations from the emission limitations in this subpart. These deviations must be reported according to the requirements in §63.8485.

(d) [Reserved]

(e) Consistent with §§63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with §63.6(e)(1) and your OM&M plan. The Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in §63.6(e).

(f) Deviations that occur during periods of control device maintenance covered by an approved routine control device maintenance exemption according to §63.8420(e) are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with the approved routine control device maintenance exemption.

(g) You must demonstrate continuous compliance with the operating limits in Table 2 to this subpart for visible emissions (VE) from tunnel kilns equipped with DLA, DIFF, or DLS/FF by monitoring VE at each kiln stack according to the requirements in paragraphs (g)(1) through (3) of this section.

(1) Perform daily VE observations of each kiln stack according to the procedures of Method 22 of 40 CFR part 60, appendix A. You must conduct the Method 22 test while the affected

source is operating under normal conditions. The duration of each Method 22 test must be at least 15 minutes.

(2) If VE are observed during any daily test conducted using Method 22 of 40 CFR part 60, appendix A, you must promptly initiate and complete corrective actions according to your OM&M plan. If no VE are observed in 30 consecutive daily Method 22 tests for any kiln stack, you may decrease the frequency of Method 22 testing from daily to weekly for that kiln stack. If VE are observed during any weekly test, you must promptly initiate and complete corrective actions according to your OM&M plan, resume Method 22 testing of that kiln stack on a daily basis, and maintain that schedule until no VE are observed in 30 consecutive daily tests, at which time you may again decrease the frequency of Method 22 testing to a weekly basis.

(3) If VE are observed during any test conducted using Method 22 of 40 CFR part 60, appendix A, you must report these deviations by following the requirements in § 63.8485.

[68 FR 26722, May 16, 2003, as amended at 71 FR 20469, Apr. 20, 2006]

NOTIFICATIONS, REPORTS, AND RECORDS

§ 63.8480 What notifications must I submit and when?

(a) You must submit all of the notifications in §§ 63.7(b) and (c), 63.8(f)(4), and 63.9 (b) through (e), (g)(1), and (h) that apply to you, by the dates specified.

(b) As specified in § 63.9(b)(2) and (3), if you start up your affected source before May 16, 2003, you must submit an Initial Notification not later than 120 calendar days after May 16, 2003.

(c) As specified in § 63.9(b)(3), if you start up your new or reconstructed affected source on or after May 16, 2003, you must submit an Initial Notification not later than 120 calendar days after you become subject to this subpart.

(d) If you are required to conduct a performance test, you must submit a notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin, as required in § 63.7(b)(1).

(e) If you are required to conduct a performance test as specified in Table 3 to this subpart, you must submit a Notification of Compliance Status as specified in § 63.9(h) and paragraphs (e)(1) and (2) of this section.

(1) For each compliance demonstration that includes a performance test conducted according to the requirements in Table 3 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th calendar day following the completion of the performance test, according to § 63.10(d)(2).

(2) In addition to the requirements in § 63.9(h)(2)(i), you must include the information in paragraphs (e)(2)(i) and (ii) of this section in your Notification of Compliance Status.

(i) The operating limit parameter values established for each affected source with supporting documentation and a description of the procedure used to establish the values.

(ii) For each APCD that includes a fabric filter, if a bag leak detection system is used, analysis and supporting documentation demonstrating conformance with EPA guidance and specifications for bag leak detection systems in § 63.8450(e).

(f) If you request a routine control device maintenance exemption according to § 63.8420(e), you must submit your request for the exemption no later than 30 days before the compliance date.

§ 63.8485 What reports must I submit and when?

(a) You must submit each report in Table 6 to this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date in Table 6 to this subpart and as specified in paragraphs (b)(1) through (5) of this section.

(1) The first compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.8395 and ending on June 30 or December 31, and lasting at least 6 months, but less than 12

months. For example, if your compliance date is March 1, then the first semiannual reporting period would begin on March 1 and end on December 31.

(2) The first compliance report must be postmarked or delivered no later than July 31 or January 31 for compliance periods ending on June 30 and December 31, respectively.

(3) Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent compliance report must be postmarked or delivered no later than July 31 or January 31 for compliance periods ending on June 30 and December 31, respectively.

(5) For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (4) of this section.

(c) The compliance report must contain the information in paragraphs (c)(1) through (7) of this section.

(1) Company name and address.

(2) Statement by a responsible official with that official's name, title, and signature, certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a startup, shutdown or malfunction during the reporting period and you took actions consistent with your SSMP and OM&M plan, the compliance report must include the information specified in §63.10(d)(5)(i).

(5) A description of control device maintenance performed while the control device was offline and the kiln controlled by the control device was operating, including the information specified in paragraphs (c)(5)(i) through (iii) of this section.

(i) The date and time when the control device was shutdown and restarted.

(ii) Identification of the kiln that was operating and the number of hours that the kiln operated while the control device was offline.

(iii) A statement of whether or not the control device maintenance was included in your approved routine control device maintenance exemption developed as specified in §63.8420(e). If the control device maintenance was included in your approved routine control device maintenance exemption, then you must report the information in paragraphs (c)(5)(iii)(A) through (C) of this section.

(A) The total amount of time that the kiln controlled by the control device operated during the current semiannual compliance period and during the previous semiannual compliance period.

(B) The amount of time that each kiln controlled by the control device operated while the control device was offline for maintenance covered under the routine control device maintenance exemption during the current semiannual compliance period and during the previous semiannual compliance period.

(C) Based on the information recorded under paragraphs (c)(5)(iii)(A) and (B) of this section, compute the annual percent of kiln operating uptime during which the control device was offline for routine maintenance using Equation 1 of this section.

$$RM = \frac{DT_p + DT_c}{KU_p + KU_c}(100) \qquad \text{(Eq. 1)}$$

Where:

RM=Annual percentage of kiln uptime during which control device was offline for routine control device maintenance

DT_p=Control device downtime claimed under the routine control device maintenance exemption for the previous semiannual compliance period

DT_c=Control device downtime claimed under the routine control device maintenance exemption for the current semiannual compliance period

KU_p=Kiln uptime for the previous semiannual compliance period

KU_c=Kiln uptime for the current semiannual compliance period

(6) If there are no deviations from any emission limitations (emission limits or operating limits) that apply to you, the compliance report must contain a statement that there were no deviations from the emission limitations during the reporting period.

(7) If there were no periods during which the CMS was out-of-control as specified in your OM&M plan, the compliance report must contain a statement that there were no periods during which the CMS was out-of-control during the reporting period.

(d) For each deviation from an emission limitation (emission limit or operating limit) that occurs at an affected source where you are not using a CMS to comply with the emission limitations in this subpart, the compliance report must contain the information in paragraphs (c)(1) through (5) and paragraphs (d)(1) and (2) of this section. This includes periods of startup, shutdown, malfunction, and routine control device maintenance.

(1) The total operating time of each affected source during the reporting period.

(2) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(e) For each deviation from an emission limitation (emission limit or operating limit) occurring at an affected source where you are using a CMS to comply with the emission limitations in this subpart, you must include the information in paragraphs (c)(1) through (5) and paragraphs (e)(1) through (13) of this section. This includes periods of startup, shutdown, malfunction, and routine control device maintenance.

(1) The total operating time of each affected source during the reporting period.

(2) The date and time that each malfunction started and stopped.

(3) The date and time that each CMS was inoperative, except for zero (low-level) and high-level checks.

(4) The date, time, and duration that each CMS was out-of-control, including the pertinent information in your OM&M plan.

(5) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction; during routine control device maintenance covered in your approved routine control device maintenance exemption; or during another period.

(6) A description of corrective action taken in response to a deviation.

(7) A summary of the total duration of the deviation during the reporting period and the total duration as a percent of the total source operating time during that reporting period.

(8) A breakdown of the total duration of the deviations during the reporting period into those that were due to startup, shutdown, control equipment problems, process problems, other known causes, and other unknown causes.

(9) A summary of the total duration of CMS downtime during the reporting period and the total duration of CMS downtime as a percent of the total source operating time during that reporting period.

(10) A brief description of the process units.

(11) A brief description of the CMS.

(12) The date of the latest CMS certification or audit.

(13) A description of any changes in CMS, processes, or control equipment since the last reporting period.

(f) If you have obtained a title V operating permit according to 40 CFR part 70 or 40 CFR part 71, you must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If you submit a compliance report according to Table 6 to this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all required information concerning deviations from any emission limitation (including any operating limit), then submitting the compliance report will satisfy any obligation to report the same deviations in the semiannual monitoring report.

However, submitting a compliance report will not otherwise affect any obligation you may have to report deviations from permit requirements to the permitting authority.

§63.8490 What records must I keep?

(a) You must keep the records listed in paragraphs (a)(1) through (4) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirements in §63.10(b)(2)(xiv).

(2) The records in §63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.

(3) Records of performance tests as required in §63.10(b)(2)(viii).

(4) Records relating to control device maintenance and documentation of your approved routine control device maintenance exemption, if you request such an exemption under §63.8420(e).

(b) You must keep the records required in Table 5 to this subpart to show continuous compliance with each emission limitation that applies to you.

(c) You must also maintain the records listed in paragraphs (c)(1) through (6) of this section.

(1) For each bag leak detection system, records of each alarm, the time of the alarm, the time corrective action was initiated and completed, and a brief description of the cause of the alarm and the corrective action taken.

(2) For each deviation of an operating limit parameter value, the date, time, and duration of the deviation, a brief explanation of the cause of the deviation and the corrective action taken, and whether the deviation occurred during a period of startup, shutdown, or malfunction.

(3) For each affected source, records of production rates on a fired-product basis.

(4) Records for any approved alternative monitoring or test procedures.

(5) Records of maintenance and inspections performed on the APCD.

(6) Current copies of your SSMP and OM&M plan, including any revisions, with records documenting conformance.

§63.8495 In what form and for how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review, according to §63.10(b)(1).

(b) As specified in §63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record onsite for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to §63.10(b)(1). You may keep the records offsite for the remaining 3 years.

OTHER REQUIREMENTS AND INFORMATION

§63.8505 What parts of the General Provisions apply to me?

Table 7 to this subpart shows which parts of the General Provisions in §§63.1 through 63.15 apply to you.

§63.8510 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency, in addition to the U.S. EPA, has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out if implementation and enforcement of this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under section 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that cannot be delegated to State, local, or tribal agencies are as specified in paragraphs (c)(1) through (4) of this section.

(1) Approval of alternatives to the applicability requirements in §§ 63.8385 and 63.8390, the compliance date requirements in § 63.8395, and the non-opacity emission limitations in § 63.8405.

(2) Approval of major changes to test methods under § 63.7(e)(2)(ii) and (f) and as defined in § 63.90.

(3) Approval of major changes to monitoring under § 63.8(f) and as defined in § 63.90.

(4) Approval of major changes to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.

§ 63.8515 What definitions apply to this subpart?

Terms used in this subpart are defined in the Clean Air Act, in § 63.2, and in this section as follows:

Air pollution control device (APCD) means any equipment that reduces the quantity of a pollutant that is emitted to the air.

Bag leak detection system means an instrument that is capable of monitoring PM loadings in the exhaust of a fabric filter in order to detect bag failures. A bag leak detection system includes, but is not limited to, an instrument that operates on triboelectric, light-scattering, light-transmittance, or other effects to monitor relative PM loadings.

Brick and structural clay products (BSCP) manufacturing facility means a plant site that manufactures brick (including, but not limited to, face brick, structural brick, and brick pavers); clay pipe; roof tile; extruded floor and wall tile; and/or other extruded, dimensional clay products. Brick and structural clay products manufacturing facilities typically process raw clay and shale, form the processed materials into bricks or shapes, and dry and fire the bricks or shapes.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart including, but not limited to, any emission limitation (including any operating limit) or work practice standard;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart for any affected source required to obtain such a permit; or

(3) Fails to meet any emission limitation (including any operating limit) or work practice standard in this subpart during startup, shutdown, or malfunction, regardless of whether or not such failure is permitted by this subpart.

Dry lime injection fabric filter (DIFF) means an APCD that includes continuous injection of hydrated lime or other sorbent into a duct or reaction chamber followed by a fabric filter.

Dry lime scrubber/fabric filter (DLS/FF) means an APCD that includes continuous injection of humidified hydrated lime or other sorbent into a reaction chamber followed by a fabric filter. These systems typically include recirculation of some of the sorbent.

Dry limestone adsorber (DLA) means an APCD that includes a limestone storage bin, a reaction chamber that is essentially a packed tower filled with limestone, and may or may not include a peeling drum that mechanically scrapes reacted limestone to regenerate the stone for reuse.

Emission limitation means any emission limit or operating limit.

Fabric filter means an APCD used to capture PM by filtering a gas stream through filter media; also known as a baghouse.

Initial startup means:

(1) For a new or reconstructed tunnel kiln controlled with a DLA, and for a tunnel kiln that would be considered reconstructed but for § 63.8390(i)(1) or § 63.8390(i)(2), the time at which the temperature in the kiln first reaches 260 °C (500 °F) and the kiln contains product; or

(2) For a new or reconstructed tunnel kiln controlled with a DIFF, DLS/FF, or WS, the time at which the kiln first reaches a level of production that is equal to 75 percent of the kiln design capacity or 12 months after the affected source begins firing BSCP, whichever is earlier.

Kiln exhaust process stream means the portion of the exhaust from a tunnel kiln that exhausts directly to the atmosphere (or to an APCD), rather than to a sawdust dryer.

Large tunnel kiln means a tunnel kiln (existing, new, or reconstructed) with a design capacity equal to or greater than 9.07 Mg/hr (10 tph) of fired product.

Particulate matter (PM) means, for purposes of this subpart, emissions of PM that serve as a measure of total particulate emissions, as measured by Method 5 (40 CFR part 60, appendix A), and as a surrogate for metal HAP contained in the particulates including, but not limited to, antimony, arsenic, beryllium, cadmium, chromium, cobalt, lead, manganese, mercury, nickel, and selenium.

Plant site means all contiguous or adjoining property that is under common control, including properties that are separated only by a road or other public right-of-way. Common control includes properties that are owned, leased, or operated by the same entity, parent entity, subsidiary, or any combination thereof.

Research and development kiln means any kiln whose purpose is to conduct research and development for new processes and products and is not engaged in the manufacture of products for commercial sale, except in a de minimis manner.

Responsible official means responsible official as defined in 40 CFR 70.2.

Small tunnel kiln means a tunnel kiln (existing, new, or reconstructed) with a design capacity less than 9.07 Mg/hr (10 tph) of fired product.

Startup means the setting in operation of an affected source and starting the production process.

Tunnel kiln means any continuous kiln that is used to fire BSCP. Some tunnel kilns have two process streams, including a process stream that exhausts directly to the atmosphere or to an APCD, and a process stream in which the kiln exhaust is ducted to a sawdust dryer where it is used to dry sawdust before being emitted to the atmosphere.

Tunnel kiln design capacity means the maximum amount of brick, in Mg (tons), that a kiln is designed to produce in one year divided by the number of hours in a year (8,760 hours). If a kiln is modified to increase the capacity, the design capacity is considered to be the capacity following modifications.

Wet scrubber (WS) means an APCD that uses water, which may include caustic additives or other chemicals, as the sorbent. Wet scrubbers may use any of various design mechanisms to increase the contact between exhaust gases and the sorbent.

TABLE 1 TO SUBPART JJJJJ OF PART 63—EMISSION LIMITS

As stated in §63.8405, you must meet each emission limit in the following table that applies to you.

For each . . .	You must meet the following emission limits . . .	Or you must comply with the following . . .
1. Existing large tunnel kiln (design capacity ≥10 tph of fired product), excluding any process stream that is ducted to a sawdust dryer prior to July 22, 2002; or including any process stream that exhausts directly to the atmosphere or to an APCD and any process stream that is first ducted to a sawdust on or after July 22, 2002; each new or reconstructed small tunnel kiln (design capacity <10 tph of fired product), including all process streams; each tunnel kiln that would be considered reconstructed but for §63.8390(i)(1), including all process streams; and each large tunnel kiln previously equipped with a DLA that would be considered reconstructed but for §63.8390(i)(2), including all process streams.	a. HF emissions must not exceed 0.029 kilograms per megagram (kg/Mg) (0.057 pounds per ton (lb/ton)) of fired product. b. HCl emissions must not exceed 0.13 kg/Mg (0.26 lb/ton) of fired product. c. PM emissions must not exceed 0.21 kg/Mg (0.42 lb/ton) of fired product.	Reduce uncontrolled HF emissions by at least 90 percent. Reduce uncontrolled HCl emissions by at least 30 percent. Not applicable.
2. New or reconstructed large tunnel kiln, including all process streams.	a. HF emissions must not exceed 0.029 kg/Mg (0.057 lb/ton) of fired product.	Reduce uncontrolled HF emissions by at least 90 percent.

For each . . .	You must meet the following emission limits . . .	Or you must comply with the following . . .
	b. HCl emissions must not exceed 0.028 kg/Mg (0.056 lb/ton) of fired product.	Reduce uncontrolled HCl emissions by at least 85 percent.
	c. PM emissions must not exceed 0.060 kg/Mg (0.12 lb/ton) of fired product.	Not applicable.

TABLE 2 TO SUBPART JJJJJ OF PART 63—OPERATING LIMITS

As stated in §63.8405, you must meet each operating limit in the following table that applies to you.

For each . . .	You must . . .
1. Kiln equipped with a DLA	a. Maintain the average pressure drop across the DLA for each 3-hour block period at or above the average pressure drop established during the performance test; and b. Maintain an adequate amount of limestone in the limestone hopper, storage bin (located at the top of the DLA), and DLA at all times; maintain the limestone feeder setting at or above the level established during the performance test; and c. Use the same grade of limestone from the same source as was used during the performance test; maintain records of the source and grade of limestone; and d. Maintain no VE from the DLA stack.
2. Kiln equipped with a DIFF or DLS/FF	a. If you use a bag leak detection system, initiate corrective action within 1 hour of a bag leak detection system alarm and complete corrective actions in accordance with your OM&M plan; operate and maintain the fabric filter such that the alarm is not engaged for more than 5 percent of the total operating time in a 6-month block reporting period; or maintain no VE from the DIFF or DLS/FF stack; and b. Maintain free-flowing lime in the feed hopper or silo and to the APCD at all times for continuous injection systems; maintain the feeder setting at or above the level established during the performance test for continuous injection systems.
3. Kiln equipped with a WS	a. Maintain the average scrubber pressure drop for each 3-hour block period at or above the average pressure drop established during the performance test; and b. Maintain the average scrubber liquid pH for each 3-hour block period at or above the average scrubber liquid pH established during the performance test; and c. Maintain the average scrubber liquid flow rate for each 3-hour block period at or above the average scrubber liquid flow rate established during the performance test; and d. If chemicals are added to the scrubber water, maintain the average scrubber chemical feed rate for each 3-hour block period at or above the average scrubber chemical feed rate established during the performance test.

TABLE 3 TO SUBPART JJJJJ OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS

As stated in §63.8445, you must conduct each performance test in the following table that applies to you.

For each . . .	You must . . .	Using . . .	According to the following requirements . . .
1. Kiln	a. Select locations of sampling ports and the number of traverse points.	Method 1 or 1A of 40 CFR part 60, appendix A.	Sampling sites must be located at the outlet of the APCD and prior to any releases to the atmosphere for all affected sources. If you choose to meet the percent emission reduction requirements for HF or HCl, a sampling site must also be located at the APCD inlet.

For each . . .	You must . . .	Using . . .	According to the following requirements . . .
	b. Determine velocities and volumetric flow rate.	Method 2 of 40 CFR part 60, appendix A.	You may use Method 2A, 2C, 2D, 2F, or 2G of 40 CFR part 60, appendix A, as appropriate, as an alternative to using Method 2 of 40 CFR part 60, appendix A.
	c. Conduct gas molecular weight analysis.	Method 3 of 40 CFR part 60, appendix A.	You may use Method 3A or 3B of 40 CFR part 60, appendix A, as appropriate, as an alternative to using Method 3 of 40 CFR part 60, appendix A.
	d. Measure moisture content of the stack gas.	Method 4 of 40 CFR part 60, appendix A.	
	e. Measure HF and HCl emissions.	Method 26A of 40 CFR part 60, appendix A; or	Conduct the test while operating at the maximum production level. You may use Method 26 of 40 CFR part 60, appendix A, as an alternative to using Method 26A of 40 CFR part 60, appendix A, when no acid PM (*e.g.,* HF or HCl dissolved in water droplets emitted by sources controlled by a WS) is present.
		Method 320 of 40 CFR part 63, appendix A.	Conduct the test while operating at the maximum production level. When using Method 320 of 40 CFR part 63, appendix A, you must follow the analyte spiking procedures of section 13 of Method 320 of 40 CFR part 63, appendix A, unless you can demonstrate that the complete spiking procedure has been conducted at a similar source.
	f. Measure PM emissions.	Method 5 of 40 CFR part 60, appendix A.	Conduct the test while operating at the maximum production level.
2. Kiln that is complying with production-based emission limits.	Determine the production rate during each test run in order to determine compliance with production-based emission limits.	Production data collected during the performance tests (*e.g.,* no. of pushes per hour, no. of bricks per kiln car, weight of a typical fired brick).	You must measure and record the production rate, on a fired-product basis, of the affected source for each of the three test runs.
3. Kiln equipped with a DLA	a. Establish the operating limit for the average pressure drop across the DLA.	Data from the pressure drop measurement device during the performance test.	You must continuously measure the pressure drop across the DLA, determine and record the block average pressure drop values for the three test runs, and determine and record the 3-hour block average of the recorded pressure drop measurements for the three test runs.

For each . . .	You must . . .	Using . . .	According to the following requirements . . .
	b. Establish the operating limit for the limestone feeder setting.	Data from the limestone feeder during the performance test.	You must ensure that you maintain an adequate amount of limestone in the limestone hopper, storage bin (located at the top of the DLA), and DLA at all times during the performance test. You must establish your limestone feeder setting one week prior to the performance test and maintain the feeder setting for the one-week period that precedes the performance test and during the performance test.
	c. Document the source and grade of limestone used.	Records of limestone purchase.	
4. Kiln equipped with a DIFF or DLS/FF.	Establish the operating limit for the lime feeder setting.	Data from the lime feeder during the performance test.	For continuous lime injection systems, you must ensure that lime in the feed hopper or silo and to the APCD is free-flowing at all times during the performance test and record the feeder setting for the three test runs. If the feed rate setting varies during the three test runs, determine and record the average feed rate from the three test runs.
5. Kiln equipped with a WS	a. Establish the operating limit for the average scrubber pressure drop.	Data from the pressure drop measurement device during the performance test.	You must continuously measure the scrubber pressure drop, determine and record the block average pressure drop values for the three test runs, and determine and record the 3-hour block average of the recorded pressure drop measurements for the three test runs.
	b. Establish the operating limit for the average scrubber liquid pH.	Data from the pH measurement device during the performace test.	You must continuously measure the scrubber liquid pH, determine and record the block average pH values for the three test runs, and determine and record the 3-hour block average of the recorded pH measurements for the three test runs.
	c. Establish the operating limit for the average scrubber liquid flow rate.	Data from the flow rate measurement device during the performance test.	You must continuously measure the scrubber liquid flow rate, determine and record the block average flow rate values for the three test runs, and determine and record the 3-hour block average of the recorded flow rate measurements for the three test runs.
6. Kiln equipped with a WS that includes chemical addition to the water.	Establish the operating limit for the average scrubber chemical feed rate.	Data from the chemical feed rate measurement device during the performance test.	You must continuously measure the scrubber chemical feed rate, determine and record the block average chemical feed rate values for the three test runs, and determine and record the 3-hour block average of the recorded chemical feed rate measurements for the three test runs.

TABLE 4 TO SUBPART JJJJJ OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS

As stated in §63.8455, you must demonstrate initial compliance with each emission limitation that applies to you according to the following table:

For each . . .	For the following emission limitation . . .	You have demonstrated initial compliance if . . .
1. Existing large tunnel kiln (design capacity ≥10 tph of fired product), excluding any process stream that is ducted to a sawdust dryer prior to July 22, 2002; or including any process stream that exhausts directly to the atmosphere or to an APCD and any process stream that is first ducted to a sawdust dryer on or after July 22, 2002; each new or reconstructed small tunnel kiln (design capacity <10 tph of fired product), including all process streams; each tunnel kiln that would be considered reconstructed but for §63.8390(i)(1), including all process streams; and each large tunnel kiln previously equipped with a DLA that would be considered reconstructed but for §63.8390(i)(2), including all process streams.	a. HF emissions must not exceed 0.029 kg/Mg (0.057 lb/ton) of fired product; or uncontrolled HF emissions must be reduced by at least 90 percent; and	i. The HF emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test, according to the calculations in §63.8445(g)(1), do not exceed 0.029 kg/Mg (0.057 lb/ton); or uncontrolled HF emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test are reduced by at least 90 percent, according to the calculations in §63.8445(g)(2); and ii. You establish and have a record of the operating limits listed in Table 2 to this subpart over the 3-hour performance test during which HF emissions did not exceed 0.029 kg/Mg (0.057 lb/ton) or uncontrolled HF emissions were reduced by at least 90 percent.
	b. HCl emissions must not exceed 0.13 kg/Mg (0.26 lb/ton) of fired product; or uncontrolled HCl emissions must be reduced by at least 30 percent; and	i. The HCl emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test, according to the calculations in §63.8445(g)(1), do not exceed 0.13 kg/Mg (0.26 lb/ton); or uncontrolled HCl emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test are reduced by at least 30 percent, according to the calculations in §63.8445(g)(2); and ii. You establish and have a record of the operating limits listed in Table 2 to this subpart over the 3-hour performance test during which HCl emissions did not exceed 0.13 kg/Mg (0.26 lb/ton) or uncontrolled HCl emissions were reduced by at least 30 percent.
	c. PM emissions must not exceed 0.21 kg/Mg (0.42 lb/ton) of fired product.	i. The PM emissions measured using Method 5 of 40 CFR part 60, appendix A, over the period of the initial performance test, according to the calculations in §63.8445(g)(1), do not exceed 0.21 kg/Mg (0.42 lb/ton); and ii. You establish and have a record of the operating limits listed in Table 2 to this subpart over the 3-hour performance test during which PM emissions did not exceed 0.21 kg/Mg (0.42 lb/ton).

For each . . .	For the following emission limitation . . .	You have demonstrated initial compliance if . . .
2. New or reconstructed large tunnel kiln, including all process streams.	a. HF emissions must not exceed 0.029 kg/Mg (0.057 lb/ton) of fired product; or uncontrolled HF emissions must be reduced by at least 90 percent; and	i. The HF emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test, according to the calculations in §63.8445(g)(1), do not exceed 0.029 kg/Mg (0.057 lb/ton); or uncontrolled HF emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test are reduced by at least 90 percent, according to the calculations in §63.8445(g)(2); and ii. You establish and have a record of the operating limits listed in Table 2 to this subpart over the 3-hour performance test during which HF emissions did not exceed 0.029 kg/Mg (0.057 lb/ton) or uncontrolled HF emissions were reduced by at least 90 percent.
	b. HCl emissions must not exceed 0.028 kg/Mg (0.056 lb/ton) of fired product; or uncontrolled HCl emissions must be reduced by at least 85 percent; and	i. The HCl emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test, according to the calculations in §63.8445(g)(1), do not exceed 0.028 kg/Mg (0.056 lb/ton); or uncontrolled HCl emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test are reduced by at least 85 percent, according to the calculations in §63.8445(g)(2); and ii. You establish and have a record of the operating limits listed in Table 2 to this subpart over the 3-hour performance test during which HCl emissions did not exceed 0.028 kg/Mg (0.056 lb/ton) or uncontrolled HCl emissions were reduced by at least 85 percent.
	c. PM emissions must not exceed 0.060 kg/Mg (0.12 lb/ton) of fired product.	i. The PM emissions measured using Method 5 of 40 CFR part 60, appendix A, over the period of the initial performance test, according to the calculations in §63.8445(g)(1), do not exceed 0.060 kg/Mg (0.12 lb/ton); and ii. You establish and have a record of the operating limits listed in Table 2 to this subpart over the 3-hour performance test during which PM emissions did not exceed 0.060 kg/Mg (0.12 lb/ton).

TABLE 5 TO SUBPART JJJJJ OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITS AND OPERATING LIMITS

As stated in §63.8470, you must demonstrate continuous compliance with each emission limit and operating limit that applies to you according to the following table:

For each . . .	For the following emission limits and operating limits . . .	You must demonstrate continuous compliance by . . .
1. Kiln equipped with a DLA.	Each emission limit in Table 1 to this subpart and each operating limit in Item 1 of Table 2 to this subpart for kilns equipped with a DLA.	i. Collecting the DLA pressure drop data according to § 63.8450(a); reducing the DLA pressure drop data to 3-hour block averages according to § 63.8450(a); maintaining the average pressure drop across the DLA for each 3-hour block period at or above the average pressure drop established during the performance test; and ii. Verifying that the limestone hopper and storage bin (located at the top of the DLA) contain adequate limestone by performing a daily visual check; and iii. Recording the limestone feeder setting daily to verify that the feeder setting is being maintained at or above the level established during the performance test; and iv. Using the same grade of limestone from the same source as was used during the performance test; maintaining records of the source and type of limestone; and v. Performing VE observations of the DLA stack at the frequency specified in § 63.8470(g) using Method 22 of 40 CFR part 60, appendix A; maintaining no VE from the DLA stack.
2. Kiln equipped with a DIFF or DLS/FF.	Each emission limit in Table 1 to this subpart and each operating limit in Item 2 of Table 2 to this subpart for kilns equipped with DIFF or DLS/FF.	i. If you use a bag leak detection system, initiating corrective action within 1 hour of a bag leak detection system alarm and completing corrective actions in accordance with your OM&M plan; operating and maintaining the fabric filter such that the alarm is not engaged for more than 5 percent of the total operating time in a 6-month block reporting period; in calculating this operating time fraction, if inspection of the fabric filter demonstrates that no corrective action is required, no alarm time is counted; if corrective action is required, each alarm is counted as a minimum of 1 hour; if you take longer than 1 hour to initiate corrective action, the alarm time is counted as the actual amount of time taken by you to initiate corrective action; or performing VE observations of the DIFF or DLS/FF stack at the frequency specified in § 63.8470(g) using Method 22 of 40 CFR part 60, appendix A; maintaining no VE from the DIFF or DLS/FF stack; and ii. Verifying that lime is free-flowing via a load cell, carrier gas/lime flow indicator, carrier gas pressure drop measurement system, or other system; recording all monitor or sensor output, and if lime is found not to be free flowing, promptly initiating and completing corrective actions in accordance with your OM&M plan; recording the feeder setting once during each shift of operation to verify that the feeder setting is being maintained at or above the level established during the performance test.
3. Kiln equipped with a WS	Each emission limit in Table 1 to this subpart and each operating limit in Item 3 of Table 2 to this subpart for kilns equipped with WS.	i. Collecting the scrubber pressure drop data according to § 63.8450(a); reducing the scrubber pressure drop data to 3-hour block averages according to § 63.8450(a); maintaining the average scrubber pressure drop for each 3-hour block period at or above the average pressure drop established during the performance test; and ii. Collecting the scrubber liquid pH data according to § 63.8450(a); reducing the scrubber liquid pH data to 3-hour block averages according to § 63.8450(a); maintaining the average scrubber liquid pH for each 3-hour block period at or above the average scrubber liquid pH established during the performance test; and iii. Collecting the scrubber liquid flow rate data according to § 63.8450(a); reducing the scrubber liquid flow rate data to 3-hour block averages according to § 63.8450(a); maintaining the average scrubber liquid flow rate for each 3-hour block period at or above the average scrubber liquid flow rate established during the performance test; and

For each . . .	For the following emission limits and operating limits . . .	You must demonstrate continuous compliance by . . .
		iv. If chemicals are added to the scrubber water, collecting the scrubber chemical feed rate data according to § 63.8450(a); reducing the scrubber chemical feed rate data to 3-hour block averages according to § 63.8450(a); maintaining the average scrubber chemical feed rate for each 3-hour block period at or above the average scrubber chemical feed rate established during the performance test.

TABLE 6 TO SUBPART JJJJJ OF PART 63—REQUIREMENTS FOR REPORTS

As stated in § 63.8485, you must submit each report that applies to you according to the following table:

You must submit . . .	The report must contain . . .	You must submit the report . . .
1. A compliance report	a. If there are no deviations from any emission limitations (emission limits, operating limits) that apply to you, a statement that there were no deviations from the emission limitations during the reporting period. If there were no periods during which the CMS was out-of-control as specified in your OM&M plan, a statement that there were no periods during which the CMS was out- of-control during the reporting period.	Semiannually according to the requirements in § 63.8485(b).
	b. If you have a deviation from any emission limitation (emission limit, operating limit) during the reporting period, the report must contain the information in § 63.8485(d) or (e). If there were periods during which the CMS was out-of-control, as specified in your OM&M plan, the report must contain the information in § 63.8485(e).	Semiannually according to the requirements in § 63.8485(b).
	c. If you had a startup, shutdown or malfunction during the reporting period and you took actions consistent with your SSMP, the compliance report must include the information in § 63.10(d)(5)(i).	Semiannually according to the requirements in § 63.8485(b).
2. An immediate startup, shutdown, and malfunction report if you took actions during a startup, shutdown, or malfunction during the reporting period that are not consistent with your SSMP.	a. Actions taken for the event according to the requirements in § 63.10(d)(5)(ii).	By fax or telephone within 2 working days after starting actions inconsistent with the plan.
	b. The information in § 63.10(d)(5)(ii)	By letter within 7 working days after the end of the event unless you have made alternative arrangements with the permitting authority.

TABLE 7 TO SUBPART JJJJJ OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART JJJJJ

As stated in § 63.8505, you must comply with the General Provisions in §§ 63.1 through 63.15 that apply to you according to the following table:

Citation	Subject	Brief description	Applies to subpart JJJJJ
§ 63.1	Applicability	Initial applicability determination; applicability after standard established; permit requirements; extensions, notifications.	Yes.
§ 63.2	Definitions	Definitions for part 63 standards	Yes.
§ 63.3	Units and Abbreviations	Units and abbreviations for part 63 standards	Yes.
§ 63.4	Prohibited Activities	Compliance date; circumvention; severability	Yes.
§ 63.5	Construction/Reconstruction	Applicability; applications; approvals	Yes.
§ 63.6(a)	Applicability	General Provisions (GP) apply unless compliance extension; GP apply to area sources that become major.	Yes.
§ 63.6(b)(1)–(4)	Compliance Dates for New and Reconstructed sources.	Standards apply at effective date; 3 years after effective date; upon startup; 10 years after construction or reconstruction commences for section 112(f).	Yes.

Citation	Subject	Brief description	Applies to subpart JJJJJ
§ 63.6(b)(5)	Notification	Must notify if commenced construction or reconstructionafter proposal.	Yes.
§ 63.6(b)(6)	[Reserved].		
§ 63.6(b)(7)	Compliance Dates for New and Reconstructed area Sources That Become Major.	Area sources that become major must comply with major source standards immediately upon becoming major, regardless of whether required to comply when they were area sources.	Yes.
§ 63.6(c)(1)–(2)	Compliance Dates for Existing Sources.	Comply according to date in subpart, which must be no later than 3 years after effective date; for section 112(f) standards, comply within 90 days of effective date unless compliance extension.	Yes.
§ 63.6(c)(3)–(4)	[Reserved]..		
§ 63.6(c)(5)	Compliance Dates for Existing area Sources That Become Major.	Area sources that become major must comply with major source standards by date indicated in subpart or by equivalent time period (for example, 3 years).	Yes.
§ 63.6(d)	[Reserved].		
§ 63.6(e)(1)–(2)	Operation & Maintenance	Operate to minimize emissions at all times; correct malfunctions as soon as practicable; requirements independently enforceable; information Administrator will use to determine if operation and maintenance requirements were met.	Yes.
§ 63.6(e)(3)	Startup, Shutdown, and Malfunction Plan (SSMP).	Requirement for startup, shutdown, and malfunction (SSM) and SSMP; content of SSMP.	Yes.
§ 63.6(f)(1)	Compliance Except During SSM.	You must comply with emission standards at all times except during SSM.	Yes.
§ 63.6(f)(2)–(3)	Methods for Determining Compliance.	Compliance based on performance test, operation and maintenance plans, records, inspection.	Yes.
§ 63.6(g)	Alternative Standard	Procedures for getting an alternative standard	Yes.
§ 63.6(h)	Opacity/VE Standards	Requirements for opacity and VE standards	No, not applicable.
§ 63.6(i)	Compliance Extension	Procedures and criteria for Administrator to grant compliance extension.	Yes.
§ 63.6(j)	Presidential Compliance Exemption.	President may exempt source category	Yes.
§ 63.7(a)(1)–(2)	Performance Test Dates	Dates for conducting initial performance testing and other compliance demonstrations; must conduct 180 days after first subject to rule.	Yes.
§ 63.7(a)(3)	Section 114 Authority	Administrator may require a performance test under CAA section 114 at any time.	Yes.
§ 63.7(b)(1)	Notification of Performance Test.	Must notify Administrator 60 days before the test	Yes.
§ 63.7(b)(2)	Notification of Rescheduling	Must notify Administrator 5 days before scheduled date of rescheduled date.	Yes.
§ 63.7(c)	Quality Assurance(QA)/Test Plan.	Requirements; test plan approval procedures; performance audit requirements; internal and external QA procedures for testing.	Yes.
§ 63.7(d)	Testing Facilities	Requirements for testing facilities	Yes.
§ 63.7(e)(1)	Conditions for Conducting Performance Tests.	Performance tests must be conducted under representative conditions.	No, § 63.8445 specifies requirements.
		Cannot conduct performance tests during SSM; not a violation to exceed standard during SSM.	Yes.
§ 63.7(e)(2)–(3)	Conditions for Conducting Performance Tests.	Must conduct according to subpart and EPA test methods unless Administrator approves alternative; must have at least three test runs of at least 1 hour each; compliance is based on arithmetic mean of three runs; conditions when data from an additional test run can be used.	Yes.
§ 63.7(f)	Alternative Test Method	Procedures by which Administrator can grant approval to use an alternative test method.	Yes.
§ 63.7(g)	Performance Test Data Analysis.	Must include raw data in performance test report; must submit performance test data 60 days after end of test with the notification of compliance status.	Yes.
§ 63.7(h)	Waiver of Tests	Procedures for Administrator to waive performance test.	Yes.
§ 63.8(a)(1)	Applicability of Monitoring Requirements.	Subject to all monitoring requirements in subpart	Yes.
§ 63.8(a)(2)	Performance Specifications	Performance Specifications in appendix B of 40 CFR part 60 apply.	Yes.

Citation	Subject	Brief description	Applies to subpart JJJJJ
§ 63.8(a)(3)	[Reserved].		
§ 63.8(a)(4)	Monitoring with Flares	Requirements for flares in § 63.11 apply	No, not applicable.
§ 63.8(b)(1)	Monitoring	Must conduct monitoring according to standard unless Administrator approves alternative.	Yes.
§ 63.8(b)(2)–(3)	Multiple Effluents and Multiple Monitoring Systems.	Specific requirements for installing and reporting on monitoring systems.	Yes.
§ 63.8(c)(1)	Monitoring System Operation and Maintenance.	Maintenance consistent with good air pollution control practices.	Yes.
§ 63.8(c)(1)(i)	Routine and Predictable SSM	Reporting requirements for SSM when action is described in SSMP.	Yes.
§ 63.8(c)(1)(ii)	SSM not in SSMP	Reporting requirements for SSM when action is not described in SSMP.	Yes.
§ 63.8(c)(1)(iii)	Compliance with Operation and Maintenance Requirements.	How Administrator determines if source complying with operation and maintenance requirements.	Yes.
§ 63.8(c)(2)–(3)	Monitoring System Installation	Must install to get representative emission and parameter measurements.	Yes.
§ 63.8(c)(4)	CMS Requirements	Requirements for CMS	No, §§ 63.8425 and 63.8465 specify requirements.
§ 63.8(c)(5)	Continuous Opacity Monitoring System (COMS) Minimum Procedures.	COMS minimum procedures	No, not applicable.
§ 63.8(c)(6)	CMS Requirements	Zero and high level calibration check requirements.	No, § 63.8425 specifies requirements.
§ 63.8(c)(7)–(8)	CMS Requirements	Out-of-control periods	No, § 63.8425 specifies requirements.
§ 63.8(d)	CMS Quality Control	Requirements for CMS quality control	No, § 63.8425 specifies requirements.
§ 63.8(e)	CMS Performance Evaluation	Requirements for CMS performance evaluation	No, § 63.8425 specifies requirements.
§ 63.8(f)(1)–(5)	Alternative Monitoring Method	Procedures for Administrator to approve alternative monitoring.	Yes.
§ 63.8(f)(6)	Alternative to Relative Accuracy Test.	Procedures for Administrator to approve alternative relative accuracy test for continuous emissions monitoring systems (CEMS).	No, not applicable.
§ 63.8(g)	Data Reduction	COMS and CEMS data reduction requirements	No, not applicable.
§ 63.9(a)	Notification Requirements	Applicability; State delegation	Yes.
§ 63.9(b)	Initial Notifications	Requirements for initial notifications	Yes.
§ 63.9(c)	Request for Compliance Extension.	Can request if cannot comply by date or if installed BACT/LAER.	Yes.
§ 63.9(d)	Notification of Special Compliance Requirements for New Source.	For sources that commence construction between proposal and promulgation and want to comply 3 years after effective date.	Yes.
§ 63.9(e)	Notification of Performance Test.	Notify Administrator 60 days prior	Yes.
§ 63.9(f)	Notification of VE/Opacity Test	Notify Administrator 30 days prior	No, not applicable.
§ 63.9(g)(1)	Additional Notifications When Using CMS.	Notification of performance evaluation	Yes.
§ 63.9(g)(2)–(3)	Additional Notifications When Using CMS.	Notification of COMS data use; notification that relative accuracy alternative criterion were exceeded.	No, not applicable.
§ 63.9(h)	Notification of Compliance Status.	Contents; submittal requirements	Yes.
§ 63.9(i)	Adjustment of Submittal Deadlines.	Procedures for Administrator to approve change in when notifications must be submitted.	Yes.
§ 63.9(j)	Change in Previous Information	Must submit within 15 days after the change	Yes.
§ 63.10(a)	Recordkeeping/Reporting	Applicability; general information	Yes.
§ 63.10(b)(1)	General Recordkeeping Requirements.	General requirements	Yes.
§ 63.10(b)(2)(i)–(v)	Records Related to SSM	Requirements for SSM records	Yes.
§ 63.10(b)(2)(vi)–(xii) and (xiv).	CMS Records	Records when CMS is malfunctioning, inoperative or out-of-control.	Yes.
§ 63.10(b)(2)(xiii)	Records	Records when using alternative to relative accuracy test.	No, not applicable.
§ 63.10(b)(3)	Records	Applicability Determinations	Yes.
§ 63.10(c)(1)–(15)	Records	Additional records for CMS	No, §§ 63.8425 and 63.8490 specify requirements.

Citation	Subject	Brief description	Applies to subpart JJJJJ
§ 63.10(d)(1) and (2)	General Reporting Requirements.	Requirements for and reporting; performance test results reporting.	Yes.
§ 63.10(d)(3)	Reporting Opacity or VE Observations.	Requirements for reporting opacity and VE	No, not applicable.
§ 63.10(d)(4)	Progress Reports	Must submit progress reports on schedule if under compliance extension.	Yes.
§ 63.10(d)(5)	SSM Reports	Contents and submission	Yes.
§ 63.10(e)(1)–(3)	Additional CMS Reports	Requirements for CMS reporting	No, §§ 63.8425 and 63.8485 specify requirements.
§ 63.10(e)(4)	Reporting COMS data	Requirements for reporting COMS data with performance test data.	No, not applicable.
§ 63.10(f)	Waiver for Recordkeeping/Reporting.	Procedures for Administrator to waive	Yes.
§ 63.11	Flares	Requirement for flares	No, not applicable.
§ 63.12	Delegation	State authority to enforce standards	Yes.
§ 63.13	Addresses	Addresses for reports, notifications, requests	Yes.
§ 63.14	Incorporation by Reference	Materials incorporated by reference	Yes.
§ 63.15	Availability of Information	Information availability; confidential information	Yes.

Subpart KKKKK—National Emission Standards for Hazardous Air Pollutants for Clay Ceramics Manufacturing

SOURCE: 68 FR 26738, May 16, 2003, unless otherwise noted.

WHAT THIS SUBPART COVERS

§ 63.8530 What is the purpose of this subpart?

This subpart establishes national emission limitations and work practice standards for hazardous air pollutants (HAP) emitted from clay ceramics manufacturing facilities. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and work practice standards.

§ 63.8535 Am I subject to this subpart?

You are subject to this subpart if you own or operate a clay ceramics manufacturing facility that is, is located at, or is part of a major source of HAP emissions according to the criteria in paragraphs (a) and (b) of this section.

(a) A clay ceramics manufacturing facility is a plant site that manufactures pressed floor tile, pressed wall tile, other pressed tile, or sanitaryware (*e.g.*, sinks and toilets). Clay ceramics manufacturing facilities typically process clay, shale, and various additives; form the processed materials into tile or sanitaryware shapes; and dry and fire the ceramic products. Glazes are applied to many tile and sanitaryware products.

(b) A major source of HAP emissions is any stationary source or group of stationary sources within a contiguous area under common control that emits or has the potential to emit any single HAP at a rate of 9.07 megagrams (10 tons) or more per year or any combination of HAP at a rate of 22.68 megagrams (25 tons) or more per year.

§ 63.8540 What parts of my plant does this subpart cover?

(a) This subpart applies to each existing, new, or reconstructed affected source at a clay ceramics manufacturing facility and to each affected source described in paragraphs (f)(1) or (f)(2) of this section.

(b) Each existing, new, or reconstructed periodic kiln, tunnel kiln, and roller kiln is an affected source regardless of design capacity. Each source that meets the description in paragraphs (f)(1) or (f)(2) also is an affected source.

(c) Kilns that are used exclusively for research and development (R&D) and are not used to manufacture products for commercial sale, except in a *de minimis* manner, are not subject to the requirements of this subpart.

(d) Kilns that are used exclusively for setting glazes on previously fired products or for refiring are not subject to the requirements of this subpart.

(e) A source is a new affected source if construction of the affected source

began after July 22, 2002, and you met the applicability criteria at the time you began construction.

(f) An affected source is reconstructed if you meet the criteria as defined in § 63.2, except as provided in paragraphs (f)(1) and (f)(2) of this section.

(1) It is not technologically and economically feasible for an existing tunnel kiln whose design capacity is less than 9.07 megagrams per hour (Mg/hr) (10 tons per hour (tph)) of fired product but is increased such that it is equal to or greater than 9.07 Mg/hr (10 tph) of fired product to meet the relevant standards (*i.e.*, new source maximum achievable control technology (MACT)) by retrofitting with a dry lime injection fabric filter (DIFF), dry lime scrubber/fabric filter (DLS/FF), or wet scrubber (WS).

(2) It is not technologically and economically feasible for an existing dry limestone adsorber (DLA)-controlled kiln whose design capacity is equal to or greater than 9.07 Mg/hr (10 tph) of fired product to meet the relevant standards by retrofitting with a DIFF, DLS/FF, or WS.

(g) An affected source is existing if it is not new or reconstructed and does not meet the descriptions provided in paragraphs (f)(1) and (f)(2) of this section.

§ 63.8545 When do I have to comply with this subpart?

(a) If you have a new or reconstructed affected source or an affected source described in § 63.8540(f)(1) or § 63.8540(f)(2), you must comply with this subpart according to paragraphs (a)(1) and (2) of this section.

(1) If the initial startup of your affected source is before May 16, 2003, then you must comply with the applicable emission limitations and work practice standards in Tables 1, 2, and 3 to this subpart no later than May 16, 2003.

(2) If the initial startup of your affected source is after May 16, 2003, then you must comply with the applicable emission limitations and work practice standards in Tables 1, 2, and 3 to this subpart upon initial startup of your affected source.

(b) If you have an existing affected source, you must comply with the work practice standards for existing sources in Table 3 to this subpart no later than May 16, 2006.

(c) If you have an existing area source that increases its emissions or its potential to emit such that it becomes a major source of HAP by adding a new affected source or by reconstructing, you must be in compliance with this subpart upon initial startup of your affected source as a major source.

(d) If you have a new area source (*i.e.*, an area source for which construction or reconstruction was commenced after July 22, 2002) that increases its emissions or its potential to emit such that it becomes a major source of HAP, you must be in compliance with this subpart upon initial startup of your affected source as a major source.

(e) You must meet the notification requirements in § 63.8630 according to the schedule in § 63.8630 and in 40 CFR part 63, subpart A. Some of the notifications must be submitted before you are required to comply with the emission limitations in this subpart.

EMISSION LIMITATIONS AND WORK PRACTICE STANDARDS

§ 63.8555 What emission limitations and work practice standards must I meet?

(a) You must meet each emission limit in Table 1 to this subpart that applies to you.

(b) You must meet each operating limit in Table 2 to this subpart that applies to you.

(c) You must meet each work practice standard in Table 3 to this subpart that applies to you.

§ 63.8560 What are my options for meeting the emission limitations and work practice standards?

(a) To meet the emission limitations in Tables 1 and 2 to this subpart, you must use one or more of the options listed in paragraphs (a)(1) and (2) of this section.

(1) *Emissions control system.* Use an emissions capture and collection system and an air pollution control device

(APCD) and demonstrate that the resulting emissions or emissions reductions meet the emission limits in Table 1 to this subpart, and that the capture and collection system and APCD meet the applicable operating limits in Table 2 to this subpart.

(2) *Process changes.* Use low-HAP raw materials or implement manufacturing process changes and demonstrate that the resulting emissions or emissions reductions meet the emission limits in Table 1 to this subpart.

(b) To meet the work practice standards in Table 3 to this subpart, for each affected kiln, you must use natural gas, or an equivalent fuel (such as propane or other clean burning fuel), as the kiln fuel at all times except during periods of natural gas curtailment or other periods when natural gas is not available.

GENERAL COMPLIANCE REQUIREMENTS

§63.8570 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limitations (including operating limits) in this subpart at all times, except during periods of startup, shutdown, and malfunction and during periods of routine control device maintenance as specified in paragraph (e) of this section.

(b) Except as specified in paragraph (e) of this section, you must always operate and maintain your affected source, including air pollution control and monitoring equipment, according to the provisions in §63.6(e)(1)(i). During the period between the compliance date specified for your affected source in §63.8545 and the date upon which continuous monitoring systems (CMS) (*e.g.*, continuous parameter monitoring systems) have been installed and verified and any applicable operating limits have been set, you must maintain a log detailing the operation and maintenance of the process and emissions control equipment.

(c) For each kiln that is subject to the emission limits specified in Table 1 to this subpart, you must develop a written startup, shutdown, and malfunction plan (SSMP) according to the provisions in §63.6(e)(3).

(d) For each kiln that is subject to the emission limits specified in Table 1 to this subpart, you must prepare and implement a written operation, maintenance, and monitoring (OM&M) plan according to the requirements in §63.8575.

(e) If you own or operate a kiln that is subject to the emission limits specified in Table 1 to this subpart and must perform routine maintenance on the control device for that kiln, you may bypass the kiln control device and continue operating the kiln upon approval by the Administrator provided you satisfy the conditions listed in paragraphs (e)(1) through (5) of this section.

(1) You must request a routine control device maintenance exemption from the Administrator. Your request must justify the need for the routine maintenance on the control device and the time required to accomplish the maintenance activities, describe the maintenance activities and the frequency of the maintenance activities, explain why the maintenance cannot be accomplished during kiln shutdowns, describe how you plan to minimize emissions to the greatest extent possible during the maintenance, and provide any other documentation required by the Administrator.

(2) The routine control device maintenance exemption must not exceed 4 percent of the annual operating uptime for each kiln.

(3) The request for the routine control device maintenance exemption, if approved by the Administrator, must be incorporated by reference in and attached to the affected source's title V permit.

(4) You must minimize HAP emissions during the period when the kiln is operating and the control device is offline.

(5) You must minimize the time period during which the kiln is operating and the control device is offline.

(f) You must be in compliance with the work practice standards in this subpart at all times, except during periods of natural gas curtailment or other periods when natural gas is not available.

(g) You must be in compliance with the provisions of subpart A of this part,

except as noted in Table 8 to this subpart.

[68 FR 26738, May 16, 2003, as amended at 71 FR 20469, Apr. 20, 2006]

§ 63.8575 What do I need to know about operation, maintenance, and monitoring plans?

(a) For each kiln that is subject to the emission limits specified in Table 1 to this subpart, you must prepare, implement, and revise as necessary an OM&M plan that includes the information in paragraph (b) of this section. Your OM&M plan must be available for inspection by the permitting authority upon request.

(b) Your OM&M plan must include, as a minimum, the information in paragraphs (b)(1) through (13) of this section.

(1) Each process and APCD to be monitored, the type of monitoring device that will be used, and the operating parameters that will be monitored.

(2) A monitoring schedule that specifies the frequency that the parameter values will be determined and recorded.

(3) The limits for each parameter that represent continuous compliance with the emission limitations in § 63.8555. The limits must be based on values of the monitored parameters recorded during performance tests.

(4) Procedures for the proper operation and routine and long-term maintenance of each APCD, including a maintenance and inspection schedule that is consistent with the manufacturer's recommendations.

(5) Procedures for installing the CMS sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the exhaust emissions (*e.g.*, on or downstream of the last APCD).

(6) Performance and equipment specifications for the sample interface, the pollutant concentration or parametric signal analyzer, and the data collection and reduction system.

(7) Continuous monitoring system performance evaluation procedures and acceptance criteria (*e.g.*, calibrations).

(8) Procedures for the proper operation and maintenance of monitoring equipment consistent with the requirements in §§ 63.8600 and 63.8(c)(1), (3), (4)(ii), (7), and (8).

(9) Continuous monitoring system data quality assurance procedures consistent with the requirements in § 63.8(d).

(10) Continuous monitoring system recordkeeping and reporting procedures consistent with the requirements in § 63.10(c), (e)(1), and (e)(2)(i).

(11) Procedures for responding to operating parameter deviations, including the procedures in paragraphs (b)(11)(i) through (iii) of this section.

(i) Procedures for determining the cause of the operating parameter deviation.

(ii) Actions for correcting the deviation and returning the operating parameters to the allowable limits.

(iii) Procedures for recording the times that the deviation began and ended, and corrective actions were initiated and completed.

(12) Procedures for keeping records to document compliance.

(13) If you operate an affected kiln and you plan to take the kiln control device out of service for routine maintenance, as specified in § 63.8570(e), the procedures specified in paragraphs (b)(13)(i) and (ii) of this section.

(i) Procedures for minimizing HAP emissions from the kiln during periods of routine maintenance of the kiln control device when the kiln is operating and the control device is offline.

(ii) Procedures for minimizing the duration of any period of routine maintenance on the kiln control device when the kiln is operating and the control device is offline.

(c) Changes to the operating limits in your OM&M plan require a new performance test. If you are revising an operating limit parameter value, you must meet the requirements in paragraphs (c)(1) and (2) of this section.

(1) Submit a notification of performance test to the Administrator as specified in § 63.7(b).

(2) After completing the performance test to demonstrate that compliance with the emission limits can be achieved at the revised operating limit parameter value, you must submit the performance test results and the revised operating limits as part of the

Notification of Compliance Status required under §63.9(h).

(d) If you are revising the inspection and maintenance procedures in your OM&M plan, you do not need to conduct a new performance test.

TESTING AND INITIAL COMPLIANCE REQUIREMENTS

§63.8585 By what date must I conduct performance tests?

For each kiln that is subject to the emission limits specified in Table 1 to this subpart, you must conduct performance tests within 180 calendar days after the compliance date that is specified for your source in §63.8545 and according to the provisions in §63.7(a)(2).

§63.8590 When must I conduct subsequent performance tests?

(a) For each kiln that is subject to the emission limits specified in Table 1 to this subpart, you must conduct a performance test before renewing your 40 CFR part 70 operating permit or at least every 5 years following the initial performance test.

(b) You must conduct a performance test when you want to change the parameter value for any operating limit specified in your OM&M plan.

§63.8595 How do I conduct performance tests and establish operating limits?

(a) You must conduct each performance test in Table 4 to this subpart that applies to you.

(b) Before conducting the performance test, you must install and calibrate all monitoring equipment.

(c) Each performance test must be conducted according to the requirements in §63.7 and under the specific conditions in Table 4 to this subpart.

(d) You must test while operating at the maximum production level.

(e) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in §63.7(e)(1).

(f) You must conduct at least three separate test runs for each performance test required in this section, as specified in §63.7(e)(3). Each test run must last at least 1 hour.

(g) You must use the data gathered during the performance test and the equations in paragraphs (g)(1) and (2) of this section to determine compliance with the emission limitations.

(1) To determine compliance with the production-based hydrogen fluoride (HF), hydrogen chloride (HCl), and particulate matter (PM) emission limits in Table 1 to this subpart, you must calculate your mass emissions per unit of production for each test run using Equation 1 of this section:

$$MP = \frac{ER}{P} \qquad \text{(Eq. 1)}$$

Where:

MP=mass per unit production, kilograms (pounds) of pollutant per megagram (ton) of fired product

ER=mass emission rate of pollutant (HF, HCl, or PM) during each performance test run, kilograms (pounds) per hour

P=production rate during each performance test run, megagrams (tons) of fired product per hour.

(2) To determine compliance with the percent reduction HF and HCl emission limits in Table 1 to this subpart, you must calculate the percent reduction for each test run using Equation 2 of this section:

$$PR = \frac{ER_i - ER_o}{ER_i}(100) \qquad \text{(Eq. 2)}$$

Where:

PR=percent reduction, percent

ER_i=mass emission rate of specific HAP (HF or HCl) entering the APCD, kilograms (pounds) per hour

ER_o=mass emission rate of specific HAP (HF or HCl) exiting the APCD, kilograms (pounds) per hour.

(h) You must establish each site-specific operating limit in Table 2 to this subpart that applies to you as specified in Table 4 to this subpart.

(i) For each kiln that is subject to the emission limits specified in Table 1 to this subpart and is equipped with an APCD that is not addressed in Table 2 to this subpart or that is using process changes as a means of meeting the emission limits in Table 1 to this subpart, you must meet the requirements in §63.8(f) and paragraphs (i)(1) and (2) of this section.

(1) Submit a request for approval of alternative monitoring procedures to the Administrator no later than the notification of intent to conduct a performance test. The request must contain the information specified in paragraphs (i)(1)(i) through (iv) of this section.

(i) A description of the alternative APCD or process changes.

(ii) The type of monitoring device or procedure that will be used.

(iii) The operating parameters that will be monitored.

(iv) The frequency that the operating parameter values will be determined and recorded to establish continuous compliance with the operating limits.

(2) Establish site-specific operating limits during the performance test based on the information included in the approved alternative monitoring procedures request and, as applicable, as specified in Table 4 to this subpart.

§ 63.8600 What are my monitoring installation, operation, and maintenance requirements?

(a) You must install, operate, and maintain each CMS according to your OM&M plan and the requirements in paragraphs (a)(1) through (5) of this section.

(1) Conduct a performance evaluation of each CMS according to your OM&M plan.

(2) The CMS must complete a minimum of one cycle of operation for each successive 15-minute period. To have a valid hour of data, you must have at least three of four equally spaced data values (or at least 75 percent if you collect more than four data values per hour) for that hour (not including startup, shutdown, malfunction, out-of-control periods, or periods of routine control device maintenance covered by a routine control device maintenance exemption as specified in § 63.8570(e)).

(3) Determine and record the 3-hour block averages of all recorded readings, calculated after every 3 hours of operation as the average of the previous 3 operating hours. To calculate the average for each 3-hour average period, you must have at least 75 percent of the recorded readings for that period (not including startup, shutdown, malfunction, out-of-control periods, or periods of routine control device maintenance covered by a routine control device maintenance exemption as specified in § 63.8570(e)).

(4) Record the results of each inspection, calibration, and validation check.

(5) At all times, maintain the monitoring equipment including, but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment.

(b) For each liquid flow measurement device, you must meet the requirements in paragraphs (a)(1) through (5) and paragraphs (b)(1) through (3) of this section.

(1) Locate the flow sensor in a position that provides a representative flowrate.

(2) Use a flow sensor with a minimum measurement sensitivity of 2 percent of the liquid flowrate.

(3) At least semiannually, conduct a flow sensor calibration check.

(c) For each pressure measurement device, you must meet the requirements in paragraphs (a)(1) through (5) and paragraphs (c)(1) through (7) of this section.

(1) Locate the pressure sensor(s) in or as close to a position that provides a representative measurement of the pressure.

(2) Minimize or eliminate pulsating pressure, vibration, and internal and external corrosion.

(3) Use a gauge with a minimum measurement sensitivity of 0.5 inch of water or a transducer with a minimum measurement sensitivity of 1 percent of the pressure range.

(4) Check the pressure tap daily to ensure that it is not plugged.

(5) Using a manometer, check gauge calibration quarterly and transducer calibration monthly.

(6) Any time the sensor exceeds the manufacturer's specified maximum operating pressure range, conduct calibration checks or install a new pressure sensor.

(7) At least monthly, inspect all components for integrity, all electrical connections for continuity, and all mechanical connections for leakage.

(d) For each pH measurement device, you must meet the requirements in

paragraphs (a)(1) through (5) and paragraphs (d)(1) through (4) of this section.

(1) Locate the pH sensor in a position that provides a representative measurement of pH.

(2) Ensure the sample is properly mixed and representative of the fluid to be measured.

(3) Check the pH meter's calibration on at least two points every 8 hours of process operation.

(4) At least monthly, inspect all components for integrity and all electrical connections for continuity.

(e) For each bag leak detection system, you must meet the requirements in paragraphs (e)(1) through (11) of this section.

(1) Each triboelectric bag leak detection system must be installed, calibrated, operated, and maintained according to the ''Fabric Filter Bag Leak Detection Guidance,'' (EPA–454/R–98–015, September 1997). This document is available from the U.S. Environmental Protection Agency (U.S. EPA); Office of Air Quality Planning and Standards; Emissions, Monitoring and Analysis Division; Emission Measurement Center (MD–19), Research Triangle Park, NC 27711. This document is also available on the Technology Transfer Network (TTN) under Emission Measurement Center, Continuous Emission Monitoring. Other types of bag leak detection systems must be installed, operated, calibrated, and maintained in a manner consistent with the manufacturer's written specifications and recommendations.

(2) The bag leak detection system must be certified by the manufacturer to be capable of detecting PM emissions at concentrations of 10 milligrams per actual cubic meter (0.0044 grains per actual cubic foot) or less.

(3) The bag leak detection system sensor must provide an output of relative PM loadings.

(4) The bag leak detection system must be equipped with a device to continuously record the output signal from the sensor.

(5) The bag leak detection system must be equipped with an audible alarm system that will sound automatically when an increase in relative PM emissions over a preset level is detected. The alarm must be located where it is easily heard by plant operating personnel.

(6) For positive pressure fabric filter systems, a bag leak detector must be installed in each baghouse compartment or cell.

(7) For negative pressure or induced air fabric filters, the bag leak detector must be installed downstream of the fabric filter.

(8) Where multiple detectors are required, the system's instrumentation and alarm may be shared among detectors.

(9) The baseline output must be established by adjusting the range and the averaging period of the device and establishing the alarm set points and the alarm delay time according to section 5.0 of the ''Fabric Filter Bag Leak Detection Guidance.''

(10) Following initial adjustment of the system, the sensitivity or range, averaging period, alarm set points, or alarm delay time may not be adjusted except as detailed in your OM&M plan. In no case may the sensitivity be increased by more than 100 percent or decreased more than 50 percent over a 365-day period unless such adjustment follows a complete fabric filter inspection which demonstrates that the fabric filter is in good operating condition. Record each adjustment.

(11) Record the results of each inspection, calibration, and validation check.

(f) For each lime or chemical feed rate measurement device, you must meet the requirements in paragraphs (a)(1) through (5) and paragraphs (f)(1) and (2) of this section.

(1) Locate the measurement device in a position that provides a representative feed rate measurement.

(2) At least semiannually, conduct a calibration check.

(g) For each limestone feed system on a DLA, you must meet the requirements in paragraphs (a)(1), (4), and (5) of this section and must ensure on a monthly basis that the feed system replaces limestone at least as frequently as the schedule set during the performance test.

(h) Requests for approval of alternate monitoring procedures must meet the requirements in §§ 63.8595(i) and 63.8(f).

§ 63.8605 How do I demonstrate initial compliance with the emission limitations and work practice standards?

(a) You must demonstrate initial compliance with each emission limitation and work practice standard that applies to you according to Table 5 to this subpart.

(b) You must establish each site-specific operating limit in Table 2 to this subpart that applies to you according to the requirements in § 63.8595 and Table 4 to this subpart.

(c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in § 63.8630(e).

CONTINUOUS COMPLIANCE REQUIREMENTS

§ 63.8615 How do I monitor and collect data to demonstrate continuous compliance?

(a) You must monitor and collect data according to this section.

(b) Except for periods of monitor malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), you must monitor continuously (or collect data at all required intervals) at all times that the affected source is operating. This includes periods of startup, shutdown, malfunction, and routine control device maintenance as specified in § 63.8570(e) when the affected source is operating.

(c) You may not use data recorded during monitoring malfunctions, associated repairs, out-of-control periods, or required quality assurance or control activities for purposes of calculating data averages. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring system to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions. You must use all the valid data collected during all other periods in assessing compliance. Any averaging period for which you do not have valid monitoring data and such data are required constitutes a deviation from the monitoring requirements.

§ 63.8620 How do I demonstrate continuous compliance with the emission limitations and work practice standards?

(a) You must demonstrate continuous compliance with each emission limit, operating limit, and work practice standard in Tables 1, 2, and 3 to this subpart that applies to you according to the methods specified in Table 6 to this subpart.

(b) For each kiln that is subject to the emission limits specified in Table 1 to this subpart and is equipped with an APCD that is not addressed in Table 2 to this subpart, or that is using process changes as a means of meeting the emission limits in Table 1 to this subpart, you must demonstrate continuous compliance with each emission limit in Table 1 to this subpart, and each operating limit established as required in § 63.8595(i)(2) according to the methods specified in your approved alternative monitoring procedures request, as described in §§ 63.8595(i)(1) and 63.8(f).

(c) You must report each instance in which you did not meet each emission limit and operating limit in this subpart that applies to you. This includes periods of startup, shutdown, malfunction, and routine control device maintenance. These instances are deviations from the emission limitations in this subpart. These deviations must be reported according to the requirements in § 63.8635.

(d) [Reserved]

(e) Consistent with §§ 63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with § 63.6(e)(1) and your OM&M plan. The Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in § 63.6(e).

(f) Deviations that occur during periods of control device maintenance covered by an approved routine control device maintenance exemption according to § 63.8570(e) are not violations if you

demonstrate to the Administrator's satisfaction that you were operating in accordance with the approved routine control device maintenance exemption.

(g) You must demonstrate continuous compliance with the operating limits in Table 2 to this subpart for visible emissions (VE) from tunnel kilns equipped with DLA, DIFF, or DLS/FF by monitoring VE at each kiln stack according to the requirements in paragraphs (g)(1) through (3) of this section.

(1) Perform daily VE observations of each kiln stack according to the procedures of Method 22 of 40 CFR part 60, appendix A. You must conduct the Method 22 test while the affected source is operating under normal conditions. The duration of each Method 22 test must be at least 15 minutes.

(2) If VE are observed during any daily test conducted using Method 22 of 40 CFR part 60, appendix A, you must promptly initiate and complete corrective actions according to your OM&M plan. If no VE are observed in 30 consecutive daily Method 22 tests for any kiln stack, you may decrease the frequency of Method 22 testing from daily to weekly for that kiln stack. If VE are observed during any weekly test, you must promptly initiate and complete corrective actions according to your OM&M plan, resume Method 22 testing of that kiln stack on a daily basis, and maintain that schedule until no VE are observed in 30 consecutive daily tests, at which time you may again decrease the frequency of Method 22 testing to a weekly basis.

(3) If VE are observed during any test conducted using Method 22 of 40 CFR part 60, appendix A, you must report these deviations by following the requirements in §63.8635.

[68 FR 26738, May 16, 2003, as amended at 71 FR 20469, Apr. 20, 2006]

NOTIFICATIONS, REPORTS, AND RECORDS

§63.8630 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.7(b) and (c), 63.8(f)(4), and 63.9 (b) through (e), (g)(1), and (h) that apply to you, by the dates specified.

(b) As specified in §63.9(b)(2) and (3), if you start up your affected source before May 16, 2003, you must submit an Initial Notification not later than 120 calendar days after May 16, 2003.

(c) As specified in §63.9(b)(3), if you start up your new or reconstructed affected source or affected source described in §63.8540(f)(1) or §63.8540(f)(2) on or after May 16, 2003, you must submit an Initial Notification not later than 120 calendar days after you become subject to this subpart.

(d) If you are required to conduct a performance test, you must submit a written notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin, as required in §63.7(b)(1).

(e) If you are required to conduct a performance test or other initial compliance demonstration as specified in Tables 4 and 5 to this subpart, you must submit a Notification of Compliance Status as specified in §63.9(h) and paragraphs (e)(1) through (3) of this section.

(1) For each compliance demonstration that includes a performance test conducted according to the requirements in Table 4 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th calendar day following the completion of the performance test, according to §63.10(d)(2).

(2) In addition to the requirements in §63.9(h)(2)(i), you must include the information in paragraphs (e)(2)(i) and (ii) of this section in your Notification of Compliance Status:

(i) The operating limit parameter values established for each affected source with supporting documentation and a description of the procedure used to establish the values.

(ii) For each APCD that includes a fabric filter, if a bag leak detection system is used, analysis and supporting documentation demonstrating conformance with EPA guidance and specifications for bag leak detection systems in §63.8600(e).

(3) For each compliance demonstration required in Table 5 to this subpart that does not include a performance test (*i.e.*, compliance demonstration for

the work practice standard), you must submit the Notification of Compliance Status before the close of business on the 30th calendar day following the completion of the compliance demonstration.

(f) If you request a routine control device maintenance exemption according to § 63.8570(e), you must submit your request for the exemption no later than 30 days before the compliance date.

(g) If you own or operate an affected kiln that is subject to the work practice standards specified in Table 3 to this subpart, and you intend to use a fuel other than natural gas or equivalent to fire the affected kiln, you must submit a notification of alternative fuel use within 48 hours of the declaration of a period of natural gas curtailment or supply interruption, as defined in § 63.8665. The notification must include the information specified in paragraphs (g)(1) through (5) of this section.

(1) Company name and address.

(2) Identification of the affected kiln.

(3) Reason you are unable to use natural gas or equivalent fuel, including the date when the natural gas curtailment was declared or the natural gas supply interruption began.

(4) Type of alternative fuel that you intend to use.

(5) Dates when the alternative fuel use is expected to begin and end.

§ 63.8635 What reports must I submit and when?

(a) You must submit each report in Table 7 to this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date in Table 7 to this subpart and as specified in paragraphs (b)(1) through (5) of this section.

(1) The first compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.8545 and ending on June 30 or December 31, and lasting at least 6 months, but less than 12 months. For example, if your compliance date is March 1, then the first semiannual reporting period would begin on March 1 and end on December 31.

(2) The first compliance report must be postmarked or delivered no later than July 31 or January 31 for compliance periods ending on June 30 and December 31, respectively.

(3) Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent compliance report must be postmarked or delivered no later than July 31 or January 31 for compliance periods ending on June 30 and December 31, respectively.

(5) For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (4) of this section.

(c) The compliance report must contain the information in paragraphs (c)(1) through (7) of this section.

(1) Company name and address.

(2) Statement by a responsible official with that official's name, title, and signature, certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a startup, shutdown or malfunction during the reporting period and you took actions consistent with your SSMP and OM&M plan, the compliance report must include the information specified in § 63.10(d)(5)(i).

(5) A description of control device maintenance performed while the control device was offline and the kiln controlled by the control device was operating, including the information specified in paragraphs (c)(5)(i) through (iii) of this section.

(i) The date and time when the control device was shutdown and restarted.

(ii) Identification of the kiln that was operating and the number of hours that the kiln operated while the control device was offline.

(iii) A statement of whether or not the control device maintenance was included in your approved routine control device maintenance exemption developed as specified in §63.8570(e). If the control device maintenance was included in your approved routine control device maintenance exemption, then you must report the information in paragraphs (c)(5)(iii)(A) through (C) of this section.

(A) The total amount of time that the kiln controlled by the control device operated during the current semiannual compliance period and during the previous semiannual compliance period.

(B) The amount of time that each kiln controlled by the control device operated while the control device was offline for maintenance covered under the routine control device maintenance exemption during the current semiannual compliance period and during the previous semiannual compliance period.

(C) Based on the information recorded under paragraphs (c)(5)(iii)(A) and (B) of this section, compute the annual percent of kiln operating uptime during which the control device was offline for routine maintenance using Equation 1 of this section.

$$RM = \frac{DT_p + DT_c}{KU_p + KU_c}(100) \qquad \text{(Eq. 1)}$$

Where:

RM=Annual percentage of kiln uptime during which control device is down for routine control device maintenance

DT_p=Control device downtime claimed under the routine control device maintenance exemption for the previous semiannual compliance period

DT_c=Control device downtime claimed under the routine control device maintenance exemption for the current semiannual compliance period

KU_p=Kiln uptime for the previous semiannual compliance period

KU_c=Kiln uptime for the current semiannual compliance period

(6) If there are no deviations from any emission limitations (emission limits or operating limits) or work practice standards that apply to you, the compliance report must contain a statement that there were no deviations from the emission limitations or work practice standards during the reporting period.

(7) If there were no periods during which the CMS was out-of-control as specified in your OM&M plan, the compliance report must contain a statement that there were no periods during which the CMS was out-of-control during the reporting period.

(d) For each deviation from an emission limitation (emission limit or operating limit) that occurs at an affected source where you are not using a CMS to comply with the emission limitations in this subpart, the compliance report must contain the information in paragraphs (c)(1) through (5) and paragraphs (d)(1) and (2) of this section. This includes periods of startup, shutdown, malfunction, and routine control device maintenance.

(1) The total operating time of each affected source during the reporting period.

(2) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(e) For each deviation from an emission limitation (emission limit or operating limit) occurring at an affected source where you are using a CMS to comply with the emission limitations in this subpart, you must include the information in paragraphs (c)(1) through (5) and paragraphs (e)(1) through (13) of this section. This includes periods of startup, shutdown, malfunction, and routine control device maintenance.

(1) The total operating time of each affected source during the reporting period.

(2) The date and time that each malfunction started and stopped.

(3) The date and time that each CMS was inoperative, except for zero (low-level) and high-level checks.

(4) The date, time, and duration that each CMS was out-of-control, including the pertinent information in your OM&M plan.

(5) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction; during routine control device maintenance covered in your approved routine control device maintenance exemption; or during another period.

(6) A description of corrective action taken in response to a deviation.

(7) A summary of the total duration of the deviation during the reporting period and the total duration as a percent of the total source operating time during that reporting period.

(8) A breakdown of the total duration of the deviations during the reporting period into those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and other unknown causes.

(9) A summary of the total duration of CMS downtime during the reporting period and the total duration of CMS downtime as a percent of the total source operating time during that reporting period.

(10) A brief description of the process units.

(11) A brief description of the CMS.

(12) The date of the latest CMS certification or audit.

(13) A description of any changes in CMS, processes, or control equipment since the last reporting period.

(f) If you have obtained a title V operating permit according to 40 CFR part 70 or 40 CFR part 71, you must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If you submit a compliance report according to Table 7 to this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all required information concerning deviations from any emission limitation (including any operating limit), then submitting the compliance report will satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submitting a compliance report will not otherwise affect any obligation you may have to report deviations from permit requirements to the permitting authority.

(g) If you own or operate an affected kiln that is subject to the work practice standard specified in Table 3 to this subpart, and you use a fuel other than natural gas or equivalent to fire the affected kiln, you must submit a report of alternative fuel use within 10 working days after terminating the use of the alternative fuel. The report must include the information in paragraphs (g)(1) through (6) of this section.

(1) Company name and address.

(2) Identification of the affected kiln.

(3) Reason for using the alternative fuel.

(4) Type of alternative fuel used to fire the affected kiln.

(5) Dates that the use of the alternative fuel started and ended.

(6) Amount of alternative fuel used.

§ 63.8640 What records must I keep?

(a) You must keep the records listed in paragraphs (a)(1) through (4) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirements in § 63.10(b)(2)(xiv).

(2) The records in § 63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.

(3) Records of performance tests as required in § 63.10(b)(2)(viii).

(4) Records relating to control device maintenance and documentation of your approved routine control device maintenance exemption, if you request such an exemption under § 63.8570(e).

(b) You must keep the records required in Table 6 to this subpart to show continuous compliance with each emission limitation that applies to you.

(c) You must also maintain the records listed in paragraphs (c)(1) through (7) of this section.

(1) For each bag leak detection system, records of each alarm, the time of the alarm, the time corrective action was initiated and completed, and a brief description of the cause of the alarm and the corrective action taken.

(2) For each deviation of an operating limit parameter value, the date, time, and duration of the deviation, a brief explanation of the cause of the deviation and the corrective action taken, and whether the deviation occurred during a period of startup, shutdown, or malfunction.

(3) For each kiln that is subject to the emission limits in Table 1, records of production rates on a fired-product weight basis.

(4) For each kiln that is subject to the emission limits in Table 1, records for any approved alternative monitoring or test procedures.

(5) For each kiln that is subject to the emission limits in Table 1, records of maintenance and inspections performed on the APCD.

(6) For each kiln that is subject to the emission limits in Table 1, current copies of your SSMP and OM&M plan, including any revisions, with records documenting conformance.

(7) Records that document compliance with any work practice standard that applies to you.

§63.8645 In what form and for how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review, according to §63.10(b)(1).

(b) As specified in §63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record onsite for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to §63.10(b)(1). You may keep the records offsite for the remaining 3 years.

OTHER REQUIREMENTS AND INFORMATION

§63.8655 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§63.1 through 63.15 apply to you.

§63.8660 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency, in addition to the U.S. EPA, has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out if implementation and enforcement of this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under section 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that cannot be delegated to State, local, or tribal agencies are as specified in paragraphs (c)(1) through (4) of this section.

(1) Approval of alternatives to the applicability requirements in §§63.8535 and 63.8540, the compliance date requirements in §63.8545, and the nonopacity emission limitations in §63.8555.

(2) Approval of major changes to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90.

(3) Approval of major changes to monitoring under §63.8(f) and as defined in §63.90.

(4) Approval of major changes to recordkeeping and reporting under §63.10(f) and as defined in §63.90.

§63.8665 What definitions apply to this subpart?

Terms used in this subpart are defined in the Clean Air Act, in §63.2, and in this section as follows:

Air pollution control device (APCD) means any equipment that reduces the quantity of a pollutant that is emitted to the air.

Bag leak detection system means an instrument that is capable of monitoring PM loadings in the exhaust of a fabric filter in order to detect bag failures. A bag leak detection system includes, but

is not limited to, an instrument that operates on triboelectric, light-scattering, light-transmittance, or other effects to monitor relative PM loadings.

Clay ceramics manufacturing facility means a plant site that manufactures pressed floor tile, pressed wall tile, other pressed tile, or sanitaryware (*e.g.*, sinks and toilets). Clay ceramics manufacturing facilities typically process clay, shale, and various additives, form the processed materials into tile or sanitaryware shapes, and dry and fire the ceramic products. Glazes are applied to many tile and sanitaryware products.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart including, but not limited to, any emission limitation (including any operating limit) or work practice standard;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart for any affected source required to obtain such a permit; or

(3) Fails to meet any emission limitation (including any operating limit) or work practice standard in this subpart during startup, shutdown, or malfunction, regardless of whether or not such failure is permitted by this subpart.

Dry lime injection fabric filter (DIFF) means an APCD that includes continuous injection of hydrated lime or other sorbent into a duct or reaction chamber followed by a fabric filter.

Dry lime scrubber/fabric filter (DLS/FF) means an APCD that includes continuous injection of humidified hydrated lime or other sorbent into a reaction chamber followed by a fabric filter. These systems typically include recirculation of some of the sorbent.

Dry limestone adsorber (DLA) means an APCD that includes a limestone storage bin, a reaction chamber that is essentially a packed tower filled with limestone, and may or may not include a peeling drum that mechanically scrapes reacted limestone to regenerate the stone for reuse.

Emission limitation means any emission limit or operating limit.

Fabric filter means an APCD used to capture PM by filtering a gas stream through filter media; also known as a baghouse.

Initial startup means:

(1) For a new or reconstructed tunnel kiln controlled with a DLA, and for a tunnel kiln that would be considered reconstructed but for § 63.8540(f)(1) or § 63.8540(f)(2), the time at which the temperature in the kiln first reaches 260 °C (500 °F) and the kiln contains product; or

(2) For a new or reconstructed tunnel kiln controlled with a DIFF, DLS/FF, or WS, the time at which the kiln first reaches a level of production that is equal to 75 percent of the kiln design capacity or 12 months after the affected source begins firing clay ceramics, whichever is earlier.

Particulate matter (PM) means, for purposes of this subpart, emissions of PM that serve as a measure of total particulate emissions, as measured by Method 5 (40 CFR part 60, appendix A), and as a surrogate for metal HAP contained in the particulates including, but not limited to, antimony, arsenic, beryllium, cadmium, chromium, cobalt, lead, manganese, mercury, nickel, and selenium.

Period of natural gas curtailment or supply interruption means a period of time during which the supply of natural gas to an affected facility is halted for reasons beyond the control of the facility. An increase in the cost or unit price of natural gas does not constitute a period of natural gas curtailment or supply interruption.

Plant site means all contiguous or adjoining property that is under common control, including properties that are separated only by a road or other public right-of-way. Common control includes properties that are owned, leased, or operated by the same entity, parent entity, subsidiary, or any combination thereof.

Research and development kiln means any kiln whose purpose is to conduct research and development for new processes and products and is not engaged in the manufacture of products for commercial sale, except in a *de minimis* manner.

Responsible official means responsible official as defined in 40 CFR 70.2.

Startup means the setting in operation of an affected source and starting the production process.

Tunnel kiln means any continuous kiln that is not a roller kiln that is used to fire clay ceramics.

Tunnel kiln design capacity means the maximum amount of clay ceramics, in Mg (tons), that a kiln is designed to produce in one year divided by the number of hours in a year (8,760 hours). If a kiln is modified to increase the capacity, the design capacity is considered to be the capacity following modifications.

Wet scrubber (WS) means an APCD that uses water, which may include caustic additives or other chemicals, as the sorbent. Wet scrubbers may use any of various design mechanisms to increase the contact between exhaust gases and the sorbent.

Work practice standard means any design, equipment, work practice, operational standard, or combination thereof, that is promulgated pursuant to section 112(h) of the Clean Air Act.

TABLE 1 TO SUBPART KKKKK OF PART 63—EMISSION LIMITS

As stated in §63.8555, you must meet each emission limit in the following table that applies to you.

For each . . .	You must meet the following emission limits . . .	Or you must comply with the following . . .
1. New or reconstructed tunnel kiln with a design capacity less than 9.07 Mg/hr (10 tph) of fired product; each tunnel kiln that would be considered reconstructed but for §63.8540(f)(1); and each tunnel kiln that would be considered reconstructed but for §63.8540(f)(2).	a. HF emissions must not exceed 0.029 kilograms per megagram (kg/Mg) (0.057 pounds per ton (lb/ton)) of fired product.	Reduce uncontrolled HF emissions by at least 90 percent.
	b. HCl emissions must not exceed 0.13 kg/Mg (0.26 lb/ton) of fired product.	Reduce uncontrolled HCl emissions by at least 30 percent.
	c. PM emissions must not exceed 0.21 kg/Mg (0.42 lb/ton) of fired product.	Not applicable.
2. New or reconstructed tunnel kiln with a design capacity equal to or greater than 10 tph of fired product.	a. HF emissions must not exceed 0.029 kg/Mg (0.057 lb/ton) of fired product.	Reduce uncontrolled HF emissions by at least 90 percent.
	b. HCl emissions must not exceed 0.028 kg/Mg (0.056 lb/ton) of fired product.	Reduce uncontrolled HCl emissions by at least 85 percent.
	c. PM emissions must not exceed 0.060 kg/Mg (0.12 lb/ton) of fired product.	Not applicable.

TABLE 2 TO SUBPART KKKKK OF PART 63—OPERATING LIMITS

As stated in §63.8555, you must meet each operating limit in the following table that applies to you.

For each . . .	You must . . .
1. Kiln equipped with a DLA	a. Maintain the average pressure drop across the DLA for each 3-hour block period at or above the average pressure drop established during the performance test; and b. Maintain a sufficient amount of limestone in the limestone hopper, storage bin (located at the top of the DLA), and DLA at all times; maintain the limestone feeder setting at or above the level established during the performance test; and c. Use the same grade of limestone from the same source as was used during the performance test; maintain records of the source and grade of limestone; and d. Maintain no VE from the DLA stack.

For each . . .	You must . . .
2. Kiln equipped with a DIFF or DLS/FF	a. If you use a bag leak detection system, initiate corrective action within 1 hour of a bag leak detection system alarm and complete corrective actions in accordance with your OM&M plan; operate and maintain the fabric filter such that the alarm is not engaged for more than 5 percent of the total operating time in a 6-month block reporting period; or maintain no VE from the DIFF or DLS/FF stack; and b. Maintain free-flowing lime in the feed hopper or silo and to the APCD at all times for continuous injection systems; maintain the feeder setting at or above the level established during the performance test for continuous injection systems.
3. Kiln equipped with a WS	a. Maintain the average scrubber pressure drop for each 3-hour block period at or above the average pressure drop established during the performance test; and b. Maintain the average scrubber liquid pH for each 3-hour block period at or above the average scrubber liquid pH established during the performance test; and c. Maintain the average scrubber liquid flow rate for each 3-hour block period at or above the average scrubber liquid flow rate established during the performance test; and d. If chemicals are added to the scrubber water, maintain the average scrubber chemical feed rate for each 3-hour block period at or above the average scrubber chemical feed rate established during the performance test.

TABLE 3 TO SUBPART KKKKK OF PART 63—WORK PRACTICE STANDARDS

As stated in §63.8555, you must comply with each work practice standard in the following table that applies to you.

For . . .	You must . . .	According to one of the following requirements . . .
Each existing, new, or reconstructed periodic kiln, tunnel kiln, or roller kiln; each tunnel kiln that would be considered reconstructed but for §63.8540(f)(1); and each tunnel kiln that would be considered reconstructed but for §63.8540(f)(2).	Minimize fuel-based HAP emissions	Use natural gas, or equivalent, as the kiln fuel, except during periods of natural gas curtailment or supply interruption, as defined in §63.8665.

TABLE 4 TO SUBPART KKKKK OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS

As stated in §63.8595, you must conduct each performance test in the following table that applies to you.

For each . . .	You must . . .	Using . . .	According to the following requirements . . .
1. New or reconstructed tunnel kiln; each tunnel kiln that would be considered reconstructed but for §63.8540(f)(1); and each tunnel kiln that would be considered reconstructed but for §63.8540(f)(2).	a. Select locations of sampling ports and the number of traverse points.	Method 1 or 1A of 40 CFR part 60, appendix A.	Sampling sites must be located at the outlet of the APCD and prior to any releases to the atmosphere for all affected sources. If you choose to meet the percent emission reduction requirements for HF or HCl, a sampling site must also be located at the APCD inlet.
	b. Determine velocities and volumetric flow rate.	Method 2 of 40 CFR part 60, appendix A.	You may use Method 2A, 2C, 2D, 2F, or 2G of 40 CFR part 60, appendix A, as appropriate, as an alternative to using Method 2 of 40 CFR part 60, appendix A.
	c. Conduct gas molecular weight analysis.	Method 3 of 40 CFR part 60, appendix A.	You may use Method 3A or 3B of 40 CFR part 60, appendix A, as appropriate, as an alternative to using Method 3 of 40 CFR part 60, appendix A.

For each . . .	You must . . .	Using . . .	According to the following requirements . . .
	d. Measure moisture content of the stack gas.	Method 4 of 40 CFR part 60, appendix A.	
	e. Measure HF and HCl emissions.	Method 26A of 40 CFR part 60, appendix A; or	Conduct the test while operating at the maximum production level. You may use Method 26 of 40 CFR part 60, appendix A, as an alternative to using Method 26A of 40 CFR part 60, appendix A, when no acid PM (*e.g.,* HF or HCl dissolved in water droplets emitted by sources controlled by a WS) is present.
		Method 320 of 40 CFR part 63, appendix A.	Conduct the test while operating at the maximum production level. When using Method 320 of 40 CFR part 63, appendix A, you must follow the analyte spiking procedures of section 13 of Method 320 of 40 CFR part 63, appendix A, unless you can demonstrate that the complete spiking procedure has been conducted at a similar source.
	f. Measure PM emissions	Method 5 of 40 CFR part 60, appendix A.	Conduct the test while operating at the maximum production level.
2. Kiln that is complying with production-based emission limits.	Determine the production rate during each test run in order to determine compliance with production-based emission limits.	Production data collected during the performance tests (*e.g.,* the number of ceramic pieces and weight per piece in the kiln during a test run divided by the amount of time to fire a piece).	You must measure and record the production rate, on a fired-product weight basis, of the affected kiln for each of the three test runs.
3. Kiln equipped with a DLA.	a. Establish the operating limit for the average pressure drop across the DLA.	Data from the pressure drop measurement device during the performance test.	You must continuously measure the pressure drop across the DLA, determine and record the block average pressure drop values for the three test runs, and determine and record the 3-hour block average of the recorded pressure drop measurements for the three test runs.
	b. Establish the operating limit for the limestone feeder setting.	Data from the limestone feeder during the performance test.	You must ensure that you maintain an adequate amount of limestone in the limestone hopper, storage bin (located at the top of the DLA), and DLA at all times during the performance test. You must establish your limestone feeder setting one week prior to the performance test and maintain the feeder setting for the one-week period that precedes the performance test and during the performance test.
	c. Document the source and grade of limestone used.	Records of limestone purchase.	

For each . . .	You must . . .	Using . . .	According to the following requirements . . .
4. Kiln equipped with a DIFF or DLS/FF.	Establish the operating limit for the lime feeder setting.	Data from the lime feeder during the performance test.	For continuous lime injection systems, you must ensure that lime in the feed hopper or silo and to the APCD is free-flowing at all times during the performance test and record the feeder setting for the three test runs. If the feed rate setting varies during the three test runs, determine and record the average feed rate from the three test runs.
5. Kiln equipped with a WS	a. Establish the operating limit for the average scrubber pressure drop.	Data from the pressure drop measurement device during the performance test.	You must continuously measure the scrubber pressure drop, determine and record the block average pressure drop values for the three test runs, and determine and record the 3-hour block average of the recorded pressure drop measurements for the three test runs.
	b. Establish the operating limit for the average scrubber liquid pH.	Data from the pH measurement device during the performance test.	You must continuously measure the scrubber liquid pH, determine and record the block average pH values for the three test runs, and determine and record the 3-hour block average of the recorded pH measurements for the three test runs.
	c. Establish the operating limit for the average scrubber liquid flow rate.	Data from the flow rate measurement device during the performance test.	You must continuously measure the scrubber liquid flow rate, determine and record the block average flow rate values for the three test runs, and determine and record the 3-hour block average of the recorded flow rate measurements for the three test runs.
6. Kiln equipped with a WS that includes chemical addition to the water.	Establish the operating limit for the average scrubber chemical feed rate.	Data from the chemical feed rate measurement device during the performance test.	You must continuously measure the scrubber chemical feed rate, determine and record the block average chemical feed rate values for the three test runs, and determine and record the 3-hour block average of the recorded chemical feed rate measurements for the three test runs.

TABLE 5 TO SUBPART KKKKK OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS AND WORK PRACTICE STANDARDS

As stated in §63.8605, you must demonstrate initial compliance with each emission limitation that applies to you according to the following table:

For each . . .	For the following . . .	You have demonstrated initial compliance if . . .
1. New or reconstructed tunnel kiln with a design capacity less than 9.07 Mg/hr (10 tph) of fired product; each tunnel kiln that would be considered reconstructed but for § 63.8540(f)(1); and each tunnel kiln that would be considered reconstructed but for § 63.8540(f)(2).	a. HF emissions must not exceed 0.029 kg/Mg (0.057 lb/ton) of fired product; or uncontrolled HF emissions must be reduced by at least 90 percent; and.	i. The HF emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test, according to the calculations in § 63.8595(g)(1), do not exceed 0.029 kg/Mg (0.057 lb/ton); or uncontrolled HF emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test are reduced by at least 90 percent, according to the calculations in § 63.8595(g)(2); and ii. You establish and have a record of the operating limits listed in Table 2 to this subpart over the 3-hour performance test during which HF emissions did not exceed 0.029 kg/Mg (0.057 lb/ton) or uncontrolled HF emissions were reduced by at least 90 percent.
	b. HCl emissions must not exceed 0.13 kg/Mg (0.26 lb/ton) of fired product; or uncontrolled HCl emissions must be reduced by at least 30 percent; and	i. The HCl emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test, according to the calculations in § 63.8595(g)(1), do not exceed 0.13 kg/Mg (0.26 lb/ton); or uncontrolled HCl emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test are reduced by at least 30 percent, according to the calculations in § 63.8595(g)(2); and ii. You establish and have a record of the operating limits listed in Table 2 to this subpart over the 3-hour performance test during which HCl emissions did not exceed 0.13 kg/Mg (0.26 lb/ton) or uncontrolled HCl emissions were reduced by at least 30 percent.
	c. PM emissions must not exceed 0.21 kg/Mg (0.42 lb/ton) of fired product.	i. The PM emissions measured using Method 5 of 40 CFR part 60, appendix A, over the period of the initial performance test, according to the calculations in § 63.8595(g)(1), do not exceed 0.21 kg/Mg (0.42 lb/ton); and ii. You establish and have a record of the operating limits listed in Table 2 to this supbart over the 3-hour performance test during which PM emissions did not exceed 0.21 kg/Mg (0.42 lb/ton).
2. New or reconstructed tunnel kiln with a design capacity equal to or greater than 10 tph of fired product.	a. HF emissions must not exceed 0.029 kg/Mg (0.057 lb/ton) of fired product; or uncontrolled HF emissions must be reduced by at least 90 percent; and	i. The HF emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test, according to the calculations in § 63.8595(g)(1), do not exceed 0.029 kg/Mg (0.057 lb/ton); or uncontrolled HF emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test are reduced by at least 90 percent, according to the calculations in § 63.8595(g)(2); and ii. You establish and have a record of the operating limits listed in Table 2 to this subpart over the 3-hour performance test during which HF emissions did not exceed 0.029 kg/Mg (0.057 lb/ton) or uncontrolled HF emissions were reduced by at least 90 percent.
	b. HCl emissions must not exceed 0.028 kg/Mg (0.056 lb.ton) of fired product; or uncontrolled HCl emissions must be reduced by at least 85 percent; and	i. The HCl emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test, according to the calculations in § 63.8595(g)(1), do not exceed 0.028 kg/Mg (0.056 lb/ton); or uncontrolled HCl emissions measured using Method 26A of 40 CFR part 60, appendix A or Method 320 of 40 CFR part 63, appendix A over the period of the initial performance test are reduced by at least 85 percent, according to the calculations in § 63.8595(g)(2); and ii. You establish and have a record of the operating limits listed in Table 2 to this subpart over the 3-hour performance test during which HCl emissions did not exceed 0.028 kg/Mg (0.056 lb/ton) or uncontrolled HCI emissions were reduced by at least 85 percent.
	c. PM emissions must not exceed 0.060 kg/Mg (0.12 lb/ton) of fired product.	i. The PM emissions measured using Method 5 of 40 CFR part 60, appendix A, over the period of the initial performance test, according to the calculations on § 63.8595(g)(1), do not exceed 0.060 kg/Mg (0.12 lb/ton); and

For each . . .	For the following . . .	You have demonstrated initial compliance if . . .
		ii. You establish and have a record of the operating limits listed in Table 2 to this subpart over the 3-hour performance test during which PM emissions did not exceed 0.060 kg/Mg (0.12 lb/ton).
3. Existing, new, or reconstructed periodic kiln, tunel kiln, or roller kiln; each tunnel kiln that would be considered reconstructed but for §63.8540(f)(1); and each tunnel kiln that would be considered reconstructed but for §63.8540(f)(2).	Minimize fuel-based HAP emissions.	You use natural gas, or equivalent, as the kiln fuel.

TABLE 6 TO SUBPART KKKKK OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITATIONS AND WORK PRACTICE STANDARDS

As stated in §63.8620, you must demonstrate continuous compliance with each emission limit and operating limit that applies to you according to the following table:

For each . . .	For the following . . .	You must demonstrate continuous compliance by . . .
1. Kiln equipped with a DLA	a. Each emission limit in Table 1 to this subpart and each operating limit in Item 1 of Table 2 to this subpart for kilns equipped with a DLA.	i. Collecting the DLA pressure drop data according to §63.8600(a); reducing the DLA pressure drop data to 3-hour block averages according to §63.8600(a); maintaining the average pressure drop across the DLA for each 3-hour block period at or above the average pressure drop established during the performance test; and ii. Verifying that the limestone hopper and storage bin (located at the top of the DLA) contain adequate limestone by performing a daily visual check; and iii. Recording the limestone feeder setting daily to verify that the feeder setting is being maintained at or above the level established during the performance test; and iv. Using the same grade of limestone from the same source as was used during the performance test; maintaining records of the source and type of limestone; and v. Performing VE observations of the DLA stack at the frequency specified in §63.8620(g) using Method 22 of 40 CFR part 60, appendix A; maintaining no VE from the DLA stack.
2. Kiln equipped with a DIFF or DLS/FF.	a. Each emission limit in Table 1 to this subpart and each operating limit in Item 2 of Table 2 to this subpart for kilns equipped with DIFF or DLS/FF.	i. If you use a bag leak detection system, initiating corrective action within 1 hour of a bag leak detection system alarm and completing corrective actions in accordance with your OM&M plan; operating and maintaining the fabric filter such that the alarm is not engaged for more than 5 percent of the total operating time in a 6-month block reporting period; in calculating this operating time fraction, if inspection of the fabric filter demonstrates that no corrective action is required, no alarm time is counted; if corrective action is required, each alarm is counted as a minimum of 1 hour; if you take longer than 1 hour to initiate corrective action, the alarm time is counted as the actual amount of time taken by you to initiate corrective action; or performing VE observations of the DIFF or DLS/FF stack at the frequency specified in §63.8620(g) using Method 22 of 40 CFR part 60, appendix A; maintaining no VE from the DIFF or DLS/FF stack; and ii. Verifying that lime is free-flowing via a load cell, carrier gas/lime flow indicator, carrier gas pressure drop measurement system, or other system; recording all monitor or sensor output, and if lime is found not to be free flowing, promptly initiating and completing corrective actions in accordance with your OM&M plan; recording the feeder setting once each shift of operation to verify that the feeder setting is being maintained at or above the level established during the performance test.

For each . . .	For the following . . .	You must demonstrate continuous compliance by . . .
3. Kiln equipped with a WS	a. Each emission limit in Table 1 to this subpart and each operating limit in Item 3 of Table 2 to this subpart for kilns equipped with WS.	i. Collecting the scrubber pressure drop data according to § 63.8600(a); reducing the scrubber pressure drop data to 3-hour block averages according to § 63.8600(a); maintaining the average scrubber pressure drop for each 3-hour block period at or above the average pressure drop established during the performance test; and ii. Collecting the scrubber liquid pH data according to § 63.8600(a); reducing the scrubber liquid pH data to 3-hour block averages according to § 63.8600(a); maintaining the average scrubber liquid pH for each 3-hour block period at or above the average scrubber liquid pH established during the performance test; and iii. Collecting the scrubber liquid flow rate data according to § 63.8600(a); reducing the scrubber liquid flow rate data to 3-hour block averages according to § 63.8600(a); maintaining the average scrubber liquid flow rate for each 3-hour block period at or above the average scrubber liquid flow rate established during the performance test; and iv. If chemicals are added to the scrubber water, collecting the scrubber chemical feed rate data according to § 63.8600(a); reducing the scrubber chemical feed rate data to 3-hour block averages according to § 63.8600(a); maintaining the average scrubber chemical feed rate for each 3-hour block period at or above the average scrubber chemical feed rate established during the performance test.
4. Existing, new, or reconstructed periodic kiln, tunnel kiln, or roller kiln; each tunnel kiln that would be considered reconstructed but for § 63.8540 (f)(1); and each tunnel kiln that would be considered reconstructed but for § 63.8540(f)(2).	Minimize fuel-based HAP emissions.	i. Maintaining records documenting your use of natural gas, or an equivalent fuel, as the kiln fuel at all times except during periods of natural gas curtailment or supply interruption; and ii. If you intend to use an alternative fuel, submitting a notification of alternative fuel use within 48 hours of the declaration of a period of natural gas curtailment or supply interruption, as defined in § 63.8665; and iii. Submitting a report of alternative fuel use within 10 working days after terminating the use of the alternative fuel, as specified in § 63.8635(g).

TABLE 7 TO SUBPART KKKKK OF PART 63—REQUIREMENTS FOR REPORTS

As stated in § 63.8635, you must submit each report that applies to you according to the following table:

You must submit . . .	The report must contain . . .	You must submit the report . . .
1. A compliance report	a. If there are no deviations from any emission limitations or work practice standards that apply to you, a statement that there were no deviations from the emission limitations or work practice standards during the reporting period. If there were no periods during which the CMS was out-of-control as specified in your OM&M plan, a statement that there were no periods during which the CMS was out-of-control during the reporting period.	Semiannually according to the requirements in § 63.8635(b).
	b. If you have a deviation from any emission limitation (emission limit, operating limit) during the reporting period, the report must contain the information in § 63.8635(d) or (e). If there were periods during which the CMS was out-of-control, as specified in your OM&M plan, the report must contain the information in § 63.8635(e).	Semiannually according to the requirements in § 63.8635(b).
	c. If you had a startup, shutdown, or malfunction during the reporting period and you took actions consistent with your SSMP, the compliance report must include the information in § 63.10(d)(5)(i).	Semiannually according to the requirements in § 63.8635(b).
2. An immediate startup, shutdown, and malfunction report if you took actions during a startup, shutdown, or malfunction during the reporting period that are not consistent with your SSMP.	a. Actions taken for the event according to the requirements in § 63.10(d)(5)(ii).	By fax or telephone within 2 working days after starting actions inconsistent with the plan.

You must submit . . .	The report must contain . . .	You must submit the report . . .
	b. The information in § 63.10(d)(5)(ii)	By letter within 7 working days after the end of the event unless you have made alternative arrangements with the permitting authority.
3. A report of alternative fuel use.	The information in § 63.8635(g)	If you are subject to the work practice standards specified in Table 3 to this subpart, and you use an alternative fuel to fire an affected kiln, by letter within 10 working days after terminating the use of the alternative fuel.

TABLE 8 TO SUBPART KKKKK OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART KKKKK

As stated in § 63.8655, you must comply with the General Provisions in §§ 63.1 through 63.15 that apply to you according to the following table:

Citation	Subject	Brief description	Applies to subpart KKKKK
§ 63.1	Applicability	Initial applicability determination; applicability after standard established; permit requirements; extensions, notifications..	Yes.
§ 63.2	Definitions	Definitions for part 63 standards	Yes.
§ 63.3	Units and Abbreviations	Units and abbreviations for part 63 standards.	Yes.
§ 63.4	Prohibited Activities	Compliance date; circumvention; severability.	Yes.
§ 63.5	Construction/Reconstruction	Applicability; applications; approvals.	Yes.
§ 63.6(a)	Applicability	General Provisions (GP) apply unless compliance extension; GP apply to area sources that become major.	Yes.
§ 63.6(b)(1)–(4)	Compliance Dates for New and Reconstructed Sources.	Standards apply at effective date; 3 years after effective date; upon startup; 10 years after construction or reconstruction commences for section 112(f).	Yes.
§ 63.6(b)(5)	Notification	Must notify if commenced construction or reconstruction after proposal.	Yes.
§ 63.6(b)(6)	[Reserved].		
§ 63.6(b)(7)	Compliance Dates for New and Reconstructed area Sources That Become Major.	Area sources that become major must comply with major source standards immediately upon becoming major, regardless of whether required to comply when they were area sources.	Yes.
§ 63.6(c)(1)–(2)	Compliance Dates for Existing Sources.	Comply according to date in subpart, which must be no later than 3 years after effective date; for section 112(f) standards, comply within 90 days of effective date unless compliance extension.	Yes.
§ 63.6(c)(3)–(4)	[Reserved].		
§ 63.6(c)(5)	Compliance Dates for Existing Area Sources That Become Major.	Area sources that become major must comply with major source standards by date indicated in subpart or by equivalent time period (for example, 3 years).	Yes.
§ 63.6(d)	[Reserved].		

Citation	Subject	Brief description	Applies to subpart KKKKK
§ 63.6(e)(1)–(2)	Operation & Maintenance	Operate to minimize emissions at all times; correct malfunctions as soon as practicable; requirements independently enforceable; information Administrator will use to determine if operation and maintenance requirements were met.	Yes.
§ 63.6(e)(3)	Startup, Shutdown, and Malfunction Plan (SSMP).	Requirement for startup, shutdown, and malfunction (SSM) and SSMP; content of SSMP.	Yes.
§ 63.6(f)(1)	Compliance Except During SSM	You must comply with emission standards at all times except during SSM.	Yes.
§ 63.6(f)(2)–(3)	Methods for Determining Compliance.	Compliance based on performance test, operation and maintenance plans, records, inspection.	Yes.
§ 63.6(g)	Alternative Standard	Procedures for getting an alternative standard.	Yes.
§ 63.6(h)	Opacity/VE Standards	Requirements for opacity and VE standards.	No, not applicable.
§ 63.6(i)	Compliance Extension	Procedures and criteria for Administrator to grant compliance extension.	Yes.
§ 63.6(j)	Presidential Compliance Exemption.	President may exempt source category.	Yes.
§ 63.7(a)(1)–(2)	Performance Test Dates	Dates for conducting initial performance testing and other compliance demonstrations; must conduct 180 days after first subject to rule.	Yes.
§ 63.7(a)(3)	Section 114 Authority	Administrator may require a performance test under CAA section 114 at any time.	Yes.
§ 63.7(b)(1)	Notification of Performance Test	Must notify Administrator 60 days before the test.	Yes.
§ 63.7(b)(2)	Notification of Rescheduling	Must notify Administrator 5 days before scheduled date of rescheduled date.	Yes.
§ 63.7(c)	Quality Assurance (QA)/Test Plan	Requirements; test plan approval procedures; performance audit requirements; internal and external QA procedures for testing.	Yes.
§ 63.7(d)	Testing Facilities	Requirements for testing facilities	Yes.
§ 63.7(e)(1)	Conditions for Conducting Performance Tests.	Performance tests must be conducted under representative conditions.	No, § 63.8595 specifies requirements.
		Cannot conduct performance tests during SSM; not a violation to exceed standard during SSM.	Yes.
§ 63.7(e)(2)–(3)	Conditions for Conducting Performance Tests.	Must conduct according to subpart and EPA test methods unless Administrator approves alternative; must have at least three test runs of at least 1 hour each; compliance is based on arithmetic mean of three runs; conditions when data from an additional test run can be used.	Yes.
§ 63.7(f)	Alternative Test Method	Procedures by which Administrator can grant approval to use an alternative test method.	Yes.
§ 63.7(g)	Performance Test Data Analysis	Must include raw data in performance test report; must submit performance test data 60 days after end of test with the notification of compliance status.	Yes.
§ 63.7(h)	Waiver of Tests	Procedures for Administrator to waive performance test.	Yes.
§ 63.8(a)(1)	Applicability of Monitoring Requirements.	Subject to all monitoring requirements in subpart.	Yes.

Citation	Subject	Brief description	Applies to subpart KKKKK
§ 63.8(a)(2)	Performance Specifications	Performance Specifications in appendix B of 40 CFR part 60 apply.	Yes.
§ 63.8(a)(3)	[Reserved].		
§ 63.8(a)(4)	Monitoring with Flares	Requirements for flares in § 63.11 apply.	No, not applicable.
§ 63.8(b)(1)	Monitoring	Must conduct monitoring according to standard unless Administrator approves alternative.	Yes.
§ 63.8(b)(2)–(3)	Multiple Effluents and Multiple Monitoring Systems.	Specific requirements for installing and reporting on monitoring systems.	Yes.
§ 63.8(c)(1)	Monitoring System Operation and Maintenance.	Maintenance consistent with good air pollution control practices.	Yes.
§ 63.8(c)(1)(i)	Routine and Predictable SSM	Reporting requirements for SSM when action is described in SSMP.	Yes.
§ 63.8(c)(1)(ii)	SSM not in SSMP	Reporting requirements for SSM when action is not described in SSMP.	Yes.
§ 63.8(c)(1)(iii)	Compliance with Operation and Maintenance Requirements.	How Administrator determines if source complying with operation and maintenance requirements.	Yes.
§ 63.8(c)(2)–(3)	Monitoring System Installation	Must install to get representative emission and parameter measurements.	Yes.
§ 63.8(c)(4)	CMS Requirements	Requirements for CMS	No, §§ 63.8575 and 63.8615 specify requirements.
§ 63.8(c)(5)	Continuous Opacity Monitoring System (COMS) Minimum Procedures.	COMS minimum procedures	No, not applicable.
§ 63.8(c)(6)	CMS Requirements	Zero and high level calibration check requirements.	No, § 63.8575 specifies requirements.
§ 63.8(c)(7)–(8)	CMS Requirements	Out-of-control periods	No, § 63.8575 specifies requirements.
§ 63.8(d)	CMS Quality Control	Requirements for CMS quality control.	No, § 63.8575 specifies requirements.
§ 63.8(e)	CMS Performance Evaluation	Requirements for CMS performance evaluation.	No, § 63.8575 specifies requirements.
§ 63.8(f)(1)–(5)	Alternative Monitoring Method	Procedures for Administrator to approve alternative monitoring.	Yes.
§ 63.8(f)(6)	Alternative to Relative Accuracy Test.	Procedures for Administrator to approve alternative relative accuracy test for continuous emission monitoring systems (CEMS).	No, not applicable.
§ 63.8(g)	Data Reduction	COMS and CEMS data reduction requirements.	No, not applicable.
§ 63.9(a)	Notification Requirements	Applicability; State delegation	Yes.
§ 63.9(b)	Initial Notifications	Requirements for initial notifications.	Yes.
§ 63.9(c)	Request for Compliance Extension.	Can request if cannot comply by date or if installed BACT/LAER.	Yes.
§ 63.9(d)	Notification of Special Compliance Requirements for New Source.	For sources that commence construction between proposal and promulgation and want to comply 3 years after effective date.	Yes.
§ 63.9(e)	Notification of Performance Test	Notify Administrator 60 days prior	Yes.
§ 63.9(f)	Notification of VE/Opacity Test	Notify Administrator 30 days prior	No, not applicable.
§ 63.9(g)(1)	Additional Notifications When Using CMS.	Notification of performance evaluation.	Yes.
§ 63.9(g)(2)–(3)	Additional Notifications When Using CMS.	Notification of COMS data use; notification that relative accuracy alternative criterion were exceeded..	No, not applicable.
§ 63.9(h)	Notification of Compliance Status	Contents; submittal requirements	Yes.
§ 63.9(i)	Adjustment of Submittal Deadlines	Procedures for Administrator to approve change in when notifications must be submitted.	Yes.
§ 63.9(j)	Change in Previous Information	Must submit within 15 days after the change.	Yes.
§ 63.10(a)	Recordkeeping/Reporting	Applicability; general information	Yes.

Citation	Subject	Brief description	Applies to subpart KKKKK
§63.10(b)(1)	General Recordkeeping Requirements.	General requirements	Yes.
§63.10(b)(2)(i)–(v)	Records Related to SSM	Requirements for SSM records	Yes.
§63.10(b)(2)(vi)–(xii) and (xiv).	CMS Records	Records when CMS is malfunctioning, inoperative or out-of-control.	Yes.
§63.10(b)(2)(xiii)	Records	Records when using alternative to relative accuracy test.	No, not applicable.
§63.10(b)(3)	Records	Applicability Determinations	Yes.
§63.10(c)(1)–(15)	Records	Additional records for CMS	No, §§63.8575 and 63.8640 specify requirements.
§63.10(d)(1) and (2)	General Reporting Requirements	Requirements for reporting; performance test results reporting.	Yes.
§63.10(d)(3)	Reporting Opacity or VE Observations.	Requirements for reporting opacity and VE.	No, not applicable.
§63.10(d)(4)	Progress Reports	Must submit progress reports on schedule if under compliance extension.	Yes.
§63.10(d)(5)	SSM Reports	Contents and submission	Yes.
§63.10(e)(1)–(3)	Additional CMS Reports	Requirements for CMS reporting	No, §§63.8575 and 63.8635 specify requirements.
§63.10(e)(4)	Reporting COMS data	Requirements for reporting COMS data with performance test data.	No, not applicable.
§63.10(f)	Waiver for Recordkeeping/Reporting.	Procedures for Administrator to waive.	Yes.
§63.11	Flares	Requirement for flares	No, not applicable.
§63.12	Delegation	State authority to enforce standards.	Yes.
§63.13	Addresses	Addresses for reports, notifications, requests.	Yes.
§63.14	Incorporation by Reference	Materials incorporated by reference.	Yes.
§63.15	Availability of Information	Information availability; confidential information.	Yes.

Subpart LLLLL—National Emission Standards for Hazardous Air Pollutants: Asphalt Processing and Asphalt Roofing Manufacturing

SOURCE: 68 FR 24577, May 7, 2003, unless otherwise noted.

WHAT THIS SUBPART COVERS

§63.8680 What is the purpose of this subpart?

This subpart establishes national emission standards for hazardous air pollutants (NESHAP) for existing and new asphalt processing and asphalt roofing manufacturing facilities. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations.

§63.8681 Am I subject to this subpart?

(a) You are subject to this subpart if you own or operate an asphalt processing facility or an asphalt roofing manufacturing facility, as defined in §63.8698, that is a major source of hazardous air pollutants (HAP) emissions, or is located at, or is part of a major source of HAP emissions.

(b) After the applicable compliance date specified in §63.8683, blowing stills, asphalt storage tanks, saturators, wet loopers, and coaters subject to the provisions of this subpart that are also subject to 40 CFR part 60, subpart UU, are required to comply only with provisions of this subpart.

(c) This subpart does not apply to any equipment that is subject to subpart CC of this part or to subpart K, Ka, or Kb of 40 CFR part 60.

(d) This subpart does not apply to asphalt processing and asphalt roofing manufacturing equipment used for research and development, as defined in §63.8698.

(e) The provisions of subpart J of 40 CFR part 60 do not apply to emissions from asphalt processing facilities subject to this subpart.

(f) A major source of HAP emissions is any stationary source or group of stationary sources within a contiguous area under common control that emits or has the potential to emit any single HAP at a rate of 9.07 megagrams (10 tons) or more per year or any combination of HAP at a rate of 22.68 megagrams (25 tons) or more per year.

[68 FR 24577, May 7, 2003, as amended at 70 FR 28364, May 17, 2005]

§ 63.8682 What parts of my plant does this subpart cover?

(a) This subpart applies to each new, reconstructed, or existing affected source at asphalt processing and asphalt roofing manufacturing facilities.

(b) The affected source is:

(1) Each asphalt processing facility as defined in § 63.8698; or

(2) Each asphalt roofing manufacturing line as defined in § 63.8698.

(i) If the asphalt roofing manufacturing line is collocated with an asphalt processing facility, the storage tanks that store asphalt flux intended for oxidation in the blowing stills and those tanks that receive asphalt directly from the on-site blowing stills are part of the asphalt processing facility. The remaining asphalt storage tanks are considered to be part of the asphalt roofing facility.

(ii) If an asphalt storage tank is shared by two or more lines at an asphalt roofing manufacturing facility, the shared storage tank is considered part of the line to which the tank supplies the greatest amount of asphalt, on an annual basis.

(iii) If a sealant or adhesive applicator is shared by two or more asphalt roofing manufacturing lines, the shared applicator is considered part of the line that provides the greatest throughput to the applicator, on an annual basis.

(c) An affected source is a new affected source if you commenced construction of the affected source after November 21, 2001, and you met the applicability criteria at the time you commenced construction.

(d) An affected source is reconstructed if you meet the criteria in the reconstruction definition in § 63.2.

(e) An affected source is existing if it is not new or reconstructed.

§ 63.8683 When must I comply with this subpart?

(a) If you have a new or reconstructed affected source and start up:

(1) On or before April 29, 2003, then you must comply with the requirements for new and reconstructed sources in this subpart no later than April 29, 2003.

(2) After April 29, 2003, then you must comply with the requirements for new and reconstructed sources in this subpart upon startup.

(b) If you have an existing affected source, you must comply with the requirements for existing sources no later than May 1, 2006.

(c) If you have an area source that increases its emissions or its potential to emit such that it becomes a (or part of a) major source of HAP, then the following requirements apply:

(1) Any portion of the existing facility that becomes a new or reconstructed affected source must be in compliance with this subpart upon startup or by April 29, 2003, whichever is later.

(2) All other parts of the source to which this subpart applies must be in compliance with this subpart by 3 years after the date the source becomes a major source.

(d) You must meet the notification requirements in § 63.8692 according to the schedules in §§ 63.8692 and 63.9. Some of the notifications must be submitted before you are required to comply with the emission limitations in this subpart.

EMISSION LIMITATIONS

§ 63.8684 What emission limitations must I meet?

(a) You must meet each emission limitation in Table 1 to this subpart that applies to you.

(b) You must meet each operating limit in Table 2 to this subpart that applies to you.

GENERAL COMPLIANCE REQUIREMENTS

§63.8685 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limitations (including operating limits) in this subpart at all times, except during periods of startup, shutdown, and malfunction.

(b) You must always operate and maintain your affected source, including air pollution control and monitoring equipment, according to the provisions in §63.6(e)(1)(i).

(c) You must develop a written startup, shutdown, and malfunction plan (SSMP) according to the provisions in §63.6(e)(3).

(d) You must develop and implement a written site-specific monitoring plan according to the provisions in §63.8688(g) and (h).

[68 FR 24577, May 7, 2003, as amended at 71 FR 20469, Apr. 20, 2006]

TESTING AND INITIAL COMPLIANCE REQUIREMENTS

§63.8686 By what date must I conduct performance tests or other initial compliance demonstrations?

(a) For existing affected sources, you must conduct performance tests no later than 180 days after the compliance date that is specified for your source in §63.8683 and according to the provisions in §63.7(a)(2).

(b) As an alternative to the requirement specified in paragraph (a) of this section, you may use the results of a previously-conducted emission test to demonstrate compliance with the emission limitations in this subpart if you demonstrate to the Administrator's satisfaction that:

(1) No changes have been made to the process since the time of the emission test; and

(2) The operating conditions and test methods used during testing conform to the requirements of this subpart; and

(3) The control device and process parameter values established during the previously-conducted emission test are used to demonstrate continuous compliance with this subpart.

(c) For new sources, you must demonstrate initial compliance no later than 180 calendar days after April 29, 2003 or within 180 calendar days after startup of the source, whichever is later.

§63.8687 What performance tests, design evaluations, and other procedures must I use?

(a) You must conduct each performance test in Table 3 to this subpart that applies to you.

(b) Each performance test must be conducted under normal operating conditions and under the conditions specified in Table 3 to this subpart.

(c) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in §63.7(e)(1).

(d) Except for opacity and visible emission observations, you must conduct three separate test runs for each performance test required in this section, as specified in §63.7(e)(3). Each test run must last at least 1 hour.

(e) You must use the following equations to determine compliance with the emission limitations.

(1) To determine compliance with the particulate matter mass emission rate, you must use Equations 1 and 2 of this section as follows:

$$E = M_{PM}/P \qquad \text{(Eq. 1)}$$

Where:

E = Particulate matter emission rate, kilograms of particulate matter per megagram of roofing product manufactured.

M_{PM} = Particulate matter mass emission rate, kilograms per hour, determined using Equation 2.

P = The asphalt roofing product manufacturing rate during the emissions sampling period, including any material trimmed from the final product, megagram per hour.

$$M_{PM} = C * Q * K \qquad \text{(Eq. 2)}$$

Where:

M_{PM} = Particulate matter mass emission rate, kilograms per hour.

C = Concentration of particulate matter on a dry basis, grams per dry standard cubic meter (g/dscm), as measured by the test method specified in Table 3 to this subpart.

Q = Vent gas stream flow rate (dry standard cubic meters per minute) at a temperature of 20 °C as measured by the test method specified in Table 3 to this subpart.

K = Unit conversion constant (0.06 minute-kilogram/hour-gram).

(2) To determine compliance with the total hydrocarbon percent reduction standard, you must use Equations 3 and 4 of this section as follows:

$$RE = \left[\left(M_{THCi} - M_{THCo}\right)/\left(M_{THCi}\right)\right] * (100) \qquad \text{(Eq. 3)}$$

Where:

RE = Emission reduction efficiency, percent.

M_{THCi} = Mass flow rate of total hydrocarbons entering the control device, kilograms per hour, determined using Equation 4.

M_{THCo} = Mass flow rate of total hydrocarbons exiting the control device, kilograms per hour, determined using Equation 4.

$$M_{THC} = C * Q * K \qquad \text{(Eq. 4)}$$

Where:

M_{THC} = Total hydrocarbon mass flow rate, kilograms per hour.

C = Concentration of total hydrocarbons on a dry basis, parts per million by volume (ppmv), as measured by the test method specified in Table 3 to this subpart.

Q = Vent gas stream flow rate (dscm/minute) at a temperature of 20 °C as measured by the test method specified in Table 3 to this subpart.

K = Unit conversion constant (1.10E–04 $(ppmv)^{-1}$ (kilogram/dscm)(minute/hour)).

(3) To determine compliance with the combustion efficiency standard, you must use Equation 5 of this section as follows:

$$CE = \left[1 - \left(CO/CO_2\right) - \left(THC/CO_2\right)\right] \qquad \text{(Eq. 5)}$$

Where:

CE = Combustion efficiency, percent.

CO = Carbon monoxide concentration at the combustion device outlet, parts per million by volume (dry), as measured by the test method specified in Table 3 to this subpart.

CO_2 = Carbon dioxide concentration at the combustion device outlet, parts per million by volume (dry), as measured by the test method specified in Table 3 to this subpart.

THC = Total hydrocarbon concentration at the combustion device outlet, parts per million by volume (dry), as measured by the test method specified in Table 3 to this subpart.

(4) To determine compliance with the total hydrocarbon destruction efficiency standard for a combustion device that does not use auxiliary fuel, you must use Equation 6 of this section as follows:

$$THC\ DE = \left[\left(CO + CO_2\right)/\left(CO + CO_2 + THC\right)\right] \qquad \text{(Eq. 6)}$$

Where:

THC DE = THC destruction efficiency, percent.

CO = Carbon monoxide concentration at the combustion device outlet, parts per million by volume (dry), as measured by the test method specified in Table 3 to this subpart.

CO_2 = Carbon dioxide concentration at the combustion device outlet, parts per million by volume (dry), as measured by the test method specified in Table 3 to this subpart.

THC = Total hydrocarbon concentration at the combustion device outlet, parts per million by volume (dry), as measured by the test method specified in Table 3 to this subpart.

[68 FR 24577, May 7, 2003, as amended at 70 FR 28364, May 17, 2005]

§ 63.8688 What are my monitoring installation, operation, and maintenance requirements?

(a) You must install, operate, and maintain each continuous parameter

monitoring system (CPMS) according to the following:

(1) The CPMS must complete a minimum of one cycle of operation for each successive 15-minute period.

(2) To determine the 3-hour average, you must:

(i) Have a minimum of four successive cycles of operation to have a valid hour of data.

(ii) Have valid data from at least three of four equally spaced data values for that hour from a CPMS that is not out-of-control according to your site-specific monitoring plan.

(iii) Determine the 3-hour average of all recorded readings for each operating day, except as stated in §63.8690(c). You must have at least two of the three hourly averages for that period using only hourly average values that are based on valid data (*i.e.*, not from out-of-control periods).

(3) You must record the results of each inspection, calibration, and validation check.

(b) For each temperature monitoring device, you must meet the requirements in paragraph (a) of this section and the following:

(1) Locate the temperature sensor in a position that provides a representative temperature.

(2) For a noncryogenic temperature range, use a temperature sensor with a minimum measurement sensitivity of 2.8 °C or 1.0 percent of the temperature value, whichever is larger.

(3) If a chart recorder is used, it must have a sensitivity in the minor division of at least 20 °F.

(4) Perform an accuracy check at least semiannually or following an operating parameter deviation:

(i) According to the procedures in the manufacturer's documentation; or

(ii) By comparing the sensor output to redundant sensor output; or

(iii) By comparing the sensor output to the output from a calibrated temperature measurement device; or

(iv) By comparing the sensor output to the output from a temperature simulator.

(5) Conduct accuracy checks any time the sensor exceeds the manufacturer's specified maximum operating temperature range or install a new temperature sensor.

(6) At least quarterly or following an operating parameter deviation, perform visual inspections of components if redundant sensors are not used.

(c) For each pressure measurement device, you must meet the requirements of paragraph (a) of this section and the following:

(1) Locate the pressure sensor(s) in, or as close as possible, to a position that provides a representative measurement of the pressure.

(2) Use a gauge with a minimum measurement sensitivity of 0.12 kiloPascals or a transducer with a minimum measurement sensitivity of 5 percent of the pressure range.

(3) Check pressure tap pluggage daily. Perform an accuracy check at least quarterly or following an operating parameter deviation:

(i) According to the procedures in the manufacturer's documentation; or

(ii) By comparing the sensor output to redundant sensor output.

(4) Conduct calibration checks any time the sensor exceeds the manufacturer's specified maximum operating pressure range or install a new pressure sensor.

(5) At least monthly or following an operating parameter deviation, perform a leak check of all components for integrity, all electrical connections for continuity, and all mechanical connections for leakage.

(6) At least quarterly or following an operating parameter deviation, perform visible inspections on all components if redundant sensors are not used.

(d) For monitoring parameters other than temperature and pressure drop, you must install and operate a CPMS to provide representative measurements of the monitored parameters.

(e) For each flare, you must install a device (including but not limited to a thermocouple, an ultraviolet beam sensor, or an infrared sensor) capable of continuously detecting the presence of a pilot flame.

(f) As an option to installing the CPMS specified in paragraph (a) of this section, you may install a continuous emissions monitoring system (CEMS) or a continuous opacity monitoring

system (COMS) that meets the requirements specified in § 63.8 and the applicable performance specifications of 40 CFR part 60, appendix B.

(g) For each monitoring system required in this section, you must develop and make available for inspection by the permitting authority, upon request, a site-specific monitoring plan that addresses the following:

(1) Installation of the CPMS, CEMS, or COMS sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the exhaust emissions (*e.g.*, on or downstream of the last control device);

(2) Performance and equipment specifications for the sample interface, the pollutant concentration or parametric signal analyzer, and the data collection and reduction system; and

(3) Performance evaluation procedures and acceptance criteria (*e.g.*, calibrations).

(h) In your site-specific monitoring plan, you must also address the following:

(1) Ongoing operation and maintenance procedures in accordance with the general requirements of § 63.8(c)(1), (c)(3), (c)(4)(ii), (c)(7), and (c)(8);

(2) Ongoing data quality assurance procedures in accordance with the general requirements of § 63.8(d); and

(3) Ongoing recordkeeping and reporting procedures in accordance with the general requirements of § 63.10(c), (e)(1), and (e)(2)(i).

(i) You must conduct a performance evaluation of each CPMS, CEMS, or COMS in accordance with your site-specific monitoring plan.

(j) You must operate and maintain the CPMS, CEMS, or COMS in continuous operation according to the site-specific monitoring plan.

§ 63.8689 How do I demonstrate initial compliance with the emission limitations?

(a) You must demonstrate initial compliance with each emission limitation that applies to you according to Table 4 to this subpart.

(b) You must establish each site-specific operating limit in Table 2 to this subpart that applies to you according to the requirements in § 63.8687 and Table 3 to this subpart.

(c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in § 63.8692(e).

CONTINUOUS COMPLIANCE REQUIREMENTS

§ 63.8690 How do I monitor and collect data to demonstrate continuous compliance?

(a) You must monitor and collect data according to this section.

(b) Except for monitor malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), you must monitor continuously (or collect data at all required intervals) at all times that the affected source is operating. This includes periods of startup, shutdown, and malfunction when the affected source is operating.

(c) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels, nor may such data be used in fulfilling a minimum data availability requirement, if applicable. You must use all the data collected during all other periods in assessing the operation of the control device and associated control system.

§ 63.8691 How do I demonstrate continuous compliance with the operating limits?

(a) You must demonstrate continuous compliance with each operating limit in Table 2 to this subpart that applies to you according to test methods specified in Table 5 to this subpart.

(b) You must report each instance in which you did not meet each operating limit in Table 5 to this subpart that applies to you. This includes periods of startup, shutdown, and malfunction. These instances are deviations from the emission limitations in this subpart. These deviations must be reported according to the requirements in § 63.8693.

(c) [Reserved]

(d) Consistent with §§63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with §63.6(e)(1). The Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in §63.6(e).

[68 FR 24577, May 7, 2003, as amended at 71 FR 20469, Apr. 20, 2006]

NOTIFICATIONS, REPORTS, AND RECORDS

§63.8692 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.6(h)(4) and (5), 63.7(b) and (c), 63.8(f), and 63.9(b) through (f) and (h) that apply to you by the dates specified.

(b) As specified in §63.9(b)(2), if you start up your affected source before April 29, 2003, you must submit an Initial Notification not later than 120 calendar days after April 29, 2003.

(c) As specified in §63.9(b)(3), if you start up your new or reconstructed affected source on or after April 29, 2003, you must submit an Initial Notification not later than 120 calendar days after you become subject to this subpart.

(d) If you are required to conduct a performance test, you must submit a notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin, as required in §63.7(b)(1).

(e) If you are required to conduct a performance test, design evaluation, opacity observation, visible emission observation, or other initial compliance demonstration as specified in Table 3 or 4 to this subpart, you must submit a Notification of Compliance Status according to §63.9(h)(2)(ii). You must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th calendar day following the completion of the performance test according to §63.10(d)(2).

(f) If you are using data from a previously-conducted emission test to serve as documentation of conformance with the emission standards and operating limits of this subpart, you must submit the test data in lieu of the initial performance test results with the Notification of Compliance Status required under paragraph (e) of this section.

§63.8693 What reports must I submit and when?

(a) You must submit each report in Table 6 to this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under §63.10(a), you must submit each report by the date in Table 6 to this subpart and according to the following dates:

(1) The first compliance report must cover the period beginning on the compliance date that is specified for your affected source in §63.8683 and ending on June 30 or December 31, whichever date is the first date following the end of the first calendar half after the compliance date that is specified for your source in §63.8683.

(2) The first compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first calendar half after the compliance date that is specified for your affected source in §63.8683.

(3) Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(5) For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), you may submit the

first and subsequent compliance reports according to the dates the permitting authority has established instead of the dates in paragraphs (b)(1) through (4) of this section.

(c) The compliance report must contain the following information:

(1) Company name and address.

(2) Statement by a responsible official with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a startup, shutdown or malfunction during the reporting period and you took actions consistent with your SSMP, the compliance report must include the information in § 63.10(d)(5)(i).

(5) If there are no deviations from any emission limitations (emission limit, operating limit, opacity limit, and visible emission limit) that apply to you, a statement that there were no deviations from the emission limitations during the reporting period.

(6) If there were no periods during which the CPMS, CEMS, or COMS was out-of-control as specified in § 63.8(c)(7), a statement that there were no periods during which the CPMS, CEMS, or COMS was out-of-control during the reporting period.

(d) For each deviation from an emission limitation (emission limit, operating limit, opacity limit, and visible emission limit), you must include the information in paragraphs (c)(1) through (6) of this section, and the information in paragraphs (d)(1) through (12) of this section. This includes periods of startup, shutdown, and malfunction.

(1) The date and time that each malfunction started and stopped.

(2) The date and time that each CPMS, CEMS, or COMS was inoperative, except for zero (low-level) and high-level checks.

(3) The date, time and duration that each CPMS, CEMS, or COMS was out-of-control, including the information in § 63.8(c)(8).

(4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(5) A summary of the total duration of the deviation during the reporting period and the total duration as a percent of the total source operating time during that reporting period.

(6) A breakdown of the total duration of the deviations during the reporting period into those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and other unknown causes.

(7) A summary of the total duration of CPMS, CEMS, or COMS downtime during the reporting period and the total duration of CPMS, CEMS, or COMS downtime as a percent of the total source operating time during that reporting period.

(8) An identification of each air pollutant that was monitored at the affected source.

(9) A brief description of the process units.

(10) A brief description of the CPMS, CEMS, or COMS.

(11) The date of the latest CPMS, CEMS, or COMS certification or audit.

(12) A description of any changes in CPMS, CEMS, or COMS, processes, or controls since the last reporting period.

(e) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 40 CFR part 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a compliance report pursuant to Table 6 to this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all required information concerning deviations from any emission limitation (including any operating limit), submission of the compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a compliance report shall not otherwise affect any obligation the affected source may have to report deviations from

permit requirements to the permit authority.

(f) If acceptable to both the Administrator and you, you may submit reports and notifications electronically.

§63.8694 What records must I keep?

(a) You must keep the following records:

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirements in §63.10(b)(2)(xiv).

(2) The records in §63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.

(3) Records of performance tests, performance evaluations, and opacity and visible emission observations as required in §63.10(b)(2)(viii).

(b) You must keep the records in §63.6(h)(6) for visible emission observations.

(c) You must keep the records required in Table 5 to this subpart to show continuous compliance with each operating limit that applies to you.

(d) Records of any shared equipment determinations as specified in §63.8682(b).

§63.8695 In what form and how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review, according to §63.10(b)(1).

(b) As specified in §63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record on site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to §63.10(b)(1). You can keep the records offsite for the remaining 3 years.

OTHER REQUIREMENTS AND INFORMATION

§63.8696 What parts of the General Provisions apply to me?

Table 7 to this subpart shows which parts of the General Provisions in §§63.1 through 63.15 apply to you.

§63.8697 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the U.S. Environmental Protection Agency (U.S. EPA), or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency, in addition to the U.S. EPA, has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out if implementation and enforcement of this subpart is delegated.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the following authorities are retained by the Administrator of U.S. EPA:

(1) Approval of alternatives to the requirements in §§63.8681, 63.8682, 63.8683, 63.8684(a) through (c), 63.8686, 63.8687, 63.8688, 63.8689, 63.8690, and 63.8691.

(2) Approval of major changes to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90.

(3) Approval of major changes to monitoring under §63.8(f) and as defined in §63.90.

(4) Approval of major changes to recordkeeping and reporting under §63.10(f) and as defined in §63.90.

§63.8698 What definitions apply to this subpart?

Terms used in this subpart are defined in the Clean Air Act, in 40 CFR 63.2, the General Provisions of this part, and in this section as follows:

Adhesive applicator means the equipment used to apply adhesive to roofing shingles for producing laminated or dimensional roofing shingles.

Asphalt flux means the organic residual material from distillation of crude oil that is generally used in asphalt roofing manufacturing and paving and non-paving asphalt products.

Asphalt loading rack means the equipment at an asphalt processing facility used to transfer oxidized asphalt from a storage tank into a tank truck, rail car, or barge.

Asphalt processing facility means any facility engaged in the preparation of asphalt flux at stand-alone asphalt processing facilities, petroleum refineries, and asphalt roofing facilities. Asphalt preparation, called ''blowing,'' is the oxidation of asphalt flux, achieved by bubbling air through the heated asphalt, to raise the softening point and to reduce penetration of the oxidized asphalt. An asphalt processing facility includes one or more asphalt flux blowing stills, asphalt flux storage tanks storing asphalt flux intended for processing in the blowing stills, oxidized asphalt storage tanks, and oxidized asphalt loading racks.

Asphalt roofing manufacturing facility means a facility consisting of one or more asphalt roofing manufacturing lines.

Asphalt roofing manufacturing line means the collection of equipment used to manufacture asphalt roofing products through a series of sequential process steps. The equipment that comprises an asphalt roofing manufacturing line varies depending on the type of substrate used (*i.e.,* organic or inorganic) and the final product manufactured (*e.g.,* roll roofing, laminated shingles). For example, an asphalt roofing manufacturing line that uses fiberglass mat as a substrate typically would not include a saturator/wet looper (or the saturator/wet looper could be bypassed if the line manufacturers multiple types of products). An asphalt roofing manufacturing line can include a saturator (including wet looper), coater, coating mixers, sealant applicators, adhesive applicators, and asphalt storage and process tanks. The number of asphalt roofing manufacturing lines at a particular facility is determined by the number of saturators (or coaters) operated in parallel. For example, an asphalt roofing manufacturing facility with two saturators (or coaters) operating in parallel would be considered to have two separate roofing manufacturing lines.

Asphalt storage tank means any tank used to store asphalt flux, oxidized asphalt, and modified asphalt, at asphalt roofing manufacturing facilities, petroleum refineries, and asphalt processing facilities. Storage tanks containing cutback asphalts (asphalts diluted with solvents to reduce viscosity for low temperature applications) and emulsified asphalts (asphalts dispersed in water with an emulsifying agent) are not subject to this subpart.

Blowing still means the equipment in which air is blown through asphalt flux to change the softening point and penetration rate of the asphalt flux, creating oxidized asphalt.

Boiler means any enclosed combustion device that extracts useful energy in the form of steam and is not an incinerator.

Coater means the equipment used to apply amended (filled or modified) asphalt to the top and bottom of the substrate (typically fiberglass mat) used to manufacture shingles and rolled roofing products.

Coating mixer means the equipment used to mix coating asphalt and a mineral stabilizer, prior to applying the stabilized coating asphalt to the substrate.

Combustion device means an individual unit of equipment such as a flare, incinerator, process heater, or boiler used for the combustion of organic hazardous air pollutant vapors.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart including, but not limited to, any emission limitation (including any operating limit), or work practice standard;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart, and that is included in the operating permit for any affected source required to obtain such a permit; or

(3) Fails to meet any emission limitation (including any operating limit) or work practice standard in this subpart during startup, shutdown, or malfunction, regardless of whether or not such failure is permitted by this subpart.

Emission limitation means any emission limit, opacity limit, operating limit, or visible emission limit.

Group 1 asphalt loading rack means an asphalt loading rack that loads asphalt with a maximum temperature of 260 °C (500 °F) or greater and has a maximum true vapor pressure of 10.4 kiloPascals (kPa) (1.5 pounds per square inch absolute (psia)) or greater.

Group 2 asphalt loading rack means an asphalt loading rack that is not a Group 1 asphalt loading rack.

Group 1 asphalt storage tank means an asphalt storage tank that meets both of the following criteria:

(1) Has a capacity of 177 cubic meters (47,000 gallons) of asphalt or greater; and

(2) Stores asphalt at a maximum temperature of 260 °C (500 °F) or greater and has a maximum true vapor pressure of 10.4 kPa (1.5 psia) or greater.

Group 2 asphalt storage tank means any asphalt storage tank with a capacity of 1.93 megagrams (Mg) of asphalt or greater that is not a Group 1 asphalt storage tank.

Incinerator means an enclosed combustion device that is used for destroying organic compounds. Auxiliary fuel may be used to heat waste gas to combustion temperatures. Any energy recovery section present is not physically formed into one manufactured or assembled unit with the combustion section; rather, the energy recovery section is a separate section following the combustion section and the two are joined by ducts or connections carrying flue gas.

Maximum true vapor pressure means the equilibrium partial pressure exerted by the stored asphalt at its maximum storage temperature.

Modified asphalt means asphalt that has been mixed with polymer modifiers.

Oxidized asphalt means asphalt that has been prepared by passing air through liquid asphalt flux in a blowing still.

Process heater means an enclosed combustion device that primarily transfers heat liberated by burning fuel directly to process streams or to heat transfer liquids other than water.

Research and development equipment means any equipment whose primary purpose is to conduct research and development to develop new processes and products, where such equipment is operated under the close supervision of technically trained personnel and is not engaged in the manufacture of products for commercial sale in commerce, except in a *de minimis* manner.

Responsible official means responsible official as defined in 40 CFR 70.2.

Saturator means the equipment in which substrate (predominantly organic felt) is filled with asphalt. Saturators are predominantly used for the manufacture of saturated felt products. The term saturator includes the saturator and wet looper.

Sealant applicator means the equipment used to apply a sealant strip to a roofing product. The sealant strip is used to seal overlapping pieces of roofing product after they have been applied.

Work practice standard means any design, equipment, work practice, or operational standard, or combination thereof, that is promulgated pursuant to section 112(h) of the Clean Air Act.

[68 FR 24577, May 7, 2003, as amended at 70 FR 28364, May 17, 2005]

TABLE 1 TO SUBPART LLLLL OF PART 63—EMISSION LIMITATIONS

For—	You must meet the following emission limitation—
1. Each blowing still, Group 1 asphalt loading rack, and Group 1 asphalt storage tank at existing, new, and reconstructed asphalt processing facilities; and each Group 1 asphalt storage tank at existing, new, and reconstructed roofing manufacturing lines; and each coating mixer, saturator (including wet looper), coater, sealant applicator, adhesive applicator, and Group 1 asphalt storage tank at new and reconstructed asphalt roofing manufacturing lines.	a. Reduce total hydrocarbon mass emissions by 95 percent, or to a concentration of 20 ppmv, on a dry basis corrected to 3 percent oxygen; b. Route the emissions to a combustion device achieving a combustion efficiency of 99.5 percent; c. Route the emissions to a combustion device that does not use auxiliary fuel achieving a total hydrocarbon (THC) destruction efficiency of 95.8 percent; d. Route the emissions to a boiler or process heater with a design heat input capacity of 44 megawatts (MW) or greater; e. Introduce the emissions into the flame zone of a boiler or process heater; or f. Route emissions to a flare meeting the requirements of § 63.11(b).
2. The total emissions from the coating mixer, saturator (including wet looper), coater, sealant applicator, and adhesive applicator at each existing asphalt roofing manufacturing line. [a]	a. Limit particulate matter emissions to 0.04 kilograms emissions per megagram (kg/Mg) (0.08 pounds per ton, lb/ton) of asphalt shingle or mineral-surfaced roll roofing produced; or b. Limit particulate matter emissions to 0.4 kg/Mg (0.8 lb/ton) of saturated felt or smooth-surfaced roll roofing produced.
3. Each saturator (including wet looper) and coater at existing, new, and reconstructed asphalt roofing manufacturing lines. [a]	a. Limit exhaust gases to 20 percent opacity; and b. Limit visible emissions from the emission capture system to 20 percent of any period of consecutive valid observations totaling 60 minutes.
4. Each Group 2 asphalt storage tank at existing, new, and reconstructed asphalt processing facility and asphalt roofing manufacturing lines. [a]	Limit exhaust gases to 0 percent opacity. [b]

[a] As an alternative to meeting the particulate matter and opacity limits, these emission sources may comply with the THC percent reduction or combustion efficiency standards.

[b] The opacity limit can be exceeded for on consecutive 15-minute period in any 24-hour period when the storage tank transfer lines are being cleared. During this 15-minute period, the control device must not be bypassed. If the emissions from the asphalt storage tank are ducted to the saturator control device, the combined emissions from the saturator and storage tank must meet the 20 percent opacity limit (specified in 4.a of table 1) during this 15-minute period. At any other time, the opacity limit applies to Group 2 asphalt storage tanks.

TABLE 2 TO SUBPART LLLLL OF PART 63—OPERATING LIMITS

For—	You must [a]
1. Non-flare combustion devices with a design heat input capacity less than 44 MW or where the emissions are not introduced into the flame zone.	Maintain the 3-hour average [b] combustion zone temperature at or above the operating limit established during the performance test.
2. Flares	Meet the operating requirements specified in § 63.11(b).
3. Control devices used to comply with the particulate matter standards.	a. Maintain the 3-hour average [b] inlet gas temperature at or below the operating limit established during the performance test; and b. Maintain the 3-hour average [b] pressure drop across the device [c] at or below the operating limit established during the performance test.
4. Control devices other than combustion devices or devices used to comply with the particulate matter emission standards.	Maintain the approved monitoring parameters within the operating limits established during the performance test.

[a] The operating limits specified in Table 2 are applicable if you are monitoring control device operating parameters to demonstrate continuous compliance. If you are using a CEMS or COMS, you must maintain emissions below the value established during the initial performance test.

[b] A 15-minute averaging period can be used as an alternative to the 3-hour averaging period for this parameter.

[c] As an alternative to monitoring the pressure drop across the control device, owners or operators using an ESP to achieve compliance with the emission limits specified in Table 1 of this subpart can monitor the voltage to the ESP. If this option is selected, the ESP voltage must be maintained at or above the operating limit established during the performance test.

TABLE 3 TO SUBPART LLLLL OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS [A,B]

For—	You must—	Using—	According to the following requirements—
1. All particulate matter, total hydrocarbon, carbon monoxide, and carbon dioxide emission tests.	a. Select sampling port's location and the number of traverse points.	i. EPA test method 1 or 1A in appendix A to part 60 of this chapter.	A. For demonstrating compliance with the total hydrocarbon percent reduction standard, the sampling sites must be located at the inlet and outlet of the control device and prior to any releases to the atmosphere. B. For demonstrating compliance with the particulate matter mass emission rate, THC destruction efficiency, THC outlet concentration, or combustion efficiency standards, the sampling sites must be located at the outlet of the control device and prior to any releases to the atmosphere.
2. All particulate matter and total hydrocarbon tests.	Determine velocity and volumetric flow rate.	EPA test method 2, 2A, 2C, 2D, 2F, or 2G, as appropriate, in appendix A to part 60 of this chapter.	
3. All particulate matter and total hydrocarbon tests.	Determine the gas molecular weight used for flow rate determination.	EPA test method 3, 3A, 3B, as appropriate, in appendix A to part 60 of this chapter.	
4. All particulate matter, total hydrocarbon, carbon monoxide, and carbon dioxide emission tests.	Measure moisture content of the stack gas.	EPA test method 4 in appendix A to part 60 of this chapter.	
5. All particulate matter emission tests.	Measure the asphalt processing rate or the asphalt roofing manufacturing rate and the asphalt content of the product manufactured, as appropriate.		
6. Each control device used to comply with the particulate matter emission standards.	Measure the concentration of particulate matter.	EPA test method 5A in appendix A to part 60 of this chapter.	For demonstrating compliance with the particulate matter standard, the performance tests must be conducted under normal operating conditions and while manufacturing the roofing product that is expected to result in the greatest amount of hazardous air pollutant emissions.
7. All opacity tests	Conduct opacity observations.	EPA test method 9 in appendix A to part 60 of this chapter.	Conduct opacity observations for at least 3 hours and obtain 30, 6-minute averages.
8. All visible emission tests.	Conduct visible emission observations.	EPA test method 22 in appendix A to part 60 of this chapter.	Modify EPA test method 22 such that readings are recorded every 15 seconds for a period of consecutive observations totaling 60 minutes.
9. Each combustion device used to comply with the combustion efficiency or THC standards.	a. Measure the concentration of carbon dioxide.	EPA test method 3A in appendix A to part 60 of this chapter.	
	b. Measure the concentration of carbon monoxide.	EPA test method 10 in appendix A to part 60 of this chapter.	
	c. Measure the concentration of total hydrocarbons.	EPA test method 25A in appendix A to part 60 of this chapter.	
10. Each control device used to comply with the THC reduction efficiency or outlet concentration standards.	Measure the concentration of total hydrocarbons.	EPA test method 25A in appendix A to part 60 of this chapter.	

For—	You must—	Using—	According to the following requirements—
11. Each combustion device.	Establish a site-specific combustion zone temperature limit.	Data from the CPMS and the applicable performance test method(s).	You must collect combustion zone temperature data every 15 minutes during the entire period of the initial 3-hour performance test, and determine the average combustion zone temperature over the 3-hour performance test by computing the average of all of the 15-minute readings.
12. Each control device used to comply with the particulate matter emission standards.	Establish a site-specific inlet gas temperature limit; and establish a site-specific limit for the pressure drop across the device.	Data from the CPMS and the applicable performance test method(s).	You must collect the inlet gas temperature and pressure drop[b] data every 15 minutes during the entire period of the initial 3-hour performance test, and determine the average inlet gas temperature and pressure drop[c] over the 3-hour performance test by computing the average of all of the 15-minute readings.
13. Each control device other than a combustion device or device used to comply with the particulate matter emission standards.	Establish site-specific monitoring parameters.	Process data and data from the CPMS and the applicable performance test method(s).	You must collect monitoring parameter data every 15 minutes during the entire period of the initial 3-hour performance test, and determine the average monitoring parameter values over the 3-hour performance test by computing the average of all of the 15-minute readings.
14. Each flare used to comply with the THC percent reduction or PM emission limits.	Assure that the flare is operated and maintained in conformance with its design.	The requirements of § 63.11(b).	

[a] As specified in § 63.8687(e), you may request that data from a previously-conducted emission test serve as documentation of conformance with the emission standards and operating limits of this subpart.

[b] Performance tests are not required if: (1) The emissions are routed to a boiler or process heater with a design heat input capacity of 44 MW or greater; or (2) the emissions are introduced into the flame zone of a boiler or process heater.

[c] As an alternative to monitoring the pressure drop across the control device, owners or operators using an ESP to achieve compliance with the emission limits specified in Table 1 of this subpart can monitor the voltage to the ESP.

TABLE 4 TO SUBPART LLLLL OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS

For—	For the following emission limitation—	You have demonstrated initial compliance if—
1. Each blowing still, Group 1 asphalt loading rack, and Group 1 asphalt storage tank, at existing, new, and reconstructed asphalt processing facilities.	a. Reduce total hydrocarbon mass emissions by 95 percent or to a concentration of 20 ppmv, on a dry basis corrected to 3 percent oxygen.	i. The total hydrocarbon emissions, determined using the equations in § 63.8687 and the test methods and procedures in Table 3 to this subpart, over the period of the performance test are reduced by at least 95 percent by weight or to a concentration of 20 ppmv, on a dry basis corrected to 3 percent oxygen; and ii. You have a record of the average control device operating parameters[a] over the performance test during which emissions were reduced according to 1.a.i. of this table.
	b. Route the emissions to a combustion device achieving a combustion efficiency of 99.5 percent.	i. The combustion efficiency of the combustion device, determined using the equations in § 63.8687 and the test methods and procedures in Table 3 to this subpart, over the period of the performance test is at least 99.5 percent; and ii. You have a record of the average combustion zone temperature[a] and carbon monoxide, carbon dioxide, and total hydrocarbon outlet concentrations over the performance test during which the combustion efficiency was at least 99.5 percent.
	c. Route the emissions to a combustion device that does not use auxiliary fuel achieving a THC destruction efficiency of 95.8 percent.	i. The THC destruction efficiency of the combustion device, determined using the equations in § 63.8687 and the test methods and procedures in Table 3 to this subpart, over the period of the performance test is at least 95.8 percent; and ii. You have a record of the average combustion zone temperature[a] and carbon monoxide, carbon dioxide, and total hydrocarbon outlet concentrations over the performance test during which the THC destruction efficiency was at least 95.8 percent.
	d. Route emissions to a boiler or process heater with a design heat input capacity of 44 MW or greater.	You have a record of the boiler or process heater design heat capacity.

For—	For the following emission limitation—	You have demonstrated initial compliance if—
	e. Introduce the emissions into the flame zone of a boiler or process heater.	You have a record that shows the emissions are being introduced into the boiler or process heater flame zone.
	f. Route emissions to a flare meeting the requirements of § 63.11(b).	You have a record of the flare design and operating requirements.
2. Each coating mixer, saturator (including wet looper), coater, sealant applicator, adhesive applicator, and Group 1 asphalt storage tank at new and reconstructed asphalt roofing manufacturing lines.	a. Reduce total hydrocarbon mass emissions by 95 percent or to a concentration of 20 ppmv, on a dry basis corrected to 3 percent oxygen.	See 1.a.i. and ii. of this table.
	b. Route the emissions to a combustion device achieving a combustion efficiency of 99.5 percent.	See 1.b.i. and ii. of this table.
	c. Route the emissions to a combustion device that does not use auxiliary fuel achieving a THC destruction efficiency of 95.8 percent.	See 1.c.i. and ii. of this table.
	d. Route emissions to a boiler or process heater with a design heat input capacity of 44 MW or greater.	See 1.d. of this table.
	e. Introduce the emissions into the flame zone of a boiler or process heater.	See 1.e. of this table.
	f. Route emissions to a flare meeting the requirements of § 63.11(b).	See 1.f. of this table.
3. The total emissions from the coating mixer, saturator (including wet looper), coater, sealant applicator, and adhesive applicator at each existing asphalt roofing manufacturing line.	a. Limit PM emissions to 0.04 kg/Mg (0.08 lb/ton) of asphalt shingle or mineral-surfaced roll roofing produced.	i. The PM emissions, determined using the equations in § 63.8687 and the test methods and procedures in Table 3 to this subpart, over the period of the performance test are no greater than the applicable emission limitation; and ii. You have a record of the average control device [a] or process parameters over the performance test during which the particulate matter emissions were no greater than the applicable emission limitation.
	b. Limit PM emissions to 0.4 kg/Mg (0.8 lb/ton) of saturated felt or smooth-surfaced roll roofing produced.	See 3.a.i. and ii. of this table.
4. Each saturator (including wet looper) and coater at an existing, new, or reconstructed asphalt roofing manufacturing line.	a. Limit visible emissions from the emissions capture system to 20 percent of any period of consecutive valid observations totaling 60 minutes.	The visible emissions, measured using EPA test method 22, for any period of consecutive valid observations totaling 60 minutes during the initial compliance period described in § 63.8686(b) do not exceed 20 percent.
	b. Limit opacity emissions to 20 percent.	The opacity, measured using EPA test method 9, for each of the first 30 6-minute averages during the initial compliance period described in § 63.8686(b) does not exceed 20 percent.
5. Each Group 2 asphalt storage tank at existing, new, and reconstructed asphalt processing facilities and asphalt roofing manufacturing lines.	Limit exhaust gases to 0 percent opacity.	The opacity, measured using EPA test method 9, for each of the first 30 6-minute averages during the initial compliance period described in § 63.8686(b) does not exceed 0 percent.

[a] If you use a CEMS or COMS to demonstrate compliance with the emission limits, you are not required to record control device operating parameters.

TABLE 5 TO SUBPART LLLLL OF PART 63—CONTINUOUS COMPLIANCE WITH OPERATING LIMITS [A]

For—	For the following operating limit—	You must demonstrate continuous compliance by—
1. Each non-flare combustion device. [b]	a. Maintain the 3-hour [c] average combustion zone temperature at or above the operating limit establishing during the performance test.	i. Passing the emissions through the control device; and ii. Collecting the combustion zone temperature data according to § 63.8688(b); and iii. Reducing combustion zone temperature data to 3-hour [c] averages according to calculations in Table 3 to this subpart; and iv. Maintaining the 3-hour [c] average combustion zone temperature within the level established during the performance test.
2. Each flare	Meet the operating requirements specified in § 63.11(b).	The flare pilot light must be present at all times and the flare must be operating at all times that emissions may be vented to it.
3. Control devices used to comply with the particulate matter emission standards.	a. Maintain the 3-hour [c] average inlet gas temperature and pressure drop across device [d] at or below the operating limits established during the performance test.	i. Passing the emissions through the control device; and ii. Collecting the inlet gas temperature and pressure drop [d] data according to § 63.8688 (b) and (c); and iii. Reducing inlet gas temperature and pressure drop [d] data to 3-hour [c] averages according to calculations in Table 3 to this subpart; and iv. Maintaining the 3-hour [c] average inlet gas temperature and pressure drop [d] within the level established during the performance test.
4. Control devices other than combustion devices or devices used to comply with the particulate matter emission.	a. Maintain the monitoring parameters within the operating limits established during the performance test.	i. Passing the emissions through the devices; ii. Collecting the monitoring parameter data according to § 63.8688(d); and iii. Reducing the monitoring parameter data to 3-hour [c] averages according to calculations in Table 3 to this subpart; and iv. Maintaining the monitoring parameters within the level established during the performance test.

[a] The operating limits specified in Table 2 and the requirements specified in Table 5 are applicable if you are monitoring control device operating parameters to demonstrate continuous compliance. If you use a CEMS or COMS to demonstrate compliance with the emission limits, you are not required to record control device operating parameters. However, you must maintain emissions below the value established during the initial performance test. Data from the CEMS and COMS must be reduced as specified in § 63.8(g).

[b] Continuous parameter monitoring is not required if (1) the emissions are routed to a boiler or process heater with a with a design heat input capacity of 44 MW or greater; or (2) the emissions are introduced into the flame zone of a boiler or process heater.

[c] A 15-minute averaging period can be used as an alternative to the 3-hour averaging period for this parameter.

[d] As an alternative to monitoring the pressure drop across the control device, owners or operators using an ESP to achieve compliance with the emission limits specified in Table 1 of this subpart can monitor the voltage to the ESP. If this option is selected, the ESP voltage must be maintained at or above the operating limit established during the performance test.

[68 FR 24577, May 7, 2003, as amended at 70 FR 28365, May 17, 2005]

TABLE 6 TO SUBPART LLLLL OF PART 63—REQUIREMENTS FOR REPORTS

You must submit—	The report must contain—	You must submit the report—
1. An initial notification	The information in § 63.9(b)	According to the requirements in § 63.9(b).
2. A notification of performance test	A written notification of the intent to conduct a performance test.	At least 60 calendar days before the performance test is scheduled to begin, as required in § 63.9(e).
3. A notification of opacity and visible emission observations.	A written notification of the intent to conduct opacity and visible emission observations.	According to the requirements in § 63.9(f).
4. Notification of compliance status	The information in § 63.9(h)(2) through (5), as applicable.	According to the requirements in § 63.9(h)(2) through (5), as applicable.
5. A compliance report	a. A statement that there were no deviations from the emission limitations during the reporting period, if there are no deviations from any emmission limitations (emission limit, operating limit, opacity limit, and visible emission limit) that apply to you.	Semiannually according to the requirements in § 63.8693(b).
	b. If there were no periods during which the CPMS, CEMS, or COMS was out-of-control as specified in § 63.8(c)(7), a statement that there were no periods during which the CPMS, CEMS, or COMS was out-of-control during the reporting period.	Semiannually according to the requirements in § 63.8693(b).

You must submit—	The report must contain—	You must submit the report—
	c. If you have a deviation from any emission limitation (emission limit, operating limit, opacity limit, and visible emission limit), the report must contain the information in § 63.8693(c). If there were periods during which the CPMS, CEMS, or COMS was out-of-control, as specified in § 63.8(c)(7), the report must contain the information in § 63.8693(d).	Semiannually according to the requirements in § 63.8693(b).
	d. If you had a startup, shutdown or malfunction during the reporting period and you took actions consistent with your startup, shutdown, and malfunction plan, the compliance report must include the information in § 63.10(d)(5)(i).	Semiannually according to the requirements in § 63.8693(b).
6. An immediate startup, shutdown, and malfunction report if you have a startup, shutdown, or malfunction during the reporting period and actions taken were not consistent with your startup, shutdown, and malfunction plan.	The information in § 63.10(d)(5)(ii)	By fax or telephone within 2 working days after starting actions inconsistent with the plan followed by a letter within 7 working days after the end of the event unless you have made alternative arrangements with the permitting authority.

TABLE 7 TO SUBPART LLLLL OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART LLLLL

Citation	Subject	Brief description	Applies to subpart LLLLL
§ 63.1	Applicability	Initial Applicability Determination; Applicability After Standard Established; Permit Requirements; Extensions, Notifications.	Yes.
§ 63.2	Definitions	Definitions for part 63 standards	Yes.
§ 63.3	Units and Abbreviations	Units and abbreviations for part 63 standards.	Yes.
§ 63.4	Prohibited Activities	Prohibited Activities; Compliance date; Circumvention, Severability.	Yes.
§ 63.5	Construction/Reconstruction	Applicability; applications; approvals	Yes.
§ 63.6(a)	Applicability	GP apply unless compliance extension GP apply to area sources that become major.	Yes.
§ 63.6(b)(1)–(4)	Compliance Dates for New and Reconstructed sources.	Standards apply at effective date; 3 years after effective date; upon startup; 10 years after construction or reconstruction commences for section 112(f).	Yes.
§ 63.6(b)(5)	Notification	Must notify if commenced construction or reconstruction after proposal.	Yes.
§ 63.6(b)(6)	[Reserved].		
§ 63.6(b)(7)	Compliance Dates for New and Reconstructed Area Sources That Become Major.	Area sources that become major must comply with major source standards immediately upon becoming major, regardless of whether required to comply when they were an area source.	Yes.
§ 63.6(c)(1)–(2)	Compliance Dates for Existing Sources.	1. Comply according to date in subpart, which must be no later than 3 years after effective date. 2. For section 112(f) standards, comply within 90 days of effective date unless compliance extension has been granted.	Yes.
§ 63.6(c)(3)–(4)	[Reserved].		
§ 63.6(c)(5)	Compliance Dates for Existing Area Sources That Become Major.	Area sources that become major must comply with major source standards by date indicated in subpart or by equivalent time period (for example, 3 years).	Yes.
§ 63.6(d)	[Reserved].		

Citation	Subject	Brief description	Applies to subpart LLLLL
§ 63.6(e)(1)	Operation & Maintenance	1. Operate to minimize emissions at all times. 2. Correct malfunctions as soon as practicable. 3. Operation and maintenance requirements independently enforceable; information Administrator will use to determine if operation and maintenance requirements were met.	Yes.
§ 63.6(e)(2)	[Reserved].		
§ 63.6(e)(3)	Startup, Shutdown, and Malfunction (SSM) Plan (SSMP).	1. Requirement for SSM and startup, shutdown, malfunction plan. 2. Content of SSMP	Yes.
§ 63.6(f)(1)	Compliance Except During SSM	You must comply with emission standards at all times except during SSM.	Yes.
§ 63.6(f)(2)–(3)	Methods for Determining Compliance	Compliance based on performance test, operation and maintenance plans, records, inspection.	Yes.
§ 63.6(g)(1)–(3)	Alternative Nonopacity Standard	Procedures for getting an alternative nonopacity standard.	Yes.
§ 63.6(h)	Opacity/Visible Emission (VE) Standards.	Requirements for opacity and VE limits.	Yes.
§ 63.6(h)(1)	Compliance with Opacity/VE Standards.	You must comply with opacity/VE emission limitations at all times except during SSM.	Yes.
§ 63.6(h)(2)(i)	Determining Compliance with Opacity/VE Standards.	If standard does not state test method, use EPA test method 9, 40 CFR 60, appendix A for opacity and EPA test method 22, 40 CFR 60, appendix A for VE.	No. The test methods for opacity and visible emissions are specified in § 63.8687.
§ 63.6(h)(2)(ii)	[Reserved].		
§ 63.6(h)(2)(iii)	Using Previous Tests to Demonstrate Compliance with Opacity/VE Standards.	Criteria for when previous opacity/VE testing can be used to show compliance with this rule.	Yes.
§ 63.6(h)(3)	[Reserved].		
§ 63.6(h)(4)	Notification of Opacity/VE Observation Date.	Must notify Administrator of anticipated date of observation.	Yes.
§ 63.6(h)(5)(i), (iii)–(v)	Conducting Opacity/VE Observations	Dates and Schedule for conducting opacity/VE observations.	Yes.
§ 63.6(h)(5)(ii)	Opacity Test Duration and Averaging Times.	Must have at least 3 hours of observation with thirty 6-minute averages.	Yes.
§ 63.6(h)(6)	Records of Conditions During Opacity/VE Observations.	Must keep records available and allow Administrator to inspect.	Yes.
§ 63.6(h)(7)(i)	Report COMS Monitoring Data from Performance Test.	Must submit COMS data with other performance test data.	Yes, if COMS used.
§ 63.6(h)(7)(ii)	Using COMS instead of EPA test method 9, 40 CFR 60, appendix A.	Can submit COMS data instead of EPA test method 9, 40 CFR 60, appendix A results even if rule requires EPA test method 9, 40 CFR 60, appendix A, but must notify Administrator before performance test.	Yes, if COMS used.
§ 63.6(h)(7)(iii)	Averaging time for COMS during performance test.	To determine compliance, must reduce COMS data to 6-minute averages.	Yes, if COMS used.
§ 63.6(h)(7)(iv)	COMS requirements	Owner/operator must demonstrate that COMS performance evaluations are conducted according to § 63.8(e), COMS are properly maintained and operated according to § 63.8(c) and data quality as § 63.8(d).	Yes, if COMS used.
§ 63.6(h)(7)(v)	Determining Compliance with Opacity/VE Standards.	COMS is probative but not conclusive evidence of compliance with opacity standard, even if EPA test method 9, 40 CFR 60, appendix A observation shows otherwise. Requirements for COMS to be probative evidence, proper maintenance, meeting PS 1, and data have not been altered.	Yes, if COMS used.

Citation	Subject	Brief description	Applies to subpart LLLLL
§ 63.6(h)(8)	Determining Compliance with Opacity/VE Standards.	Administrator will use all COMS, EPA test method 9, 40 CFR 60, appendix A, and EPA test method 22, 40 CFR 60, appendix A results, as well as information about operation and maintenance to determine compliance.	Yes.
§ 63.6(h)(9)	Adjusted Opacity Standard	Procedures for Administrator to adjust an opacity standard.	Yes.
§ 63.6(i)	Compliance Extension	Procedures and criteria for Administrator to grant compliance extension.	Yes.
§ 63.6(j)	Presidential Compliance Exemption	President may exempt source category from requirement to comply with rule.	Yes.
§ 63.7(a)(1)–(2)	Performance Test Dates	Dates for conducting initial performance testing and other compliance demonstrations. Must conduct 180 days after first subject to rule.	Yes.
§ 63.7(a)(3)	Section 114 Authority	Administrator may require a performance test under CAA section 114 at any time.	Yes.
§ 63.7(b)(1)	Notification of Performance Test	Must notify Administrator 60 days before the test.	Yes.
§ 63.7(b)(2)	Notification of Rescheduling	If rescheduling a performance test is necessary, must notify Administrator 5 days before scheduled date of rescheduled date.	Yes.
§ 63.7(c)	Quality Assurance/Test Plan	1. Requirement to submit site-specific test plan 60 days before the test or on date Administrator agrees with: 2. Test plan approval procedures 3. Performance audit requirements 4. Internal and external QA procedures for testing.	Yes.
§ 63.7(d)	Testing Facilities	Requirements for testing facilities	Yes.
§ 63.7(e)(1)	Conditions for Conducting Performance Tests.	1. Performance tests must be conducted under representative conditions. Cannot conduct performance tests during SSM. 2. Not a violation to exceed standard during SSM.	Yes.
§ 63.7(e)(2)	Conditions for Conducting Performance Tests.	Must conduct according to rule and EPA test methods unless Administrator approves alternative.	Yes.
§ 63.7(e)(3)	Test Run Duration	1. Must have three test runs of at least 1 hour each. 2. Compliance is based on arithmetic mean of three runs. 3. Conditions when data from an additional test run can be used.	Yes.
§ 63.7(f)	Alternative Test Method	Procedures by which Administrator can grant approval to use an alternative test method.	Yes.
§ 63.7(g)	Performance Test Data Analysis	1. Must include raw data in performance test report. 2. Must submit performance test data 60 days after end of test with the Notification of Compliance Status. 3. Keep data for 5 years	Yes.
§ 63.7(h)	Waiver of Tests	Procedures for Administrator to waive performance test.	Yes.
§ 63.8(a)(1)	Applicability of Monitoring Requirements.	Subject to all monitoring requirements in standard.	Yes.
§ 63.8(a)(2)	Performance Specifications	Performance Specifications in appendix B of part 60 apply.	Yes, if CEMS used.
§ 63.8(a)(3)	[Reserved]		
§ 63.8(a)(4)	Monitoring with Flares	Unless your rule says otherwise, the requirements for flares in § 63.11 apply.	Yes.
§ 63.8(b)(1)	Monitoring	Must conduct monitoring according to standard unless Administrator approves alternative.	Yes.

Citation	Subject	Brief description	Applies to subpart LLLLL
§ 63.8(b) (2)–(3)	Multiple Effluents and Multiple Monitoring Systems.	1. Specific requirements for installing monitoring systems. 2. Must install on each effluent before it is combined and before it is released to the atmosphere unless Administrator approves otherwise. 3. If more than one monitoring system on an emission point, must report all monitoring system results, unless one monitoring system is a backup.	Yes.
§ 63.8(c)(1)	Monitoring System Operation and Maintenance.	Maintain monitoring system in a manner consistent with good air pollution control practices.	Yes.
§ 63.8(c)(1)(i)	Routine and predictable CMS malfunction.	1. Keep parts for routine repairs readily available. 2. Reporting requirements for CMS malfunction when action is described in SSM plan.	Yes.
§ 63.8(c)(1)(ii)	CMS malfunction not in SSP plan	Reporting requirements for CMS malfunction when action is not described in SSM plan.	Yes.
§ 63.8(c)(1)(iii)	Compliance with Operation and Maintenance Requirements.	1. How Administrator determines if source complying with operation and maintenance requirements. 2. Review of source O&M procedures, records, manufacturer's instructions, recommendations, and inspection of monitoring system.	Yes.
§ 63.8(c)(2)–(3)	Monitoring System Installation	1. Must install to get representative emission and parameter measurements. 2. Must verify operational status before or at performance test.	Yes.
§ 63.8(c)(4)	CMS Requirements	CMS must be operating except during breakdown, out-of-control, repair, maintenance, and high-level calibration drifts.	No; § 63.8690 specifies the CMS requirements.
§ 63.8(c)(4)(i)–(ii)	CMS Requirements	1. COMS must have a minimum of one cycle of sampling and analysis for each successive 10-second period and one cycle of data recording for each successive 6-minute period. 2. CEMS must have a minimum of one cycle of operation for each successive 15-minute period.	Yes, if COMS used.
§ 63.8(c)(5)	COMS Minimum Procedures	COMS minimum procedures	Yes.
§ 63.8(c)(6)	CMS Requirements	Zero and High level calibration check requirements.	No; § 63.8688 specifies the CMS requirements.
§ 63.8(c)(7)–(8)	CMS Requirements	Out-of-control periods, including reporting.	Yes.
§ 63.8(d)	CMS Quality Control	1. Requirements for CMS quality control, including calibration, etc. 2. Must keep quality control plan on record for the life of the affected source. 3. Keep old versions for 5 years after revisions.	No; § 63.8688 specifies the CMS requirements.
§ 63.8(e)	CMS Performance Evaluation	Notification, performance evaluation test plan, reports.	No; § 63.8688 specifies the CMS requirements.
§ 63.8(f)(1)–(5)	Alternative Monitoring Method	Procedures for Administrator to approve alternative monitoring.	Yes.
§ 63.8(f)(6)	Alternative to Relative Accuracy Test	Procedures for Administrator to approve alternative relative accuracy tests for CEMS.	Yes, if CEMS used.
§ 63.8(g)(1)–(4)	Data Reduction	1. COMS 6-minute averages calculated over at least 36 evenly spaced data points. 2. CEMS 1-hour averages computed over at least 4 equally spaced data points.	Yes, if CEMS or COMS used.

Citation	Subject	Brief description	Applies to subpart LLLLL
§ 63.8(g)(5)	Data Reduction	Data that cannot be used in computing averages for CMS.	No; § 63.8690 specifies the CMS requirements.
§ 63.9(a)	Notification Requirements	Applicability and State Delegation	Yes.
§ 63.9(b)(1)–(5)	Initial Notifications	1. Submit notification 120 days after effective date. 2. Notification of intent to construct/reconstruct; notification of commencement of construct/reconstruct; notification of startup. 3. Contents of each	Yes.
§ 63.9(c)	Request for Compliance Extension	Can request if cannot comply by date or if installed Best Achievable Control Technology (BACT)/Lowest Achievable Emission Rate (LAER).	Yes.
§ 63.9(d)	Notification of Special Compliance Requirements for New Source.	For sources that commence construction between proposal and promulgation and want to comply 3 years after effective date.	Yes.
§ 63.9(e)	Notification of Performance Test	Notify Administrator 60 days prior	Yes.
§ 63.9(f)	Notification of VE/Opacity Test	Notify Administrator 30 days prior	Yes.
§ 63.9(g)	Additional Notifications When Using CMS.	1. Notification of performance evaluation. 2. Notification using COMS data 3. Notification that the criterion for use of alternative to relative accuracy testing was exceeded.	No; § 63.8692 specifies the CMS notification requirements.
§ 63.9(h)(1)–(6)	Notification of Compliance Status	1. Contents. 2. Due 60 days after end of performance test or other compliance demonstration, except for opacity/VE, which are due 30 days after. 3. When to submit to Federal vs. State authority.	Yes.
§ 63.9(i)	Adjustment of Submittal Deadlines	Procedures for Administrator to approve change in dates when notifications must be submitted.	Yes.
§ 63.9(j)	Change in Previous Information	Must submit within 15 days after the change.	Yes.
§ 63.10(a)	Recordkeeping/Reporting	1. Applies to all, unless compliance extension. 2. When to submit to Federal vs. State authority. 3. Procedures for owners of more than 1 source.	Yes.
§ 63.10(b)(1)	Recordkeeping/Reporting	1. General Requirements 2. Keep all records readily available. 3. Keep for 5 years	Yes.
§ 63.10(b)(2)(i)–(v)	Records related to Startup, Shutdown, and Malfunction.	1. Occurrence of each of operation (process equipment). 2. Occurrence of each malfunction of air pollution equipment. 3. Maintenance on air pollution control equipment. 4. Actions during startup, shutdown, and malfunction.	Yes.
§ 63.10(b)(2)(vi) and (x–xi).	CMS Records	1. Malfunctions, inoperative, out-of-control. 2. Calibration checks 3. Adjustments, maintenance	Yes.
§ 63.10(b)(2)(vii)–(ix)	Records	1. Measurements to demonstrate compliance with emission limitations. 2. Performance test, performance evaluation, and visible emission observation results. 3. Measurements to determine conditions of performance tests and performance evaluations.	Yes.
§ 63.10(b)(2)(xii)	Records	Records when under waiver	Yes
§ 63.10(b)(2)(xiii)	Records	Records when using alternative to relative accuracy test.	Yes.

Citation	Subject	Brief description	Applies to subpart LLLLL
§ 63.10(b)(2)(xiv)	Records	All documentation supporting Initial Notification and Notification of Compliance Status.	Yes.
§ 63.10(b)(3)	Records	Applicability determinations	Yes.
§ 63.10(c)(1)–(6), (9)–(15).	Records	Additional records for CMS	No; § 63.8694 specifies the CMS recordkeeping requirements.
§ 63.10(c)(7)–(8)	Records	Records of excess emissions and parameter monitoring exceeedances for CMS.	No; § 63.8694 specifies the CMS recordkeeping requirements.
§ 63.10(d)(1)	General Reporting Requirements	Requirement to report	Yes.
§ 63.10(d)(2)	Report of Performance Test Results	When to submit to Federal or State authority.	Yes.
§ 63.10(d)(3)	Reporting Opacity or VE Observations	What to report and when	Yes.
§ 63.10(d)(4)	Progress Reports	Must submit progress reports on schedule if under compliance extension.	Yes.
§ 63.10(d)(5)	Startup, Shutdown, and Malfunction Reports.	Contents and submission	Yes.
§ 63.10(e)(1), (2)	Additional CMS Reports	1. Must report results for each CEM on a unit. 2. Written copy of performance evaluation. 3. Three copies of COMS performance evaluation.	Yes.
§ 63.10(e)(3)	Reports	Excess emission reports	No; § 63.8693 specifies the reporting requirements.
§ 63.10(e)(3)(i)–(iii)	Reports	Schedule for reporting excess emissions and parameter monitor exceedances (now defined as deviations).	No; § 63.8693 specifies the reporting requirements.
§ 63.10(e)(3)(iv)–(v)	Excess Emissions Reports	1. Requirement to revert to the frequency specified in the relevant standard if there is an excess emissions and parameter monitor exceedances (now defined as deviations). 2. Provision to request semiannual reporting after compliance for one year. 3. Submit report by 30th day following end of quarter or calendar half. 4. If there has not been an exceedance or excess emission (now defined as deviations), report content is a statement that there have been no deviations.	No; § 63.8693 specifies the reporting requirements.
§ 63.10(e)(3)(iv)–(v)	Excess Emissions Reports	Must submit report containing all of the information in § 63.10(c)(5)(13), § 63.8(c)(7)–(8).	No; § 63.8693 specifies the reporting requirements.
§ 63.10(e)(3)(vi)–(viii)	Excess Emissions Report and Summary Report.	1. Requirements for reporting excess emissions for CMS (now called deviations). 2. Requires all of the information in § 63.10(c)(5)(13), § 63.8(c)(7)–(8).	No; § 63.8693 specifies the reporting requirements.
§ 63.10(e)(4)	Reporting COMS data	Must submit COMS data with performance test data.	Yes, if COMS used.
§ 63.10(f)	Waiver for Recordkeeping/Reporting	Procedures for Administrator to waive	Yes.
§ 63.11	Flares	Requirements for flares	Yes.
§ 63.12	Delegation	State authority to enforce standards	Yes.
§ 63.13	Addresses	Addresses where reports, notifications, and requests are sent.	Yes.
§ 63.14	Incorporation by Reference	Test methods incorporated by reference.	Yes.
§ 63.15	Availability of Information	Public and confidential information	Yes.

[68 FR 24577, May 7, 2003, as amended at 71 FR 20469, Apr. 20, 2006]

Subpart MMMMM—National Emission Standards for Hazardous Air Pollutants: Flexible Polyurethane Foam Fabrication Operations

SOURCE: 68 FR 18070, Apr. 14, 2003, unless otherwise noted.

WHAT THIS SUBPART COVERS

§63.8780 What is the purpose of this subpart?

This subpart establishes national emission standards for hazardous air pollutants (NESHAP) emitted from flexible polyurethane foam fabrication operations. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission standards.

§63.8782 Am I subject to this subpart?

(a) You are subject to this subpart if you own or operate a flexible polyurethane foam fabrication plant site that operates a flame lamination affected source, as defined at §63.8784(b)(2), and that is located at, or is part of a major emission source of hazardous air pollutants (HAP) or that operates a loop slitter affected source, as defined at §63.8784(b)(1), that meets the criteria in paragraphs (a)(1) and (2) of this section.

(1) The loop slitter affected source uses one or more HAP-based adhesives at any time on or after April 14, 2003.

(2) The loop slitter affected source is located at or is part of a major source of HAP.

(b) A flexible polyurethane foam fabrication plant site is a plant site where pieces of flexible polyurethane foam are bonded together or to other substrates using HAP-based adhesives or flame lamination.

(c) A major source of HAP is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons or more per year or any combination of HAP at a rate of 25 tons or more per year.

(d) This subpart does not apply to the following processes in paragraphs (d)(1) and (2) of this section:

(1) Processes that produce flexible polyurethane or rebond foam as defined in subpart III of this part.

(2) A research and development facility, as defined in section 112(c)(7) of the Clean Air Act (CAA).

§63.8784 What parts of my plant does this subpart cover?

(a) This subpart applies to each existing, new, or reconstructed affected source at facilities engaged in flexible polyurethane foam fabrication.

(b) The affected sources are defined in this section in paragraphs (b)(1) and (2) of this section.

(1) The loop slitter adhesive use affected source is the collection of all loop slitters and associated adhesive application equipment used to apply HAP-based adhesives to bond foam to foam at a flexible polyurethane foam fabrication plant site.

(2) The flame lamination affected source is the collection of all flame lamination lines associated with the flame lamination of foam to any substrate at a flexible polyurethane foam fabrication plant site.

(c)(1) A new affected source is one that commences construction after August 8, 2001 and meets the applicability criteria of §63.8782 at the time construction commences.

(2) If you add one or more flame lamination lines at a plant site where flame lamination lines already exist, the added line(s) shall be a new affected source and meet new source requirements if the added line(s) has the potential to emit 10 tons per year or more of any HAP or 25 tons or more per year of any combination of HAP.

(d) A reconstructed affected source is one that commences reconstruction after August 8, 2001 and meets the criteria for reconstruction as defined in §63.2.

(e) For each new or reconstructed flame lamination affected source, you must develop a written startup, shutdown, and malfunction plan according to the provisions in §63.6(e)(3).

[68 FR 18070, Apr. 14, 2003, as amended at 71 FR 20470, Apr. 20, 2006]

§ 63.8786 When do I have to comply with this subpart?

(a) If you have a new or reconstructed affected source, you must comply with this subpart according to paragraphs (a)(1) and (2) of this section.

(1) If you start up your new or reconstructed affected source before April 14, 2003, then you must comply with the emission standards for new or reconstructed sources in this subpart no later than April 14, 2003.

(2) If you start up your new or reconstructed affected source on or after April 14, 2003, then you must comply with the emission standards for new or reconstructed sources in this subpart upon startup of your affected source.

(b) If you have an existing loop slitter affected source, you must comply with the emission standards for existing sources no later than 1 year after April 14, 2003.

(c) If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP and an affected source subject to this subpart, the provisions in paragraphs (c)(1) and (2) of this section apply.

(1) A new affected source as specified at § 63.8784(c) or a reconstructed affected source as specified at § 63.8784(d) must be in compliance with this subpart upon startup.

(2) An existing affected source as specified at § 63.8784(e) must be in compliance with this subpart no later than 1 year after the date on which the area source became a major source.

(d) You must meet the notification requirements in § 63.8816 according to the schedule in § 63.8816 and in subpart A of this part. Some of the notifications must be submitted before you are required to comply with the emission standards in this subpart.

(e) If you have a loop slitter affected source, you must have data on hand beginning on the compliance date specified in paragraph (b) of this section as necessary to demonstrate that your adhesives are not HAP-based. The types of data necessary are described in §§ 63.8802 and 63.8810.

EMISSION LIMITATIONS

§ 63.8790 What emission limitations must I meet?

(a) You must meet each emission limit in Table 1 to this subpart that applies to you.

(b) You must meet each operating limit in Table 2 to this subpart that applies to you.

GENERAL COMPLIANCE REQUIREMENTS

§ 63.8794 What are my general requirements for complying with this subpart?

(a) For each loop slitter adhesive use affected source, you must be in compliance with the requirements in this subpart at all times.

(b) For each new or reconstructed flame lamination affected source, you must be in compliance with the requirements in this subpart at all times, except during periods of startup, shutdown, and malfunction.

(c) You must always operate and maintain your affected source, including air pollution control and monitoring equipment, according to the provisions in § 63.6(e)(1)(i).

(d) During the period between the compliance date specified for your new or reconstructed flame lamination affected source in § 63.8786, and the date upon which continuous compliance monitoring systems have been installed and verified and any applicable operating limits have been set, you must maintain a log detailing the operation and maintenance of the process and emissions control equipment.

(e) For each new or reconstructed flame lamination affected source, you must develop a written startup, shutdown, and malfunction plan according to the provisions in § 63.6(e)(3).

(f) For each monitoring system required in this section for new or reconstructed flame lamination sources, you must develop and submit for approval a site-specific monitoring plan that addresses the requirements in paragraphs (f)(1) through (3) of this section.

(1) Installation of the continuous monitoring system (CMS) sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the

exhaust emissions (*e.g.*, on or downstream of the last control device);

(2) Performance and equipment specifications for the sample interface, the pollutant concentration or parametric signal analyzer, and the data collection and reduction system; and

(3) Performance evaluation procedures and acceptance criteria (*e.g.*, calibrations).

(g) In your site-specific monitoring plan, you must also address the ongoing procedures specified in paragraphs (g)(1) through (3) of this section.

(1) Ongoing operation and maintenance procedures in accordance with the general requirements of §§63.8(c)(1), (3), (4)(ii), (7), and (8), and 63.8804;

(2) Ongoing data quality assurance procedures in accordance with the general requirements of §63.8(d); and

(3) Ongoing recordkeeping and reporting procedures in accordance with the general requirements of §63.10(c), (e)(1), and (e)(2)(i).

[68 FR 18070, Apr. 14, 2003, as amended at 71 20470, Apr. 20, 2006]

TESTING AND INITIAL COMPLIANCE REQUIREMENTS

§63.8798 By what date must I conduct performance tests or other initial compliance demonstrations?

(a) For each loop slitter affected source, you must conduct the initial compliance demonstration by the compliance date that is specified for your source in §63.8786.

(b) For each new or reconstructed flame lamination affected source, you must conduct performance tests within 180 calendar days after the compliance date that is specified for your source in §63.8786 and according to the provisions in §63.7(a)(2).

§63.8800 What performance tests and other procedures must I use to demonstrate compliance with the emission limit for flame lamination?

(a) You must conduct each performance test in Table 3 to this subpart that applies to you.

(b) Each performance test must be conducted according to the requirements in §63.7(e)(1) and under the specific conditions in Table 3 to this subpart.

(c) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in §63.7(e)(1).

(d) You must conduct at least three separate test runs for each performance test required in this section, as specified in §63.7(e)(3). Each test run must last at least 1 hour.

(e) You must determine the percent reduction of HAP emissions during the performance test according to paragraphs (e)(1) through (3) of this section.

(1) If you use chlorinated fire retardant foams, determine the percent reduction of HCl to represent HAP emissions from the source. If you do not use chlorinated fire retardant foams, determine the percent reduction of HCN to represent HAP emissions from the source.

(2) Calculate the concentration of HAP at the control device inlet and at the control device outlet using the procedures in the specified test method.

(3) Compare the calculated HAP concentration at the control device inlet to the calculated HAP concentration at the control device outlet to determine the percent reduction over the period of the performance test, using Equation 1 of this section:

$$R=\frac{\sum_{i=1}^{n} E_{inlet,\,i}-\sum_{i=1}^{n} E_{outlet,\,i}}{\sum_{i=1}^{n} E_{inlet,\,i}}(100) \quad \text{[Eq. 1]}$$

Where:

R=Efficiency of control device, percent.

$E_{inlet,i}$=HAP concentration of control device inlet stream for test run i, mg/dscm.

$E_{outlet,i}$=HAP concentration of control device outlet stream for test run i, mg/dscm.

n=Number of runs conducted for the performance test.

(f) You must also meet the requirements in paragraphs (f)(1) and (2) of this section.

(1) Conduct the performance tests using foams that are representative of foams typically used at your flame lamination affected source. If you use foams containing chlorinated fire retardants, you must conduct the performance tests using these foams.

(2) Establish all applicable operating limits that correspond to the control

system efficiency as described in Table 3 to this subpart.

§ 63.8802 What methods must I use to demonstrate compliance with the emission limitation for loop slitter adhesive use?

(a) *Determine the HAP content for each material used.* To determine the HAP content for each material used in your foam fabrication operations, you must use one of the options in paragraphs (a)(1) through (3) of this section. If you use the option in paragraph (a)(3) of this section, you are subject to the provisions of paragraph (a)(4) of this section.

(1) *Method 311 (appendix A to 40 CFR part 63).* You may use Method 311 for determining the mass fraction of HAP. Use the procedures specified in paragraphs (a)(1)(i) and (ii) of this section when determining HAP content by Method 311.

(i) Include in the HAP total each HAP that is measured to be present at 0.1 percent by mass or more for Occupational Safety and Health Administration (OSHA)-defined carcinogens as specified in 29 CFR 1910.1200(d)(4) and at 1.0 percent by mass or more for other compounds. For example, if toluene (not an OSHA carcinogen) is measured to be 0.5 percent of the material by mass, you do not need to include it in the HAP total. Express the mass fraction of each HAP you measure as a value truncated to four places after the decimal point (for example, 0.1234).

(ii) Calculate the total HAP content in the test material by adding up the individual HAP contents and truncating the result to three places after the decimal point (for example, 0.123).

(2) *Alternative method.* You may use an alternative test method for determining mass fraction of HAP if you obtain prior approval by the Administrator. You must follow the procedure in § 63.7(f) to submit an alternative test method for approval.

(3) *Information from the supplier or manufacturer of the material.* You may rely on information other than that generated by the test methods specified in paragraphs (a)(1) and (2) of this section to determine the mass fraction of HAP according to paragraphs (a)(3)(i) and (ii) of this section. This information may include, but is not limited to, a material safety data sheet (MSDS), a certified product data sheet (CPDS), or a manufacturer's hazardous air pollutant data sheet.

(i) Include in the HAP total each HAP that is present at 0.1 percent by mass or more for OSHA-defined carcinogens as specified in 29 CFR 1910.1200(d)(4) and at 1.0 percent by mass or more for other compounds. For example, if toluene (not an OSHA carcinogen) is 0.5 percent of the material by mass, you do not have to include it in the HAP total.

(ii) If the HAP content is provided by the material supplier or manufacturer as a range, then you must use the upper limit of the range for determining compliance.

(4) *Verification of supplier or manufacturer information.* Although you are not required to perform testing to verify the information obtained according to paragraph (a)(3) of this section, the Administrator may require a separate measurement of the total HAP content using the methods specified in paragraph (a)(1) or (2) of this section. If this measurement exceeds the total HAP content provided by the material supplier or manufacturer, then you must use the measured HAP content to determine compliance.

(b) [Reserved]

§ 63.8806 How do I demonstrate initial compliance with the emission limitations?

(a) You must demonstrate initial compliance with each emission limit that applies to you according to Table 4 to this subpart.

(b) You must establish each site-specific operating limit in Table 2 to this subpart that applies to you according to the requirements in § 63.8800 and Table 3 to this subpart.

(c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in § 63.8816(e) through (h).

CONTINUOUS COMPLIANCE REQUIREMENTS

§63.8810 How do I monitor and collect data to demonstrate continuous compliance?

(a) If you own or operate a loop slitter adhesive use affected source, you must meet the requirements in paragraphs (a)(1) and (2) of this section.

(1) Maintain a list of each adhesive and the manufacturer or supplier of each.

(2) Maintain a record of EPA Method 311 (appendix A to 40 CFR part 63), approved alternative method, or other reasonable means of HAP content determinations indicating the mass percent of each HAP for each adhesive.

(b) If you own or operate a new or reconstructed flame lamination affected source, you must meet the requirements in paragraphs (b)(1) through (3) of this section if you use a scrubber, or paragraph (b)(4) of this section if you use any other control device.

(1) Keep records of the daily average scrubber inlet liquid flow rate.

(2) Keep records of the daily average scrubber effluent pH.

(3) If you use a venturi scrubber, keep records of daily average pressure drop across the venturi.

(4) Keep records of operating parameter values for each operating parameter that applies to you.

(c) If you own or operate a new or reconstructed flame lamination affected source, you must meet the requirements in paragraphs (c)(1) through (4) of this section.

(1) Except for periods of monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), you must monitor continuously (or collect data at all required intervals) at all times that the affected source is operating. This includes periods of startup, shutdown, and malfunction when the affected source is operating. A monitoring malfunction includes, but is not limited to, any sudden, infrequent, not reasonably preventable failure of the monitoring device to provide valid data. Monitoring failures that are caused by poor maintenance or careless operation are not malfunctions.

(2) In data average calculations and calculations used to report emission or operating levels, you may not use data recorded during monitoring malfunctions, associated repairs, or recorded during required quality assurance or control activities. Nor may such data be used in fulfilling any applicable minimum data availability requirement. You must use all the data collected during all other periods in assessing the operation of the control device and associated control system.

(3) You must conduct a performance evaluation of each CMS in accordance with your site-specific monitoring plan.

(4) You must operate and maintain the CMS in continuous operation according to the site-specific monitoring plan.

§63.8812 How do I demonstrate continuous compliance with the emission limitations?

(a) You must demonstrate continuous compliance with each emission limit and operating limit in Tables 1 and 2 to this subpart that applies to you according to the methods specified in Table 5 to this subpart.

(b) You must report each instance in which you did not meet each emission limit and each operating limit in Tables 1 and 2 to this subpart that apply to you. For new or reconstructed flame lamination affected sources, this includes periods of startup, shutdown, and malfunction. These instances are deviations from the operating limits in this subpart. These deviations must be reported according to the requirements in §63.8818.

(c) [Reserved]

(d) Consistent with §§63.6(e) and 63.7(e)(1), deviations that occur at a new or reconstructed flame lamination affected source during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the Administrator's satisfaction that you were operating in accordance with §63.6(e)(1). The Administrator will determine whether deviations that occur at a new or reconstructed flame lamination affected source during a period of startup, shutdown, or malfunction are violations, according to the provisions in §63.6(e).

(e) You also must meet the following requirements if you are complying with the adhesive use ban for loop slitter adhesive use described in § 63.8790(a).

(1) If, after you submit the Notification of Compliance Status, you use an adhesive for which you have not previously verified percent HAP mass using the methods in § 63.8802, you must verify that each adhesive used in the affected source meets the emission limit, using any of the methods in § 63.8802.

(2) You must update the list of all the adhesives used at the affected source.

(3) With the compliance report for the reporting period during which you used the new adhesive, you must submit the updated list of all adhesives and a statement certifying that, as purchased, each adhesive used at the affected source during the reporting period met the emission limit in Table 1 to this subpart.

[68 FR 18070, Apr. 14, 2003, as amended at 71 FR 20470, Apr. 20, 2006]

NOTIFICATION, REPORTS, AND RECORDS

§ 63.8816 What notifications must I submit and when?

(a) You must submit all of the notifications in §§ 63.7(b) and (c), 63.8(f), and 63.9(b) through (h) that apply to you.

(b) If you own or operate an existing loop slitter or flame lamination affected source, submit an initial notification no later than 120 days after April 14, 2003.

(c) If you own or operate a new or reconstructed loop slitter or flame lamination affected source, submit the application for construction or reconstruction required by § 63.9(b)(1)(iii) in lieu of the initial notification.

(d) If you own or operate a new or reconstructed flame lamination affected source, submit a notification of intent to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin, as required in § 63.7(b)(1).

(e) If you own or operate a loop slitter affected source, submit a Notification of Compliance Status according to § 63.9(h)(2)(ii) within 60 days of the compliance date specified in § 63.8786.

(f) If you own or operate a new or reconstructed flame lamination affected source, submit a Notification of Compliance Status according to § 63.9(h)(2)(ii) that includes the results of the performance test conducted according to the requirements in Table 3 to this subpart. You must submit the notification before the close of business on the 60th calendar day following the completion of the performance test according to § 63.10(d)(2).

(g) For each new or reconstructed flame lamination affected source, the Notification of Compliance Status must also include the information in paragraphs (g)(1) and (2) that applies to you.

(1) The operating parameter value averaged over the full period of the performance test (for example, average pH).

(2) The operating parameter range within which HAP emissions are reduced to the level corresponding to meeting the applicable emission limits in Table 1 to this subpart.

(h) For each loop slitter adhesive use affected source, the Notification of Compliance Status must also include the information listed in paragraphs (h)(1) and (2) of this section.

(1) A list of each adhesive used at the affected source, its HAP content (percent by mass), and the manufacturer or supplier of each.

(2) A statement certifying that each adhesive that was used at the affected source during the reporting period met the emission limit in Table 1 to this subpart.

§ 63.8818 What reports must I submit and when?

(a) You must submit each report in Table 6 to this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each compliance report for new or reconstructed flame lamination affected sources semiannually according to paragraphs (b)(1) through (4) of this section.

(1) The first compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.8786 and ending

on June 30 or December 31, whichever date is the first date following the end of the first calendar half after the compliance date that is specified for your source in §63.8786.

(2) The first compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first calendar half after the compliance date that is specified for your affected source in §63.8786.

(3) Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) Each subsequent compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(c) For each loop slitter adhesive use affected source, you may submit annual compliance reports in place of semiannual reports.

(d) For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (4) of this section.

(e) The compliance report must contain the information in paragraphs (e)(1) through (5) of this section.

(1) Company name and address.

(2) Statement by a responsible official with that official's name, title, and signature, certifying the truth, accuracy and completeness of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If there are no deviations from any emission limitations (emission limit or operating limit) that applies to you, a statement that there were no deviations from the emission limitations during the reporting period.

(5) For each deviation from an emission limitation that occurs, the compliance report must contain the information specified in paragraphs (e)(5)(i) through (iii) of this section.

(i) The total operating time of each affected source during the reporting period.

(ii) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(iii) Information on the number, duration, and cause for continuous parameter monitoring system (CPMS) downtime incidents, if applicable, other than downtime associated with zero and span and other daily calibration checks.

(f) The compliance report for a new or reconstructed flame lamination affected source must also contain the following information in paragraphs (f)(1) through (3) of this section.

(1) If you had a startup, shutdown or malfunction at your new or reconstructed flame lamination affected source during the reporting period and you took actions consistent with your startup, shutdown, and malfunction plan, the compliance report must include the information in §63.10(d)(5)(i).

(2) If there were no periods during which the CPMS was out-of-control in accordance with the monitoring plan, a statement that there were no periods during which the CPMS was out-of-control during the reporting period.

(3) If there were periods during which the CPMS was out-of-control in accordance with the monitoring plan, the date, time, and duration of each out-of-control period.

(g) The compliance report for a loop slitter adhesive use affected source must also contain the following information in paragraphs (g)(1) and (2) of this section.

(1) For each annual reporting period during which you use an adhesive that was not included in the list submitted with the Notification of Compliance Status in §63.8816(h) (1), an updated list of all adhesives used at the affected source.

(2) A statement certifying that each adhesive that was used at the affected source during the reporting period met

the emission limit in Table 1 to this subpart.

(h) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 40 CFR part 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a compliance report pursuant to Table 6 to this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all required information concerning deviations from any emission limitation (including any operating limit) in this subpart, submission of the compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority.

(i) For each startup, shutdown, or malfunction during the reporting period where the source does not meet the emission limitations set out in § 63.8790 that occurs at a new or reconstructed flame lamination affected source and that is not consistent with your startup, shutdown, and malfunction plan, you must submit an immediate startup, shutdown and malfunction report.

(1) An initial report containing a description of the actions taken for the event must be submitted by fax or telephone within 2 working days after starting actions inconsistent with the plan.

(2) A followup report containing the information listed in § 63.10(d)(5)(ii) must be submitted within 7 working days after the end of the event unless you have made alternative reporting arrangements with the permitting authority.

§ 63.8820 What records must I keep?

(a) You must keep a copy of each notification and report that you submit to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirements in § 63.10(b)(2)(xiv).

(b) For each new or reconstructed flame lamination affected source, you must also keep the following records specified in paragraphs (b)(1) through (4) of this section.

(1) The records in § 63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.

(2) Records of performance tests, as required in § 63.10(b)(2)(viii).

(3) Records of operating parameter values.

(4) Records of the date and time that each deviation started and stopped and whether the deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(c) For each loop slitter adhesive use affected source, you must keep the following records specified in paragraphs (c)(1) and (2) of this section.

(1) A list of each adhesive and the manufacturer or supplier of each.

(2) A record of EPA Method 311 (appendix A to 40 CFR part 63), approved alternative method, or other reasonable means of determining the mass percent of total HAP for each adhesive used at the affected source.

§ 63.8822 In what form and how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review, according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record on site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1). You can keep the records offsite for the remaining 3 years.

OTHER REQUIREMENTS AND INFORMATION

§ 63.8826 What parts of the General Provisions apply to me?

Table 7 to this subpart shows which sections of the General Provisions in §§ 63.1 through 63.15 apply to you.

§63.8828 Who implements and enforces this subpart?

(a) This subpart can be implemented and enforced by us, the U.S. Environmental Protection Agency (U.S. EPA), or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency, in addition to the U.S. EPA, has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out if implementation and enforcement of this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities in paragraphs (c)(1) through (4) that cannot be delegated to State, local, or tribal agencies are as follows:

(1) Approval of alternatives to requirements in §§63.8780, 63.8782, 63.8784, 63.8786, and 63.8790.

(2) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90.

(3) Approval of major alternatives to monitoring under §63.8(f) and as defined in §63.90.

(4) Approval of major alternatives to recordkeeping and reporting under §63.10(f) and as defined in §63.90.

§63.8830 What definitions apply to this subpart?

Terms used in this subpart are defined in the CAA, in 40 CFR 63.2, and in this section as follows:

Adhesive means any chemical substance that is applied for the purpose of bonding foam to foam, foam to fabric, or foam to any other substrate, other than by mechanical means. Products used on humans and animals, adhesive tape, contact paper, or any other product with an adhesive incorporated onto it in an inert substrate shall not be considered adhesives under this subpart.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emission limitation (including any operating limit); or

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or

(3) Fails to meet any emission limitation (including any operating limit) in this subpart during startup, shutdown, or malfunction, regardless of whether or not such failure is permitted by this subpart.

Emission limitation means any emission limit or operating limit.

Flame lamination means the process of bonding flexible foam to one or more layers of material by heating the foam surface with an open flame.

Flame lamination line means the flame laminator and associated rollers.

HAP-based adhesive means an adhesive containing 5 percent (by weight) or more of HAP, according to EPA Method 311 (appendix A to 40 CFR part 63) or another approved alternative.

Loop slitter means a machine used to create thin sheets of foam from the large blocks of foam or ''buns'' created at a slabstock flexible polyurethane foam production plant.

Research and development process means a laboratory or pilot plant operation whose primary purpose is to conduct research and development into new processes and products where the operations are under the close supervision of technically trained personnel, and which is not engaged in the manufacture of products for commercial sale, except in a *de minimis* manner.

Responsible official means responsible official as defined in 40 CFR 70.2.

TABLE 1 TO SUBPART MMMMM OF PART 63—EMISSION LIMITS

As stated in §63.8790(a), you must comply with the emission limits in the following table:

For . . .	You must . . .
1. Each existing, new, or reconstructed loop slitter adhesive use affected source.	Not use any HAP-based adhesives.
2. Each new or reconstructed flame lamination affected source	Reduce HAP emissions by 90 percent.
3. Each existing flame lamination affected sources	There are no emission limits for existing flame lamination sources. However, you must submit an initial notification per §63.8816(b).

TABLE 2 TO SUBPART MMMMM OF PART 63—OPERATING LIMITS FOR NEW OR RECONSTRUCTED FLAME LAMINATION AFFECTED SOURCES

As stated in §63.8790(b), you must comply with the operating limits in the following table:

For each . . .	You must . . .
1. Scrubber	a. Maintain the daily average scrubber inlet liquid flow rate above the minimum value established during the performance test. b. Maintain the daily average scrubber effluent pH within the operating range value established during the performance test. c. If you use a venturi scrubber, maintain the daily average pressure drop across the venturi within the operating range value established during the performance test.
2. Other type of control device to which flame lamination emissions are ducted.	Maintain your operating parameter(s) within the ranges established during the performance test and according to your monitoring plan.

TABLE 3 TO SUBPART MMMMM OF PART 63—PERFORMANCE TEST REQUIREMENTS FOR NEW OR RECONSTRUCTED FLAME LAMINATION AFFECTED SOURCES

As stated in §63.8800, you must comply with the requirements for performance tests for new or reconstructed flame lamination affected sources in the following table using the requirements in rows 1 through 5 of the table if you are measuring HCl and using a scrubber, row 6 if you are measuring HCN and using a scrubber, and row 7 if you are using any other control device.

For each new or reconstructed flame lamination affected source, you must . . .	Using . . .	According to the following requirements . . .
1. Select sampling port's location and the number of traverse ports.	Method 1 or 1A in appendix A to part 60 of this chapter.	Sampling sites must be located at the inlet and outlet of the scrubber and prior to any releases to the atmosphere.
2. Determine velocity	Method 2, 2A, 2C, 2D, 2F, or 2G in appendix A to part 60 of this chapter.	
3. Determine gas molecular weight.	Not applicable	Assume a molecular weight of 29 (after moisture correction) for calculation purposes.
4. Measure moisture content of the stack gas.	Method 4 in appendix A to part 60 of this chapter.	
5. Measure HCl concentration if you use chlorinated fire retardants in the laminated foam.	a. Method 26A in appendix A to part 60 of this chapter.	i. Measure total HCl emissions and determine the reduction efficiency of the control device using Method 26A. ii. Collect scrubber liquid flow rate, scrubber effluent pH, and pressure drop (pressure drop data only required for venturi scrubbers) every 15 minutes during the entire duration of each 1-hour test run, and determine the average scrubber liquid flow rate, scrubber effluent pH, and pressure drop (pressure drop data only required for Venturi scrubbers) over the period of the performance test by computing the average of all of the 15-minute readings.

For each new or reconstructed flame lamination affected source, you must . . .	Using . . .	According to the following requirements . . .
6. Measure HCN concentration if you do not use chlorinated fire retardants in the laminated foam.	a. A method approved by the Administrator.	i. Conduct the performance test according to the site-specific test plan submitted according to §63.7(c)(2)(i). Measure total HCN emissions and determine the reduction efficiency of the control device. Any performance test which measures HCN concentrations must be submitted for the administrator's approval prior to testing. You must use EPA Method 301 (40 CFR part 63, Appendix A) to validate your method. ii. Collect scrubber liquid flow rate, scrubber effluent pH, and pressure drop (pressure drop data only required for venturi scrubbers) every 15 minutes during the entire duration of each 1-hour test run, and determine the average scrubber liquid flow rate, scrubber effluent pH, and pressure drop (pressure drop data only required for venturi scrubbers) over the period of the performance test by computing the average of all of the 15-minute readings.
7. Determine control device efficiency and establish operating parameter limits with which you will demonstrate continuous compliance with the emission limit that applies to the source if you use any control device other than a scrubber.	a. EPA-approved methods and data from the continuous parameter monitoring system.	i. Conduct the performance test according to the site-specific test plan submitted according to §63.7(c)(2)(i). ii. Collect operating parameter data as specified in the site-specific test plan.

TABLE 4 TO SUBPART MMMMM OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITS

As stated in §63.8806, you must comply with the requirements to demonstrate initial compliance with the applicable emission limits in the following table:

For . . .	For the following emission limit . . .	You have demonstrated initial compliance if . . .
1. Each new, reconstructed, or existing loop slitter adhesive use affected source.	Eliminate use of HAP-based adhesives ..	You do not use HAP-based adhesives.
2. Each new or reconstructed flame lamination affected source using a scrubber.	Reduce HAP emissions by 90 percent ...	The average HAP emissions, measured over the period of the performance test(s), are reduced by 90 percent.
3. Each new or reconstructed flame lamination affected source using any other control device emissions by.	Reduce HAP emissions by 90 percent ...	The average HAP emissions, measured over the period of the performance test(s), are reduced by 90 percent.

TABLE 5 TO SUBPART MMMMM OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITS AND OPERATING LIMITS

As stated in §63.8812(a), you must comply with the requirements to demonstrate continuous compliance with the applicable emission limits or operating limits in the following table:

For . . .	For the following emission limits or operating limits . . .	You must demonstrate continuous compliance by . . .
1. Each new, reconstructed, or existing loop slitter affected source.	Eliminate use of HAP-based adhesives ..	Not using HAP-based adhesives.

For . . .	For the following emission limits or operating limits . . .	You must demonstrate continuous compliance by . . .
2. Each new or reconstructed flame lamination affected source using a scrubber.	a. Maintain the daily average scrubber inlet liquid flow rate above the minimum value established during the performance. b. Maintain the daily average scrubber effluent pH within the operating range established during the performance test. c. Maintain the daily average pressure drop across the venturi within the operating range established during the performance test. If you use another type of scrubber (*e.g.,* packed bed or spray tower scrubber), monitoring pressure drop is not required.	i. Collecting the scrubber inlet liquid flow rate and effluent pH monitoring data according to § 63.8804(a) through (c). ii. Reducing the data to 1-hour and daily block averages according to the requirements in § 63.8804(a). iii. Maintaining each daily average scrubber inlet liquid flow rate above the minimum value established during the performance test. iv. Maintaining the daily average scrubber effluent pH within the operating range established during the performance test. v. If you use a venturi scrubber, maintaining the daily average pressure drop across the venturi within the operating range established during the performance test.
3. Each new or reconstructed flame lamination affected source using any other control device.	a. Maintain the daily average operating parameters above the minimum value established during the performance test, or within the range established during the performance test, as applicable.	i. Collected the operating parameter data according to the site-specific test plan. ii. Reducing the data to one-hour averages according to the requirements in § 63.8804(a). iii. Maintaining the daily average during the rate above the minimum value established during the performance test, or within the range established during the performance test, as applicable.

TABLE 6 TO SUBPART MMMMM OF PART 63—REQUIREMENTS FOR REPORTS

As stated in § 63.8818(a), you must submit a compliance report that includes the information in § 63.8818(e) through (g) as well as the information in the following table. Rows 1 and 3 of the following table apply to loop slitter affected sources. Rows 1 through 5 apply to flame lamination affected sources. You must also submit startup, shutdown, and malfunction reports according to the requirements in the following table if you own or operate a new or reconstructed flame lamination affected source.

If . . .	Then you must submit a report or statement that . . .
1. There are no deviations from any emission limitations that apply to you.	There were no deviations from the emission limitations during the reporting period.
2. There were no periods during which the operating parameter monitoring systems were out-of-control in accordance with the monitoring plan.	There were no periods during which the CPMS were out-of-control during the reporting period.
3. There was a deviation from any emission limitation during the reporting period.	Contains the information in § 63.8818(e)(5).
4. There were periods during which the operating parameter monitoring systems were out-of-control in information in accordance with the monitoring plan.	Contains the information in § 63.8818(f)(3).
5. There was a startup, shutdown, or malfunction where the source did not meet the emission limitations set out in § 63.8790 at a new or reconstructed flame lamination affected source during the reporting period that is not consistent with your startup, shutdown, and malfunction plan..	Contains the information in § 63.8818(i).

TABLE 7 TO SUBPART MMMMM OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART MMMMM

As stated in § 63.8826, you must comply with the applicable General Provisions requirements according to the following table:

Citation	Requirement	Applies to subpart MMMMM	Explanation
§ 63.1	Initial applicability determination; applicability after standard established; permit requirements; extensions; notifications.	Yes.	
§ 63.2	Definitions	Yes	Additional definitions are found in § 63.8830.
§ 63.3	Units and abbreviations	Yes.	
§ 63.4	Prohibited activities; compliance date; circumvention, severability.	Yes.	
§ 63.5	Construction/reconstruction applicability; applications; approvals.	Yes.	
§ 63.6(a)	Compliance with standards and maintenance requirements-applicability.	Yes.	
§ 63.6(b)(1)–(4)	Compliance dates for new or reconstructed sources.	Yes	§ 63.8786 specifies compliance dates.
§ 63.6(b)(5)	Notification if commenced construction or reconstruction after proposal.	Yes.	
§ 63.6(b)(6)	[Reserved]	Yes.	
§ 63.6(b)(7)	Compliance dates for new or reconstructed area sources that become major.	Yes	§ 63.8786 specifies compliance dates.
§ 63.6(c)(1)–(2)	Compliance dates for existing sources.	Yes	§ 63.8786 specifies compliance dates.
§ 63.6(c)(3)–(4)	[Reserved]	Yes.	
§ 63.6(c)(5)	Compliance dates for existing area sources that become major.	Yes	§ 63.8786 specifies compliance dates.
§ 63.6(d)	[Reserved]	Yes.	
§ 63.6(e)(1)	Operation and maintenance requirements.	Yes.	
§ 63.6(e)(2)	[Reserved]	Yes.	
§ 63.6(e)(3)	Startup, shutdown, and malfunction plans.	Yes	Only applies to new or reconstructed flame lamination affected sources.
§ 63.6(f)(1)	Compliance except during SSM	Yes	Only applies to new or reconstructed flame lamination affected sources.
§ 63.6(f)(2)–(3)	Methods for determining compliance.	Yes.	
§ 63.6(g)	Use of an alternative nonopacity emission standard.	Yes.	
§ 63.6(h)	Compliance with opacity/visible emission standards.	No	Subpart MMMMM does not specify opacity or visible emission standards.
§ 63.6(i)	Extension of compliance with emission standards.	Yes.	
§ 63.6(j)	Presidential compliance exemption.	Yes.	
§ 63.7(a)(1)–(2)	Performance test dates	Yes	Except for loop slitter affected sources as specified in § 63.8798(a).
§ 63.7(a)(3)	Administrator's section 114 authority to require a performance test.	Yes.	
§ 63.7(b)	Notification of performance test and rescheduling.	Yes.	
§ 63.7(c)	Quality assurance program and site-specific test plans.	Yes.	
§ 63.7(d)	Performance testing facilities	Yes.	
§ 63.7(e)(1)	Conditions for conducting performance tests.	Yes.	
§ 63.7(f)	Use of an alternative test method.	Yes.	
§ 63.7(g)	Performance test data analysis, recordkeeping, and reporting.	Yes.	
§ 63.7(h)	Waiver of performance tests	Yes.	

Citation	Requirement	Applies to subpart MMMMM	Explanation
§ 63.8(a)(1)–(2)	Applicability of monitoring requirements.	Yes	Unless otherwise specified, all of § 63.8 applies only to new or reconstructed flame lamination sources. Additional monitoring requirements for these sources are found in §§ 63.8794(f) and (g) and 63.8804.
§ 63.8(a)(3)	[Reserved]	Yes.	
§ 63.8(a)(4)	Monitoring with flares	No	Subpart MMMMM does not refer directly or indirectly to § 63.11.
§ 63.8(b)	Conduct of monitoring and procedures when there are multiple effluents and multiple monitoring systems.	Yes.	
§ 63.8(c)(1)–(3)	Continuous monitoring system (CMS) operation and maintenance.	Yes	Applies as modified by § 63.8794(f) and (g).
§ 63.8(c)(4)	Continuous monitoring system requirements during breakdown, out-of-control, repair, maintenance, and high-level calibration drifts.	Yes	Applies as modified by § 63.8794(g).
§ 63.8(c)(5)	Continuous opacity monitoring system (COMS) minimum procedures.	No	Subpart MMMMM does not have opacity or visible emission standards.
§ 63.8(c)(6)	Zero and high level calibration checks.	Yes	Applies as modified by § 63.8794(f).
§ 63.8(c)(7)–(8)	Out-of-control periods, including reporting.	Yes.	
§ 63.8(d)–(e)	Quality control program and CMS performance evaluation.	No	Applies as modified by § 63.8794(f) and (g).
§ 63.8(f)(1)–(5)	Use of an alternative monitoring method.	Yes.	
§ 63.8(f)(6)	Alternative to relative accuracy test.	No	Only applies to sources that use continuous emissions monitoring systems (CEMS).
§ 63.8(g)	Data reduction	Yes	Applies as modified by § 63.8794(g).
§ 63.9(a)	Notification requirements—applicability.	Yes.	
§ 63.9(b)	Initial notifications	Yes	Except § 63.8816(c) requires new or reconstructed affected sources to submit the application for construction or reconstruction required by § 63.9(b)(1)(iii) in lieu of the initial notification.
§ 63.9(c)	Request for compliance extension.	Yes.	
§ 63.9(d)	Notification that a new source is subject to special compliance requirements.	Yes.	
§ 63.9(e)	Notification of performance test	Yes.	
§ 63.9(f)	Notification of visible emissions/opacity test.	No	Subpart MMMMM does not have opacity or visible emission standards.
§ 63.9(g)(1)	Additional CMS notifications—date of CMS performance evaluation.	Yes.	
§ 63.9(g)(2)	Use of COMS data	No	Subpart MMMMM does not require the use of COMS.
§ 63.9(g)(3)	Alternative to relative accuracy testing.	No	Applies only to sources with CEMS.
§ 63.9(h)	Notification of compliance status	Yes.	
§ 63.9(i)	Adjustment of submittal deadlines.	Yes.	
§ 63.9(j)	Change in previous information	Yes.	
§ 63.10(a)	Recordkeeping/reporting applicability.	Yes.	

Citation	Requirement	Applies to subpart MMMMM	Explanation
§ 63.10(b)(1)	General recordkeeping requirements.	Yes	§§ 63.8820 and 63.8822 specify additional recordkeeping requirements.
§ 63.10(b)(2)(i)–(xi)	Records related to startup, shutdown, and malfunction periods and CMS.	Yes	Only applies to new or reconstructed flame lamination affected sources.
§ 63.10(b)(2)(xii)	Records when under waiver	Yes.	
§ 63.10(b)(2)(xiii)	Records when using alternative to relative accuracy test.	No	Applies only to sources with CEMS.
§ 63.10(b)(2)(xiv)	All documentation supporting initial notification and notification of compliance status.	Yes	
§ 63.10(b)(3)	Recordkeeping requirements for applicability determinations.	Yes.	
§ 63.10(c)	Additional recordkeeping requirements for sources with CMS.	Yes	Applies as modified by § 63.8794(g).
§ 63.10(d)(1)	General reporting requirements	Yes	§ 63.8818 specifies additional reporting requirements.
§ 63.10(d)(2)	Performance test results	Yes	
§ 63.10(d)(3)	Opacity or visible emissions observations.	No	Subpart MMMMM does not specify opacity or visible emission standards.
§ 63.10(d)(4)	Progress reports for sources with compliance extensions.	Yes.	
§ 63.10(d)(5)	Startup, shutdown, and malfunction reports.	Yes	Only applies to new or reconstructed flame lamination affected sources.
§ 63.10(e)(1)	Additional CMS reports—general.	Yes	Applies as modified by § 63.8794(g).
§ 63.10(e)(2)(i)	Results of CMS performance evaluations.	Yes	Applies as modified by § 63.8794(g).
§ 63.10(e)(2)	Results of continuous opacity monitoring systems performance evaluations.	No	Subpart MMMMM does require the use of COMS.
§ 63.10(e)(3)	Excess emissions/CMS performance reports.	Yes	Only applies to new or reconstructed flame lamination affected sources.
§ 63.10(e)(4)	Continuous opacity monitoring system data reports.	No	Subpart MMMMM does not require the use of COMS.
§ 63.10(f)	Recordkeeping/reporting waiver	Yes	
§ 63.11.	Control device requirements—applicability.	No	Facilities subject to subpart MMMMM do not use flares as control devices.
§ 63.12	State authority and delegations	Yes	§ 63.8828 lists those sections of subparts MMMMM and A that are not delegated.
§ 63.13	Addresses	Yes.	
§ 63.14	Incorporation by reference	Yes	Subpart MMMMM does not incorporate any material by reference.
§ 63.15	Availability of information/confidentiality..	Yes.	