

§ 408.140

**Subpart N—Tuna Processing Subcategory**

**§ 408.140 Applicability; description of the tuna processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing of tuna.

[40 FR 55781, Dec. 1, 1975]

**§ 408.141 Specialized definitions.**

For the purpose of this subpart:

(a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.

(b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.

(c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.142 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kg/kkg of seafood)	
TSS .....	8.3	3.3
Oil and grease .....	2.1	0.84
pH .....	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS .....	8.3	3.3

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Oil and grease .....	2.1	0.84
pH .....	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 44 FR 45945, Aug. 9, 1979; 60 FR 33943, June 29, 1995]

**§ 408.143 [Reserved]**

**§ 408.144 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH .....	No limitation.
BOD5 .....	Do.
Oil and grease .....	Do.

[40 FR 6439, Feb. 11, 1975, as amended at 60 FR 33943, June 29, 1995]

**§ 408.145 Standards of performance for new sources.**

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kg/kkg of seafood)	
BOD5 .....	20	8.1
TSS .....	7.5	3.0
Oil and grease .....	1.9	0.76
pH .....	( <sup>1</sup> )	( <sup>1</sup> )