

§ 424.32

methods of analysis set forth in part 401 of this chapter shall apply to this subpart.

§ 424.32 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Metric units (kg/kkg processed)		
TSS	2.659	1.330
Chromium total	0.053	0.026
Manganese total532	.266
pH	(¹)	(¹)
English units (lb/ton processed)		
TSS	5.319	2.659
Chromium total	0.106	0.053
Manganese total	1.064	.532
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

[39 FR 6809, Feb. 22, 1974, as amended at 60 FR 33957, June 29, 1995]

§ 424.33 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best available technology economically achievable.

The following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best available technology economically achievable:

40 CFR Ch. I (7–1–09 Edition)

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Metric units (kg/kkg processed)		
Chromium total	0.0054	0.0027
Manganese total054	.027
English units (lb/ton of raw material)		
Chromium total011	.0054
Manganese total108	.054

[44 FR 50745, Aug. 29, 1979]

§ 424.34 [Reserved]

§ 424.35 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Metric units (kg/kkg processed)		
TSS	0.271	0.136
Chromium total0054	.0027
Manganese total	0.054	.027
pH	(¹)	(¹)
English units (lb/ton processed)		
TSS542	.271
Chromium total011	.0054
Manganese total108	.054
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

§ 424.36 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33957, June 29, 1995]