

**§ 437.24**

**§ 437.24 New source performance standards (NSPS).**

Except as provided in § 437.20(b), any new source subject to this subpart must achieve the following performance standards: Standards for oil and grease, pH, TSS, arsenic, cadmium, chromium, cobalt, copper, lead, mercury, tin, zinc, butylbenzyl phthalate, carbazole, n-decane, bis(2-ethylhexyl) phthalate, fluoranthene, and n-octadecane are the same as the corresponding limitation specified in § 437.21.

[65 FR 81300, Dec. 22, 2000, as amended at 68 FR 71023, Dec. 22, 2003]

**§ 437.25 Pretreatment standards for existing sources (PSES).**

Except as provided in 40 CFR 403.7, 403.13 or § 437.20(b), and no later than December 22, 2003, any existing source subject to this subpart must achieve the following pretreatment standards:

**PRETREATMENT STANDARDS (PSES)**

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly avg. <sup>1</sup>
<b>Metal Parameters</b>		
Chromium .....	0.947	0.487
Cobalt .....	56.4	18.8
Copper .....	0.405	0.301
Lead .....	0.222	0.172
Tin .....	0.249	0.146
Zinc .....	6.95	4.46
<b>Organic Parameters</b>		
Bis(2-ethylhexyl) phthalate ....	0.267	0.158
Carbazole .....	0.392	0.233
n-Decane .....	5.79	3.31
Fluoranthene .....	0.787	0.393
n-Octadecane .....	1.22	0.925

<sup>1</sup> mg/L (ppm).

[65 FR 81300, Dec. 22, 2000, as amended at 68 FR 71023, Dec. 22, 2003]

**§ 437.26 Pretreatment standards for new sources (PSNS).**

Except as provided in 40 CFR 403.7 or § 437.20(b), any new source subject to this subpart must achieve the following pretreatment standards: Standards for chromium, cobalt, copper, lead, tin, zinc, carbazole, n-decane, bis(2-ethylhexyl) phthalate, fluoranthene, and n-octadecane are the same

**40 CFR Ch. I (7-1-10 Edition)**

as the corresponding limitation specified in § 437.21.

[65 FR 81300, Dec. 22, 2000, as amended at 68 FR 71023, Dec. 22, 2003]

**Subpart C—Organics Treatment and Recovery**

**§ 437.30 Applicability.**

(a) Except as provided in § 437.1(b), (c), or (d) or in paragraph (b) of this section, this subpart applies to that portion of the discharge of wastewater from a CWT facility that results from the treatment of, or recovery of organic material from, both organic wastes received from off-site and other CWT wastewater associated with the treatment of, or recovery of organic wastes.

(b) In order to ensure appropriate treatment rather than dilution of dissimilar wastes, an NPDES permit writer or control authority may require a new source or an existing facility subject to § 437.30 to achieve alternative effluent limitations and standards as defined in § 437.2 (h) in the following circumstances:

(1) The facility receives, on a continuing basis, flows of process wastewater from five or fewer facilities subject to 40 CFR Subchapter N limitations and standards; and

(2) The process wastewater flows received for treatment at the facility have relatively consistent pollutant profiles.

**§ 437.31 Effluent limitations attainable by the application of the best practicable control technology currently available (BPT).**

Except as provided in 40 CFR 125.30 through 125.32 or § 437.30(b), any existing point source subject to this subpart must achieve the following effluent limitations representing the application of BPT:

**BPT LIMITATIONS**

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly avg. <sup>1</sup>
<b>Conventional Parameters</b>		
BOD <sub>5</sub> .....	163	53.0
pH .....	( <sup>2</sup> )	( <sup>2</sup> )
TSS .....	216	61.3