

§ 25.26-5 Commercial fishing industry vessels.

(a) The owner of a fishing vessel, a fish processing vessel, or a fish tender vessel, 11 meters (36 feet) or more in length, except for vessels described in paragraph (b) or (c) of this section, shall ensure that the vessel does not operate on the high seas or beyond three miles from the coastline of the Great Lakes unless it has on board a float-free, automatically activated Category 1 406 MHz EPIRB stowed in a manner so that it will float-free if the vessel sinks.

(b) The owner of a fishing vessel, fish processing vessel, or a fish tender vessel less than 11 meters (36 feet) in length, or 11 meters or more in length which has a builder's certification that the vessel is constructed with sufficient inherently buoyant material to keep the flooded vessel afloat, shall ensure that the vessel does not operate on the high seas or beyond three miles from the coastline of the Great Lakes, unless it has installed in a readily accessible location at or near the principal steering station—

(1) A manually activated Category 2 406 MHz EPIRB; or

(2) A float-free, automatically activated Category 1 406 MHz EPIRB.

(3) Until February 1, 1998, a 121.5/243.0 MHz EPIRB meeting § 25.26-30.

(c) The owner of a fishing vessel, fish processing vessel or a fish tender vessel 11 meters (36 feet) or more in length that does not have installed galley or berthing facilities, shall ensure that the vessel does not operate on the high seas or beyond three miles from the coastline of the Great Lakes unless it has on board a float-free, automatically activated Category 1 406 MHz EPIRB stowed in a manner so that it will float free if the vessel sinks.

[CGD 87-016a, 58 FR 13367, Mar. 10, 1993; 58 FR 27658, May 11, 1993, as amended by CGD 95-028, 62 FR 51196, Sept. 30, 1997; USCG-1998-4442, 63 FR 52189, Sept. 30, 1998]

§ 25.26-10 EPIRB requirements for uninspected passenger vessels.

(a) Uninspected passenger vessels less than 100 gross tons are not required to carry an EPIRB.

(b) The owner, operator, or master of an uninspected passenger vessel of at

least 100 gross tons must ensure that the vessel does not operate beyond three miles from shore as measured from the territorial sea baseline seaward or more than three miles from the coastline of the Great Lakes, unless it has onboard a float-free, automatically activated Category 1 406 MHz EPIRB stowed in a manner so that it will float free if the vessel sinks.

[USCG-1999-5040, 67 FR 34776, May 15, 2002]

§ 25.26-20 Other manned uninspected commercial vessels.

(a) The owner of a manned uninspected commercial vessel 11 meters (36 feet) or more in length, other than a vessel under § 25.26-5 or § 25.26-10 or under paragraph (b) of this section, shall ensure that the vessel does not operate on the high seas or beyond three miles from the coastline of the Great Lakes, unless it has on board a float-free, automatically activated Category 1 406 MHz EPIRB stowed in a manner so that it will float free if the vessel sinks.

(b) The owner of a manned uninspected commercial vessel less than 11 meters (36 feet) in length, or 11 meters or more in length which has a builder's certification that the vessel is constructed with sufficient inherently buoyant material to keep the flooded vessel afloat, shall ensure that the vessel does not operate on the high seas or beyond three miles from the coastline of the Great Lakes, unless it has installed in a readily accessible location at or near the principal steering station—

(1) A manually activated Category 2 406 MHz EPIRB; or

(2) A float-free, automatically activated Category 1 406 MHz EPIRB.

[CGD 87-016a, 58 FR 13367, Mar. 10, 1993; 58 FR 27658, May 11, 1993, as amended by CGD 95-028, 62 FR 51196, Sept. 30, 1997; USCG-1998-4442, 63 FR 52189, Sept. 30, 1998]

§ 25.26-50 Servicing of EPIRBs.

(a) The master of each vessel required to have an EPIRB under this subpart shall ensure that each EPIRB on board is tested and serviced as required by this section.

(b) The EPIRB must be tested immediately after installation and at least once each month thereafter, unless it

is an EPIRB installed in a Coast Guard approved inflatable liferaft that is tested annually during the servicing of the liferaft by an approved servicing facility. The test shall be conducted in accordance with the manufacturer's instructions, using the visual or audio indicator on the EPIRB. If the EPIRB is not operating, it must be repaired or replaced with an operating EPIRB.

(c) The battery of the EPIRB must be replaced—

(1) Immediately after the EPIRB is used for any purpose other than being tested; and

(2) Before the expiration date that is marked on the battery.

[CGD 87-016a, 58 FR 13367, Mar. 10, 1993; 58 FR 27658, May 11, 1993]

§ 25.26-60 Exemptions.

(a) A skiff or work boat is not required to carry an EPIRB if—

(1) Its "mother ship" is required to carry an EPIRB under this subpart; and

(2) When not in use, the skiff or work boat is carried on board the mother ship.

(b) Each Coast Guard District Commander may, on a case-by-case basis, grant exemptions from the carriage requirements of EPIRBs in this subpart for certain geographic areas within the boundaries of his or her own district if the District Commander determines that an EPIRB will not significantly enhance the overall safety of the vessel and crew. Exemptions may be limited to specific time periods. Exemptions granted under this paragraph must be:

(1) Issued in writing by the cognizant Coast Guard District Commander for each individual application; and

(2) For geographic locations and may be limited to specific time periods.

Subpart 25.30—Fire Extinguishing Equipment

§ 25.30-1 Application.

(a) The provisions of this subpart, with the exception of § 25.30-90, shall apply to all vessels contracted for on or after November 19, 1952. Vessels contracted for prior to that date shall meet the requirements of § 25.30-90.

§ 25.30-5 General provisions.

(a) Where equipment in this subpart is required to be of an approved type, such equipment requires the specific approval of the Commandant. Such approvals are published in the FEDERAL REGISTER, and in addition, are contained in Coast Guard publication COMDTINST M16714.3 (Series), Equipment Lists.

(b) All hand portable fire extinguishers, semiportable fire extinguishing systems, and fixed fire extinguishing systems shall be of an approved type.

[CGFR 65-50, 30 FR 16653, Dec. 30, 1965, as amended by CGD 96-041, 61 FR 50726, Sept. 27, 1996]

§ 25.30-10 Hand-portable fire extinguishers and semi-portable fire-extinguishing systems.

(a) Hand portable fire extinguishers and semiportable fire extinguishing systems are classified by a combination letter and number symbol. The letter indicating the type of fire which the unit could be expected to extinguish, and the number indicating the relative size of the unit.

(b) For the purpose of this subchapter, all required hand portable fire extinguishers and semiportable fire extinguishing systems are of the "B" type; i.e., suitable for extinguishing fires involving flammable liquids, greases, etc.

(c) The number designations for size run from "I" for the smallest to "V" for the largest. Sizes I and II are hand-portable fire extinguishers; sizes III, IV, and V are semi-portable fire-extinguishing systems, which must be fitted with hose and nozzle or other practical means to cover all portions of the space involved. Examples of the sizes for some of the typical hand-portable fire extinguishers and semi-portable fire-extinguishing systems appear in Table 25.30-10(C):

TABLE 25.30-10(C)

Classification	Foam, liters (gallons)	Carbon dioxide, kilograms (pounds)	Dry chemical, kilograms (pounds)
B-I	6.5 (1¾)	2 (4)	1 (2)
B-II	9.5 (2½)	7 (15)	4.5 (10)
B-III	45 (12)	16 (35)	9 (20)
B-IV	75 (20)	23 (50)	13.5 (30)