- (5) Boilerrooms. On tankships contracted for on or after November 19, 1952, a carbon dioxide or foam system shall be installed for the protection of all spaces containing oil fired boilers, either main or auxiliary, their fuel oil service pumps and/or such fuel oil units as the heaters, strainers, valves, manifolds, etc., that are subject to the discharge pressure of the fuel oil service pumps.
- (6) Machinery spaces. A carbon dioxide system shall be installed for the protection of machinery spaces containing internal combustion propelling engines using fuel having a flashpoint of less than 110 degrees F.
- (7) Internal combustion installations. Fire-extinguishing systems shall be provided for internal combustion installations in accordance with the following:
- (i) If a fire-extinguishing system is installed to protect an internal combustion installation, the system shall be of the carbon dioxide type.
- (ii) On vessels of 1,000 gross tons and over on an international voyage, the construction or conversion of which is contracted for on or after May 26, 1965, a fixed carbon dioxide system shall be installed in all spaces containing internal combustion or gas turbine main propulsion machinery, auxiliaries with an aggregate power of 1,000 b.h.p. or greater, or their fuel oil units, including purifiers, valves, and manifolds.
- (iii) On vessels of 1,000 gross tons and over, the construction, conversion or automation of which is contracted for on or after January 1, 1968, a fixed carbon dioxide system shall be installed in all spaces containing internal combustion or gas turbine main propulsion machinery, auxiliaries with an aggregate power of 1,000 b.h.p. or greater, or their fuel oil units, including purifiers, valves and manifolds.
- (8) Enclosed ventilating system. On tankships contracted for on or after January 1, 1962, where an enclosed ventilating system is installed for electric propulsion motors or generators, a carbon dioxide extinguishing system shall be installed in such system.
- (b) The arrangements and details of the fire-extinguishing systems shall be

as set forth in subparts 34.10 through 34.20.

[CGFR 65–50, 30 FR 16694, Dec. 30, 1965, as amended by CGFR 67–90, 33 FR 1015, Jan. 26, 1968; CGD 77–057a, 44 FR 66502, Nov. 19, 1979; CGD 95–027, 61 FR 25998, May 23, 1996]

## $\S\,34.05\text{--}10$ Portable and semiportable extinguishers—TB/ALL.

- (a) All portable and semiportable extinguishers on board tank vessels shall be of an approved type.
- (b) The type, size, location and arrangement of portable and semiportable extinguishers shall be as set forth in subpart 34.50.

[CGFR 65–50, 30 FR 16694, Dec. 30, 1965, as amended by CGFR 70–143, 35 FR 19905, Dec.  $30,\,1970$ ]

#### § 34.05–20 Fire axes—T/ALL.

- (a) Fire axes shall be provided on all tankships.
- (b) The location and arrangement of fire axes shall be as set forth in subpart 34 60.

# Subpart 34.10—Fire Main System, Details

### §34.10-1 Application—TB/ALL.

- (a) On all tankships the provisions of this subpart, with the exception of §34.10-90, shall apply to all fire main installations contracted for on or after May 26, 1965. Installations contracted for prior to May 26, 1965, shall meet the requirements of §34.10-90.
- (b) If a fire main system is installed on a tank barge, the system shall meet the intent of this subpart insofar as reasonable and practicable.

### $\S 34.10-5$ Fire pumps—T/ALL.

(a) Tankships shall be equipped with independently driven fire pumps in accordance with table 34.10–5(a).

TABLE 34.10-5(a)—FIRE PUMPS

Size vessel, L.O.A. (feet)		Minimum	Powerful streams	Minimum hy- drant and hose size (inches)	
Over—	Not over—	number of pumps	of water per pump	Exterior stations	Interior stations
100 250 400	100 250 400 650	(1) 21 2 2	32 32 32 32	1½ 1½ 1½ 42½	1½ 1½ 1½ 1½