

§ 72.05–35

Other windows or air ports opening onto open decks or enclosed promenades need not have wire inserted glass.

(g) Skylights to spaces containing auxiliary internal combustion machinery having an aggregate horsepower of 1,000 or more, and to boiler and main engine rooms, shall be capable of being closed from outside the space. If glass is fitted in such skylights, it shall be of the wire inserted type. The glass panels shall be fitted with permanently attached shutters of steel or equivalent metal.

§ 72.05–35 Hatch covers and shifting boards.

(a) Wood hatch covers may be used between cargo spaces. Hatch covers in other locations shall meet the requirements for deck construction noted in tables 72.05–10 (f) and (g).

(b) Tonnage openings in “A” Class bulkheads shall be closed by means of steel plates.

§ 72.05–40 Insulation, other than for structural fire protection.

(a) Any insulation installed for heat and comfort, refrigeration (including air conditioning), or for any other purpose, and all material incidental to its installation, shall be approved Incombustible Materials. This paragraph shall not apply to such insulation installed in cargo spaces, refrigerated storerooms, individual refrigerator boxes, nor to pipe and machinery coverings or laggings within the machinery spaces.

(b) [Reserved]

§ 72.05–45 Paint.

(a) An excessive number of coats of paint will be discouraged unless non-combustible paint is used.

(b) Nitrocellulose or other highly flammable or noxious fume-producing paints or lacquers shall not be used.

§ 72.05–50 Ventilation.

(a) Where the term *duct* is used in this section, it shall include trunks, plenums, and any other type of ventilation piping, chambers, or duct work.

(b) Where automatic fire dampers are required, they shall be designed to operate at approximately 165 degrees F.

46 CFR Ch. I (10–1–10 Edition)

for normal locations, and approximately 212 degrees F. for locations such as galleys. The dampers shall be so designed as to close against the anticipated draft in the duct. The damper shall be made accessible for periodic inspection by means of a hinged or bolted plate in the duct. The damper and the portion of duct containing the damper shall be constructed of at least $\frac{1}{8}$ inch steel plate suitably stiffened. No insulation need be applied to the damper blade.

(c) Where ventilation ducts are required to meet bulkhead requirements, the space within the duct shall be considered to be the same as the space served by the ventilator, and the duct shall be insulated to meet the applicable requirements of tables 72.05–10(d) and 72.05–10(e).

(d) All ventilation systems shall be designed, where practicable, so that all ducts leading to the various enclosures are kept within the main vertical zones. No duct may serve spaces in more than one main vertical zone.

(e) Where of necessity, ducts pass through main vertical zone bulkheads, automatic fire dampers shall be fitted adjacent to the bulkhead. The duct between the bulkhead and the damper shall meet the applicable bulkhead requirements. The damper shall be fitted on at least one side of the bulkhead with a visible indicator showing whether the damper is in the open or closed position. The indicator may be connected to the manual operating device rather than the damper blade so that it might show as being open when it had automatically closed, but could never be open if the indicator showed it to be closed. The damper shall be capable of being manually closed from both sides of the bulkhead. The operating positions for the damper shall be marked as required by § 78.47–53 of this subchapter.

(f) Vent ducts serving stairway enclosures shall serve no other spaces.

(g) Ventilation ducts serving cargo or main machinery spaces which pass through accommodation spaces or safety areas shall be fitted with an automatic fire damper adjacent to the point of entry. Between the bulkhead or deck and the damper, and in addition, on vertical ducts for a distance of