

(c) Each internal opening fixed with appliances to ensure watertight integrity which are used intermittently during operation of the unit while afloat must meet the following:

(1) Each door, hatch, and scuttle must—

(i) Be remotely controlled from a normally manned control station, and be operable locally from both sides of the bulkhead; or

(ii) If there is no means of remote control there must be an alarm system which signals whether the appliance is open or closed both locally at each appliance and in a normally manned control station.

(2) Each closing appliance must remain watertight under the design water pressure of the watertight boundary of which it is a part.

(d) Each external opening fitted with an appliance to ensure weathertight integrity must be located so that it would not be submerged below the final equilibrium waterline if the unit is subjected simultaneously to—

(1) Damage causing flooding described in §174.075 through §174.085 of this chapter; and

(2) A wind heeling moment calculated in accordance with §174.055 of this chapter using a wind velocity of 50 knots (25.8 meters per second).

[CGD 73-251, 43 FR 56808, Dec. 4, 1978, as amended by CGD 79-023, 48 FR 51008, Nov. 4, 1983]

FIRE PROTECTION: GENERAL

§ 108.123 Isolation of combustible material.

Each internal combustion engine exhaust, boiler and galley uptake, and similar heat source must be separated or insulated from combustible materials.

§ 108.127 Storage lockers for combustibles.

Each oil and paint locker must be made of steel or an equivalent material or be completely lined with steel or an equivalent material as described in §108.131(c) of this subpart.

STRUCTURAL FIRE PROTECTION

§ 108.131 Definitions.

(a) *Standard Fire Test* means the test in which specimens of the relevant bulkheads or decks, having a surface of approximately 4.65 square meters (50 square feet) and a height of 2.44 meters (8 feet) resembling as closely as possible the intended construction and including, where appropriate, at least one joint, are exposed in a test furnace to a series of temperature relationships approximately as follows:

(1) At the end of 5 minutes—538°C. (1,000°F.)

(2) At the end of 10 minutes—704°C. (1,300°F.)

(3) At the end of 30 minutes—843°C. (1,550°F.)

(4) At the end of 60 minutes—927°C. (1,700°F.)

(b) Bulkheads and decks are defined and classed as follows:

(1) *A class bulkhead or deck* means a bulkhead or deck that—

(i) Is made of steel or other equivalent material; and

(ii) Prevents the passage of flame and smoke for 60 minutes if subjected to the standard fire test.

(2) *A 60 bulkhead or deck* means an A class bulkhead or deck that—

(i) Is insulated with approved insulation, bulkhead panels, or deck covering;

(ii) If subjected to the standard fire test for 60 minutes, has an average temperature rise on the unexposed side of the insulated bulkhead or deck of less than 139°C. (250°F.) above the temperature before the standard fire test and has a temperature rise at any point on the unexposed surface, including any joint, of less than 180°C. (325°F.) above the temperature before the standard fire test.

(3) *B class bulkhead or deck* means a bulkhead or deck that—

(i) Is made of approved noncombustible material;

(ii) Prevents flame from passing through it for 30 minutes if subjected to the standard fire test.

(4) *C class bulkhead or deck* means a bulkhead or deck made of approved noncombustible material.

(c) *Equivalent material* means a material that by itself or with insulation