

Subpart C—Miscellaneous

- 132.310 Fixed fire-extinguishing systems for paint lockers.
- 132.320 Helicopter-landing decks.
- 132.330 Fire monitors.
- 132.340 Equipment installed although not required.
- 132.350 Tests and inspections of fire-extinguishing equipment.
- 132.360 Fire axes.
- 132.370 Added requirements for fixed independent and portable tanks.

AUTHORITY: 46 U.S.C. 3306, 3307; Department of Homeland Security Delegation No. 0170.1.

SOURCE: CGD 82–004 and CGD 86–074, 62 FR 49348, Sept. 19, 1997, unless otherwise noted.

Subpart A—Fire Main

§ 132.100 General.

(a) Except as provided by paragraphs (b) and (c) of this section, each vessel must be equipped with a fire main that complies with this subpart.

(b) Each vessel of less than 100 gross tons and not more than 19.8 meters (65 feet) in length may have, instead of a fire main that complies with this subpart, a hand-operated pump and a hose capable of providing an effective stream of water to each part of the vessel.

(c) A garden hose of nominal inside diameter of at least 16 millimeters (5/8-inch) complies with paragraph (b) of this section if the hose is—

(1) Of good commercial grade and is constructed of an inner rubber tube, plies of braided-fabric reinforcement, and an outer cover made of rubber or equivalent fire-resistant material; and

(2) Fitted with a commercial garden-hose nozzle of high-grade bronze or equivalent metal capable of providing a solid stream and a spray pattern.

§ 132.110 Piping.

(a) Except as provided for liftboats by § 134.180 of this subchapter, each fitting, flange, valve, and run of piping must meet the applicable requirements of part 128 of this subchapter. Piping must be—

- (1) Hot-dip galvanized;
- (2) At least extra-heavy schedule; or
- (3) Of a suitable corrosion-resistant material.

(b) Each distribution cut-off valve must be marked in compliance with § 131.820 of this subchapter.

§ 132.120 Fire pumps.

(a) Except as provided by § 132.100(b) of this subpart, each vessel must be equipped with one self-priming power-driven fire pump capable of delivering a single stream of water from the highest hydrant, through the hose and nozzle at a Pitot-tube pressure of at least 345 kPa (50 psi [pounds per square inch]).

(b) Each fire pump must be fitted on the discharge side with a pressure gauge.

(c) Each fire pump must be fitted on the discharge side with a relief valve set to relieve at either 172 kPa (25 psi) in excess of the pressure necessary to maintain the requirements of paragraph (a) of this section or 862 kPa (125 psi), whichever is greater. The relief valve is optional if the pump is not capable of developing pressure exceeding the greater amount.

(d) If two propulsion engines are installed, the pump required by paragraph (a) of this section may be driven by one of the engines. If only one propulsion engine is installed, the pump must be driven by a source of power independent of the engine.

(e) If two fire pumps are installed, and if one pump remains available for service on the fire main at any time, the other pump may be used for other purposes.

(f) Each fire pump must be capable of providing the quantity of water required to comply with paragraph (a) of this section while meeting any other demands placed on it, as by a branch line connected to the fire main for washing the anchor or the deck.

(g) No branch line may be directly connected to the fire main except for fighting fires or for washing the anchor or the deck. Each discharge line for any other purpose must be clearly marked and must lead from a discharge manifold near the fire pump.

(h) When a fire monitor is connected to the fire main system, it must lead from a discharge manifold near the fire pump.

(i) The total cross-sectional area of piping leading from a fire pump may