

§ 419.27

40 CFR Ch. I (7-1-09 Edition)

Pollutant or pollutant property	NSPS effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed
	Metric units (kilograms per 1,000 m <sup>3</sup> of feedstock)	
BOD <sub>5</sub> .....	16.3	8.7
TSS .....	11.3	7.2
COD <sup>1</sup> .....	118.0	61
oil and grease .....	4.8	2.6
Phenolic compounds .....	0.119	0.058
Ammonia (as N) .....	18.8	8.6
Sulfide .....	0.105	0.048
Total chromium .....	0.24	0.14
Hexavalent chromium .....	0.020	0.0088
pH .....	( <sup>2</sup> )	( <sup>2</sup> )
	English units (pounds per 1,000 bbl of feedstock)	
BOD <sub>5</sub> .....	5.8	3.1
TSS .....	4.0	2.5
COD <sup>1</sup> .....	41.5	21
Oil and grease .....	1.7	0.93
Phenolic compounds .....	0.042	0.020
Ammonia (as N) .....	6.6	3.0
Sulfide .....	0.037	0.017
Total chromium .....	0.084	0.049
Hexavalent chromium .....	0.0072	0.0032
pH .....	( <sup>2</sup> )	( <sup>2</sup> )

<sup>1</sup> See footnote following table in § 419.13(d).  
<sup>2</sup> Within the range 6.0 to 9.0.

(b) The limits set forth in paragraph (a) of this section are to be multiplied by the following factors to calculate the maximum for any 1 day and maximum average of daily values for 30 consecutive days.

(1) Size Factor.

1,000 bbl of feedstock per stream day	Size factor
Less than 24.9 .....	0.91
25.0 to 49.9 .....	0.95
50.0 to 74.9 .....	1.04
75.0 to 99.9 .....	1.13
100.0 to 124.9 .....	1.23
125.0 to 149.9 .....	1.35
150.0 or greater .....	1.41

(2) Process factor.

Process configuration	Process factor
Less than 2.49 .....	0.58
2.5 to 3.49 .....	0.63
3.5 to 4.49 .....	0.74
4.5 to 5.49 .....	0.88
5.5 to 5.99 .....	1.00
6.0 to 6.49 .....	1.09
6.5 to 6.99 .....	1.19
7.0 to 7.49 .....	1.29

Process configuration	Process factor
7.5 to 7.99 .....	1.41
8.0 to 8.49 .....	1.53
8.5 to 8.99 .....	1.67
9.0 to 9.49 .....	1.82
9.5 or greater .....	1.89

(3) See the comprehensive example in subpart D, § 419.42(b)(3).

(c) The provisions of § 419.16(c) apply to discharges of process wastewater pollutants attributable to ballast water by a point source subject to the provisions of this subpart.

(d) The quantity and quality of pollutants or pollutant properties controlled by this paragraph, attributable to once-through cooling water, are excluded from the discharge allowed by paragraph (b) of this section. Once-through cooling water may be discharged with a total organic carbon concentration not to exceed 5 mg/l.

(e) *Effluent limitation for runoff.* [Reserved]

[47 FR 46446, Oct. 18, 1982, as amended at 50 FR 28523, July 12, 1985; 50 FR 32414, Aug. 12, 1985]

§ 419.27 Pretreatment standards for new sources (PSNS).

Except as provided in 40 CFR 403.7, any new source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following pretreatment standards for new sources (PSNS).

(a) The following standards apply to the total refinery flow contribution to the POTW.

Pollutant or pollutant property	Pretreatment standards for new sources—maximum for any 1 day
	Milligrams per liter (mg/l)
Oil and grease .....	100
Ammonia (as N) .....	100

<sup>1</sup> Where the discharge to the POTW consists solely of sour waters, the owner or operator has the option of complying with this limit or the daily maximum mass limitation for ammonia set forth in § 419.26(a) and (b).

(b) The following standard is applied to the cooling tower discharge part of the total refinery flow to the POTW by multiplying: (1) The standard; (2) by

**Environmental Protection Agency**

**§ 419.32**

the total refinery flow to the POTW; and (3) by the ratio of the cooling tower discharge flow to the total refinery flow.

Pollutant or pollutant property	Pretreatment standards for new sources—maximum for any 1 day
	Milligrams per liter (mg/l)
Total chromium .....	1

**Subpart C—Petrochemical Subcategory**

**§ 419.30 Applicability; description of the petrochemical subcategory.**

The provisions of this subpart are applicable to all discharges from any facility that produces petroleum products by the use of topping, cracking, and petrochemical operations whether or not the facility includes any process in addition to topping, cracking, and petrochemical operations. The provisions of this subpart shall not be applicable, however, to facilities that include the processes specified in subpart D or E of this part.

**§ 419.31 Specialized definitions.**

For the purpose of this subpart:

(a) The general definitions, abbreviations, and methods of analysis set forth in part 401 of this chapter and the specialized definitions set forth in § 419.11 shall apply.

(b) The term *petrochemical operations* shall mean the production of second-generation petrochemicals (*i.e.*, alcohols, ketones, cumene, styrene, etc.) or first generation petrochemicals and isomerization products (*i.e.*, BTX, olefins, cyclohexane, etc.) when 15 percent or more of refinery production is as first-generation petrochemicals and isomerization products.

**§ 419.32 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

(a) Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must

achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Pollutant or pollutant property	BPT Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed
	Metric units (kilograms per 1,000 m <sup>3</sup> of feedstock)	
BOD <sub>5</sub> .....	34.6	18.4
TSS .....	23.4	14.8
COD <sup>1</sup> .....	210.0	109.0
Oil and grease .....	11.1	5.9
Phenolic compound .....	0.25	0.120
Ammonia as N .....	23.4	10.6
Sulfide .....	0.22	0.099
Total chromium .....	0.52	0.30
Hexavalent chromium .....	0.046	0.020
pH .....	( <sup>2</sup> )	( <sup>2</sup> )
	English units (pounds per 1,000 bbl of feedstock)	
BOD <sub>5</sub> .....	12.1	6.5
TSS .....	8.3	5.25
COD <sup>1</sup> .....	74.0	38.4
Oil and grease .....	3.9	2.1
Phenolic compounds .....	0.088	0.0425
Ammonia as N .....	8.25	3.8
Sulfide .....	0.078	0.035
Total chromium .....	0.183	0.107
Hexavalent chromium .....	0.016	0.0072
pH .....	( <sup>2</sup> )	( <sup>2</sup> )

<sup>1</sup> See footnote following table in § 419.13(d).

<sup>2</sup> Within the range of 6.0 to 9.0.

(b) The limits set forth in paragraph (a) of this section are to be multiplied by the following factors to calculate the maximum for any one day and maximum average of daily values for thirty consecutive days.

(1) Size factor.

1,000 barrels of feedstock per stream day	Size factor
Less than 24.9 .....	0.73
25.0 to 49.9 .....	0.76
50.0 to 74.9 .....	0.83
75.0 to 99.9 .....	0.91
100.0 to 124.9 .....	0.99
125.0 to 149.9 .....	1.08
150.0 or greater .....	1.13

(2) Process factor.

Process configuration	Process factor
Less than 4.49 .....	0.73