

**§ 439.26**

standards specified in §§ 439.23 and 439.24.

[68 FR 12273, Mar. 13, 2003]

**§ 439.26 Pretreatment standards for existing sources (PSES).**

Except as provided in 40 CFR 403.7 and 403.13, any existing source subject to this subpart must achieve the following standards by September 21, 2001:

**PRETREATMENT STANDARDS (PSES)**

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly average <sup>1</sup>
Acetone .....	20.7	8.2
n-Amyl acetate .....	20.7	8.2
Ethyl acetate .....	20.7	8.2
Isopropyl acetate .....	20.7	8.2
Methylene chloride .....	3.0	0.7

<sup>1</sup> mg/L (ppm).

[68 FR 12273, Mar. 13, 2003]

**§ 439.27 Pretreatment standards for new sources (PSNS).**

Except as provided in 40 CFR 403.7, any new source subject to this subpart must achieve the following pretreatment standards:

Regulated parameter	Pretreatment standards <sup>1</sup>	
	Maximum daily discharge	Average monthly discharge must not exceed
1 Acetone .....	20.7	8.2
2 n-Amyl acetate .....	20.7	8.2
3 Ethyl acetate .....	20.7	8.2
4 Isopropyl acetate .....	20.7	8.2
5 Methylene chloride .....	3.0	0.7

<sup>1</sup> Mg/L (ppm).

[63 FR 50431, Sept. 21, 1998; 64 FR 48104, Sept. 2, 1999]

**Subpart C—Chemical Synthesis Products**

**§ 439.30 Applicability.**

This subpart applies to discharges of process wastewater resulting from the manufacture of pharmaceutical products by chemical synthesis.

[63 FR 50431, Sept. 21, 1998]

**§ 439.31 Special definitions.**

For the purpose of this subpart:

**40 CFR Ch. I (7–1–11 Edition)**

(a) *Chemical synthesis* means using one or a series of chemical reactions in the manufacturing process of a specified product.

(b) *Product* means any pharmaceutical product manufactured by chemical synthesis.

[68 FR 12273, Mar. 13, 2003]

**§ 439.32 Effluent limitations attainable by the application of the best practicable control technology currently available (BPT).**

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the application of BPT:

(a) The limitation for BOD<sub>5</sub> is the same as specified in § 439.12(a).

(b) The limitation for TSS is the same as specified in § 439.12(b).

(c) The limitations for COD are the same as specified in § 439.12(c) and (d).

(d) The limitations for cyanide are the same as specified in § 439.12(e), (f) and (g).

[63 FR 50431, Sept. 21, 1998, as amended at 68 FR 12273, Mar. 13, 2003]

**§ 439.33 Effluent limitations attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the application of BCT: Limitations for BOD<sub>5</sub>, TSS and pH are the same as the corresponding limitations in § 439.32.

[63 FR 50432, Sept. 21, 1998]

**§ 439.34 Effluent limitations attainable by the application of best available technology economically achievable (BAT).**

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the application of BAT:

(a) The limitations are the same as specified in § 439.14(a).

(b) The limitations for COD are the same as specified in § 439.12(c) and (d).