### § 62.14690

### MONITORING

# § 62.14690 What monitoring equipment must I install and what parameters must I monitor?

- (a) If you are using a wet scrubber to comply with the emission limitation under §62.14630, you must install, calibrate (to manufacturers' specifications), maintain, and operate devices (or establish methods) for monitoring the value of the operating parameters used to determine compliance with the operating limits listed in table 2 of this subpart. These devices (or methods) must measure and record the values for these operating parameters at the frequencies indicated in table 2 of this subpart at all times except as specified in §62.14695(a).
- (b) If you use a fabric filter to comply with the requirements of this subpart, you must install, calibrate, maintain, and continuously operate a bag leak detection system as specified in paragraphs (b)(1) through (8) of this section.
- (1) You must install and operate a bag leak detection system for each exhaust stack of the fabric filter.
- (2) Each bag leak detection system must be installed, operated, calibrated, and maintained in a manner consistent with the manufacturer's written specifications and recommendations.
- (3) The bag leak detection system must be certified by the manufacturer to be capable of detecting particulate matter emissions at concentrations of 10 milligrams per actual cubic meter or less
- (4) The bag leak detection system sensor must provide output of relative or absolute particulate matter loadings.
- (5) The bag leak detection system must be equipped with a device to continuously record the output signal from the sensor.
- (6) The bag leak detection system must be equipped with an alarm system that will sound automatically when an increase in relative particulate matter emissions over a preset level is detected. The alarm must be located where it is easily heard by plant operating personnel.
- (7) For positive pressure fabric filter systems, a bag leak detection system must be installed in each baghouse

compartment or cell. For negative pressure or induced air fabric filters, the bag leak detector must be installed downstream of the fabric filter.

- (8) Where multiple detectors are required, the system's instrumentation and alarm may be shared among detectors
- (c) If you are using an emission control system other than a wet scrubber to comply with the emission limitations under §62.14630, you must install, calibrate (to the manufacturers' specifications), maintain, and operate the equipment necessary to monitor compliance with the site-specific operating limits established using the procedures in §62.14640.

# § 62.14695 Is there a minimum amount of monitoring data I must obtain?

- (a) Except for monitoring malfunctions, associated repairs, and required quality assurance or quality control activities (including, as applicable, calibration checks and required zero and span adjustments of the monitoring system), you must conduct all monitoring at all times the CISWI unit is operating.
- (b) Do not use data recorded during monitor malfunctions, associated repairs, and required quality assurance or quality control activities for meeting the requirements of this subpart, including data averages and calculations. You must use all the data collected during all other periods in assessing compliance with the operating limits.

## RECORDKEEPING AND REPORTING

### §62.14700 What records must I keep?

You must maintain the 13 items (as applicable) as specified in paragraphs (a) through (m) of this section for a period of at least 5 years:

- (a) Calendar date of each record.
- (b) Records of the data described in paragraphs (b)(1) through (6) of this section:
- (1) The CISWI unit charge dates, times, weights, and hourly charge rates.
- (2) Liquor flow rate to the wet scrubber inlet every 15 minutes of operation, as applicable.