

§ 32.60-15

or such piping shall have a wall thickness equal to or greater than the innerbottom plating, but not less than schedule 80, and shall be welded continuously on both sides of the innerbottom plating.

[CGFR 65-50, 30 FR 16671, Dec. 30, 1965, as amended by CGFR 69-72, 34 FR 17481, Oct. 29, 1969]

§ 32.60-15 Segregation of cargo; Grade E—TB/ALL.

(a) *General.* The galleys, living quarters, navigation spaces, general cargo spaces, boilerrooms, and enclosed spaces containing machinery, where sources of vapor ignition are normally present, shall be segregated from the cargo tanks by tight bulkheads and intervening spaces are not required.

(b) *Cargo tank spaces.* Cargo tank spaces can be terminated at any deck with hatches on the same deck, but the vent lines shall be extended to the weather deck. Butterworth openings and extension rods may be located on the tank top.

§ 32.60-20 Pumprooms on tank vessels carrying Grade A, B, C, D and/or E liquid cargo—TB/ALL.

(a) *Cargo pumps.* In tank vessels carrying Grade A, B, C, or D liquid cargo, cargo pumps shall be isolated from source of vapor ignition by gastight bulkheads. A gastight bulkhead between the pumproom and the pump engine room may be pierced for drive shaft and pump engine control rods provided such openings are fitted with stuffing boxes or other approved gland arrangement. A steam driven pump shall not be considered a source of vapor ignition provided the steam temperature does not exceed 500 °F.

(b) *Ventilation for pumprooms on tank vessels the construction or conversion of which is started between July 1, 1951, and January 1, 1963.* (1) Pumprooms of all tank vessels, the construction or conversion of which is started between July 1, 1951, and January 1, 1963, shall be ventilated in such a way as to remove vapors from points near the floor level or bilges. Pumprooms on tankships handling Grade A, B, or C liquid cargo, with machinery located below the freeboard deck, shall be equipped with power ventilation. Pumprooms

46 CFR Ch. I (10-1-11 Edition)

equipped with power ventilation shall have the ventilation outlets terminate more than six feet from any opening to the interior part of the vessel which normally contains sources of vapor ignition.

(2) For all tank vessels, the construction or conversion of which is started between October 1, 1959, and January 1, 1963, the power ventilation shall not produce a source of vapor ignition in either the pumproom or the ventilation systems associated with the pumproom. The capacity of power ventilation units shall be sufficient to effect a complete change of air in not more than 3 minutes, based upon the volume of the pumproom and associated trunks up to the deck at which access from the weather is provided.

(c) *Ventilation for pumprooms on tank vessels the construction or conversion of which is started on or after January 1, 1963.* (1) For all tank vessels, the construction or conversion of which is started on or after January 1, 1963, the cargo pumprooms shall be fitted in accordance with paragraphs (a) and (d) of this section. Cargo pumprooms on these vessels shall be ventilated in such a way as to remove vapors from points near the floor level or bilges. Cargo pumprooms on tank vessels handling Grade A, B, or C liquid cargo, shall be equipped with power ventilation of the exhaust type having capacity sufficient to effect a complete change of air in not more than 3 minutes based upon the volume of the pumproom and associated trunks up to the deck at which access from the weather is provided.

(2) The power ventilation units shall not produce a source of vapor ignition in either the pumproom or the ventilation systems associated with the pumproom. Inlets to exhaust ducts shall be provided and located near the floor level at points where concentrations of vapors may be expected. Ventilation from the weather deck shall be provided. Power supply ventilation may be fitted in lieu of natural ventilation, but when fitted shall be arranged to avoid turbulence in the cargo pumproom. Cargo pumprooms equipped with power ventilation shall have the ventilation outlets terminate more than 6 feet from any opening to the interior