

chapter. Firehose nozzles previously approved under subpart 162.027 of this chapter may be retained so long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. A suitable hose rack or other device must be provided. Hose racks on weather decks must be located to afford protection from heavy seas. The hose must be stored in a location that is readily visible.

TABLE 34.10-10(e) HYDRANTS WITH COAST GUARD APPROVED LOW-VELOCITY WATER SPRAY APPLICATORS

Location	Number of hydrants with approved applicators	Approved applicator length (feet)
Living space	1	4
Weather deck	4	10 or 12
Machinery space	2	4

(f) Each combination firehose nozzle previously approved under subpart 162.027 of this chapter in the locations listed in table 34.10-10(E) must have a low-velocity water spray applicator also previously approved under subpart 162.027 of this chapter that is of the length listed in that table.

(g) The pipes and fire station hydrants shall be so placed that the fire hose may be easily coupled to them. All hydrants shall be so located as to be readily accessible. If deck cargo is carried, it shall not interfere with access to the fire station hydrants, and the pipes shall be arranged as far as practicable to avoid risk of damage by such cargo.

(h) Each fire station hydrant or “y” branch shall be equipped with a valve so that the hose may be removed while there is pressure on the fire main.

(i) Fire station hydrant connections shall be brass, bronze, or other equivalent metal. Couplings shall either:

- (1) Use National Standard fire hose coupling threads for the 1½ inch (38 millimeter) and 2½ inch (64 millimeter) hose sizes, i.e. 9 threads per inch for 1½ inch hose, and 7½ threads per inch for 2½ inch hose; or
- (2) Be a uniform design for each hose diameter throughout the vessel.

(j) Fire hose shall be 50 feet in length except on weather decks the hose shall

be increased in length if necessary to enable a single length to be goose-necked over each side of the vessel. If two fire mains are installed on the weather decks, the length of hose shall be such that it may be goose-necked over the side from the nearest fire main.

(k) Fire hose when part of the fire equipment shall not be used for any other purpose than fire extinguishing, fire drills, and testing.

(l) Fire hose shall be connected to outlets at all times. However, in heavy weather on open decks where no protection is afforded the hose may be removed temporarily from the hydrant and stowed in an accessible location nearby. While in port, fire hose in way of cargo area shall be kept ready for immediate use. The fire hose may be temporarily removed when it will interfere with the handling of cargo.

(m) Each section of fire hose used after January 1, 1980 must be lined commercial fire hose that conforms to Underwriters’ Laboratories, Inc. Standard 19 or Federal Specification ZZ-H-451E. Hose that bears the label of Underwriters’ Laboratories, Inc. as lined fire hose is accepted as conforming to this requirement. Each section of replacement fire hose or any section of new fire hose placed aboard a vessel after January 1, 1977 must also conform to the specification required by this paragraph.

(n) Coupling shall conform to the requirements of paragraph (h) of this section.

(o) Each low-velocity water spray applicator under paragraph (f) of this section must have fixed brackets, hooks, or other means for stowing next to the hydrant.

[CGFR 65-50, 30 FR 16694, Dec. 30, 1965, as amended by CGD 74-60, 41 FR 43151, Sept. 30, 1976; CGD 76-086, 44 FR 2391, Jan. 11, 1979; CGD 95-027, 61 FR 25999, May 23, 1996; CGD 95-028, 62 FR 51199, Sept. 30, 1997]

§ 34.10-15 Piping—T/ALL.

(a) All piping, valves and fittings shall meet the applicable requirements of subchapter F (Marine Engineering) of this chapter.

(b) An adequate number of valves shall be installed to isolate damaged

§ 34.10-90

46 CFR Ch. I (10-1-11 Edition)

sections of piping except on self-propelled vessels carrying bulk liquefied gases that must have stop valves:

- (1) At cross connections;
- (2) At the front of the after deck house; and
- (3) In the cargo area spaced 40 m (131 ft.) or less between hydrants.

(c) All distribution valves shall be marked as required by § 35.40-10 of this subchapter.

(d) Tankships of 500 gross tons and over on an international voyage must be provided with at least one international shore connection which meets ASTM F 1121 (incorporated by reference, see § 34.01-15). Facilities must be available enabling such a connection to be used on either side of the vessel.

(e) For tankships on an international voyage, the diameter of the fire main shall be sufficient for the effective distribution of the maximum required discharge from two fire pumps operating simultaneously. This requirement is in addition to § 34.10-5(b). The discharge of this quantity of water through hoses and nozzles at a sufficient number of adjacent hydrants shall be at a minimum Pitot tube pressure of approximately 71 pounds per square inch on self-propelled vessels that carry bulk liquefied gases and approximately 50 pounds per square inch on other tankships.

[CGFR 65-50, 30 FR 16694, Dec. 30, 1965, as amended by CGD 74-289, 44 FR 26006, May 3, 1979, CGD 88-032, 56 FR 35821, July 29, 1991; USCG-2000-7790, 65 FR 58459, Sept. 29, 2000]

§ 34.10-90 Installations contracted for prior to May 26, 1965—T/ALL.

(a) Installations contracted for prior to January 1, 1962, shall meet the following requirements:

(1) Existing arrangements, materials and facilities previously approved shall be considered satisfactory so long as they meet the minimum requirements of this paragraph and they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs and alterations may be made to the same standards as the original installation.

(2) Except as further modified by this paragraph, the details of the systems shall be in general agreement with

§§ 34.10-5 through 34.10-15 insofar as is reasonable and practicable.

(3) Tankships of less than 500 gross tons shall be equipped with an efficient hand pump capable of delivering 50 gallons per minute or a power-driven pump of equivalent capacity. However, on tankships of 20 gross tons or under where it is impracticable to install a hand or power-operated fire pump, or on tankships with only one man in the crew, at least one additional B-II fire extinguisher may be accepted in lieu of a fire pump.

(4) Tankships of 500 gross tons and over but not over 1,000 gross tons shall be provided with one independently power-driven pump.

(5) Tankships of over 1,000 gross tons shall be provided with two independently power-driven pumps.

(6) On tankships of 500 gross tons and over, the capacity of the combined fire pump installation shall be one-fifth gallon per minute per gross ton of the ship. The maximum total fire pump capacity required for any tankship shall be 800 gallons per minute.

(7) Each fire pump on a tankship of 500 gross tons or more must deliver enough water to the fire main so that the topmost outlet on the fire main emits two jets of water at a Pitot tube pressure of 50 pounds per square inch through two combination solid stream and water spray firehose nozzles meeting paragraph (10) of this section.

(8) On oil-burning tankships, provided with two fire pumps, where the engine and fire rooms are not entirely separated by iron or steel bulkheads, or if fuel can drain from fireroom bilges into the engineroom, one of the fire pumps shall be located in an accessible space separate from the machinery compartment. On all tankships contracted for on or after November 19, 1952, the requirements of paragraph (f) of § 34.10-5 shall be met.

(9) Fire hydrant outlets shall have a minimum diameter of 1½ inches.

(10) Each fire station hydrant on a tankship of 500 gross tons or more must have at least 1 length of firehose. Each firehose on the hydrant must have a combination solid stream and water spray firehose nozzle that meets the requirements of subpart 162.027. Firehose