

nozzles previously approved under subpart 162.027 of this chapter may be retained so long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection.

(11) On each tankship of 1000 gross tons or more, the firehose nozzle required by paragraph (a)(10) of this section on each of the following hydrants must have a low-velocity water-spray applicator that was previously approved under subpart 162.027 and that connects to that nozzle when the nozzle itself was previously approved under subpart 162.027—

(i) At least two hydrants in the Machinery and boiler spaces; and

(ii) At least 25 percent of other hydrants.

(12) Vessels contracted for on or after July 1, 1954, shall meet the requirements of § 34.10-10(h).

(b) Installations contracted for on or after January 1, 1962, but prior to May 26, 1965, shall meet the following requirements:

(1) Existing arrangements, materials, facilities, and equipment, except firehose nozzles, previously approved shall be considered satisfactory as long as they meet the minimum requirements of this paragraph and they are maintained in good conditions to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs and alterations may be made to the same standards as the original installation.

(2) Each fire station hydrant must have at least 1 length of firehose. Each firehose on the hydrant must have a combination solid stream and water spray firehose nozzle that meets the requirements of subpart 162.027. Firehose nozzles previously approved under subpart 162.027 of this chapter may be retained so long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. If the firehose nozzles were previously approved under subpart 162.027, each of the number of hydrants in the locations listed in table 34.10-10(E) must have a low-velocity water spray applicator that—

(i) Was previously approved under subpart 162.027 of this chapter;

(ii) Is the length listed in table 34.10-10(E); and

(iii) Meets § 34.10-10(o).

[CGFR 65-50, 30 FR 16694, Dec. 30, 1965, as amended by CGD 76-086, 44 FR 2391, Jan. 11, 1979; CGD 95-027, 61 FR 25999, May 23, 1996]

### Subpart 34.13—Steam Smothering Systems

SOURCE: CGD 95-027, 61 FR 25999, May 23, 1996, unless otherwise noted.

#### § 34.13-1 Application—T/ALL.

Steam smothering fire extinguishing systems are not permitted on vessels contracted for on or after January 1, 1962. Previously approved installations may be retained as long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection.

### Subpart 34.15—Carbon Dioxide Extinguishing Systems, Details

#### § 34.15-1 Application—T/ALL.

(a) Where a carbon dioxide extinguishing system is installed, the provisions of this subpart, with the exception of § 34.15-90, shall apply to all installations contracted for on or after January 1, 1962. Installations contracted for prior to January 1, 1962, shall meet the requirements of § 34.15-90.

(b) The requirements of this subpart are based on a “high pressure system,” i.e., one in which the carbon dioxide is stored in liquid form at atmospheric temperature. Details for “low pressure systems,” i.e., those in which the carbon dioxide is stored in liquid form at a continuously controlled low temperature, may be specifically approved by the Commandant where it is demonstrated that a comparable degree of safety and fire extinguishing ability is achieved.

#### § 34.15-5 Quantity, pipe sizes, and discharge rates—T/ALL.

(a) *General.* (1) The amount of carbon dioxide required for each space shall be as determined by paragraphs (b) through (d) of this section.

(b) *Total available supply.* (1) A separate supply of carbon dioxide need not be provided for each space protected. The total available supply shall be at

§ 34.15-5

46 CFR Ch. I (10-1-11 Edition)

least sufficient for the space requiring the greatest amount.

(c) *Dry cargo spaces.* (1) The number of pounds of carbon dioxide required for each space shall be equal to the gross volume of the space in cubic feet divided by 30.

(2) Although separate piping shall be led to each cargo hold and 'tween deck, for the purpose of determining the amount of carbon dioxide required, a cargo compartment will be considered as the space between watertight or firescreen bulkheads and from the tank top or lowest deck to the deck head of the uppermost space on which cargo may be carried. If a trunk extends beyond such deck, the trunk volume shall be included. Tonnage openings shall be considered as sealed for this purpose.

(3) Branch lines to the various cargo holds and 'tween decks shall not be less than 3/4-inch standard pipe size.

(4) No specific discharge rate need be applied to such systems.

(d) *Machinery spaces, pumprooms, paint lockers, and similar spaces.* (1) Except as provided in paragraph (d)(4) of this section, the number of pounds of carbon dioxide required for each space shall be equal to the gross volume of the space divided by the appropriate factor noted in Table 34.15-5(d)(1). If fuel can drain from the compartment being protected to an adjacent compartment, or if the compartments are not entirely separate, the requirements for both compartments shall be used to determine the amount of carbon dioxide to be provided. The carbon dioxide shall be arranged to discharge into both such compartments simultaneously.

TABLE 34.15-5(d)(1)

Gross volume of compartment, cubic feet		Factor
Over	Not Over	
	500	15
500	1,600	16
1,600	4,500	18
4,000	50,000	20
50,000	.....	22

(2) For the purpose of the above requirement of this paragraph, the volume of a machinery space shall be taken as exclusive of the normal machinery casing unless the boiler, inter-

nal combustion propelling machinery, or fuel oil installations subject to the discharge pressure of the fuel oil service pump extend into such space, in which case the volume shall be taken to the top of the casing or the next material reduction in casing area, whichever is lower. The terms "normal machinery casing" and "material reduction in casing area" shall be defined as follows:

(i) By "normal machinery casing" shall be meant a casing the area of which is not more than 40 percent of the maximum area of the machinery space.

(ii) By "material reduction in casing area" shall be meant a reduction to at least 40 percent of the casing area.

(3) For the purpose of the above requirements of this paragraph, the volume of a pumproom shall include the pumproom and all associated trunks up to the deck at which access from the weather is provided.

(4) For tankships on an international voyage contracted for on or after May 26, 1965, the amount of carbon dioxide required for a space containing propulsion boilers or internal combustion propulsion machinery shall be as given by paragraphs (d) (1) and (2) of this section or by dividing the entire volume, including the casing, by a factor of 25, whichever is the larger.

(5) Branch lines in the various spaces shall be noted in Table 34.15-5(d)(5).

TABLE 34.15-5(d)(5)

Maximum quantity of carbon dioxide required, pounds	Minimum pipe sizes, inches	Maximum quantity of carbon dioxide required, pounds	Minimum pipe size inches
100	1/2	2,500	2 1/2
225	3/4	4,450	3
300	1	7,100	3 1/2
600	1 1/4	10,450	4
1,000	1 1/2	15,000	4 1/2
2,450	2	.....	.....

(6) Distribution piping within the space shall be proportioned from the supply line to give proper distribution to the outlets without throttling.

(7) The number, type and location of discharge outlets shall be such as to give a uniform distribution throughout the space.

(8) The total area of all discharge outlets shall not exceed 85 percent nor

be less than 35 percent of the nominal cylinder outlet area or the area of the supply pipe, whichever is smaller. The nominal cylinder outlet area in square inches shall be determined by multiplying the factor 0.0022 by the number of pounds of carbon dioxide required, except that in no case shall this outlet area be less than 0.110 square inches.

(9) The discharge of at least 85 percent of the required amount of carbon dioxide shall be complete within 2 minutes.

[CGFR 65-50, 30 FR 16694, Dec. 30, 1965, as amended at 45 FR 64188, Sept. 29, 1980; CGD 95-028, 62 FR 51199, Sept. 30, 1997; USCG-1999-6216, 64 FR 53223, Oct. 1, 1999]

#### § 34.15-10 Controls—T/ALL.

(a) Except as noted in § 34.15-20(b), all controls and valves for the operation of the system shall be outside the space protected, and shall not be located in any space that might be cut off or made inaccessible in the event of fire in any of the spaces protected.

(b) If the same cylinders are used to protect more than one space, a manifold with normally closed stop valves shall be used to direct the carbon dioxide into the proper space. If cylinders are used to protect only one space, a normally closed stop valve shall be installed between the cylinders and the space except for systems of the type indicated in § 34.15-5(d) which contain not more than 300 pounds of carbon dioxide.

(c) Distribution piping to the dry cargo spaces shall be controlled from not more than two stations. One of the stations controlling the system for the main machinery space shall be located as convenient as practicable to one of the main-escapes from the space. All control stations and the individual valves and controls shall be marked as required by § 35.40-10 of the subchapter.

(d) Systems of the type indicated in § 34.15-5(d) shall be actuated at each station by one control operating the valve to the space and a separate control releasing at least the required amount of carbon dioxide. These two controls shall be located in a box or other enclosure clearly identified for the particular space. Systems installed without a stop valve shall be operated

by one control releasing at least the required amount of carbon dioxide.

(e) Where provisions are made for the simultaneous release of a given amount of carbon dioxide by operation of a remote control, provisions shall also be made for manual control at the cylinders. Where gas pressure from pilot cylinders is used as a means for releasing the remaining cylinders, not less than two pilot cylinders shall be used for systems consisting of more than two cylinders. Each of the pilot cylinders shall be capable of manual control at the cylinder, but the remaining cylinders need not be capable of individual manual control.

(f) Systems of the type indicated in § 34.15-5(d), which are of more than 300 pounds of carbon dioxide shall be fitted with an approved delayed discharge so arranged that the alarm will be sounded for at least 20 seconds before the carbon dioxide is released into the space. Such systems of not more than 300 pounds of carbon dioxide shall also have a similar delayed discharge, except for spaces which have a suitable horizontal escape.

(g) All distribution valves and controls shall be of an approved type. All controls shall be suitably protected.

(h) Complete but simple instructions for the operation of the systems must be located in a conspicuous place at or near all pull boxes, stop valve controls and in the CO<sub>2</sub> cylinder storage room. On systems in which the CO<sub>2</sub> cylinders are not within the protected space, these instructions must also include a schematic diagram of the system and instructions detailing alternate methods of discharging the system should the manual release or stop valve controls fail to operate. Each control valve to branch lines must be marked to indicate the related space served.

(i) If the space or enclosure containing the carbon dioxide supply or controls is to be locked, a key to the space or enclosure shall be in a break-glass-type box conspicuously located adjacent to the opening.

[CGFR 65-50, 30 FR 16694, Dec. 30, 1965, as amended by CGD 74-100R, 40 FR 6208, Feb. 10, 1975; USCG-1999-6216, 64 FR 53223, Oct. 1, 1999]