

Coast Guard, DHS

§ 118.300

160.156 is acceptable in meeting the intent of this section. On a vessel of not more than 19.8 meters (65 feet) in length, a required rescue boat must be acceptable to the cognizant OCMI.

[CGD 85-080, 61 FR 911, Jan. 10, 1996, as amended at 62 FR 51351, Sept. 30, 1997; 62 FR 64305, Dec. 5, 1997]

PART 118—FIRE PROTECTION EQUIPMENT

Subpart A—General Provisions

Sec.

118.115 Applicability to existing vessels.

118.120 Equipment installed but not required.

Subpart B [Reserved]

Subpart C—Fire Main System

118.300 Fire pumps.

118.310 Fire main and hydrants.

118.320 Fire hoses and nozzles.

Subpart D—Fixed Fire Extinguishing and Detecting Systems

118.400 Where required.

118.410 Fixed gas fire extinguishing systems.

118.420 Pre-engineered fixed gas fire extinguishing systems.

118.425 Galley hood fire extinguishing systems.

Subpart E—Portable Fire Extinguishers

118.500 Required number, type, and location.

118.520 Installation and location.

Subpart F—Additional Equipment

118.600 Fire axe.

AUTHORITY: 46 U.S.C. 2103, 3306; E.O. 12234, 45 FR 58801, 3 CFR, 1980 Comp., p. 277; Department of Homeland Security Delegation No. 0170.1.

SOURCE: CGD 85-080, 61 FR 917, Jan. 10, 1996, unless otherwise noted.

Subpart A—General Provisions

§ 118.115 Applicability to existing vessels.

(a) Except as otherwise required by paragraphs (b) and (c) of this section, an existing vessel must comply with the fire protection equipment regulations applicable to the vessel on March

10, 1996, or, as an alternative, the vessel may comply with the regulation in this part.

(b) An existing vessel with a hull, or a machinery space boundary bulkhead or deck, composed of wood or fiber reinforced plastic, or sheathed on the interior in fiber reinforced plastic, must comply with the requirements of § 118.400 of this part on or before March 11, 1999.

(c) New installations of fire protection equipment on an existing vessel, which are completed to the satisfaction of the cognizant Officer in Charge, Marine Inspection (OCMI) on or after March 11, 1996, must comply with the regulations of this part. Replacement of existing equipment installed on the vessel prior to March 11, 1996, need not comply with the regulations in this part.

§ 118.120 Equipment installed but not required.

Fire extinguishing and detecting equipment installed on a vessel in excess of the requirements of §§ 118.400 and 118.500 of this part must be designed, constructed, installed and maintained in a manner acceptable to the Commandant.

Subpart B [Reserved]

Subpart C—Fire Main System

§ 118.300 Fire pumps.

(a) A self priming, power driven fire pump must be installed on each vessel.

(b) On a vessel without overnight accommodations, or with overnight accommodations for not more than 49 passengers, the fire pump must be capable of delivering a single hose stream from the highest hydrant, through the hose and nozzle required by § 118.320 of this part, at a pitot tube pressure of 345 kPa (50 psi).

(c) On a vessel carrying more than 600 passengers or with overnight accommodations for more than 49 passengers, the fire pump must meet § 76.10-5 of this chapter.

(d) A fire pump may be driven by a propulsion engine. A fire pump must be permanently connected to the fire main and may be connected to the