

## § 72.34

(ii) Provisions that exist for prompt communications among principal response organizations to offsite emergency personnel who would be responding onsite.

(iii) Adequate emergency facilities and equipment to support the emergency response onsite are provided and maintained.

(iv) Adequate methods, systems, and equipment for assessing and monitoring actual or potential consequences of a radiological emergency condition are available.

(v) Arrangements are made for medical services for contaminated and injured onsite individuals.

(vi) Radiological Emergency Response Training has been made available to those offsite who may be called to assist in an emergency onsite.

(16) Arrangements made for providing information to the public.

(c) For an ISFSI that is:

(1) located on the site, or

(2) located within the exclusion area as defined in 10 CFR part 100, of a nuclear power reactor licensed for operation by the Commission, the emergency plan required by 10 CFR 50.47 shall be deemed to satisfy the requirements of this section.

(d) A licensee with a license issued under this part may take reasonable action that departs from a license condition or a technical specification (contained in a license issued under this part) in an emergency when this action is immediately needed to protect the public health and safety and no action consistent with license conditions and technical specifications that can provide adequate or equivalent protection is immediately apparent.

[60 FR 32441, June 22, 1995]

## § 72.34 Environmental report.

Each application for an ISFSI or MRS license under this part must be accompanied by an Environmental Report which meets the requirements of subpart A of part 51 of this chapter.

## 10 CFR Ch. I (1–12 Edition)

### Subpart C—Issuance and Conditions of License

#### § 72.40 Issuance of license.

(a) Except as provided in paragraph (c) of this section, the Commission will issue a license under this part upon a determination that the application for a license meets the standards and requirements of the Act and the regulations of the Commission, and upon finding that:

(1) The applicant's proposed ISFSI or MRS design complies with subpart F;

(2) The proposed site complies with the criteria in subpart E;

(3) If on the site of a nuclear power plant or other licensed activity or facility, the proposed ISFSI would not pose an undue risk to the safe operation of such nuclear power plant or other licensed activity or facility;

(4) The applicant is qualified by reason of training and experience to conduct the operation covered by the regulations in this part;

(5) The applicant's proposed operating procedures to protect health and to minimize danger to life or property are adequate;

(6) Except for DOE, the applicant for an ISFSI or MRS is financially qualified to engage in the proposed activities in accordance with the regulations in this part;

(7) The applicant's quality assurance plan complies with subpart G;

(8) The applicant's physical protection provisions comply with subpart H. DOE has complied with the safeguards and physical security provisions identified in § 72.24(o);

(9) The applicant's personnel training program complies with subpart I;

(10) Except for DOE, the applicant's decommissioning plan and its financing pursuant to § 72.30 provide reasonable assurance that the decontamination and decommissioning of the ISFSI or MRS at the end of its useful life will provide adequate protection to the health and safety of the public;

(11) The applicant's emergency plan complies with § 72.32;

(12) The applicable provisions of part 170 of this chapter have been satisfied;

(13) There is reasonable assurance that: (i) The activities authorized by the license can be conducted without

endangering the health and safety of the public and (ii) these activities will be conducted in compliance with the applicable regulations of this chapter; and

(14) The issuance of the license will not be inimical to the common defense and security.

(b) A license to store spent fuel and reactor-related GTCC waste in the proposed ISFSI or to store spent fuel, high-level radioactive waste, and reactor-related GTCC waste in the proposed MRS may be denied if construction on the proposed facility begins before a finding approving issuance of the proposed license with any appropriate conditions to protect environmental values. Grounds for denial may be the commencement of construction prior to a finding by the Director, Office of Nuclear Materials Safety and Safeguards or designee or a finding after a public hearing by the presiding officer, Atomic Safety and Licensing Board, or the Commission acting as a collegial body, as appropriate, that the action called for is the issuance of the proposed license with any appropriate conditions to protect environmental values. This finding is to be made on the basis of information filed and evaluations made pursuant to subpart A of part 51 of this chapter or in the case of an MRS on the basis of evaluations made pursuant to sections 141(c) and (d) or 148(a) and (c) of NWPA (96 Stat. 2242, 2243, 42 U.S.C. 10161(c), (d); 101 Stat. 1330-235, 1330-236, 42 U.S.C. 10168(a), (c)), as appropriate, and after weighing the environmental, economic, technical and other benefits against environmental costs and considering available alternatives.

(c) For facilities that have been covered under previous licensing actions including the issuance of a construction permit under part 50 of this chapter, a reevaluation of the site is not required except where new information is discovered which could alter the original site evaluation findings. In this case, the site evaluation factors involved will be reevaluated.

[53 FR 31658, Aug. 19, 1988, as amended at 66 FR 51840, Oct. 11, 2001]

#### § 72.42 Duration of license; renewal.

(a) Each license issued under this part must be for a fixed period of time to be specified in the license. The license term for an ISFSI must not exceed 40 years from the date of issuance. The license term for an MRS must not exceed 40 years from the date of issuance. Licenses for either type of installation may be renewed by the Commission at the expiration of the license term upon application by the licensee for a period not to exceed 40 years and under the requirements of this rule. Application for ISFSI license renewals must include the following:

(1) TLAAAs that demonstrate that structures, systems, and components important to safety will continue to perform their intended function for the requested period of extended operation; and

(2) A description of the AMP for management of issues associated with aging that could adversely affect structures, systems, and components important to safety.

(b) Applications for renewal of a license should be filed in accordance with the applicable provisions of subpart B of this part at least 2 years before the expiration of the existing license. The application must also include design bases information as documented in the most recently updated FSAR as required by § 72.70. Information contained in previous applications, statements, or reports filed with the Commission under the license may be incorporated by reference provided that these references are clear and specific.

(c) In any case in which a licensee, not less than two years prior to expiration of its existing license, has filed an application in proper form for renewal of a license, the existing license shall not expire until a final decision concerning the application for renewal has been made by the Commission.

[53 FR 31658, Aug. 19, 1988, as amended at 76 FR 8890, Feb. 16, 2011]

#### § 72.44 License conditions.

(a) Each license issued under this part shall include license conditions. The license conditions may be derived