

### § 35.1345

(2) Sample the floor in a room, hallway, stairwell, or common area connected to the dust containment area, within five feet outside the area (one sample).

[64 FR 50218, Sept. 15, 1999, as amended at 69 FR 34274, June 21, 2004]

### § 35.1345 Occupant protection and worksite preparation.

This section establishes procedures for protecting dwelling unit occupants and the environment from contamination from lead-contaminated or lead-containing materials during hazard reduction activities.

(a) *Occupant protection.* (1) Occupants shall not be permitted to enter the worksite during hazard reduction activities (unless they are employed in the conduct of these activities at the worksite), until after hazard reduction work has been completed and clearance, if required, has been achieved.

(2) Occupants shall be temporarily relocated before and during hazard reduction activities to a suitable, decent, safe, and similarly accessible dwelling unit that does not have lead-based paint hazards, except if:

(i) Treatment will not disturb lead-based paint, dust-lead hazards or soil-lead hazards;

(ii) Only the exterior of the dwelling unit is treated, and windows, doors, ventilation intakes and other openings in or near the worksite are sealed during hazard control work and cleaned afterward, and entry free of dust-lead hazards, soil-lead hazards, and debris is provided;

(iii) Treatment of the interior will be completed within one period of 8-day-time hours, the worksite is contained so as to prevent the release of leaded dust and debris into other areas, and treatment does not create other safety, health or environmental hazards (e.g., exposed live electrical wiring, release of toxic fumes, or on-site disposal of hazardous waste); or

(iv) Treatment of the interior will be completed within 5 calendar days, the worksite is contained so as to prevent the release of leaded dust and debris into other areas, treatment does not create other safety, health or environmental hazards; and, at the end of work on each day, the worksite and the

### 24 CFR Subtitle A (4-1-12 Edition)

area within at least 10 feet (3 meters) of the containment area is cleaned to remove any visible dust or debris, and occupants have safe access to sleeping areas, and bathroom and kitchen facilities.

(3) The dwelling unit and the worksite shall be secured against unauthorized entry, and occupants' belongings protected from contamination by dust-lead hazards and debris during hazard reduction activities. Occupants' belongings in the containment area shall be relocated to a safe and secure area outside the containment area, or covered with an impermeable covering with all seams and edges taped or otherwise sealed.

(b) *Worksite preparation.* (1) The worksite shall be prepared to prevent the release of leaded dust, and contain lead-based paint chips and other debris from hazard reduction activities within the worksite until they can be safely removed. Practices that minimize the spread of leaded dust, paint chips, soil and debris shall be used during worksite preparation.

(2) A warning sign shall be posted at each entry to a room where hazard reduction activities are conducted when occupants are present; or at each main and secondary entryway to a building from which occupants have been relocated; or, for an exterior hazard reduction activity, where it is easily read 20 feet (6 meters) from the edge of the hazard reduction activity worksite. Each warning sign shall be as described in 29 CFR 1926.62(m), except that it shall be posted irrespective of employees' lead exposure and, to the extent practicable, provided in the occupants' primary language.

### § 35.1350 Safe work practices.

(a) *Prohibited methods.* Methods of paint removal listed in § 35.140 shall not be used.

(b) *Occupant protection and worksite preparation.* Occupants and their belongings shall be protected, and the worksite prepared, in accordance with § 35.1345. A person performing this work shall be trained on hazards and either be supervised or have completed successfully one of the specified courses, in accordance with § 35.1330(a)(4).