

**Pt. 63, Subpt. UUUUU, Table 1**

**40 CFR Ch. I (7-1-12 Edition)**

*Work practice standard* means any design, equipment, work practice, or operational standard, or combination

thereof, which is promulgated pursuant to CAA section 112(h).

[77 FR 9464, Feb. 16, 2012, as amended at 77 FR 23405, Apr. 19, 2012]

**TABLE 1 TO SUBPART UUUUU OF PART 63—EMISSION LIMITS FOR NEW OR RECONSTRUCTED EGUS**

As stated in § 63.9991, you must comply with the following applicable emission limits:

If your EGU is in this subcategory . . .	For the following pollutants . . .	You must meet the following emission limits and work practice standards . . .	Using these requirements, as appropriate (e.g., specified sampling volume or test run duration) and limitations with the test methods in Table . . .
1. Coal-fired unit not low rank virgin coal.	<p>a. Filterable particulate matter (PM). OR Total non-Hg HAP metals OR individual HAP metals: .....</p> <p>Antimony (Sb) ..... Arsenic (As) ..... Beryllium (Be) ..... Cadmium (Cd) ..... Chromium (Cr) ..... Cobalt (Co) ..... Lead (Pb) ..... Manganese (Mn) ..... Nickel (Ni) ..... Selenium (Se) .....</p> <p>b. Hydrogen chloride (HC1) ...  OR. Sulfur dioxide (<math>\text{SO}_2</math>)<sup>3</sup> .....</p> <p>c. Mercury (Hg) .....</p>	<p>7.0E-3 lb/MWh<sup>1</sup> ..... OR 6.0E-2 lb/GWh .....</p> <p>OR</p> <p>8.0E-3 lb/GWh. 3.0E-3 lb/GWh. 6.0E-4 lb/GWh. 4.0E-4 lb/GWh. 7.0E-3 lb/GWh. 2.0E-3 lb/GWh. 2.0E-3 lb/GWh. 4.0E-3 lb/GWh. 4.0E-2 lb/GWh. 6.0E-3 lb/GWh. 4.0E-4 lb/MWh .....</p> <p>4.0E-1 lb/MWh .....</p> <p>2.0E-4 lb/GWh .....</p>	<p>Collect a minimum of 4 dscm per run.</p> <p>Collect a minimum of 4 dscm per run.</p> <p>Collect a minimum of 3 dscm per run.</p> <p>For Method 26A, collect a minimum of 3 dscm per run. For ASTM D6348-03<sup>2</sup> or Method 320, sample for a minimum of 1 hour.</p> <p><math>\text{SO}_2</math> CEMS. Hg CEMS or sorbent trap monitoring system only.</p>
2. Coal-fired units low rank virgin coal.	<p>a. Filterable particulate matter (PM). OR Total non-Hg HAP metals .....</p> <p>OR Individual HAP metals:  Antimony (Sb) ..... Arsenic (As) ..... Beryllium (Be) ..... Cadmium (Cd) ..... Chromium (Cr) ..... Cobalt (Co) ..... Lead (Pb) ..... Manganese (Mn) ..... Nickel (Ni) ..... Selenium (Se) .....</p> <p>b. Hydrogen chloride (HCl) ...  OR Sulfur dioxide (<math>\text{SO}_2</math>)<sup>3</sup> .....</p>	<p>7.0E-3 lb/MWh<sup>1</sup> ..... OR 6.0E-2 lb/GWh .....</p> <p>OR</p> <p>8.0E-3 lb/GWh. 3.0E-3 lb/GWh. 6.0E-4 lb/GWh. 4.0E-4 lb/GWh. 7.0E-3 lb/GWh. 2.0E-3 lb/GWh. 2.0E-3 lb/GWh. 4.0E-3 lb/GWh. 4.0E-2 lb/GWh. 6.0E-3 lb/GWh. 4.0E-4 lb/MWh .....</p> <p>4.0E-1 lb/MWh .....</p>	<p>Collect a minimum of 4 dscm per run.</p> <p>Collect a minimum of 4 dscm per run.</p> <p>Collect a minimum of 3 dscm per run.</p> <p>For Method 26A, collect a minimum of 3 dscm per run. For ASTM D6348-03<sup>2</sup> or Method 320, sample for a minimum of 1 hour.</p> <p><math>\text{SO}_2</math> CEMS.</p>

**Environmental Protection Agency**
**Pt. 63, Subpt. UUUUU, Table 1**

If your EGU is in this subcategory . . .	For the following pollutants . . .	You must meet the following emission limits and work practice standards . . .	Using these requirements, as appropriate (e.g., specified sampling volume or test run duration) and limitations with the test methods in Table . . .
	c. Mercury (Hg) .....	4.0E-2 lb/GWh .....	Hg CEMS or sorbent trap monitoring system only.
3. IGCC unit .....	a. Filterable particulate matter (PM). OR Total non-Hg HAP metals .....  OR Individual HAP metals:  Antimony (Sb) ..... Arsenic (As) ..... Beryllium (Be) ..... Cadmium (Cd) ..... Chromium (Cr) ..... Cobalt (Co) ..... Lead (Pb) ..... Manganese (Mn) ..... Nickel (Ni) ..... Selenium (Se) ..... b. Hydrogen chloride (HCl) ....  OR Sulfur dioxide ( $\text{SO}_2$ ) <sup>3</sup> c. Mercury (Hg) .....	7.0E-2 lb/MWh <sup>4</sup> ..... 9.0E-2 lb/MWh <sup>5</sup> ..... OR 4.0E-1 lb/GWh .....	Collect a minimum of 1 dscm per run.  Collect a minimum of 1 dscm per run.  Collect a minimum of 2 dscm per run.  For Method 26A, collect a minimum of 1 dscm per run; for Method 26, collect a minimum of 120 liters per run. For ASTM D6348-03 <sup>2</sup> or Method 320, sample for a minimum of 1 hour.  SO <sub>2</sub> CEMS. Hg CEMS or sorbent trap monitoring system only.
4. Liquid oil-fired unit—continental (excluding limited-use liquid oil-fired subcategory units).	a. Filterable particulate matter (PM).  OR Total HAP metals .....  OR Individual HAP metals:  Antimony (Sb) ..... Arsenic (As) ..... Beryllium (Be) ..... Cadmium (Cd) ..... Chromium (Cr) ..... Cobalt (Co) ..... Lead (Pb) ..... Manganese (Mn) ..... Nickel (Ni) ..... Selenium (Se) ..... Mercury (Hg)  b. Hydrogen chloride (HCl)	7.0E-2 lb/MWh <sup>1</sup> ..... 2.0E-4 lb/MWh .....	Collect a minimum of 1 dscm per run.  Collect a minimum of 2 dscm per run.  Collect a minimum of 2 dscm per run.  For Method 30B sample volume determination (Section 8.2.4), the estimated Hg concentration should nominally be $<\frac{1}{2}$ the standard. For Method 26A, collect a minimum of 3 dscm per run. For ASTM D6348-03 <sup>2</sup> or Method 320, sample for a minimum of 1 hour.

Pt. 63, Subpt. UUUUU, Table 1

40 CFR Ch. I (7-1-12 Edition)

If your EGU is in this subcategory . . .	For the following pollutants . . .	You must meet the following emission limits and work practice standards . . .	Using these requirements, as appropriate (e.g., specified sampling volume or test run duration) and limitations with the test methods in Table . . .
	c. Hydrogen fluoride (HF)	4.0E-4 lb/MWh .....	For Method 26A, collect a minimum of 3 dscm per run. For ASTM D6348-03 <sup>2</sup> or Method 320, sample for a minimum of 1 hour.
5. Liquid oil-fired unit—non-continental (excluding limited-use liquid oil-fired sub-category units).	a. Filterable particulate matter (PM).  OR Total HAP metals  OR Individual HAP metals:  Antimony (Sb) ..... Arsenic (As) ..... Beryllium (Be) ..... Cadmium (Cd) ..... Chromium (Cr) ..... Cobalt (Co) ..... Lead (Pb) ..... Manganese (Mn) ..... Nickel (Ni) ..... Selenium (Se) ..... Mercury (Hg) .....	2.0E-1 lb/MWh <sup>1</sup> .....  OR 7.0E-3 lb/MWh .....	Collect a minimum of 1 dscm per run.  Collect a minimum of 1 dscm per run.  Collect a minimum of 3 dscm per run.  For Method 30B sample volume determination (Section 8.2.4), the estimated Hg concentration should nominally be < ½ the standard.
	b. Hydrogen chloride (HCl)	2.0E-3 lb/MWh .....	For Method 26A, collect a minimum of 1 dscm per run; for Method 26, collect a minimum of 120 liters per run. For ASTM D6348-03 <sup>2</sup> or Method 320, sample for a minimum of 1 hour
	c. Hydrogen fluoride (HF)	5.0E-4 lb/MWh .....	For Method 26A, collect a minimum of 3 dscm per run. For ASTM D6348-03 <sup>2</sup> or Method 320, sample for a minimum of 1 hour.
6. Solid oil-derived fuel-fired unit.	a. Filterable particulate matter (PM).  OR Total non-Hg HAP metals  OR Individual HAP metals:  Antimony (Sb) ..... Arsenic (As) ..... Beryllium (Be) ..... Cadmium (Cd) ..... Chromium (Cr) ..... Cobalt (Co) ..... Lead (Pb) ..... Manganese (Mn) ..... Nickel (Ni) ..... Selenium (Se) ..... b. Hydrogen chloride (HCl) .....	2.0E-2 lb/MWh <sup>1</sup> .....  OR 6.0E-1 lb/GWh .....	Collect a minimum of 1 dscm per run.  Collect a minimum of 1 dscm per run.  Collect a minimum of 3 dscm per run.  For Method 26A, collect a minimum of 3 dscm per run. For ASTM D6348-03 <sup>2</sup> or Method 320, sample for a minimum of 1 hour.

**Environmental Protection Agency**
**Pt. 63, Subpt. UUUUU, Table 2**

If your EGU is in this subcategory . . .	For the following pollutants . . .	You must meet the following emission limits and work practice standards . . .	Using these requirements, as appropriate (e.g., specified sampling volume or test run duration) and limitations with the test methods in Table . . .
	OR Sulfur dioxide ( $\text{SO}_2$ ) <sup>3</sup> ..... c. Mercury (Hg) .....	4.0E-1 lb/MMBtu or 5.0E-1 lb/GWh ..... 2.0E-3 lb/GWh .....	$\text{SO}_2$ CEMS. Hg CEMS or Sorbent trap monitoring system only.

<sup>1</sup> Gross electric output.

<sup>2</sup> Incorporated by reference, see § 63.14.

<sup>3</sup> You may not use the alternate  $\text{SO}_2$  limit if your EGU does not have some form of FGD system and  $\text{SO}_2$  CEMS installed.

<sup>4</sup> Duct burners on syngas; gross electric output.

<sup>5</sup> Duct burners on natural gas; gross electric output

**TABLE 2 TO SUBPART UUUUU OF PART 63—EMISSION LIMITS FOR EXISTING EGUs**

As stated in § 63.9991, you must comply with the following applicable emission limits:<sup>1</sup>

If your EGU is in this sub-category . . .	For the following pollutants . . .	You must meet the following emission limits and work practice standards . . .	Using these requirements, as appropriate (e.g., specified sampling volume or test run duration) and limitations with the test methods in Table 5 . . .
1. Coal-fired unit not low rank virgin coal.	a. Filterable particulate matter (PM). OR Total non-Hg HAP metals ..... OR Individual HAP metals:  Antimony (Sb) ..... Arsenic (As) ..... Beryllium (Be) ..... Cadmium (Cd) ..... Chromium (Cr) ..... Cobalt (Co) ..... Lead (Pb) ..... Manganese (Mn) ..... Nickel (Ni) ..... Selenium (Se) .....  b. Hydrogen chloride (HCl) ....  OR Sulfur dioxide ( $\text{SO}_2$ ) <sup>4</sup> ..... c. Mercury (Hg) .....	3.0E-2 lb/MMBtu or 3.0E-1 lb/MWh. <sup>2</sup> OR 5.0E-5 lb/MMBtu or 5.0E-1 lb/GWh. OR 8.0E-1 lb/TBtu or 8.0E-3 lb/GWh. 1.1E0 lb/TBtu or 2.0E-2 lb/GWh. 2.0E-1 lb/TBtu or 2.0E-3 lb/GWh. 3.0E-1 lb/TBtu or 3.0E-3 lb/GWh. 2.8E0 lb/TBtu or 3.0E-2 lb/GWh. 8.0E-1 lb/TBtu or 8.0E-3 lb/GWh. 1.2E0 lb/TBtu or 2.0E-2 lb/GWh. 4.0E0 lb/TBtu or 5.0E-2 lb/GWh. 3.5E0 lb/TBtu or 4.0E-2 lb/GWh. 5.0E0 lb/TBtu or 6.0E-2 lb/GWh. 2.0E-3 lb/MMBtu or 2.0E-2 lb/MWh.  OR 2.0E-1 lb/MMBtu or 1.5E0 lb/MWh. 1.2E0 lb/TBtu or 1.3E-2 lb/GWh.	Collect a minimum of 1 dscm per run. Collect a minimum of 1 dscm per run. Collect a minimum of 3 dscm per run.  For Method 26A, collect a minimum of 0.75 dscm per run; for Method 26, collect a minimum of 120 liters per run. For ASTM D6348-03 <sup>3</sup> or Method 320, sample for a minimum of 1 hour.  SO <sub>2</sub> CEMS. LEE Testing for 30 days with 10 days maximum per Method 30B run or Hg CEMS or sorbent trap monitoring system only. Collect a minimum of 1 dscm per run. Collect a minimum of 1 dscm per run.
2. Coal-fired unit low rank virgin coal.	a. Filterable particulate matter (PM). OR Total non-Hg HAP metals .....	3.0E-2 lb/MMBtu or 3.0E-1 lb/MWh. <sup>2</sup> OR 5.0E-5 lb/MMBtu or 5.0E-1 lb/GWh.	Collect a minimum of 1 dscm per run.