

all forms supplied to the cogeneration unit, excluding energy produced by the cogeneration unit itself. Each form of energy supplied shall be measured by the lower heating value of that form of energy calculated as follows:

$$\text{LHV} = \text{HHV} - 10.55(\text{W} + 9\text{H})$$

Where:

LHV = lower heating value of fuel in Btu/lb,  
 HHV = higher heating value of fuel in Btu/lb,  
 W = Weight % of moisture in fuel, and  
 H = Weight % of hydrogen in fuel.

*Total energy output* means, with regard to a cogeneration unit, the sum of useful power and useful thermal energy produced by the cogeneration unit.

*Unit* means a stationary, fossil-fuel-fired boiler or combustion turbine or other stationary, fossil-fuel-fired combustion device.

*Unit operating day* means a calendar day in which a unit combusts any fuel.

*Unit operating hour* or *hour of unit operation* means an hour in which a unit combusts any fuel.

*Useful power* means, with regard to a cogeneration unit, electricity or mechanical energy made available for use, excluding any such energy used in the power production process (which process includes, but is not limited to, any on-site processing or treatment of fuel combusted at the unit and any on-site emission controls).

*Useful thermal energy* means, with regard to a cogeneration unit, thermal energy that is:

(1) Made available to an industrial or commercial process (not a power production process), excluding any heat contained in condensate return or makeup water;

(2) Used in a heating application (*e.g.*, space heating or domestic hot water heating); or

(3) Used in a space cooling application (*i.e.*, thermal energy used by an absorption chiller).

*Utility power distribution system* means the portion of an electricity grid owned or operated by a utility and dedicated to delivering electricity to customers.

[65 FR 2727, Jan. 18, 2000, as amended at 71 FR 74795, Dec. 13, 2006; 72 FR 59207, Oct. 19, 2007]

### § 97.303 Measurements, abbreviations, and acronyms.

Measurements, abbreviations, and acronyms used in this subpart and subparts BBBB through IIII are defined as follows:

Btu—British thermal unit.  
 CO<sub>2</sub>—carbon dioxide.  
 H<sub>2</sub>O—water.  
 Hg—mercury.  
 hr—hour.  
 kW—kilowatt electrical.  
 kWh—kilowatt hour.  
 lb—pound.  
 mmBtu—million Btu.  
 MWe—megawatt electrical.  
 MWh—megawatt hour.  
 NO<sub>x</sub>—nitrogen oxides.  
 O<sub>2</sub>—oxygen.  
 ppm—parts per million.  
 scfh—standard cubic feet per hour.  
 SO<sub>2</sub>—sulfur dioxide.  
 yr—year.

### § 97.304 Applicability.

(a) Except as provided in paragraph (b) of this section:

(1) The following units in a State shall be CAIR NO<sub>x</sub> Ozone Season units, and any source that includes one or more such units shall be a CAIR NO<sub>x</sub> Ozone Season source, subject to the requirements of this subpart and subparts BBBB through HHHH of this part: any stationary, fossil-fuel-fired boiler or stationary, fossil-fuel-fired combustion turbine serving at any time, since the later of November 15, 1990 or the start-up of the unit(s) combustion chamber, a generator with nameplate capacity of more than 25 MWe producing electricity for sale.

(2) If a stationary boiler or stationary combustion turbine that, under paragraph (a)(1) of this section, is not a CAIR NO<sub>x</sub> Ozone Season unit begins to combust fossil fuel or to serve a generator with nameplate capacity of more than 25 MWe producing electricity for sale, the unit shall become a CAIR NO<sub>x</sub> Ozone Season unit as provided in paragraph (a)(1) of this section on the first date on which it both combusts fossil fuel and serves such generator.

(b) The units in a State that meet the requirements set forth in paragraph (b)(1)(i), (b)(2)(i), or (b)(2)(ii) of this section shall not be CAIR NO<sub>x</sub> Ozone Season units: