

**§ 265.1030**

**40 CFR Ch. I (7-1-12 Edition)**

closure under paragraph (a) of this section.

[55 FR 50486, Dec. 6, 1990, as amended at 71 FR 40276, July 14, 2006]

**Subparts X-Z [Reserved]**

**Subpart AA—Air Emission Standards for Process Vents**

SOURCE: 55 FR 25507, June 21, 1990, unless otherwise noted.

**§ 265.1030 Applicability.**

(a) The regulations in this subpart apply to owners and operators of facilities that treat, store, or dispose of hazardous wastes (except as provided in § 265.1).

(b) Except for §§ 265.1034, paragraphs (d) and (e), this subpart applies to process vents associated with distillation, fractionation, thin-film evaporation, solvent extraction, or air or steam stripping operations that manage hazardous wastes with organic concentrations of at least 10 ppmw, if these operations are conducted in one of the following:

(1) A unit that is subject to the permitting requirements of 40 CFR part 270, or

(2) A unit (including a hazardous waste recycling unit) that is not exempt from permitting under the provisions of 40 CFR 262.34(a) (i.e., a hazardous waste recycling unit that is not a 90-day tank or container) and that is located at a hazardous waste management facility otherwise subject to the permitting requirements of 40 CFR part 270, or

(3) A unit that is exempt from permitting under the provisions of 40 CFR 262.34(a) (i.e., a “90-day” tank or container) and is not a recycling unit under the requirements of 40 CFR 261.6.

NOTE: The requirements of §§ 265.1032 through 265.1036 apply to process vents on hazardous waste recycling units previously exempt under paragraph 261.6(c)(1). Other exemptions under §§ 261.4, and 265.1(c) are not affected by these requirements.]

(c) The requirements of this subpart do not apply to the pharmaceutical manufacturing facility, commonly referred to as the Stonewall Plant, located at Route 340 South, Elkton, Vir-

ginia, provided that facility is operated in compliance with the requirements contained in a Clean Air Act permit issued pursuant to 40 CFR 52.2454. The requirements of this subpart shall apply to the facility upon termination of the Clean Air Act permit issued pursuant to 40 CFR 52.2454.

(d) The requirements of this subpart do not apply to the process vents at a facility where the facility owner or operator certifies that all of the process vents that would otherwise be subject to this subpart are equipped with and operating air emission controls in accordance with the process vent requirements of an applicable Clean Air Act regulation codified under 40 CFR part 60, part 61, or part 63. The documentation of compliance under regulations at 40 CFR part 60, part 61, or part 63 shall be kept with, or made readily available with, the facility operating record.

[55 FR 25507, June 21, 1990, as amended at 56 FR 19290, Apr. 26, 1991; 61 FR 59968, Nov. 25, 1996; 62 FR 52642, Oct. 8, 1997; 62 FR 64661, Dec. 8, 1997]

**§ 265.1031 Definitions.**

As used in this subpart, all terms shall have the meaning given them in § 264.1031, the Act, and parts 260-266.

**§ 265.1032 Standards: Process vents.**

(a) The owner or operator of a facility with process vents associated with distillation, fractionation, thin-film evaporation, solvent extraction or air or steam stripping operations managing hazardous wastes with organic concentrations at least 10 ppmw shall either:

(1) Reduce total organic emissions from all affected process vents at the facility below 1.4 kg/h (3 lb/h) and 2.8 Mg/yr (3.1 tons/yr), or

(2) Reduce, by use of a control device, total organic emissions from all affected process vents at the facility by 95 weight percent.

(b) If the owner or operator installs a closed-vent system and control device to comply with the provisions of paragraph (a) of this section, the closed-vent system and control device must meet the requirements of § 265.1033.

(c) Determinations of vent emissions and emission reductions or total organic compound concentrations

achieved by add-on control devices may be based on engineering calculations or performance tests. If performance tests are used to determine vent emissions, emission reductions, or total organic compound concentrations achieved by add-on control devices, the performance tests must conform with the requirements of § 265.1034(c).

(d) When an owner or operator and the Regional Administrator do not agree on determinations of vent emissions and/or emission reductions or total organic compound concentrations achieved by add-on control devices based on engineering calculations, the test methods in § 265.1034(c) shall be used to resolve the disagreement.

**§ 265.1033 Standards: Closed-vent systems and control devices.**

(a)(1) Owners or operators of closed-vent systems and control devices used to comply with provisions of this part shall comply with the provisions of this section.

(2)(i) The owner or operator of an existing facility who cannot install a closed-vent system and control device to comply with the provisions of this subpart on the effective date that the facility becomes subject to the requirements of this subpart must prepare an implementation schedule that includes dates by which the closed-vent system and control device will be installed and in operation. The controls must be installed as soon as possible, but the implementation schedule may allow up to 30 months after the effective date that the facility becomes subject to this subpart for installation and startup.

(ii) Any unit that begins operation after December 21, 1990, and is subject to the requirements of this subpart when operation begins, must comply with the rules immediately (i.e., must have control devices installed and operating on startup of the affected unit); the 30-month implementation schedule does not apply.

(iii) The owner or operator of any facility in existence on the effective date of a statutory or EPA regulatory amendment that renders the facility subject to this subpart shall comply with all requirements of this subpart as soon as practicable but no later than 30 months after the amendment's effective

date. When control equipment required by this subpart can not be installed and begin operation by the effective date of the amendment, the facility owner or operator shall prepare an implementation schedule that includes the following information: Specific calendar dates for award of contracts or issuance of purchase orders for the control equipment, initiation of on-site installation of the control equipment, completion of the control equipment installation, and performance of any testing to demonstrate that the installed equipment meets the applicable standards of this subpart. The owner or operator shall enter the implementation schedule in the operating record or in a permanent, readily available file located at the facility.

(iv) Owners and operators of facilities and units that become newly subject to the requirements of this subpart after December 8, 1997, due to an action other than those described in paragraph (a)(2)(iii) of this section must comply with all applicable requirements immediately (i.e., must have control devices installed and operating on the date the facility or unit becomes subject to this subpart; the 30-month implementation schedule does not apply).

(b) A control device involving vapor recovery (e.g., a condenser or adsorber) shall be designed and operated to recover the organic vapors vented to it with an efficiency of 95 weight percent or greater unless the total organic emission limits of § 265.1032(a)(1) for all affected process vents can be attained at an efficiency less than 95 weight percent.

(c) An enclosed combustion device (e.g., a vapor incinerator, boiler, or process heater) shall be designed and operated to reduce the organic emissions vented to it by 95 weight percent or greater; to achieve a total organic compound concentration of 20 ppmv, expressed as the sum of the actual compounds, not carbon equivalents, on a dry basis corrected to 3 percent oxygen; or to provide a minimum residence time of 0.50 seconds at a minimum temperature of 760 °C. If a boiler or process heater is used as the control device, then the vent stream shall be