

§ 34.15-10

(5) Branch lines in the various spaces shall be noted in Table 34.15-5(d)(5).

TABLE 34.15-5(d)(5)

| Maximum quantity of carbon dioxide required, pounds | Minimum pipe sizes, inches | Maximum quantity of carbon dioxide required, pounds | Minimum pipe size inches |
|---|----------------------------|---|--------------------------|
| 100 | 1/2 | 2,500 | 2 1/2 |
| 225 | 3/4 | 4,450 | 3 |
| 300 | 1 | 7,100 | 3 1/2 |
| 600 | 1 1/4 | 10,450 | 4 |
| 1,000 | 1 1/2 | 15,000 | 4 1/2 |
| 2,450 | 2 | | |

(6) Distribution piping within the space shall be proportioned from the supply line to give proper distribution to the outlets without throttling.

(7) The number, type and location of discharge outlets shall be such as to give a uniform distribution throughout the space.

(8) The total area of all discharge outlets shall not exceed 85 percent nor be less than 35 percent of the nominal cylinder outlet area or the area of the supply pipe, whichever is smaller. The nominal cylinder outlet area in square inches shall be determined by multiplying the factor 0.0022 by the number of pounds of carbon dioxide required, except that in no case shall this outlet area be less than 0.110 square inches.

(9) The discharge of at least 85 percent of the required amount of carbon dioxide shall be complete within 2 minutes.

[CGFR 65-50, 30 FR 16694, Dec. 30, 1965, as amended at 45 FR 64188, Sept. 29, 1980; CGD 95-028, 62 FR 51199, Sept. 30, 1997; USCG-1999-6216, 64 FR 53223, Oct. 1, 1999]

§ 34.15-10 Controls—T/ALL.

(a) Except as noted in § 34.15-20(b), all controls and valves for the operation of the system shall be outside the space protected, and shall not be located in any space that might be cut off or made inaccessible in the event of fire in any of the spaces protected.

(b) If the same cylinders are used to protect more than one space, a manifold with normally closed stop valves shall be used to direct the carbon dioxide into the proper space. If cylinders are used to protect only one space, a normally closed stop valve shall be installed between the cylinders and the space except for systems of the type in-

dicated in § 34.15-5(d) which contain not more than 300 pounds of carbon dioxide.

(c) Distribution piping to the dry cargo spaces shall be controlled from not more than two stations. One of the stations controlling the system for the main machinery space shall be located as convenient as practicable to one of the main-escapes from the space. All control stations and the individual valves and controls shall be marked as required by § 35.40-10 of the subchapter.

(d) Systems of the type indicated in § 34.15-5(d) shall be actuated at each station by one control operating the valve to the space and a separate control releasing at least the required amount of carbon dioxide. These two controls shall be located in a box or other enclosure clearly identified for the particular space. Systems installed without a stop valve shall be operated by one control releasing at least the required amount of carbon dioxide.

(e) Where provisions are made for the simultaneous release of a given amount of carbon dioxide by operation of a remote control, provisions shall also be made for manual control at the cylinders. Where gas pressure from pilot cylinders is used as a means for releasing the remaining cylinders, not less than two pilot cylinders shall be used for systems consisting of more than two cylinders. Each of the pilot cylinders shall be capable of manual control at the cylinder, but the remaining cylinders need not be capable of individual manual control.

(f) Systems of the type indicated in § 34.15-5(d), which are of more than 300 pounds of carbon dioxide shall be fitted with an approved delayed discharge so arranged that the alarm will be sounded for at least 20 seconds before the carbon dioxide is released into the space. Such systems of not more than 300 pounds of carbon dioxide shall also have a similar delayed discharge, except for spaces which have a suitable horizontal escape.

(g) All distribution valves and controls shall be of an approved type. All controls shall be suitably protected.

(h) Complete but simple instructions for the operation of the systems must be located in a conspicuous place at or near all pull boxes, stop valve controls

and in the CO₂ cylinder storage room. On systems in which the CO₂ cylinders are not within the protected space, these instructions must also include a schematic diagram of the system and instructions detailing alternate methods of discharging the system should the manual release or stop valve controls fail to operate. Each control valve to branch lines must be marked to indicate the related space served.

(i) If the space or enclosure containing the carbon dioxide supply or controls is to be locked, a key to the space or enclosure shall be in a break-glass-type box conspicuously located adjacent to the opening.

[CGFR 65-50, 30 FR 16694, Dec. 30, 1965, as amended by CGD 74-100R, 40 FR 6208, Feb. 10, 1975; USCG-1999-6216, 64 FR 53223, Oct. 1, 1999]

§ 34.15-15 Piping—T/ALL.

(a) The piping, valves, and fittings shall have a bursting pressure of not less than 6,000 pounds p.s.i.

(b) All piping, in nominal sizes not over ¾-inch shall be at least Schedule 40 (standard weight) and in nominal sizes over ¾-inch, shall be at least Schedule 80 (extra heavy).

(c) All piping, valves, and fittings of ferrous materials shall be protected inside and outside against corrosion unless specifically approved otherwise by the Commandant.

(d) A pressure relief valve or equivalent set to relieve between 2,400 and 2,800 pounds p.s.i. shall be installed in the distributing manifold or such other location as to protect the piping in the event that all branch line shut-off valves are closed.

(e) All deadend lines shall extend at least 2 inches beyond the last orifice and shall be closed with cap or plug.

(f) All piping, valves, and fittings shall be securely supported, and where necessary, protected against injury.

(g) Drains and dirt traps shall be fitted where necessary to prevent the accumulation of dirt or moisture. Drains and dirt traps shall be located in accessible locations where possible.

(h) Piping shall be used for no other purpose except that it may be incorporated with the fire-detecting system.

(i) Piping passing through living quarters shall not be fitted with drains or other openings within such spaces.

(j) Installation test requirements are:

(1) Upon completion of the piping installation, and before the cylinders are connected, a pressure test shall be applied as set forth in this paragraph. Only carbon dioxide or other inert gas shall be used for this test.

(2) The piping from the cylinders to the stop valves in the manifold shall be subjected to a pressure of 1,000 pounds p.s.i. With no additional gas being introduced to the system, it shall be demonstrated that the leakage of the system is such as not to permit a pressure drop of more than 150 pounds per square inch per minute for 2-minute period.

(3) The individual branch lines to the various spaces protected shall be subjected to a test similar to that described in the preceding paragraph with the exception that the pressure used shall be 600 pounds p.s.i. in lieu of 1,000 pounds p.s.i. For the purpose of this test, the distribution piping shall be capped within the space protected at the first joint ahead of the nozzles.

(4) In lieu of the tests prescribed in the preceding paragraphs in this section, small independent systems protecting spaces such as emergency generator rooms, lamp lockers, etc., may be tested by blowing out the piping with the air at a pressure of at least 100 pounds p.s.i.

§ 34.15-20 Carbon dioxide storage—T/ALL.

(a) Except as provided in paragraph (b) of this section, the cylinders shall be located outside the spaces protected, and shall not be located in any space that might be cut off or made inaccessible in the event of a fire in any of the spaces protected.

(b) Systems of the type indicated in § 34.15-5(d), consisting of not more than 300 pounds of carbon dioxide, may have the cylinders located within the space protected. If the cylinder stowage is within the space protected, the system shall be arranged in an approved manner to be automatically operated by a heat actuator within the space in addition to the regular remote and local controls.

(c) The space containing the cylinders shall be properly ventilated and designed to preclude an anticipated