

§ 34.15-25

ambient temperature in excess of 130 degrees F.

(d) Cylinders shall be securely fastened and supported, and where necessary, protected against injury.

(e) Cylinders shall be so mounted as to be readily accessible and capable of easy removal for recharging and inspection. Provisions shall be available for weighing the cylinders.

(f) Where subject to moisture, cylinders shall be so installed as to provide a space of at least 2 inches between the flooring and the bottom of the cylinders.

(g) Cylinders shall be mounted in an upright position or inclined not more than 30 degrees from the vertical. However, cylinders which are fitted with flexible or bent siphon tubes may be inclined not more than 80 degrees from the vertical.

(h) Where check valves are not fitted on each independent cylinder discharge, plugs or caps shall be provided for closing outlets when cylinders are removed for inspection or refilling.

(i) All cylinders used for storing carbon dioxide must be fabricated, tested, and marked in accordance with §§ 147.60 and 147.65 of this chapter.

[CGFR 65-50, 30 FR 16694, Dec. 30, 1965, as amended at 53 FR 7748, Mar. 10, 1988; USCG-1999-6216, 64 FR 53223, Oct. 1, 1999]

§ 34.15-25 Discharge outlets—T/ALL.

(a) Discharge outlets shall be of an approved type.

§ 34.15-30 Alarms—T/ALL.

(a) Spaces required to have a delayed discharge by § 34.15-10(f) which are protected by a carbon dioxide extinguishing system and are normally accessible to persons on board while the vessel is being navigated, other than paint and lamp lockers and similar small spaces, shall be fitted with an approved audible alarm in such spaces which will be automatically sounded before the carbon dioxide is admitted to the space. The alarm shall be conspicuously and centrally located and shall be marked as required by § 35.40-7 of this subchapter. Such alarms shall be so arranged as to sound during the 20-second delay period prior to the discharge of carbon dioxide into the space, and the alarm shall depend on no

46 CFR Ch. I (10-1-12 Edition)

source of power other than the carbon dioxide.

§ 34.15-35 Enclosure openings—T/ALL.

(a) Except for cargo spaces, the operation of the carbon dioxide system shall automatically shut down any mechanical ventilation to that space. This will not be required where the carbon dioxide system is a secondary system in addition to another approved primary system protecting the space.

(b) Where natural ventilation is provided for spaces protected by a carbon dioxide extinguishing system, provisions shall be made for easily and effectively closing off the ventilation.

(c) Means shall be provided for closing all other openings to the space protected from outside such space. In this respect, relatively tight doors, shutters, or dampers shall be provided for openings in the lower portion of the space. The construction shall be such that openings in the upper portion of the space can be closed off either by permanently installed means or by the use of canvas or other material which is normally carried by the vessel.

§ 34.15-40 Pressure relief—T/ALL.

(a) Where necessary, relatively tight compartments such as refrigeration spaces, paint lockers, etc., shall be provided with suitable means for relieving excessive pressure accumulating within the compartment when the carbon dioxide is injected.

§ 34.15-50 Lockout valves—T/ALL.

(a) A lockout valve must be provided on any carbon dioxide extinguishing system protecting a space over 6,000 cubic feet in volume and installed or altered after July 9, 2013. "Altered" means modified or refurbished beyond the maintenance required by the manufacturer's design, installation, operation and maintenance manual.

(b) The lockout valve must be a manually operated valve located in the discharge manifold prior to the stop valve or selector valves. When in the closed position, the lockout valve must provide complete isolation of the system from the protected space or spaces, making it impossible for carbon dioxide to discharge in the event of equipment failure during maintenance.

(c) The lockout valve design or locking mechanism must make it obvious whether the valve is open or closed.

(d) A valve is considered a lockout valve if it has a hasp or other means of attachment to which, or through which, a lock can be affixed, or it has a locking mechanism built into it.

(e) The master or person-in-charge must ensure that the valve is locked open at all times, except while maintenance is being performed on the extinguishing system, when the valve must be locked in the closed position.

(f) Lockout valves added to existing systems must be approved by the Commandant as part of the installed system.

[USCG-2006-24797, 77 FR 33873, June 7, 2012]

§ 34.15-60 Odorizing units—T/ALL.

Each carbon dioxide extinguishing system installed or altered after July 9, 2013, must have an approved odorizing unit to produce the scent of wintergreen, the detection of which will serve as an indication that carbon dioxide gas is present in a protected area and any other area into which the carbon dioxide may migrate. "Altered" means modified or refurbished beyond the maintenance required by the manufacturer's design, installation, operation and maintenance manual.

[USCG-2006-24797, 77 FR 33873, June 7, 2012]

§ 34.15-90 Installations contracted for prior to January 1, 1962—T/ALL.

(a) Installations contracted for prior to November 19, 1952, shall meet the requirements of this paragraph.

(1) Existing arrangements, materials, and facilities previously approved shall be considered satisfactory so long as they meet the minimum requirements of this paragraph and they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs and alterations may be made to the same standards as the original installation.

(2) The details of the systems shall be in general agreement with §§ 34.15-5 through 34.15-40 insofar as is reasonable and practicable, with the exception of § 34.15-5(d)(1) through (3) covering spaces other than cargo spaces, which systems may be installed in ac-

cordance with paragraphs (a) (4) through (7) of this section.

(3) For cargo tanks at least one pound of carbon dioxide shall be available for each 30 cubic feet of the largest cargo tank. The discharge of the required amount of carbon dioxide shall be complete within 5 minutes.

(4) In boiler rooms, the bilges shall be protected by a system discharging principally below the floor plates. Perforated pipe may be used in lieu of discharge nozzles for such systems. The number of pounds of carbon dioxide shall be equal to the gross volume of the boiler room taken to the top of the boilers divided by 36. In the event of an elevated boiler room which drains to the machinery space, the system shall be installed in the engine room bilge and the gross volume shall be taken to the flat on which the boilers are installed.

(5) In machinery spaces where main propulsion internal combustion machinery is installed, the number of pounds of carbon dioxide required shall be equal to the gross volume of the space taken to the underside of the deck forming the hatch opening divided by 22.

(6) In miscellaneous spaces other than cargo or main machinery spaces the number of pounds of carbon dioxide required shall be equal to the gross volume of the space divided by 22.

(7) Branch lines to the various spaces other than cargo and similar spaces shall be as noted in Table 34.15-90(a)(7). This table is based on cylinders having discharge outlets and siphon tubes of 3/8-inch diameter.

TABLE 34.15-90(a)(7)

Number of cylinders		Nominal pipe size, inches
Over	Not over	
	2	1/2-standard.
2	4	3/4-standard.
4	6	1-extra heavy.
6	12	1 1/4-extra heavy.
12	16	1 1/2-extra heavy.
16	27	2-extra heavy.
27	39	2 1/2-extra heavy.
39	60	3-extra heavy.
60	80	3 1/2-extra heavy.
80	104	4-extra heavy.
104	165	5-extra heavy.

(b) Installations contracted for on or after November 19, 1952, but prior to