

§ 72.05-55

6 feet above the damper, the duct shall meet the applicable bulkhead requirements.

(h) Exhausts from galleys shall meet the applicable bulkhead requirements. In addition, an automatic damper shall be installed in exhaust ducts over frying vats, etc.

(i) In all ventilation systems, manually operated dampers or other suitable means shall be provided in accessible locations, outside the spaces served by the system, for shutting off the passage of air in the event of fire; however, no dampers shall be placed in exhaust ducts from film lockers or projection rooms.

(j) For information regarding controls of electrically powered ventilation systems, see subchapter J (Electrical Engineering) of this chapter.

§ 72.05-55 Furniture and furnishings.

(a) For the purpose of this subpart, rooms containing "fire resistant furnishings" will be considered to be those in which:

(1) All case furniture such as desks, wardrobes, dressing tables, bureaus, dressers, etc., shall be constructed entirely of approved incombustible materials; except that a combustible veneer not exceeding 1/8 inch may be used on the top surface of such articles.

(2) All free standing furniture such as chairs, sofas, tables, etc., shall be constructed with frames of approved incombustible materials.

(3) All draperies shall be of approved fire resistant fabrics.

(4) All rugs and carpets shall be of wool or other material having equivalent fire resistive qualities.

(b) Waste paper baskets shall be constructed of approved incombustible materials with solid sides and bottoms.

(c) Passageways and stairway enclosures shall contain only fire resistant furnishings. In addition, all upholstery and padding of chairs, sofas, etc., in these areas, shall be of approved fire resistant materials.

§ 72.05-90 Vessels contracted for prior to May 26, 1965.

(a) Vessels of 100 gross tons and over, contracted for prior to May 26, 1965, on an international voyage; and vessels of 100 gross tons and over, contracted for

46 CFR Ch. I (10-1-12 Edition)

on or after May 28, 1936, and prior to May 26, 1965, not on an international voyage; shall meet the following requirements:

(1) Existing structure, arrangements, and materials previously approved will be considered satisfactory so long as they meet the minimum requirements of this paragraph and are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs and alterations may be made to the same standards as the original construction.

(2) The details shall be in general agreement with §§ 72.05-5 through 72.05-60.

(b) Vessels of 100 gross tons and over, contracted for prior to May 28, 1936, not on an international voyage, shall meet the following requirements:

(1) Existing structure, arrangements, and materials previously approved will be considered satisfactory so long as they meet the minimum requirements of this paragraph and are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs and alterations may be made to the same standards as the original construction.

(2) All vessels in ocean or coastwise service shall be fitted above the bulkhead deck with fire-resisting bulkheads and doors spaced not more than 131 feet apart which are capable of resisting the passage of flame for a period of at least 1 hour.

(3) All vessels with berth or state-room accommodations for 50 or more passengers shall be fitted with an approved automatic sprinkling system unless deemed unnecessary by the Commandant. This system shall be so installed as to protect all enclosed parts of the vessel accessible to passengers or crew while the vessel is being navigated, except cargo holds, machinery spaces, and when of fire-resisting construction, toilets, bathrooms, and spaces of similar construction. Where, in the case of a particular vessel, the Commandant does not consider the installation of an automatic water-sprinkling system necessary, such vessel shall be protected in such enclosed parts of the vessel as the Commandant shall deem necessary, with an automatic electric or pneumatic fire-