

(b) Distribution piping to the various zones shall be controlled from one station. Each branch line to the various zones shall be fitted with a stop valve which shall be marked as required by § 78.47–15 of this subchapter.

[CGFR 65–50, 30 FR 16940, Dec. 30, 1965, as amended by USCG–2004–18884, 69 FR 58347, Sept. 30, 2004]

§ 76.23–20 Piping.

(a) All piping, valves, and fittings shall meet the applicable requirements of subchapter F (Marine Engineering) of this chapter.

(b) All piping, valves, and fittings of ferrous materials shall be protected inside and outside against corrosion unless specifically approved by the Commandant.

(c) All piping, valves, fittings, and sprinkler heads shall be securely supported, and where necessary, protected against injury.

(d) Drains and dirt traps shall be fitted where necessary to prevent the accumulation of dirt or moisture.

(e) Piping shall be used for no other purpose.

§ 76.23–25 Sprinkler heads.

(a) Sprinkler heads shall be of an approved type.

(b) [Reserved]

§ 76.23–90 Installations contracted for prior to November 19, 1952.

(a) Installations contracted for prior to November 19, 1952, shall meet the following requirements:

(1) Existing arrangements, materials, and facilities previously approved shall be considered satisfactory so long as they meet the minimum requirements of this paragraph and they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs and replacements may be made to the same standards as the original installation.

(2) The details of the system shall be in general agreement with §§ 76.23–5 through 76.23–25 insofar as is reasonable and practicable. Existing piping, pumping facilities, and sprinkler heads or perforated pipes may be retained provided all portions of the overhead are effectively sprayed and all portions of the deck are covered.

(b) [Reserved]

Subpart 76.25—Automatic Sprinkling System, Details

§ 76.25–1 Application.

Where an automatic sprinkling system is installed, the systems must comply with NFPA 13 (incorporated by reference; see 46 CFR 76.01–2).

[USCG–2003–16630, 73 FR 65192, Oct. 31, 2008]

§ 76.25–5 Zoning.

(a) The automatic sprinkling system shall be divided into separate zones to restrict the area covered by any particular alarm signal.

(b) No sprinkling zone shall contain more than 250 sprinkler heads.

(c) The sprinkling zone may cover more than one deck, in which case, the boundaries shall be maintained in a vertical line insofar as is reasonable and practicable. The boundaries of the zone shall be coincident with bulkheads of Class “A” construction such as main vertical zone or watertight bulkheads.

(d) Spaces in different main vertical zones shall not be included in the same sprinkling zone.

§ 76.25–10 Size and arrangement of sprinkler heads and pipe sizes.

(a) *General.* (1) The system shall be so designed and arranged that the overhead is effectively sprayed and that all portions of the deck are covered.

(2) One-half inch sprinkler heads shall be used. Sprinkler heads shall be so arranged that no portion of the overhead or vertical projection of the deck is more than 7 feet from a sprinkler head.

(b) *Pipe sizes.* (1) The sizes of branch lines, single cross mains, feed mains, and risers shall be in proportion to the number of sprinkler heads served. The minimum pipe sizes shall be as given in table 76.25–10(b)(1).