

## Coast Guard, DHS

## § 78.47-30

### § 78.47-11 Carbon dioxide warning signs.

Each entrance to a space storing carbon dioxide cylinders, a space protected by carbon dioxide systems, or any space into which carbon dioxide might migrate must be conspicuously marked as follows:

(a) Spaces storing carbon dioxide—“CARBON DIOXIDE GAS CAN CAUSE INJURY OR DEATH. VENTILATE THE AREA BEFORE ENTERING. A HIGH CONCENTRATION CAN OCCUR IN THIS AREA AND CAN CAUSE SUFFOCATION.”.

(b) Spaces protected by carbon dioxide—“CARBON DIOXIDE GAS CAN CAUSE INJURY OR DEATH. WHEN ALARM OPERATES OR WINTERGREEN SCENT IS DETECTED, DO NOT ENTER UNTIL VENTILATED. LOCK OUT SYSTEM WHEN SERVICING.” The reference to wintergreen scent may be omitted for carbon dioxide systems not required to have odorizing units and not equipped with such units.

(c) Spaces into which carbon dioxide might migrate—“CARBON DIOXIDE GAS CAN CAUSE INJURY OR DEATH. DISCHARGE INTO NEARBY SPACE CAN COLLECT HERE. WHEN ALARM OPERATES OR WINTERGREEN SCENT IS DETECTED VACATE IMMEDIATELY.” The reference to wintergreen scent may be omitted for carbon dioxide systems not required to have odorizing units and not equipped with such units.

[USCG-2006-24797, 77 FR 33877, Jun. 7, 2012]

### § 78.47-13 Fire detecting and manual alarm, automatic sprinkler, and smoke detecting alarm bells.

(a) The fire detecting and manual alarm automatic sprinklers, and smoke detecting alarm bells in the engine room shall be identified by at least 1 inch red lettering “FIRE ALARM”, “SPRINKLER ALARM” or “SMOKE DETECTING ALARM” as appropriate. Where such alarms on the bridge or in the fire control station do not form a part of an easily identifiable alarm cabinet, the bells shall be suitably identified as above.

(b) [Reserved]

### § 78.47-15 Fire extinguishing system branch lines.

(a) The branch line valves of all fire extinguishing systems shall be plainly and permanently marked indicating the spaces served.

(b) [Reserved]

### § 78.47-17 Fire extinguishing system controls.

Each control cabinet or space containing valves or manifolds for a fire extinguishing system must be distinctly marked in conspicuous red letters at least 2 inches high: “[CARBON DIOXIDE/STEAM/FOAM/WATER SPRAY/MANUAL SPRINKLING/AUTOMATIC SPRINKLING/CLEAN AGENT—as appropriate] FIRE SYSTEM.”.

[USCG-2006-24797, 77 FR 33877, Jun. 7, 2012]

### § 78.47-20 Fire hose stations.

(a) Each fire hydrant shall be identified in red letters and figures at least 2 inches high “FIRE STATION NO 1,” “2,” “3,” etc. Where the hose is not stowed in the open or behind glass so as to be readily seen, this identification shall be so placed as to be readily seen from a distance.

(b) [Reserved]

### § 78.47-23 Supervised patrol stations.

(a) Each supervised patrol clock or key station shall be numbered.

(b) [Reserved]

### § 78.47-25 Emergency squad equipment.

(a) Lockers or spaces containing equipment for the use of the emergency squad shall be marked “EMERGENCY SQUAD EQUIPMENT.”

(b) [Reserved]

### § 78.47-27 Self-contained breathing apparatus.

Lockers or spaces containing self-contained breathing apparatus shall be marked “SELF-CONTAINED BREATHING APPARATUS.”

[CGD 95-028, 62 FR 51205, Sept. 30, 1997]

### § 78.47-30 Hand portable fire extinguishers.

(a) Each hand portable fire extinguisher shall be marked with a number