

§ 147.65

(2) Carry only nitrogen or air, unless permission is granted by Commandant (CG-OES) to do otherwise.

[CGD 84-044, 53 FR 7749, Mar. 10, 1988, as amended by CGD 95-072, 60 FR 50465, Sept. 29, 1995; CGD 96-041, 61 FR 50731, Sept. 27, 1996; USCG-2006-24797, 77 FR 33886, June 7, 2012]

§ 147.65 Carbon dioxide and halon fire extinguishing systems.

(a) Carbon dioxide or halon cylinders forming part of a fixed fire extinguishing system must be retested, at least, every 12 years. If a cylinder is discharged and more than five years have elapsed since the last test, it must be retested before recharging.

(b) Carbon dioxide or halon cylinders must be rejected for further service when they—

(1) Leak;

(2) Are dented, bulging, severely corroded, or otherwise in a weakened condition;

(3) Have lost more than five percent of their tare weight; or

(4) Have been involved in a fire.

(c) Cylinders which have contained carbon dioxide or halon and have not been tested within five years must not be used to contain another compressed gas on board a vessel, unless the cylinder is retested and re-marked in accordance with § 147.60 (a)(3) and (a)(4).

(d) Flexible connections between cylinders and distribution piping of semi-portable or fixed carbon dioxide fire extinguishing systems and discharge hoses in semi-portable carbon dioxide fire extinguishing systems must be renewed or tested at a pressure of 6.9 MPa (1000 psig). At test pressure, the pressure must not drop at a rate greater than 1.03 MPa (150 psi) per minute for a two minute period. The test must be performed when the cylinders are retested.

(e) Flexible connections between cylinders and distribution piping of fixed halon fire extinguishing systems must be tested at a pressure of one and one-half times the cylinder service pressure as marked on the cylinder. At test pressure, the pressure must not drop at a rate greater than 1.03 MPa (150 psi) per minute for a two minute period. The test must be performed when the cylinders are retested.

46 CFR Ch. I (10-1-12 Edition)

§ 147.66 Inert gas fire extinguishing systems.

(a) Inert gas cylinders forming part of a clean agent fixed fire extinguishing system must be retested every five years, except that cylinders with a water capacity of 125 pounds or less may be retested every 10 years in accordance with 49 CFR 180.209(b).

(b) An inert gas cylinder must be removed from service if it:

(1) Leaks;

(2) Is dented, bulging, severely corroded, or otherwise weakened;

(3) Has lost more than 5 percent of its tare weight; or

(4) Has been involved in a fire.

(c) Flexible connections between cylinders and discharge piping for fixed inert gas fire extinguishing systems must be renewed or retested in accordance with section 7.3 of NFPA 2001 (incorporated by reference, see § 147.7).

[USCG-2006-24797, 77 FR 33886, June 7, 2012]

§ 147.67 Halocarbon fire extinguishing systems.

(a) Each halocarbon cylinder forming part of a clean agent fixed fire extinguishing system must be:

(1) Retested at least once every 12 years and before recharging if it has been discharged and more than five years have elapsed since the last test; or

(2) As an alternative, a cylinder conforming to the requirements of 49 CFR 180.209(g) may be given the complete external visual inspection in lieu of hydrostatic testing provided for by that section.

(b) A halocarbon cylinder must be removed from service if it:

(1) Leaks;

(2) Is dented, bulging, severely corroded, or otherwise weakened;

(3) Has lost more than 5 percent of its tare weight; or

(4) Has been involved in a fire.

(c) Flexible connections between cylinders and discharge piping for halocarbon fire extinguishing systems must be renewed or retested in accordance with section 7.3 of NFPA 2001 (incorporated by reference, see § 147.7).

[USCG-2006-24797, 77 FR 33886, June 7, 2012]