

§ 141.553

(b) [Reserved]

§ 141.553 My system practices lime softening—is there any special provision regarding my combined filter effluent?

If your system practices lime softening, you may acidify representative combined filter effluent turbidity samples prior to analysis using a protocol approved by the State.

INDIVIDUAL FILTER TURBIDITY REQUIREMENTS

§ 141.560 Is my system subject to individual filter turbidity requirements?

If your system is a subpart H system serving fewer than 10,000 people and utilizing conventional filtration or direct filtration, you must conduct continuous monitoring of turbidity for each individual filter at your system. The following requirements apply to continuous turbidity monitoring:

- (a) Monitoring must be conducted using an approved method in § 141.74(a);
- (b) Calibration of turbidimeters must be conducted using procedures specified by the manufacturer;
- (c) Results of turbidity monitoring must be recorded at least every 15 minutes;
- (d) Monthly reporting must be completed according to § 141.570; and
- (e) Records must be maintained according to § 141.571.

§ 141.561 What happens if my system's turbidity monitoring equipment fails?

If there is a failure in the continuous turbidity monitoring equipment, your system must conduct grab sampling every four hours in lieu of continuous monitoring until the turbidimeter is back on-line. Your system has 14 days to resume continuous monitoring before a violation is incurred.

§ 141.562 My system only has two or fewer filters—is there any special provision regarding individual filter turbidity monitoring?

Yes, if your system only consists of two or fewer filters, you may conduct continuous monitoring of combined filter effluent turbidity in lieu of individual filter effluent turbidity monitoring.

40 CFR Ch. I (7–1–13 Edition)

toring. Continuous monitoring must meet the same requirements set forth in § 141.560(a) through (d) and § 141.561.

§ 141.563 What follow-up action is my system required to take based on continuous turbidity monitoring?

Follow-up action is required according to the following tables:

If * * *	Your system must * * *
(a) The turbidity of an individual filter (or the turbidity of combined filter effluent (CFE) for systems with 2 filters that monitor CFE in lieu of individual filters) exceeds 1.0 NTU in two consecutive recordings 15 minutes apart.	Report to the State by the 10th of the following month and include the filter number(s), corresponding date(s), turbidity value(s) which exceeded 1.0 NTU, and the cause (if known) for the exceedance(s).
If a system was required to report to the State * * *	Your system must * * *
(b) For three months in a row and turbidity exceeded 1.0 NTU in two consecutive recordings 15 minutes apart at the same filter (or CFE for systems with 2 filters that monitor CFE in lieu of individual filters).	Conduct a self-assessment of the filter(s) within 14 days of the day the filter exceeded 1.0 NTU in two consecutive measurements for the third straight month unless a CPE as specified in paragraph (c) of this section was required. Systems with 2 filters that monitor CFE in lieu of individual filters must conduct a self-assessment on both filters. The self-assessment must consist of at least the following components: assessment of filter performance; development of a filter profile; identification and prioritization of factors limiting filter performance; assessment of the applicability of corrections; and preparation of a filter self-assessment report.
(c) For two months in a row and turbidity exceeded 2.0 NTU in 2 consecutive recordings 15 minutes apart at the same filter (or CFE for systems with 2 filters that monitor CFE in lieu of individual filters).	Arrange to have a comprehensive performance evaluation (CPE) conducted by the State or a third party approved by the State not later than 60 days following the day the filter exceeded 2.0 NTU in two consecutive measurements for the second straight month. If a CPE has been completed by the State or a third party approved by the State within the 12 prior months or the system and State are jointly participating in an ongoing Comprehensive Technical Assistance (CTA) project at the system, a new CPE is not required. If conducted, a CPE must be completed and submitted to the State no later than 120 days following the day the filter exceeded 2.0 NTU in two consecutive measurements for the second straight month.