

§ 411.32

the United States," May 1961, and subsequent amendments, or equivalent regional or state rainfall probability information developed therefrom.

§ 411.32 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

(a) Except as provided in §§ 125.30 through 125.32, and subject to the provisions of paragraph (b) of this section, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations
TSS	Not to exceed 50 mg/l.
pH	Within the range 6.0 to 9.0.

(b) Any untreated overflow from facilities designed, constructed and operated to treat the volume of runoff from materials storage piles which is associated with a 10-year, 24-hour rainfall event shall not be subject to the pH and TSS limitations stipulated in paragraph (a) of this section.

[39 FR 6591, Feb. 20, 1974, as amended at 60 FR 33951, June 29, 1995]

§ 411.33 [Reserved]

§ 411.34 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
TSS	Do.

[40 FR 6440, Feb. 11, 1975, as amended at 60 FR 33951, June 29, 1995]

40 CFR Ch. I (7-1-12 Edition)

§ 411.35 Standards of performance for new sources.

(a) Subject to the provisions of paragraph (b) of this section the following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations
TSS	Not to exceed 50 mg/l.
pH	Within the range 6.0 to 9.0.

(b) Any overflow from facilities designed, constructed and operated to treat to the applicable limitations the precipitation and runoff resulting from a 10-year, 24-hour precipitation event shall not be subject to the limitations of this section.

[42 FR 10681, Feb. 23, 1977]

§ 411.36 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33951, June 29, 1995]

§ 411.37 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

The following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best conventional pollutant control technology.

(a) Subject to the provisions of paragraph (b) of this section, the following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best conventional pollutant control technology.

Effluent characteristic	Effluent limitations
TSS	Not to exceed 50 mg/l.