

Environmental Protection Agency

§ 445.20

(m) The regulated parameters for this part listed with approved methods of analysis in the attachments to Methods 625 and 1625B in appendix A at 40 CFR part 136 are as follows:

- (1) Aniline.
- (2) Benzoic acid.
- (3) p-Cresol.
- (4) Pyridine.
- (5) a-Terpineol.

§ 445.3 General pretreatment standards.

Any source subject to this part that introduces wastewater pollutants into a publicly owned treatment works (POTW) must comply with 40 CFR part 403.

Subpart A—RCRA Subtitle C Hazardous Waste Landfill

§ 445.10 Applicability.

Except as provided in § 445.1, this subpart applies to discharges of wastewater from landfills subject to the provisions of 40 CFR part 264, *Standards for Owners and Operators of Hazardous Waste Treatment, Storage, and Disposal Facilities, Subpart N—(Landfills)*; and 40 CFR part 265, *Interim Status Standards for Owners and Operators of Hazardous Waste Treatment, Storage, and Disposal Facilities, Subpart N—(Landfills)*.

§ 445.11 Effluent limitations attainable by the application of the best practicable control technology currently available (BPT).

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations which represent the application of BPT:

| EFFLUENT LIMITATIONS | | |
|------------------------|----------------------------|-----------------------------------|
| Regulated parameter | Maximum daily ¹ | Maximum monthly avg. ¹ |
| BOD ₅ | 220 | 56 |
| TSS | 88 | 27 |
| Ammonia (as N) | 10 | 4.9 |
| α-Terpineol | 0.042 | 0.019 |
| Aniline | 0.024 | 0.015 |
| Benzoic acid | 0.119 | 0.073 |
| Naphthalene | 0.059 | 0.022 |
| p-Cresol | 0.024 | 0.015 |
| Phenol | 0.048 | 0.029 |
| Pyridine | 0.072 | 0.025 |
| Arsenic | 1.1 | 0.54 |

EFFLUENT LIMITATIONS—Continued

| Regulated parameter | Maximum daily ¹ | Maximum monthly avg. ¹ |
|---------------------|----------------------------|-----------------------------------|
| Chromium | 1.1 | 0.46 |
| Zinc | 0.535 | 0.296 |
| pH | (²) | (²) |

¹ Milligrams per liter (mg/L, ppm).
² Within the range 6 to 9.

[65 FR 3048, Jan. 19, 2000; 65 FR 14344, Mar. 16, 2000]

§ 445.12 Effluent limitations attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations which represent the application of BCT: Limitations for BOD₅, TSS and pH are the same as the corresponding limitations specified in § 445.11.

§ 445.13 Effluent limitations representing the degree of effluent reduction attainable by the application of best available technology economically achievable (BAT).

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations which represent the application of BAT: Limitations for ammonia (as N), a-terpineol, aniline, benzoic acid, naphthalene, p-cresol, phenol, pyridine, arsenic, chromium and zinc are the same as the corresponding limitations specified in § 445.11.

§ 445.14 New source performance standards (NSPS).

Any new source subject to this subpart must achieve the following performance standards: Standards are the same as those specified in § 445.11.

Subpart B—RCRA Subtitle D Non-Hazardous Waste Landfill

§ 445.20 Applicability.

Except as provided in § 445.1, this subpart applies to discharges of wastewater from landfills subject to the provisions of 40 CFR part 258, *Criteria for Municipal Solid Waste Landfills*; and 40 CFR part 257, *Criteria for Classification*