

(2) For the purpose of the above requirement of this paragraph, the volume of a machinery space shall be taken as exclusive of the normal machinery casing unless the boiler, internal combustion machinery, or fuel oil installations extend into such space in which case the volume shall be taken to the top of the casing or the next material reduction in casing area, whichever is lower. For installations contracted for on or after October 1, 1959, "normal machinery casing" and "material reduction in casing area" shall be defined as follows:

(i) By "normal machinery casing" shall be meant a casing the area of which is not more than 40 percent of the maximum area of the machinery space.

(ii) By "material reduction in casing area" shall be meant a reduction to at least 40 percent of the casing area.

(3) For vessels on an international voyage contracted for on or after May 26, 1965, the amount of carbon dioxide required for a space containing propulsion boilers or internal combustion propulsion machinery shall be as given by paragraphs (d) (1) and (2) of this section or by dividing the entire volume, including the casing, by a factor of 25, whichever is the larger.

(4) Branch lines to the various spaces shall be as noted in table 76.15-5(d)(4).

TABLE 76.15-5(d)(4)

| Maximum quantity of carbon dioxide required, pounds | Minimum nominal pipe size, inches | Maximum quantity of carbon dioxide required, pounds | Minimum nominal pipe size, inches |
|---|-----------------------------------|---|-----------------------------------|
| 100 .....   | 1/2                               | 2,500 .....   | 2 1/2                             |
| 225 .....   | 3/4                               | 4,450 .....   | 3                                 |
| 300 .....   | 1                                 | 7,100 .....   | 3 1/2                             |
| 600 .....   | 1 1/4                             | 10,450 .....  | 4                                 |
| 1,000 .....   | 1 1/2                             | 15,000 .....  | 4 1/2                             |
| 2,450 .....   | 2                                 |   |                                   |

(5) Distribution piping within the space shall be proportioned from the supply line to give proper distribution to the outlets without throttling.

(6) The number, type, and location of discharge outlets shall be such as to give a uniform distribution throughout the space.

(7) The total area of all discharge outlets shall not exceed 85 percent nor be less than 35 percent of the nominal

cylinder outlet area or the area of the supply pipe, whichever is smaller. The nominal cylinder outlet area in square inches shall be determined by multiplying the factor 0.0022 by the number of pounds of carbon dioxide required, except that in no case shall this outlet area be less than 0.110 square inch.

(8) The discharge of at least 85 percent of the required amount of carbon dioxide shall be complete within 2 minutes.

(e) *Spaces specially suitable for vehicles.* (1) The number of pounds of carbon dioxide required shall be equal to the gross volume of the largest "tight" space divided by 22. In no case, however, shall it be less than that required by paragraph (c) of this section.

(2) The arrangement of valves and piping shall be such that the required quantity of carbon dioxide may be discharged into any "tight" space. The discharge of the required quantity of carbon dioxide shall be completed within 2 minutes.

(3) Except as noted in paragraphs (e) (1) and (2) of this section, the requirements of paragraph (d) of this section shall apply.

[CGFR 65-50, 30 FR 16940, Dec. 30, 1965, as amended by CGFR, 66-33, 31 FR 15283, Dec. 6, 1966; CGD 95-028, 62 FR 51204, Sept. 30, 1997; USCG-1999-6216, 64 FR 53225, 53226, Oct. 1, 1999; USCG-2010-0759, 75 FR 60003, Sept. 29, 2010]

**§ 76.15-10 Controls.**

(a) Except as noted in § 76.15-20(b), all controls and valves for the operation of the system shall be outside the space protected, and shall not be located in any space that might be cut off or made inaccessible in the event of fire in any of the spaces protected.

(b) If the same cylinders are used to protect more than one hazard, a manifold with normally closed stop valves shall be used to direct the carbon dioxide into the proper space. If cylinders are used to protect only one hazard, a normally closed stop valve shall be installed between the cylinders and the hazard except for systems of the type indicated in § 76.15-5(d) which contain not more than 300 pounds of carbon dioxide.

(c) Distribution piping to the various cargo spaces shall be controlled from

## §76.15-15

not more than two stations. One of the stations controlling the system for the main machinery space shall be located as convenient as practicable to one of the main escapes from the space. All control stations and the individual valves and controls shall be marked as required by §§78.47-15 and 78.47-17 of this subchapter.

(d) Systems of the type indicated in §76.15-5(d) shall be actuated by one control operating the valve to the space and a separate control releasing at least the required amount of carbon dioxide. These two controls shall be located in a box or other enclosure clearly identified for the particular space. Those systems installed without a stop valve shall be operated by one control releasing at least the required amount of carbon dioxide.

(e) Where provisions are made for the simultaneous release of a given amount of carbon dioxide by operation of a remote control, provisions shall also be made for manual control at the cylinders. Where gas pressure from pilot cylinders is used as a means for releasing the remaining cylinders, not less than two pilot cylinders shall be used for systems consisting of more than two cylinders. Each of the pilot cylinders shall be capable of manual control at the cylinder, but the remaining cylinders need not be capable of individual manual control.

(f) Systems of the type indicated in §76.15-5(d), other than systems for tanks, which are of more than 300 pounds of carbon dioxide, shall be fitted with an approved delayed discharge so arranged that the alarm will be sounded for at least 20 seconds before the carbon dioxide is released into the space. Such systems of not more than 300 pounds of carbon dioxide shall also have a similar delayed discharge, except for those systems for tanks and for spaces which have a suitable horizontal escape. This paragraph shall be applicable only to systems installed on or after July 1, 1957.

(g) All distribution valves and controls shall be of an approved type. All controls shall be suitably protected.

(h) Complete but simple instructions for the operation of the systems must be located in a conspicuous place at or near all pull boxes, stop valve controls

## 46 CFR Ch. I (10-1-13 Edition)

and in the CO<sub>2</sub> cylinder storage room. On systems in which the CO<sub>2</sub> cylinders are not within the protected space, these instructions must also include a schematic diagram of the system and instructions detailing alternate methods of discharging the system should the manual release or stop valve controls fail to operate. Each control valve to branch lines must be marked to indicate the related space served.

(i) If the space or enclosure containing the carbon dioxide supply or controls is to be locked, a key to the space or enclosure shall be in a break-glass-type box conspicuously located adjacent to the opening.

[CGFR 65-60, 30 FR 16940, Dec. 30, 1965, as amended by CGD 74-100R, 40 FR 6209, Feb. 10, 1975; USCG-1999-6216, 64 FR 53226, Oct. 1, 1999]

### §76.15-15 Piping.

(a) The piping, valves, and fittings shall have a bursting pressure of not less than 6,000 p.s.i.

(b) All piping, in nominal sizes not over ¾ inch, shall be at least Schedule 40 (standard weight), and in nominal sizes over ¾ inch, shall be at least Schedule 80 (extra heavy).

(c) All piping, valves, and fittings of ferrous materials shall be protected inside and outside against corrosion unless specifically approved otherwise by the Commandant.

(d) A pressure relief valve or equivalent set to relieve between 2,400 and 2,800 p.s.i. shall be installed in the distributing manifold or such other location as to protect the piping in the event that all branch line shut-off valves are closed.

(e) All dead end lines shall extend at least 2 inches beyond the last orifice and shall be closed with cap or plug.

(f) All piping, valves, and fittings shall be securely supported, and where necessary, protected against injury.

(g) Drains and dirt traps shall be fitted where necessary to prevent the accumulation of dirt or moisture. Drains and dirt traps shall be located in accessible locations where possible.

(h) Piping shall be used for no other purpose except that it may be incorporated with the fire detecting system.

(i) Piping passing through living quarters shall not be fitted with drains or other openings within such spaces.