

Coast Guard, DHS

§ 78.47-45

§ 78.47-25 Emergency squad equipment.

(a) Lockers or spaces containing equipment for the use of the emergency squad shall be marked "EMERGENCY SQUAD EQUIPMENT."

(b) [Reserved]

§ 78.47-27 Self-contained breathing apparatus.

Lockers or spaces containing self-contained breathing apparatus shall be marked "SELF-CONTAINED BREATHING APPARATUS."

[CGD 95-028, 62 FR 51205, Sept. 30, 1997]

§ 78.47-30 Hand portable fire extinguishers.

(a) Each hand portable fire extinguisher shall be marked with a number and the location where stowed shall be marked with a corresponding number at least ½ inch high. Where only one type and size of hand portable fire extinguisher is carried, the numbering may be omitted.

(b) [Reserved]

§ 78.47-33 Emergency lights.

(a) All emergency lights shall be marked with a letter "E" at least ½ inch high.

(b) [Reserved]

§ 78.47-35 Fire doors.

(a) All doors in main vertical zone bulkheads or stairway enclosures, except from individual rooms such as staterooms, fan rooms, lockers, etc., shall be numbered conspicuously on an etched plate or equivalent in not less than ⅜ inch letters and figures "F. S. D. 1," "2," "3," etc. If stenciled or similar notice is used, the letters and figures shall be at least 1 inch high. The number shall be conspicuous with the door in the open position.

(b) [Reserved]

§ 78.47-37 Watertight doors.

(a) All watertight doors in subdivision bulkheads shall be numbered conspicuously on both sides on an etched plate or equivalent in not less than ⅜ inch letters and figures "W. T. D. 1," "2," "3," etc. If a stenciled or similar notice is used, the letters and figures shall be at least 1 inch high. If the con-

struction is such that the number cannot be seen with the door in the open position, a similar number shall be placed on the frame or other location immediately adjacent to the door. All watertight door remote control stations shall be marked in the same manner, and in addition, the direction of operation of the lever or wheel to open and close the door shall be conspicuously marked.

(b) Class 1 doors fitted in accordance with the requirements in §170.255 of this chapter must additionally be marked "RECLOSE AFTER USE."

[CGFR 65-50, 30 FR 16955, Dec. 30, 1965, as amended by CGD 79-023, 48 FR 51008, Nov. 4, 1983]

§ 78.47-38 Valves and closing appliances.

(a) All valves and closing appliances, or other mechanisms which may be required to be operated for damage control purposes in case of emergency shall be conspicuously marked with letters at least 1 inch high identifying the control and the direction of operation. In all cases indication shall be provided to show whether the control is open or closed.

(b) [Reserved]

§ 78.47-40 Exit signs.

(a) Illuminated exit signs are required and must be installed in accordance with subchapter J (Electrical Engineering Regulations) of this chapter.

(b) Small rooms or spaces having a secondary means of escape which is not obviously apparent shall have a suitable sign in red letters "EMERGENCY EXIT" directing attention to such escape.

CROSS REFERENCE: See subchapter J (Electrical Engineering) of this chapter for minimum size.

[CGFR 65-50, 30 FR 16955, Dec. 30, 1965, as amended by CGD 74-125A, 47 FR 15232, Apr. 8, 1982]

§ 78.47-45 Markings for lifesaving appliances, instructions to passengers, and stowage locations.

Lifesaving appliances, instructions to passengers, and stowage locations must