

Coast Guard, DHS

§ 111.05–33

GROUND DETECTION

§ 111.05–21 Ground detection.

There must be ground detection for each:

- (a) Electric propulsion system;
- (b) Ship's service power system;
- (c) Lighting system; and
- (d) Power or lighting distribution system that is isolated from the ship's service power and lighting system by transformers, motor generator sets, or other devices.

§ 111.05–23 Location of ground indicators.

Ground indicators must:

- (a) Be at the vessel's ship's service generator distribution switchboard for the normal power, normal lighting, and emergency lighting systems;
- (b) Be at the propulsion switchboard for propulsion systems; and
- (c) Be readily accessible.
- (d) Be provided (at the distribution switchboard or at another location, such as a centralized monitoring position for the circuit affected) for each feeder circuit that is isolated from the main source by a transformer or other device.

NOTE TO PARAGRAPH (d): An alarm contact or indicating device returned to the main switchboard via a control cable, that allows the detecting equipment to remain near the transformer or other isolating device for local troubleshooting, is allowed.

[CGD 74–125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 94–108, 61 FR 28276, June 4, 1996; 62 FR 23907, May 1, 1997]

§ 111.05–25 Ungrounded systems.

Each ungrounded system must be provided with a suitably sensitive ground detection system located at the respective switchboard which provides continuous indication of circuit status to ground with a provision to momentarily remove the indicating device from the reference ground.

[CGD 94–108, 61 FR 28276, June 4, 1996]

§ 111.05–27 Grounded neutral alternating current systems.

Grounded neutral and high-impedance grounded neutral alternating current systems must have a suitably sensitive ground detection system which indicates current in the ground connec-

tion, is able to withstand the maximum available fault current without damage, and provides continuous indication of circuit status to ground. A provision must be included to compare indications under fault conditions with those under normal conditions.

[CGD 94–108, 62 FR 23907, May 1, 1997]

§ 111.05–29 Dual voltage direct current systems.

Each dual voltage direct current system must have a suitably sensitive ground detection system which indicates current in the ground connection, has a range of at least 150 percent of neutral current rating and indicates the polarity of the fault.

[CGD 94–108, 61 FR 28276, June 4, 1996]

GROUNDING CONDUCTORS

§ 111.05–31 Grounding conductors for systems.

(a) A conductor for grounding a direct-current system must be the larger of:

- (1) The largest conductor supplying the system; or
- (2) No. 8 AWG (8.4mm²).

(b) A conductor for grounding the neutral of an alternating-current system must meet Table 111.05–31(b).

TABLE 111.05–31(b)—NEUTRAL GROUNDING CONDUCTOR FOR ALTERNATING-CURRENT SYSTEM

Size of the largest generator cable or equivalent for parallel generators—AWG-MCM (mm ²)		Size of the system grounding conductor—AWG(mm ²)
Greater than	Less than or equal to	
.....	2 (33.6)	8 (8.4)
2 (33.6)	0 (53.5)	6 (13.3)
0 (53.5)	3/0 (85.0)	4 (21.2)
3/0 (85.0)	350 MCM (177)	2 (33.6)
350 MCM (177)	600 MCM (304)	0 (53.5)
600 MCM (304)	1100 MCM (557)	2/0 (67.5)
1100 MCM (557)	3/0 (85.0)

§ 111.05–33 Equipment safety grounding (bonding) conductors.

(a) Each equipment-grounding conductor must be sized in accordance with Section 250.122 of NFPA NEC 2002 (incorporated by reference; see 46 CFR 110.10–1).

(b) Each equipment-grounding conductor (other than a system-grounding