

other toxic vaporizing liquids shall be removed from all vessels.

**§ 95.50-10 Location.**

(a) Approved hand portable fire extinguishers and semiportable fire extinguishing systems shall be installed in accordance with Table 95.50-10(a). The location of the equipment shall be to

the satisfaction of the Officer in Charge, Marine Inspection. Nothing in this paragraph shall be construed as limiting the Officer in Charge, Marine Inspection, from requiring such additional equipment as he deems necessary for the proper protection of the vessel.

TABLE 95.50-10(a)—HAND PORTABLE FIRE EXTINGUISHER AND SEMI-PORTABLE FIRE-EXTINGUISHING SYSTEMS

| Space   | Classification (see § 95.50-5)      | Quantity and location   |
|---|-------------------------------------|---|
| <i>Safety areas<sup>1</sup></i>   |                                     |   |
| Wheelhouse or fire control room .....   | .....                               | None required.  |
| Stairway and elevator enclosures .....  | .....                               | Do.   |
| Communicating corridors .....   | A-II .....                          | 1 in each main corridor not more than 150 feet apart. (May be located in stairways.)                                |
| Lifeboat embarkation and lowering stations .....  | .....                               | None required.  |
| Radio room.   |                                     |   |
| C-1 <sup>2</sup> .....  | 2 in vicinity of exit. <sup>2</sup> |   |
| <i>Accommodations<sup>1</sup></i>   |                                     |   |
| Staterooms, toilet spaces, public spaces, offices, lockers, isolated storerooms, and pantries, open decks, etc. | .....                               | None required.  |
| <i>Service spaces<sup>1</sup></i>   |                                     |   |
| Galleys .....   | B-II or C-II .....                  | 1 for each 2,500 square feet or fraction thereof suitable for hazards involved.                                     |
| Paint and lamp rooms .....  | B-II .....                          | 1 outside space in vicinity of exit.  |
| Accessible baggage, mail, and specie rooms, and storerooms ...  | A-II .....                          | 1 for each 2,500 square feet or fraction thereof located in vicinity of exits, either inside or outside the spaces. |
| Carpenter shop and similar spaces .....   | A-II .....                          | 1 outside the space in vicinity of exit.  |
| <i>Machinery spaces</i>   |                                     |   |
| Coal-fired boilers: Bunker and boiler space .....   | .....                               | None required.  |
| Oil-fired boilers: Spaces containing oil-fired boilers, either main or auxiliary, or their fuel-oil units.      | B-II; B-V .....                     | 2 required <sup>3</sup> ; 1 required. <sup>4</sup>  |
| Internal combustion or gas turbine propelling machinery spaces  | B-II .....                          | 1 for each 1,000 brake horsepower, but not less than 2 nor more than 6. <sup>5</sup>                                |
|   | B-III .....                         | 1 required. <sup>6,7</sup>  |
| Electric propulsive motors or generators of open type .....   | C-II .....                          | 1 for each propulsion motor or generator unit.  |
| Enclosed ventilating systems for motors and generators of electric propelling machinery.                        | .....                               | None required.  |
| Auxiliary spaces:   |                                     |   |
| Internal combustion or gas turbine .....  | B-II .....                          | 1 outside the space in vicinity of exit. <sup>7</sup>   |
| Electric emergency motors or generators .....   | C-II .....                          | 1 outside the space in vicinity of exit. <sup>8</sup>   |
| Steam .....   | .....                               | None required.  |
| Trunks to machinery spaces .....  | .....                               | Do.   |
| Fuel tanks .....  | .....                               | Do.   |
| <i>Cargo spaces</i>   |                                     |   |
| Inaccessible during voyage, including trunks and cargo tanks .....  | .....                               | Do.   |
| Accessible during voyage .....  | .....                               | Do.   |

<sup>1</sup> For motorboats, the total number of hand portable fire extinguishers required for safety areas, accommodation spaces, and service spaces shall be 1 B-II for motorboats of less than 50 gross tons and 2 B-II for motor boats of 50 gross tons and over. Two B-I hand portable fire extinguishers may be substituted for 1 B-II.

<sup>2</sup> For vessels on an international voyage, substitute 1 C-II in vicinity of exit.

<sup>3</sup> Vessels of less than 1,000 gross tons require 1.

<sup>4</sup> Vessels of less than 1,000 gross tons may substitute 1 B-IV.

<sup>5</sup> Only 1 required for motorboats.

<sup>6</sup> If oil burning donkey boiler fitted in space, the B-V previously required for the protection of the boiler may be substituted. Not required where a fixed carbon dioxide system is installed.

<sup>7</sup> Not required on vessels of less than 300 gross tons if fuel has a flashpoint higher than 110 °F.

<sup>8</sup> Not required on vessels of less than 300 gross tons.

**§ 95.50-15**

(b) Semiportable fire extinguishing systems shall be located in the open so as to be readily seen.

(c) If hand portable fire extinguishers are not located in the open or behind glass so that they may be readily seen, they may be placed in enclosures together with the fire hose, provided such enclosures are marked as required by § 97.37-15 of this subchapter.

(d) Hand portable fire extinguishers and their stations shall be numbered in accordance with § 97.37-23 of this subchapter.

(e) Hand portable or semiportable extinguishers, which are required on their nameplates to be protected from freezing, shall not be located where freezing temperatures may be expected.

**§ 95.50-15 Spare charges.**

(a) For all vessels other than motorboats spare charges shall be carried for at least 50 percent of each size and each variety, i.e. foam, soda-acid, carbon dioxide, etc., of hand portable fire extinguisher required by § 95.50-10(a). However, if the unit is of such variety that it cannot be readily recharged by the vessel's personnel, one spare unit of the same classification shall be carried in lieu of spare charges for all such units of the same size and variety.

(b) Spare charges shall be so packaged as to minimize the hazards to personnel while recharging the units. Acid shall be contained in a Crown stopper type of bottle.

**§ 95.50-20 Semiportable fire extinguishers.**

(a) The frame or support of each size III, IV, and V fire extinguisher required by Table 95.50-10(a) must be welded or otherwise permanently attached to a bulkhead or deck.

(b) If an approved size III, IV, or V fire extinguisher has wheels and is not required by Table 95.50-10(a), it must be securely stowed when not in use to prevent it from rolling out of control under heavy sea conditions.

[CGD 77-039, 44 FR 34133, June 14, 1979]

**46 CFR Ch. I (10-1-13 Edition)**

**§ 95.50-90 Vessels contracted for prior to November 19, 1952.**

(a) Vessels contracted for prior to November 19, 1952, shall meet the following requirements:

(1) The provisions of §§ 95.50-5 through 95.50-15 shall be met with the exception that existing installations in safety areas and service spaces may be maintained if in the opinion of the Officer in Charge, Marine Inspection, they are in general agreement with the degree of safety prescribed by Table 95.50-10(a). In such cases, minor modifications may be made to the same standard as the original installation: *Provided*, That in no case will a greater departure from the standards of Table 95.50-10(a) be permitted than presently exists.

**Subpart 95.60—Fire Axes**

**§ 95.60-1 Application.**

(a) The provisions of this subpart shall apply to all vessels other than motorboats.

**§ 95.60-5 Number required.**

(a) All vessels except barges shall carry at least the minimum number of fire axes as set forth in Table 95.60-5(a). Nothing in this paragraph shall be construed as limiting the Officer in Charge, Marine Inspection, from requiring such additional fire axes as he deems necessary for the proper protection of the vessel.

TABLE 95.60-5(a)

| Gross tons |          | Number of axes |
|------------|----------|----------------|
| Over       | Not over |                |
|            | 50       | 1              |
| 50         | 200      | 2              |
| 200        | 500      | 4              |
| 500        | 1,000    | 6              |
| 1,000      |          | 8              |

(b) Manned barges shall carry at least two fire axes.

**§ 95.60-10 Location.**

(a) Fire axes shall be distributed throughout the spaces available to persons on board so as to be most readily available in the event of emergency.