

## Nuclear Regulatory Commission

## § 55.45

(2) Facility operating limitations in the technical specifications and their bases.

(3) Facility licensee procedures required to obtain authority for design and operating changes in the facility.

(4) Radiation hazards that may arise during normal and abnormal situations, including maintenance activities and various contamination conditions.

(5) Assessment of facility conditions and selection of appropriate procedures during normal, abnormal, and emergency situations.

(6) Procedures and limitations involved in initial core loading, alterations in core configuration, control rod programming, and determination of various internal and external effects on core reactivity.

(7) Fuel handling facilities and procedures.

### § 55.45 Operating tests.

(a) *Content.* The operating tests administered to applicants for operator and senior operator licenses in accordance with paragraph (b)(1) of this section are generally similar in scope. The content will be identified, in part, from learning objectives derived from a systematic analysis of licensed operator or senior operator duties performed by each facility licensee and contained in its training program and from information in the Final Safety Analysis Report, system description manuals and operating procedures, facility license and license amendments, Licensee Event Reports, and other materials requested from the facility licensee by the Commission. The operating test, to the extent applicable, requires the applicant to demonstrate an understanding of and the ability to perform the actions necessary to accomplish a representative sample from among the following 13 items.

(1) Perform pre-startup procedures for the facility, including operating of those controls associated with plant equipment that could affect reactivity.

(2) Manipulate the console controls as required to operate the facility between shutdown and designated power levels.

(3) Identify annunciators and condition-indicating signals and perform ap-

propriate remedial actions where appropriate.

(4) Identify the instrumentation systems and the significance of facility instrument readings.

(5) Observe and safely control the operating behavior characteristics of the facility.

(6) Perform control manipulations required to obtain desired operating results during normal, abnormal, and emergency situations.

(7) Safely operate the facility's heat removal systems, including primary coolant, emergency coolant, and decay heat removal systems, and identify the relations of the proper operation of these systems to the operation of the facility.

(8) Safely operate the facility's auxiliary and emergency systems, including operation of those controls associated with plant equipment that could affect reactivity or the release of radioactive materials to the environment.

(9) Demonstrate or describe the use and function of the facility's radiation monitoring systems, including fixed radiation monitors and alarms, portable survey instruments, and personnel monitoring equipment.

(10) Demonstrate knowledge of significant radiation hazards, including permissible levels in excess of those authorized, and ability to perform other procedures to reduce excessive levels of radiation and to guard against personnel exposure.

(11) Demonstrate knowledge of the emergency plan for the facility, including, as appropriate, the operator's or senior operator's responsibility to decide whether the plan should be executed and the duties under the plan assigned.

(12) Demonstrate the knowledge and ability as appropriate to the assigned position to assume the responsibilities associated with the safe operation of the facility.

(13) Demonstrate the applicant's ability to function within the control room team as appropriate to the assigned position, in such a way that the facility licensee's procedures are adhered to and that the limitations in its license and amendments are not violated.

## § 55.46

## 10 CFR Ch. I (1–1–14 Edition)

(b) *Implementation—Administration.* The operating test will be administered in a plant walkthrough and in either—

(1) A simulation facility that the Commission has approved for use after application has been made by the facility licensee under § 55.46(b);

(2) A plant-referenced simulator (§ 55.46(c)); or

(3) The plant, if approved for use in the administration of the operating test by the Commission under § 55.46(b).

[52 FR 9460, Mar. 25, 1987, as amended at 53 FR 43421, Oct. 27, 1988; 62 FR 59276, Nov. 3, 1997; 66 FR 52667, Oct. 17, 2001]

### § 55.46 Simulation facilities.

(a) *General.* This section addresses the use of a simulation facility for the administration of the operating test and plant-referenced simulators to meet experience requirements for applicants for operator and senior operator licenses.

(b) *Commission-approved simulation facilities and Commission approval of use of the plant in the administration of the operating test.* (1) Facility licensees that propose to use a simulation facility, other than a plant-referenced simulator, or the plant in the administration of the operating test under §§ 55.45(b)(1) or 55.45(b)(3), shall request approval from the Commission. This request must include:

(i) A description of the components of the simulation facility intended to be used, or the way the plant would be used for each part of the operating test, unless previously approved; and

(ii) A description of the performance tests for the simulation facility as part of the request, and the results of these tests; and

(iii) A description of the procedures for maintaining examination and test integrity consistent with the requirements of § 55.49.

(2) The Commission will approve a simulation facility or use of the plant for administration of operating tests if it finds that the simulation facility and its proposed use, or the proposed use of the plant, are suitable for the conduct of operating tests for the facility licensee's reference plant under § 55.45(a).

(c) *Plant-referenced simulators.* (1) A plant-referenced simulator used for the

administration of the operating test or to meet experience requirements in § 55.31(a)(5) must demonstrate expected plant response to operator input and to normal, transient, and accident conditions to which the simulator has been designed to respond. The plant-referenced simulator must be designed and implemented so that it:

(i) Is sufficient in scope and fidelity to allow conduct of the evolutions listed in §§ 55.45(a)(1) through (13), and 55.59(c)(3)(i)(A) through (AA), as applicable to the design of the reference plant.

(ii) Allows for the completion of control manipulations for operator license applicants.

(2) Facility licensees that propose to use a plant-referenced simulator to meet the control manipulation requirements in § 55.31(a)(5) must ensure that:

(i) The plant-referenced simulator utilizes models relating to nuclear and thermal-hydraulic characteristics that replicate the most recent core load in the nuclear power reference plant for which a license is being sought; and

(ii) Simulator fidelity has been demonstrated so that significant control manipulations are completed without procedural exceptions, simulator performance exceptions, or deviation from the approved training scenario sequence.

(3) A simulation facility consisting solely of a plant-referenced simulator must meet the requirements of paragraph (c)(1) of this section and the criteria in paragraphs (d)(1) and (4) of this section for the Commission to accept the plant-referenced simulator for conducting operating tests as described in § 55.45(a) of this part, requalification training as described in § 55.59(c)(3) of this part, or for performing control manipulations that affect reactivity to establish eligibility for an operator's license as described in § 55.31(a)(5).

(d) *Continued assurance of simulator fidelity.* Facility licensees that maintain a simulation facility shall:

(1) Conduct performance testing throughout the life of the simulation facility in a manner sufficient to ensure that paragraphs (c)(2)(ii), as applicable, and (d)(3) of this section are met. The results of performance tests must be retained for four years after the