

(f) Fire extinguishers adequate in number and suitable for the hazard shall be provided. These extinguishers shall be located in the immediate area where pressure vessels, drums and containers containing flammable liquids or gases are stored or in use. Such extinguishers shall be ready for use at all times.

Subpart L—Electrical Machinery

§ 1915.181 Electrical circuits and distribution boards.

(a) The provisions of this section shall apply to ship repairing and shipbuilding and shall not apply to shipbreaking.

(b) Before an employee is permitted to work on an electrical circuit, except when the circuit must remain energized for testing and adjusting, the circuit shall be deenergized and checked at the point at which the work is to be done to insure that it is actually deenergized. When testing or adjusting an energized circuit a rubber mat, duck board, or other suitable insulation shall be used underfoot where an insulated deck does not exist.

(c) De-energizing the circuit shall be accomplished by opening the circuit breaker, opening the switch, or removing the fuse, whichever method is appropriate. The circuit breaker, switch, or fuse location shall then be locked out or tagged in accordance with § 1915.89.

(d) When work is performed immediately adjacent to an open-front energized board or in back of an energized board, the board shall be covered or some other equally safe means shall be used to prevent contact with any of the energized parts.

[47 FR 16986, Apr. 20, 1982, as amended at 67 FR 44545, July 3, 2002; 76 FR 24711, May 2, 2011]

Subparts M–O [Reserved]

Subpart P—Fire Protection in Shipyard Employment

SOURCE: 69 FR 55702, Sept. 15, 2004, unless otherwise noted.

§ 1915.501 General provisions.

(a) *Purpose.* The purpose of the standard in this subpart is to require employers to protect all employees from fire hazards in shipyard employment, including employees engaged in fire response activities.

(b) *Scope.* This subpart covers employers with employees engaged in shipyard employment aboard vessels and vessel sections, and on land-side operations regardless of geographic location.

(c) *Employee participation.* The employer must provide ways for employees or employee representatives, or both to participate in developing and periodically reviewing programs and policies adopted to comply with this subpart.

(d) *Multi-employer worksites—(1) Host employer responsibilities.* The host employer's responsibilities are to:

(i) Inform all employers at the worksite about the content of the fire safety plan including hazards, controls, fire safety and health rules, and emergency procedures;

(ii) Make sure the safety and health responsibilities for fire protection are assigned as appropriate to other employers at the worksite; and

(iii) If there is more than one host employer, each host employer must communicate relevant information about fire-related hazards to other host employers. When a vessel owner or operator (temporarily) becomes a host shipyard employer by directing the work of ships' crews on repair or modification of the vessel or by hiring other contractors directly, the vessel owner or operator must also comply with these provisions for host employers.

(2) *Contract employer responsibilities.* The contract employer's responsibilities are to:

(i) Make sure that the host employer knows about the fire-related hazards associated with the contract employer's work and what the contract employer is doing to address them; and

(ii) Advise the host employer of any previously unidentified fire-related hazards that the contract employer identifies at the worksite.