

Pt. 63, Subpt. UUU, Table 33

40 CFR Ch. I (7–1–14 Edition)

| For . . . | You must . . . | Using . . . | According to these requirements . . . |
|-----------|---|---|--|
| | j. Measure thermal incinerator: oxygen concentration (percent, dry basis) in the vent stream. | Data from the continuous parameter monitoring system. | Collect oxygen concentration (percent, dry basis) data every 15 minutes during the entire period of the performance test; and determine and record the minimum hourly average percent excess oxygen concentration. |
| | k. If you use a continuous emission monitoring system, measure TRS concentration. | Data from continuous emission monitoring system. | Collect TRS data every 15 minutes for 24 consecutive operating hours. Reduce the data to 1-hour averages computed from four or more data points equally spaced over each 1-hour period. |

[67 FR 17773, Apr. 11, 2002, as amended at 70 FR 6942, Feb. 9, 2005]

TABLE 33 TO SUBPART UUU OF PART 63—INITIAL COMPLIANCE WITH HAP EMISSION LIMITS FOR SULFUR RECOVERY UNITS

As stated in §63.1568(b)(5), you shall meet each requirement in the following table that applies to you.

| For . . . | For the following emission limit . . . | You have demonstrated initial compliance if . . . |
|--|---|--|
| 1. Each new or existing Claus sulfur recovery unit part of a sulfur recovery plant of 20 long tons per day or more and subject to the NSPS for sulfur oxides in 40 CFR 60.104(a)(2). | a. 250 pmv (dry basis) SO ₂ at zero percent excess air if you use an oxidation or reduction control system followed by incineration. | You have already conducted a performance test to demonstrate initial compliance with the NSPS and each 12-hour rolling average concentration of SO ₂ emissions measured by the continuous emission monitoring system is less than or equal to 250 ppmv (dry basis) at zero percent excess air. As part of the Notification of Compliance Status, you must certify that your vent meets the SO ₂ limit. You are not required to do another performance test to demonstrate initial compliance. You have already conducted a performance evaluation to demonstrate initial compliance with the applicable performance specification. As part of your Notification of Compliance Status, you must certify that your continuous emission monitoring system meets the applicable requirements in §63.1572. You are not required to do another performance evaluation to demonstrate initial compliance. |

Environmental Protection Agency

Pt. 63, Subpt. UUU, Table 33

| For . . . | For the following emission limit . . . | You have demonstrated initial compliance if . . . |
|---|---|--|
| <p>2. Option 1: Elect NSPS. Each new or existing sulfur recovery unit (Claus or other type, regardless of size) not subject to the NSPS for sulfur oxides in 40 CFR 60.104(a)(2).</p> | <p>b. 300 ppmv of reduced sulfur compounds calculated as ppmv SO₂ (dry basis) at zero percent excess air if you use a reduction control system without incineration.</p> | <p>You have already conducted a performance test to demonstrate initial compliance with the NSPS and each 12-hour rolling average concentration of reduced sulfur compounds measured by your continuous emission monitoring system is less than or equal to 300 ppmv, calculated as ppmv SO₂ (dry basis) at zero percent excess air. As part of the Notification of Compliance Status, you must certify that your vent meets the SO₂ limit. You are not required to do another performance test to demonstrate initial compliance. You have already conducted a performance evaluation to demonstrate initial compliance with the applicable performance specification. As part of your Notification of Compliance Status, you must certify that your continuous emission monitoring system meets the applicable requirements in § 63.1572. You are not required to do another performance evaluation to demonstrate initial compliance.</p> |
| | <p>a. 250 ppmv (dry basis) of SO₂ at zero percent excess air if you use an oxidation or reduction control system followed by incineration.</p> | <p>Each 12-hour rolling average concentration of SO₂ emissions measured by the continuous emission monitoring system during the initial performance test is less than or equal to 250 ppmv (dry basis) at zero percent excess air; and your performance evaluation shows the monitoring system meets the applicable requirements in § 63.1572.</p> |
| | <p>b. 300 ppmv of reduced sulfur compounds calculated as ppmv SO₂ (dry basis) at zero percent excess air if you use a reduction control system without incineration.</p> | <p>Each 12-hour rolling average concentration of reduced sulfur compounds measured by the continuous emission monitoring system during the initial performance test is less than or equal to 300 ppmv, calculated as ppmv SO₂ (dry basis) at zero percent excess air; and your performance evaluation shows the continuous emission monitoring system meets the applicable requirements in § 63.1572.</p> |
| <p>3. Option 2: TRS limit. Each new or existing sulfur recovery unit (Claus or other type, regardless of size) not subject to the NSPS for sulfur oxides in 40 CFR 60.104(a)(2).</p> | <p>300 ppmv of TRS compounds expressed as an equivalent SO₂ concentration (dry basis) at zero percent oxygen.</p> | <p>If you use continuous parameter monitoring systems, the average concentration of TRS emissions measured using Method 15 during the initial performance test is less than or equal to 300 ppmv expressed as equivalent SO₂ concentration (dry basis) at zero percent oxygen. If you use a continuous emission monitoring system, each 12-hour rolling average concentration of TRS emissions measured by the continuous emission monitoring system during the initial performance test is less than or equal to 300 ppmv expressed as an equivalent SO₂ (dry basis) at zero percent oxygen; and your performance evaluation shows the continuous emission monitoring system meets the applicable requirements in § 63.1572.</p> |

[70 F.R. 6962, Feb. 9, 2005]