

§ 35.40-8

November 19, 1952, must be conspicuously marked: “WHEN ALARM SOUNDS VACATE AT ONCE. [CARBON DIOXIDE/CLEAN AGENT—as appropriate] BEING RELEASED.”

[USCG-2006-24797, 77 FR 33874, June 7, 2012]

§ 35.40-8 Carbon dioxide warning signs—T/ALL.

Each entrance to a space storing carbon dioxide cylinders, a space protected by carbon dioxide systems, or any space into which carbon dioxide might migrate must be conspicuously marked as follows:

(a) Spaces storing carbon dioxide—“CARBON DIOXIDE GAS CAN CAUSE INJURY OR DEATH. VENTILATE THE AREA BEFORE ENTERING. A HIGH CONCENTRATION CAN OCCUR IN THIS AREA AND CAN CAUSE SUFFOCATION.”

(b) Spaces protected by carbon dioxide—“CARBON DIOXIDE GAS CAN CAUSE INJURY OR DEATH. WHEN ALARM OPERATES OR WINTERGREEN SCENT IS DETECTED, DO NOT ENTER UNTIL VENTILATED. LOCK OUT SYSTEM WHEN SERVICING.” The reference to wintergreen scent may be omitted for carbon dioxide systems not required to have odorizing units and not equipped with such units.

(c) Spaces into which carbon dioxide might migrate—“CARBON DIOXIDE GAS CAN CAUSE INJURY OR DEATH. DISCHARGE INTO NEARBY SPACE CAN COLLECT HERE. WHEN ALARM OPERATES OR WINTERGREEN SCENT IS DETECTED VACATE IMMEDIATELY.” The reference to wintergreen scent may be omitted for carbon dioxide systems not required to have odorizing units and not equipped with such units.

[USCG-2006-24797, 77 FR 33874, June 7, 2012]

§ 35.40-10 Steam, foam, carbon dioxide, or clean agent fire smothering apparatus—TB/ALL.

Each steam, foam, carbon dioxide, or clean agent fire fighting apparatus must be marked “[CARBON DIOXIDE/STEAM/FOAM/CLEAN AGENT—as appropriate] FIRE APPARATUS” in red letters at least 2 inches high. Branch pipe valves leading to the several com-

46 CFR Ch. I (10-1-14 Edition)

partments must be distinctly marked to indicate the compartments or parts of the vessel to which they lead.

[USCG-2006-24797, 77 FR 33874, June 7, 2012]

§ 35.40-15 Fire hose stations—TB/ALL.

At each fire hose valve there shall be marked in not less than 2-inch red letters and figures: “FIRE STATION 1,” 2, 3, etc.

§ 35.40-17 Foam hose/monitor stations—T/ALL.

(a) At each required foam hose/monitor valve there shall be marked in not less than 2-inch red letters and figures: “FOAM STATION 1,” 2, 3, etc.

(b) [Reserved]

§ 35.40-18 Water spray systems—TB/ALL.

(a) Water spray system apparatus shall be marked: “WATER SPRAY SYSTEM,” as appropriate, in not less than 2-inch red letters.

(b) The control valve, and its control if located remotely, shall be distinctly marked to indicate the compartment protected.

§ 35.40-20 Emergency equipment—TB/ALL.

Each locker and space where emergency equipment is stowed must be marked “EMERGENCY EQUIPMENT” or “SELF-CONTAINED BREATHING APPARATUS”, as appropriate.

[CGD 86-036, 57 FR 43824, Oct. 23, 1992]

§ 35.40-25 Fire extinguishers—TB/ALL.

Each fire extinguisher shall be marked with a number and the location where stowed shall be marked in corresponding numbers in at least ½ inch figures.

§ 35.40-30 Instructions for changing steering gear—TB/ALL.

Instructions in at least ½ inch letters and figures shall be posted in the steering engine room, relating in order, the different steps to be taken in changing to the emergency steering gear. Each clutch, gear wheel, lever, valve or switch which is used during the changeover shall be numbered or lettered on a brass plate or painted so that the markings can be recognized at