

§ 111.50-7

(ii) Near an easily ignitable material or where explosive gas or vapor may accumulate.

§ 111.50-7 Enclosures.

(a) Each enclosure of an overcurrent protective device must meet Sections 240-30 and 240-33 of NFPA NEC 2002 (incorporated by reference; see 46 CFR 110.10-1).

(b) No enclosure may be exposed to the weather unless accepted by the Commandant.

[CGD 74-125A, 47 FR 15236, Apr. 8, 1982, as amended by USCG-2003-16630, 73 FR 65197, Oct. 31, 2008]

§ 111.50-9 Disconnecting and guarding.

Disconnecting and guarding of overcurrent protective devices must meet Part IV of Article 240 of NFPA NEC 2002 (incorporated by reference; see 46 CFR 110.10-1).

[USCG-2003-16630, 73 FR 65197, Oct. 31, 2008]

Subpart 111.51—Coordination of Overcurrent Protective Devices

§ 111.51-1 Purpose.

The purpose of this subpart is to provide continuity of service for equipment vital to the propulsion, control or safety of the vessel under short-circuit conditions through coordination and selective operation of overcurrent protective devices.

§ 111.51-3 Protection of vital equipment.

(a) The coordination of overcurrent protective devices must be demonstrated for all potential plant configurations.

(b) Overcurrent protective devices must be installed so that:

(1) A short-circuit on a circuit that is not vital to the propulsion, control, or safety of the vessel does not trip equipment that is vital; and

(2) A short-circuit on a circuit that is vital to the propulsion, control, or safety of the vessel is cleared only by the protective device that is closest to the point of the short-circuit.

[CGD 74-125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 94-108, 62 FR 23908, May 1, 1997]

46 CFR Ch. I (10-1-14 Edition)

Subpart 111.52—Calculation of Short-Circuit Currents

§ 111.52-1 General.

The available short-circuit current must be computed—

(a) From the aggregate contribution of all generators that can simultaneously operate in parallel;

(b) From the largest probable motor load; and

(c) With a three phase fault on the load terminals of the protective device.

[CGD 74-125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 94-108, 61 FR 28279, June 4, 1996]

§ 111.52-3 Systems below 1500 kilowatts.

The following short-circuit assumptions must be made for a system with an aggregate generating capacity below 1500 kilowatts, unless detailed computations in accordance with § 111.52-5 are submitted:

(a) The maximum short-circuit current of a direct current system must be assumed to be 10 times the aggregate normal rated generator currents plus six times the aggregate normal rated currents of all motors that may be in operation.

(b) The maximum asymmetrical short-circuit current for an alternating current system must be assumed to be 10 times the aggregate normal rated generator currents plus four times the aggregate normal rated currents of all motors that may be in operation.

(c) The average asymmetrical short-circuit current for an alternating-current system must be assumed to be $8\frac{1}{2}$ times the aggregate normal rated generator currents plus $3\frac{1}{2}$ times the aggregate normal rated currents of all motors that may be in operation.

§ 111.52-5 Systems 1500 kilowatts or above.

Short-circuit calculations must be submitted for systems with an aggregate generating capacity of 1500 kilowatts or more by utilizing one of the following methods:

(a) Exact calculations using actual impedance and reactance values of system components.