

following proposal for the collection of information under the provisions of the Paperwork Reduction Act (44 U.S.C. Chapter 35).

1. Type of submission, new, revision, or extension: Extension.

2. The title of the information collection: NRC Form 314—Certificate of Disposition of Materials.

3. The form number if applicable: NRC Form 314.

4. How often the collection is required: The form is submitted once, when a licensee terminates its license.

5. Who will be required or asked to report: Persons holding an NRC license for the possession and use of radioactive byproduct, source, or special nuclear material who are ceasing licensed activities and terminating the license.

6. An estimate of the number of responses: 400.

7. An estimate of the total number of hours needed to complete the requirement or request: An average of 0.5 hours per response, for a total of 200 hours.

8. An indication of whether Section 3504(h), Pub. L. 96-511 applies: Not applicable.

9. Abstract: NRC Form 314 furnishes information to NRC regarding transfer or other disposition of radioactive material by licensees who wish to terminate their licenses. The information is used by NRC as part of the basis for its determination that the facility has been cleared of radioactive material before the facility is released for unrestricted use.

Copies of the submittal may be inspected or obtained for a fee from the NRC Public Document Room, 2120 L Street, NW., (Lower Level), Washington, DC.

Comments and questions may be directed by mail to the OMB reviewer, Troy Hillier, Office of Information and Regulatory Affairs (3150-0028), NEOB-10202, Office of Management and Budget, Washington, DC 20503.

Comments may also be communicated by telephone at (202) 395-3084.

The NRC Clearance Officer is Brenda Jo. Shelton, (301) 415-7233.

Dated at Rockville, Maryland, this 14th day of March, 1995.

For the Nuclear Regulatory Commission.

**Gerald F. Cranford,**

*Designated Senior Official for Information Resources Management.*

[FR Doc. 95-6873 Filed 3-20-95; 8:45 am]

BILLING CODE 7590-01-M

### Documents Containing Reporting or Recordkeeping Requirements; Office of Management and Budget Review

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Notice of the Office of Management and Budget review of information collection.

**SUMMARY:** The Nuclear Regulatory Commission (NRC) has recently submitted to the Office of Management and Budget (OMB) for review the following proposal for the collection of information under the provisions of the Paperwork Reduction Act (44 U.S.C. Chapter 35).

1. Type of submission, new, revision, or extension: Revision.

2. The title of the information collection: 10 CFR Part 39—Licenses and Radiation Safety Requirements for Well Logging.

3. The form number if applicable: Not applicable.

4. How often the collection is required: Applications for new licenses and amendments may be submitted at any time. Applications for renewal are submitted every 5 years. Reports are submitted as events occur.

5. Who will be required or asked to report: Applicants for and holders of specific licenses authorizing the use of licensed radioactive material in well logging.

6. An estimate of the number of responses: 643.

7. An estimate of the total number of hours needed to complete the requirement or request: Approximately 3.2 hours annually per respondent for applications and reports, plus approximately 214 hours annually per recordkeeper. The industry total burden is 13,676 hours annually.

8. An indication of whether Section 3504(h), Pub. L. 96-511 applies: Not applicable.

9. Abstract: NRC regulations in 10 CFR Part 39 establish radiation safety requirements for the use of radioactive material in well logging operations. The information in the applications, reports and records is used by the NRC staff to ensure that the health and safety of the public is protected and that licensee possession and use of source and byproduct material is in compliance with license and regulatory requirements.

Copies of the submittal may be inspected or obtained for a fee from the NRC Public Document Room, 2120 L Street, NW., (Lower Level), Washington, DC.

Comments and questions may be directed by mail to the OMB reviewer:

Troy Hillier, Office of Information and Regulatory Affairs (3150-0130), NEOB-10202, Office of Management and Budget, Washington, DC 20503.

Comments may also be communicated by telephone at (202) 395-3084.

The NRC Clearance Officer is Brenda Jo. Shelton, (301) 415-7233.

Dated at Rockville, Maryland, this 14th day of March, 1995.

For the Nuclear Regulatory Commission.

**Gerald F. Cranford,**

*Designated Senior Official for Information Resources Management.*

[FR Doc. 95-6876 Filed 3-20-95; 8:45 am]

BILLING CODE 7590-01-M

### [Docket No. 318]

### Baltimore Gas and Electric Company; Calvert Cliffs Nuclear Power Plant Unit No. 2, Environmental Assessment and Funding of No Significant Impact

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of exemptions from Facility Operating License No. DPR-69, issued to Baltimore Gas and Electric Company (the licensee), for operation of the Calvert Cliffs Nuclear Power Plant, Unit No. 2 (CC2) located in Calvert County, Maryland.

### Environmental Assessment

#### Identification of the Proposed Action

This Environmental Assessment has been prepared to address potential environmental issues related to the licensee's application of February 24, 1995. The proposed action would exempt the licensee from: (1) The requirements of 10 CFR Part 50, Appendix J, Paragraph III.D.1.(a), to permit a one-time interval extension between the first and second Type A test (containment integrated leak rate test) for approximately 24 months from the spring 1995 refueling outage to the spring 1997 refueling outage and, (2) would extend the second 10-year service period to 12 years allowing the third Type A test to be performed during the spring 1999 refueling outage.

#### The Need for the Proposed Action

The proposed action is needed to permit the licensee to defer the Type A test from the spring 1995 refueling outage to the spring 1997 refueling outage, which will also result in extending the second 10-year service period to 12 years to allow the third Type A test to be performed, thereby deferring the cost of performing the tests and elimination of the time required to perform the test from the critical path schedule during the upcoming spring

1995 refueling outage. In addition, not performing the test during this outage will reduce the occupational radiation exposure which is consistent with as low as reasonable achievable goal of the licensee's Radiation Protection Program.

#### *Environmental Impacts of the Proposed Action*

The Commission has completed its evaluation of the proposed action and concludes that the one-time interval extension between the first and second Type A tests and the extension of the 10-year service period to 12 years would not increase the probability or consequences of accidents previously analyzed and the proposed exemptions would not affect facility radiation levels or facility radiological effluents. The licensee has analyzed the results of previous Type A tests performed at CC2. Although the first test was not successful, the licensee promptly identified and corrected the problems. As a result, the last three tests have been successful and have demonstrated good containment performance. The licensee will continue to be required to conduct the Type B and C local leak rate tests which, subsequent to the prompt corrective actions following the initial Type A test, have been shown to be the principal means of detecting containment leakage paths with the Type A tests confirming the Type B and C test results. It is also noted that the licensee, as a condition of the proposed exemptions, will perform the visual containment inspection although it is only required by Appendix J to be conducted in conjunction with Type A tests. The NRC staff considers that these inspections, though limited in scope, provide an important added level of confidence in the continued integrity of the containment boundary. The change will not increase the probability or consequences of accidents, no changes are being made in the types of any effluents that may be released offsite, and there is no significant increase in the allowable individual or cumulative occupational radiation exposure. Accordingly, the Commission concludes that there are no significant radiological environmental impacts associated with the proposed action.

With regard to potential nonradiological impacts, the proposed action does involve features located entirely within the restricted area as defined in 10 CFR Part 20. It does not affect nonradiological plant effluents and has no other environmental impact. Accordingly, the Commission concludes that there are no significant nonradiological environmental impacts associated with the proposed action.

#### *Alternatives to the Proposed Action*

Since the Commission has concluded there is no measurable environmental impact associated with the proposed action, any alternatives with equal or greater environmental impact need not be evaluated. As an alternative to the proposed action, the NRC staff considered denial of the proposed action. Denial of the application would result in no change in current environmental impacts.

#### *Alternative Use of Resources*

This action does not involve the use of any resources not previously considered in the Final Environmental Statement for the Calvert Cliffs Nuclear Power Plant, Unit No. 2.

#### *Agencies and Persons Consulted*

In accordance with its stated policy, the NRC staff consulted with the Maryland State official regarding the environmental impact of the proposed action. The State official had no comments.

#### **Finding of No Significant Impact**

Based upon the environmental assessment, the Commission concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee's letter dated February 24, 1995, which is available for public inspection at the Commission's Public Document Room, The Gelman Building, 2120 L Street NW., Washington, DC, and at the local public document room located at the Calvert County Library, Prince Frederick, Maryland 20678.

Dated at Rockville, Maryland, this 15th day of March, 1995.

For the Nuclear Regulatory Commission.

**Ledyard B. Marsh,**

*Director, Project Directorate I-1, Division of Reactor Projects—I/II, Office of Nuclear Reactor Regulation.*

[FR Doc. 95-6877 Filed 3-20-95; 8:45 am]

BILLING CODE 7590-01-M

#### **Advisory Committee on Reactor Safeguards Subcommittee Meeting on Planning and Procedures; Notice of Meeting**

The ACRS Subcommittee on Planning and Procedures will hold a meeting on April 5, 1995, Room T-2B1, 11545 Rockville Pike, Rockville, Maryland.

The entire meeting will be open to public attendance, with the exception of

a portion that may be closed pursuant to 5 U.S.C. 552b(c) (2) and (6) to discuss organizational and personnel matters that relate solely to internal personnel rules and practices of ACRS, and matters the release of which would constitute a clearly unwarranted invasion of personal privacy.

The agenda for the subject meeting shall be as follows:

*Wednesday, April 5, 1995—2:00 p.m. Until the Conclusion of Business*

The Subcommittee will discuss proposed ACRS activities and related matters. It will also discuss the status of the appointment of members to the ACRS. The purpose of this meeting is to gather information, analyze relevant issues and facts, and to formulate proposed positions and actions, as appropriate, for deliberation by the full Committee.

Oral statements may be presented by members of the public with the concurrence of the Subcommittee Chairman; written statements will be accepted and made available to the Committee. Electronic recordings will be permitted only during those portions of the meeting that are open to the public, and questions may be asked only by members of the Subcommittee, its consultants, and staff. Persons desiring to make oral statements should notify the cognizant ACRS staff person named below five days prior to the meeting, if possible, so that appropriate arrangements can be made.

Further information regarding topics to be discussed, the scheduling of sessions open to the public, whether the meeting has been canceled or rescheduled, the Chairman's ruling on requests for the opportunity to present oral statements, and the time allotted therefore can be obtained by contracting the cognizant ACRS staff person, Dr. John T. Larkins (telephone: 301/415-7360) between 7:30 a.m. and 4:15 p.m. (EST). Persons planning to attend this meeting are urged to contact the above named individual one or two working days prior to the meeting to be advised of any changes in schedule, etc., that may have occurred.

Dated: March 15, 1995.

**Sam Duraiswamy**

*Chief, Nuclear Reactors Branch.*

[FR Doc. 95-6879 Filed 3-20-95; 8:45 am]

BILLING CODE 7590-01-M

#### **OFFICE OF MANAGEMENT AND BUDGET**

#### **National Information Infrastructure; Public Meeting**

**AGENCY:** Office of Management and Budget.

**ACTION:** National Information Infrastructure Security issues forum; notice of public meeting and request for public comments.

**SUMMARY:** The National Information Infrastructure Security Issues Forum