

statements should be addressed to Charles H. Atherton, Secretary, Commission of Fine Arts, at the above address or call the above number.

Dated in Washington, D.C. 27 July 1995.

Charles H. Atherton,
Secretary.

[FR Doc. 95-20533 Filed 8-17-95; 8:45 am]

BILLING CODE 6330-01-M

NATIONAL SCIENCE FOUNDATION

Collection of Information Submitted for OMB Review

In accordance with the Paperwork Reduction Act and OMB Guidelines, the National Science Foundation is posting an expedited notice of information collection that will affect the public. Interested persons are invited to submit comments by September 15, 1995. Copies of materials may be obtained at the NSF address or telephone number shown below.

(A) *Agency Clearance Officer.* Herman G. Fleming, Division of Contracts, Policy, and Oversight, National Science Foundation, 4201 Wilson Boulevard, Arlington, VA 22230, or by telephone (703) 306-1243. Comments may also be submitted to:

(B) *OMB Desk Officer.* Office of Information and Regulatory Affairs, ATTN: Jonathan Winer, Desk Officer, OMB, 722 Jackson Place, Room 3208, NEOB, Washington, DC 20503.

Title: Evaluation of the National Science Foundation's Science and Technology Centers Program (STC).

Affected Public: Individuals or households and non-profit institutions.

Respondents/Reporting Burden: 850 respondents, 680 total burden hours.

Abstract: NSF needs to evaluate the accomplishments and impacts of its Science and Technology Centers program in order to (1) Make a number of management decisions regarding the future of the program, and (2) report to OMB and the Congress under the GPRA pilot study arrangement; information will be gathered from Principal Investigators, Deans, industry and education users, and Ph.D graduates in industry and their supervisors.

Dated: August 15, 1995.

Herman G. Fleming,
Reports Clearance Officer.

[FR Doc. 95-20523 Filed 8-17-95; 8:45 am]

BILLING CODE 7555-01-M

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-382]

In the Matter of Entergy Operations, Inc., (Waterford Steam Electric Station, Unit 3); Exemption

I

Entergy Operations, Inc., (the licensee) is the holder of Facility Operating License No. NPF-38, which authorizes operation of the Waterford Steam Electric Station, Unit 3 (Waterford 3). The operating license provides, among other things, that the licensee is subject to all rules, regulations, and orders of the Commission now and hereafter in effect.

The facility consists of a pressurized water reactor at the licensee's site in St. Charles Parish, Louisiana.

II

Title 10 CFR 73.55, "Requirements for physical protection of licensed activities in nuclear power reactors against radiological sabotage," paragraph (a), in part, states that "The licensee shall establish and maintain an onsite physical protection system and security organization which will have as its objective to provide high assurance that activities involving special nuclear material are not inimical to the common defense and security and do not constitute an unreasonable risk to the public health and safety."

10 CFR 73.55(d), "Access Requirements," paragraph (1), specifies that "The licensee shall control all points of personnel and vehicle access into a protected area." 10 CFR 73.55(d)(5) requires that "A numbered picture badge identification system shall be used for all individuals who are authorized access to protected areas without escort." 10 CFR 73.55(d)(5) also states that an individual not employed by the licensee (i.e., contractors) may be authorized access to protected areas without escort provided the individual "receives a picture badge upon entrance into the protected area which must be returned upon exit from the protected area . . ."

The licensee proposed to implement an alternative unescorted access control system which would eliminate the need to issue and retrieve badges at each entrance/exit location and would allow all individuals with unescorted access to keep their badge with them when departing the site.

An exemption from 10 CFR 73.55(d)(5) is required to allow contractors who have unescorted access to take their badges offsite instead of

returning them when exiting the site. By letter dated October 24, 1994, the licensee requested an exemption from certain requirements of 10 CFR 73.55(d)(5) for this purpose.

III

Pursuant to 10 CFR 73.5, "Specific exemptions," the Commission may, upon application of any interested person or upon its own initiative, grant such exemptions from the requirements of the regulations in this part as it determines are authorized by law and will not endanger life or property or the common defense and security, and are otherwise in the public interest.

Pursuant to 10 CFR 73.55, the Commission may authorize a licensee to provide alternative measures for protection against radiological sabotage provided the licensee demonstrates that the alternative measures have "the same high assurance objective" and meet "the general performance requirements" of the regulation, and "the overall level of system performance provides protection against radiological sabotage equivalent" to that which would be provided by the regulation.

Currently, employee and contractor identification/access control cards are issued and retrieved on the occasion of each entry to and exit from the protected areas of the Waterford 3 site. Station security personnel are required to maintain control of the badges while the individuals are offsite. This practice has been in effect at the Waterford 3, since the operating license was issued. Security personnel retain each identification access control card, when not in use by the authorized individual, within appropriately designed storage receptacles inside a bullet-resistant enclosure. An individual who meets the access authorization requirements is issued a picture identification card which also serves as an access control card. This card allows entry into preauthorized areas of the station. While entering the plant in the present configuration, an authorized individual is "screened" by the required detection equipment and by the issuing security officer. Having received the badge, the individual proceeds to the access portal, inserts the access control card into the card reader, and passes through the turnstile which is unlocked by the access card. Once inside the station, the access card allows entry into areas if the preauthorized criteria are met.

This present procedure is labor intensive since security personnel are required to verify badge issuance, ensure badge retrieval, and maintain the badges in orderly storage until the next entry into the protected area. The