

8. Cinergy Services, Inc.

[Docket No. ER98-748-000]

Take notice that on November 21, 1997, on behalf of its operating companies, The Cincinnati Gas & Electric Company and PSI Energy, Inc., Cinergy Services, Inc. (Cinergy), tendered for filing a Service Agreement between Cinergy and the Town of Chalmers (Customer).

Cinergy and Customer have requested an effective date of February 1, 1998.

Copies of the filing were served upon the Town of Chalmers, Northern Indiana Public Service Company and the Indiana Utility Regulatory Commission.

Comment date: December 24, 1997, in accordance with Standard Paragraph E at the end of this notice.

9. Cinergy Services, Inc.

[Docket No. ER98-749-000]

Take notice that on November 21, 1997, on behalf of its operating companies, The Cincinnati Gas & Electric Company and PSI Energy, Inc., Cinergy Services, Inc. (Cinergy), tendered for filing a Service Agreement between Cinergy and the Town of Winamac (Customer).

Cinergy and Customer have requested an effective date of February 1, 1998.

Copies of the filing were served upon the Town of Winamac, Northern Indiana Public Service Company and the Indiana Utility Regulatory Commission.

Comment date: December 24, 1997, in accordance with Standard Paragraph E at the end of this notice.

10. Cinergy Services, Inc.

[Docket No. ER98-750-000]

Take notice that on November 21, 1997, on behalf of its operating companies, The Cincinnati Gas & Electric Company and PSI Energy, Inc., Cinergy Services, Inc. (Cinergy), tendered for filing a Service Agreement between Cinergy and the Town of Kingsford Heights (Customer).

Cinergy and Customer have requested an effective date of February 1, 1998.

Copies of the filing were served upon the Town of Kingsford Heights, Northern Indiana Public Service Company and the Indiana Utility Regulatory Commission.

Comment date: December 24, 1997, in accordance with Standard Paragraph E at the end of this notice.

11. Panther Creek Partners

[Docket No. QF87-59-010]

On December 5, 1997, Panther Creek Partners (Applicant) of 1001 Industrial Road, Nesquehoning, Pennsylvania 18240 submitted for filing an amendment to its application for

recertification of a facility as a qualifying small power production facility pursuant to Section 292.207(b) of the Commission's Regulations. No determination has been made that the submittal constitutes a complete filing.

The amendment provides information requested by Commission staff in support of the original submittal and also requests certification of additional sources of waste fuel not identified in the original application.

Comment date: December 29, 1997, in accordance with Standard Paragraph E at the end of this notice.

Standard Paragraph

E. Any person desiring to be heard or to protest said filing should file a motion to intervene or protest with the Federal Energy Regulatory Commission, 888 First Street, N.E., Washington, D.C. 20426, in accordance with Rules 211 and 214 of the Commission's Rules of Practice and Procedure (18 CFR 385.211 and 18 CFR 385.214). All such motions or protests should be filed on or before the comment date. Protests will be considered by the Commission in determining the appropriate action to be taken, but will not serve to make protestants parties to the proceeding. Any person wishing to become a party must file a motion to intervene. Copies of this filing are on file with the Commission and are available for public inspection.

Lois D. Cashell,*Secretary.*

[FR Doc. 97-32892 Filed 12-16-97; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY**Federal Energy Regulatory Commission****Notice of Intent to File Application for New License**

December 11, 1997.

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection:

a. Type of filing: Notice of Intent to File Application for New License.

b. Project No.: 719.

c. Date filed: October 14, 1997.

d. Submitted By: Trinity Conservancy, Inc.

e. Name of Project: Trinity Power Project.

f. Location: On Phelps and James Creeks in Chelan County, Washington.

g. Filed Pursuant to: Section 15 of the Federal Power Act, 18 CFR 16.6 of the Commission's regulations.

h. Expiration date of original license: November 1, 2002.

i. The facilities under this license consist of small diversion dams on Phelps and James Creeks and flumes and penstocks leading to a powerhouse with a total installed capacity of 240 kilowatts.

j. Pursuant to 18 CFR 16.7, information on the project is available by contacting: Reid L. Brown, President, Trinity Conservancy, Inc., 3139 E. Lake Sammamish, Issaquah, WA 98029.

k. FERC contact: Héctor M. Pérez, (202) 219-2843.

l. Pursuant to 18 CFR 16.9(b)(1) each application for a new license and any competing license applications must be filed with the Commission at least 24 months prior to the expiration of the existing license. All applications for license for this project must be filed by November 1, 2000.

Linwood A. Watson, Jr.,*Acting Secretary.*

[FR Doc. 97-32840 Filed 12-16-97; 8:45 am]

BILLING CODE 6717-01-M

DEPARTMENT OF ENERGY**Federal Energy Regulatory Commission****Notice of Application Ready for Environmental Analysis**

December 11, 1997.

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection:

a. Type of Application: New Major License.

b. Project No.: 1991-09.

c. Date filed: April 1, 1996.

d. Applicant: City of Bonners Ferry.

e. Name of Project: Moyie River Hydroelectric.

f. Location: On the Moyie River in Boundary County, Idaho.

g. Filed Pursuant to: Federal Power Act 16 U.S.C. §§ 791(a)-825(r).

h. Applicant Contact: Mike Woodward, P.E., City of Bonners Ferry, 7232 Main Street, Bonners Ferry, ID 83805, 208 267-3105.

i. FERC Contact: Tim Looney at (202) 219-2852.

j. The project would consist of: (1) a 92-foot-concrete dam, impounding a 450-acre-foot reservoir, (2) a combination penstock/pressure tunnel about 990 feet long, (3) three powerhouses with a total installed capacity of 3,950 kilowatts, (4) a 1.3-mile-long, 13.8-kilovolt transmission line, and (5) appurtenant facilities.

k. Status of Environmental Analysis: This application is now ready for