Date of issuance: November 10, 2003.

Effective date: November 10, 2003, and shall be implemented within 60 days from the date of issuance.

Amendment No.: 223.

Renewed Facility Operating License No. DPR–40: The amendment revised the Technical Specifications.

Date of initial notice in ***Federal Register:*** March 18, 2003 (68 FR 12955).

The October 14, 2003, supplemental letter provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 10, 2003.

No significant hazards consideration comments received: No.

PPL Susquehanna, LLC, Docket Nos. 50–387 and 50–388, Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania.

Date of application for amendments: May 6, 2003, as supplemented by letters dated August 12 and September 18, 2003.

Brief description of amendments: These amendments deleted Technical Specification (TS) 3.3.1.3, ''Oscillation Power Range Monitor (OPRM) Instrumentation,'' and revised TS 3.4.1, ''Recirculation Loops Operating,'' to formally extend the currently implemented requirements, which define appropriately conservative restrictions to plant operation and operator response to thermal hydraulic instability events. In addition, the amendments revise TS 3.4.1 to refer to the power flow map in the core operating limits report and include a reference in TS 5.6.5.

Date of issuance: October 29, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment Nos.: 215 and 190.

Facility Operating License Nos. NPF–14 and NPF–22: The amendments revised the Technical Specifications.

Date of initial notice in ***Federal Register****:* June 24, 2003 (68 FR 37582).

The supplemental letters dated August 12 and September 18, 2003, provided clarifying information that did not change the scope of the amendment as described in the initial notice of the proposed action published in the **Federal Register** notice (68 FR 37582, June 24, 2003), or the U.S. Nuclear Regulatory Commission staff's proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 29, 2003.

No significant hazards consideration comments received: No.

Tennessee Valley Authority, Docket Nos. 50–259, 50–260, and 50–296, Browns Ferry Nuclear Plant, Units 1, 2, and 3, Limestone County, Alabama.

Date of application for amendments: July 25, 2003.

Description of amendment request: The amendments revised Technical Specification 3.1.8, ''Scram Discharge Volume (SDV) Vent and Drain Valves,'' to allow a vent or drain line with one inoperable valve to be isolated instead of requiring the valve to be restored to operable status within 7 days.

Date of issuance: November 3, 2003.

Effective date: Date of issuance, to be implemented within 60 days.

Amendment Nos.: 248, 285, and 243.

Facility Operating License Nos. DPR–33, DPR–52, and DPR–68. Amendments revised the Technical Specifications.

Date of initial notice in ***Federal Register:*** September 18, 2003 (68 FR 54753).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation.

No significant hazards consideration comments received: No.

Dated at Rockville, Maryland, this 17th day of November, 2003.

For the Nuclear Regulatory Commission.

Eric Leeds,

Deputy Director, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 03–29107 Filed 11–24–03; 8:45 am]

BILLING CODE 7590–01–P

OFFICE OF PERSONNEL MANAGEMENT

Federal Employees' Group Life Insurance Program: New Option B Premiums

AGENCY: Office of Personnel Management.

ACTION: Notice.

SUMMARY: The Office of Personnel Management (OPM) is announcing new Federal Employees' Group Life Insurance (FEGLI) premiums for the upper age bands of Option B. The premiums will be maintained on the FEGLI Web site at *http://www.opm.gov/insure/life.*

EFFECTIVE DATE: January 1, 2004.

FOR FURTHER INFORMATION CONTACT: Karen Leibach, (202) 606–0004.

SUPPLEMENTARY INFORMATION: On December 30, 2002, OPM published a **Federal Register** notice (67 FR 79659) announcing premium changes for FEGLI and new age bands for Options B and C. The premiums for the new Option B age bands are being phased in over a 3-year period. The first set of premiums for these age bands was effective the first pay period beginning on or after January 1, 2003.

This notice announces the second phase of the Option B premium changes. These premiums are effective the first pay period beginning on or after January 1, 2004.

OPTION B PREMIUM PER $1,000 OF INSURANCE

Age band	Biweekly	Monthly
70–74	$1.03	$2.232
75–79	1.43	3.098
80 and over	1.83	3.965

The premiums for compensationers, who are paid every 4 weeks, are 2 times the biweekly premium amounts.

Premiums for other FEGLI coverages, including premiums for other Option B age bands, are not changing.

U.S. Office of Personnel Management.

Kay Coles James,

Director.

[FR Doc. 03–29438 Filed 11–24–03; 8:45 am]

BILLING CODE 6325–50–P

SECURITIES AND EXCHANGE COMMISSION

[Release No. 34–48800; File No. SR–Amex–2002–116]

Self-Regulatory Organizations; Notice of Filing of a Proposed Rule Change and Amendment Nos. 1, 2, 3, and 4 Thereto by the American Stock Exchange LLC Relating to Specialist Stabilization Requirements for Derivative Products

November 17, 2003.

Pursuant to Section 19(b)(1) of the Securities Exchange Act of 1934 (''Act'')[1] and Rule 19b–4 thereunder,[2] notice is hereby given that on December 27, 2002, the American Stock Exchange LLC (''Amex'' or ''Exchange'') filed with the Securities and Exchange Commission (''Commission'') the proposed rule change as described in

[1] 15 U.S.C. 78s(b)(1).

[2] 17 CFR 240.19b–4.