

the proceeding. Any person wishing to become a party must file a notice of intervention or motion to intervene, as appropriate. Such notices, motions, or protests must be filed on or before the comment date. Anyone filing a motion to intervene or protest must serve a copy of that document on the Applicant and all parties to this proceeding.

The Commission encourages electronic submission of protests and interventions in lieu of paper using the "eFiling" link at <http://www.ferc.gov>. Persons unable to file electronically should submit an original and 14 copies of the protest or intervention to the Federal Energy Regulatory Commission, 888 First Street, NE., Washington, DC 20426.

This filing is accessible on-line at <http://www.ferc.gov>, using the "eLibrary" link and is available for review in the Commission's Public Reference Room in Washington, DC. There is an "eSubscription" link on the Web site that enables subscribers to receive e-mail notification when a document is added to a subscribed docket(s). For assistance with any FERC Online service, please e-mail FERCOnlineSupport@ferc.gov, or call (866) 208-3676 (toll free). For TTY, call (202) 502-8659.

Linda Mitry,

Deputy Secretary.

[FR Doc. E5-1705 Filed 4-11-05; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 12451-001, Minnesota]

SAF Hydroelectric Company, LLC; Notice of Availability of Environmental Assessment

April 6, 2005.

In accordance with the National Environmental Policy Act of 1969 and the Federal Energy Regulatory Commission's (Commission) regulations, 18 CFR part 380 (FERC Order No. 486 and 52 FR 47,897) the Office of Energy Projects Staff (staff) reviewed the application for an original license for the Lower St. Anthony Falls Hydroelectric Project, located on the Mississippi River in the city of Minneapolis in Hennepin County, Minnesota, and prepared an environmental assessment (EA) for the project. The project would occupy 2.26 acres of Federal lands owned by the U.S. Army Corps of Engineers (Corps).

In this EA, the staff analyzes the potential environmental effects of the proposed project and concludes that licensing the project, with staff's recommended measures, would not constitute a major Federal action significantly affecting the quality of the human environment.

A copy of the EA and application is available for review at the Commission in the Public Reference Room, or may be viewed on the Commission's Web site at <http://www.ferc.gov> using the "e-Library" link. Enter the docket number excluding the last three digits in the docket number field to access the document. For assistance, contact FERC Online Support at FERCOnlineSupport@ferc.gov or toll-free at 1-866-208-3676, or for TTY, 202-502-8659.

Any comments should be filed within 30 days from the date of this notice and should be addressed to Magalie R. Salas, Secretary, Federal Energy Regulatory Commission, 888 First Street, NE., Washington, DC 20426. Please affix "Lower St. Anthony Falls Project, P-12451" to all comments. For further information, please contact Monte TerHaar at (202) 502-6035 or at monte.terhaar@ferc.gov.

Comments may be filed electronically via the Internet in lieu of paper. See 18 CFR 385.2001(a)(1)(iii) and the instructions on the Commission's Web site at <http://www.ferc.gov> under the "e-Filing" link. The Commission strongly encourages electronic filings.

Linda Mitry,

Deputy Secretary.

[FR Doc. E5-1686 Filed 4-11-05; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

Notice of Application Accepted for Filing and Soliciting Comments, Motions To Intervene, and Protests

April 5, 2005.

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection:

a. *Type of Application:* Preliminary Permit.

b. *Project No.:* 12542-000.

c. *Date Filed:* September 22, 2004.

d. *Applicant:* Hydrodynamic, LLC.

e. *Name of Project:* Upper Turnbull Project.

f. *Location:* The proposed project would be located on the U.S. Bureau of Reclamation's existing Greenfield

Irrigation District canal system, using irrigation diversions from the Sun River below Gibson Dam, at the canal and drop structure identified in item K below, in Teton and Cascade Counties, Montana.

g. *Filed Pursuant to:* Federal Power Act, 16 U.S.C. 791(a)-825(r).

h. *Applicant Contacts:* Mr. Roger Kirk, Hydrodynamics, LLC, PO Box 1136, Bozeman, MT 59771-1136, (406) 587-5086.

i. *FERC Contact:* Mr. Robert Bell, (202) 502-6062.

j. *Deadline for filing motions to intervene, protests and comments:* 30 days from the issuance date of this notice.

All documents (original and eight copies) should be filed with: Magalie R. Salas, Secretary, Federal Energy Regulatory Commission, 888 First Street, NE., Washington, DC 20426. Comments, protests, and interventions may be filed electronically via the Internet in lieu of paper; see 18 CFR 385.2001(a)(1)(iii) and the instructions on the Commission's Web site under the "e-Filing" link. The Commission strongly encourages electronic filings. Please include the project number (P-12542-000) on any comments or motions filed.

The Commission's Rules of Practice and Procedure require all intervenors filing documents with the Commission to serve a copy of that document on each person in the official service list for the project. Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

k. *Competing Application:* Project No. 12539-000, Date Filed: September 9, 2004, Date Issued: December 31, 2004, Due Date: March 2, 2005.

l. *Description of Project:* The proposed project would consist of: (1) A diversion structure, at crest elevation 4,322 feet mean sea level (msl), on the Spring Valley Canal, (2) a 1400-foot-long, 8-foot Diameter penstock, (3) a proposed powerhouse containing one generating unit having an installed capacity 4 megawatts, (4) a tailrace returning flows to the canal at elevation 3,818 feet msl, (5) a ¼-mile-long, 69-KV transmission line and (6) appurtenant facilities. The applicant estimates the project would have an average annual generation of 16.2 gigawatt-hours.

m. *Locations of Applications:* A copy of the application is available for inspection and reproduction at the Commission in the Public Reference Room, located at 888 First Street, NE.,